

Electrical Installation Condition Report

Requirements for Electrical Installations - BS 7671:2018
(IET Wiring Regulations 18th Edition)



Information for recipients:

The purpose of this report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).

The person ordering the report should have received the Original©Report and the inspector should have retained a duplicate.

The Original©Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.

Where the installation incorporates residual current devices (RCDs) there should be a notice at or near the devices stating that they should be tested every 6 months. **For safety reasons it is important that these instructions are followed.**

Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The Inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licencing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.

For items classified in Section K as C1 (“Danger Present”), **the safety of those using the installation is at risk**, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.

For items classified in Section K as C2 (“Potentially Dangerous”), **the safety of those using the installation may be at risk** and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where it has been stated in Section K that an observation requires further investigation code FI the inspection has revealed an apparent deficiency which may result on a code C1 or C2 could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons competent in such work. The recommended date by which the next inspection is due is stated in Section F of the report under ‘Recommendations’ and on label at or near to the consumer unit/distribution board.

ELECTRICAL INSTALLATION CONDITION REPORT

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

A. Details of the Installation

Client	UPP Residential Services Ltd	Installation	Swansea University Bay Campus - Elinor 14
Address	First Floor 12 Arthur Street London,	Address	Reception - Ground Floor Tower Information Centre Fabian Way, Crymlyn Burrows Swansea
Postcode	EC4R 9AB	Postcode	SA1 8EN

B. Reason for Producing this Report *This form is to be used only for reporting on the condition of an existing installation.*

Essential information requested by the client in accordance with the electricity at work regulations 1989.

Date(s) on which the inspection and testing were carried out to

C. Details of Installation which is the Subject of this Report

Description of premises Domestic Commercial Industrial Other (please specify)

Estimated age of the wiring system years

Evidence of alterations or addition Yes No Not apparent if 'Yes', estimated years

Records of installation available Yes No Records held by

Date of last inspection Electrical Installation Certificate No. or previous Inspection Report No.

D. Extent of Electrical Installation Covered by this Report:

Testing of all sub mains, lighting and power circuits, within the constraints of the agreed limitations.

Agreed Limitations and Operational Limitations (Regulations 653.2)

- Unable to completely isolate the installation. Unable to access the sealed supply device characteristics. Ze and Ip have been taken with all earthing and bonding in place. Insulation resistance testing has been carried out to regulation 643.3.3 on circuits where it was impracticable to disconnect load.

Agreed with:

The inspection and testing detailed within this report and accompanying schedule has been carried out in accordance with BS 7671: 2018 (IET Wiring Regulations) amended to

It should be noted that cables concealed within trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

E. Summary of the Condition of the Installation

General conditions of the installation (in terms of electrical safety)

Installation Details

Overall assessment of the installation in terms of its suitability for continued use **SATISFACTORY** ***UNSATISFACTORY**

*An UNSATISFACTORY assessment indicates that dangerous (code C1), or potentially dangerous (code C2), Further investigation (code FI) conditions have been identified

F. Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potential dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further Investigation required' (code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by (date)

ELECTRICAL INSTALLATION CONDITION REPORT

FT/ 110147629
EICR



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

G. Declaration

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company	PHS Compliance	Inspected and tested by	Authorised for issue by
Address	Kid Glove Road, Golborne, Warrington,	Name:	Liam Kimble
		Signature:	
Postcode	WA3 3GR		
Branch No.		Position:	Electrical Test Engineer
Scheme No.		Date:	11/07/2022
			Technical Auditor
			10/08/2022

EICRs are produced by a UKAS accredited inspection body, No. 0433

H. Schedule(s)

1 schedule(s) of inspection and 83 schedule(s) of test results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

I. Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S TN-C-S TT Other Please specify

Number & Type of live conductors AC DC No. of phases 3 No. of wires 4

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ 400/230 v Nominal frequency, f⁽¹⁾ 50 Hz Confirmation of supply polarity

Prospective fault current, I_{pr} ⁽²⁾ 4.2 kA External loop impedance, Z_e ⁽²⁾ 0.11 Ω

Supply Protective Device BS (EN) LIM Type LIM Rated Current LIM A

No. of Additional Supplies N/A

J. Particulars of Installation Referred to in this Report

Means of Earthing

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) Distributors facility Installation Earth Electrode

Location Electrode resistance to earth Ω Maximum Demand (load) LIM Amps KVA

Main Protective Conductors	Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper	95 mm ²	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor	Copper	50 mm ²	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>

Main Supply Conductor Material Copper csa 120 mm² (connection / continuity) (✓) or Value

Main Switch Location Mains Room mm² Water installation Ω To structural steel Ω

Fuse/device rating or setting 400 A Voltage rating 400 V Gas installation pipes Ω To lightning protection NA Ω

If RCD main switch: Rated residual operating current I_{Δn} N/A mA Oil installation pipes NA Ω Other NA Ω

BS(EN) 60947-3 No. of Poles 4 Current Rating 400 A Rated time delay N/A ms Measured operating trip time N/A ms

K. Observations

Explanation of codes

Referring to the attached schedule of inspection and test results, and subject to the limitations at Section D.

- No remedial work required
- The following observations are made

C1	Danger present. Risk of Injury. Immediate remedial action required.
C2	Potentially dangerous. Urgent remedial action required.
C3	Improvement recommended.
F1	Further Investigation required without delay

Item No.	Observations	Code
1	Observation: Damaged socket, earth pin broke by entrance Location: DB LL1 CCT 1/L2 Regulation: 416.2	C2
2	Observation: Screws missing from DB cover, cover still secure. Location: DB PL Regulation: 416.2.3	C3
3	Observation: Screws missing from Accessory Location: DB PL 3/L3 Regulation: 416.2.3	C3
4	Observation: Screws missing from Accessory Location: Outside socket roof space Regulation: 416.2.3	C3

ELECTRICAL INSTALLATION CONDITION REPORT

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

5	Observation: Screws missing from conduit lid Location: DB PL CCT 2/L3 Regulation: 416.2.3	C3
6	Observation: Conduit lid is missing. Location: Plant room behind control panel Regulation: 521.10.1	C3
7	Observation: No mechanical protection for single insulated cables. 35mm Location: Plant room behind control panel Regulation: 521.10.1	C2
8	Observation: Cables are not adequately supported. cable clips needed Location: OS2 Controller Regulation: 522.8.4	C3
9	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: MSP CCT 1/TP Regulation: 537.2.4	FI
10	Observation: Over rated over current protective device in relation to the current carrying capacity of the connected. 70 degrees current carrying capacity cables have been used as the cables are installed with lower rated cables. Location: MSP CCT 6/TP Regulation: 433.1.1	C2
11	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB PL CCT 12/TP Regulation: 537.2.4	FI

One of the following codes, as appropriate, has been allocated to each of the observations made above and/or any attached observation sheets to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1	Danger present. Risk of Injury. Immediate remedial action required.	
C2	Potentially dangerous. Urgent remedial action required.	1, 7, 10
C3	Improvement recommended.	2, 3, 4, 5, 6, 8
FI	Further Investigation required without delay	9, 11

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

Outcomes						
Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further Investigation:	Not Verified:	Limitation:	Not Applicable:
	or					
Item No.	Description					Outcome
1.0 External Condition Of Intake Equipment (Visual Inspection Only) Where inadequacies are encountered, it is recommended that the person ordering the report informs the appropriate authority						
1.1	Service cable					
1.2	Service head					
1.3	Earthing arrangement					
1.4	Meter tails					
1.5	Metering equipment					
1.6	Isolator (where present)					
2.0 Parallel Or Switched Alternative Sources Of Supply						
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)					
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)					
3.0 Automatic Disconnection Of Supply						
3.1	Main earthing/bonding arrangements (411.3; Chap 54)					
3.1.1	Presence of distributors earthing arrangement (542.1.2.1; 542.1.2.2)					
3.1.2	Presence of installation earth electrode arrangement (542.1.2.3)					
3.1.3	Adequacy of earthing conductor size (542.3; 543.1.1)					
3.1.4	Adequacy of earthing conductor connections (542.3.2)					
3.1.5	Accessibility of earthing conductor connections (543.3.2)					
3.1.6	Adequacy of main protective bonding conductor sizes (544.1)					
3.1.7	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)					
3.1.8	Accessibility of all protective bonding connections (543.3.2)					
3.1.9	Provision of earthing/bonding labels at all appropriate locations (514.13)					
3.2	FELV - requirements satisfied (411.7; 411.7.1)					
4.0 Other Methods Of Protection (Where any of the methods listed below are employed details should be provided on separate sheets)						
4.1	Non-conducting location (418.1)					
4.2	Earth-free local equipotential bonding (418.2)					
4.3	Electrical separation (Section 413; 418.3)					
4.4	Double insulation (Section 412)					
4.5	Reinforced insulation (Section 412)					
5.0 Distribution Equipment						
5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)					
5.2	Security of fixing (134.1.1)					
5.3	Condition of insulation of live parts (416.1)					
5.4	Adequacy/security of barriers (416.2)					
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)					
5.6	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)					
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)					
5.8	Presence and effectiveness of obstacles (417.2)					
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)					
5.10	Operation of main switch(es) (functional check) (643.10)					
5.11	Manual operation of circuit-breakers and RCD(s) to prove disconnection (643.10)					
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)					
5.13	RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2)					
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBO(s) (411.3.3; 415.1)					
5.15	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)					
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)					
5.17	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)					
5.18	Presence of alternative supply warning notice at or near equipment, where required (514.15)					
5.19	Presence of next inspection recommendation label (514.12.1)					
5.2	Presence of other required labelling (please specify) (Section 514)					
5.21	Compatibility of protective device, base and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.4.5; 411.4.6; Sections 432; 433)					
5.22	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)					
5.23	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)					
5.24	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)					
6.0 Distribution Circuits						

**Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)**

6.1	Identification of conductors (514.3.1)	✓
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓ _{C3}
6.3	Condition of insulation of live parts (416.1)	✓
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. Integrity of containment (521.10.1)	✓
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	✓
6.6	Cables correctly terminated in enclosures (Section 526)	✓
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	✓
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓ _{C2}
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	✓
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	✓
6.15	Cables concealed under floors, above ceilings, in walls/partitions less than 50 mm from a surface, and in partitions containing metal parts	
6.15.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202) or	✓
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.204)	✓
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
6.17	Band II cables segregated/separated from Band I cables (528.1)	✓
6.18	Cables segregated/separated from non-electrical services (528.3)	✓
6.19	Condition of circuit accessories (651.2)	✓
6.20	Suitability of circuit accessories for external influences (512.2)	✓
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
6.22	Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/record numbers and locations of items inspected (Section 526)	✓
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; 537)	✓
6.24	General condition of wiring systems (651.2)	✓
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)	✓
7.0 CONSUMER UNIT/DISTRIBUTION BOARD(S)		
7.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1)	✓
7.2	Security of fixing (134.1.1)	✓
7.3	Condition of enclosure(s) in terms of IP rating (Barriers etc) (416.2)	✓
7.4	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	✓
7.5	Enclosure/obstacles not damaged/deteriorated so as to impair safety (651.2)	✓
7.5.1	Presence and effectiveness of obstacles (417.2)	✓
7.6	Presence of main linked switch (as required by 462.1.201)	✓
7.7	Operation of main switch (functional check) (643.10)	✓
7.8	Manual operation of circuit-breakers and RCD(s) (test button) to prove disconnection (643.10)	✓
7.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	✓ _{F1}
7.10	Presence of RCD six-monthly test notice at or near consumer unit/distribution board (514.12.2)	✓
7.11	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	✓
7.12	Presence of alternative supply warning notice at or consumer unit/distribution board (514.15)	✓
7.13	Presence of other required labelling (Please specify) (Section 514)	✓
7.14	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	✓
7.15	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3)	✓
7.16	Protection against mechanical damage where cables enter consumer unit/distribution board (132.14.1; 522.8.1; 522.8.5; 522.8.11)	✓
7.17	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	✓
7.18	RCD(s) provided for fault protection - includes RCBO(s)(411.4.204; 411.5.2; 531.2)	✓
7.19	RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1)	✓
7.20	Confirmation of indication that SPD is functional (651.4)	✓ _{NA}
7.21	Confirmation that ALL conductor connections, including connections to the busbars are correctly located in terminals and are tight and secure (526.1)	✓
7.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	✓ _{NA}
7.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	✓ _{NA}
8.0 FINAL CIRCUITS		
8.1	Identification of conductors (514.3.1)	✓
8.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓ _{C3}
8.3	Condition of insulation of live parts (416.1)	✓

**Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)**

8.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	✓
8.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)	✓
8.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
8.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	⚠
8.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
8.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	✓
8.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓
8.10	Connected cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	✓
8.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (522.6.204)	✓
8.12	Provision of additional requirements for protection by RCD not exceeding 30 mA:	
8.12.1	For all socket-outlets of rating 32 A or less unless exempt (4.11.3.3)	✓
8.12.2	For the supply of Mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	✓
8.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	✓
8.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	✓
8.12.5	For circuits supplying luminaires within domestic (household) premises (411.3.4)	✓
8.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
8.14	Band II cables segregated/separated from Band I cables (528.1)	✓
8.15	Cables segregated/separated from communications cabling (528.2)	✓
8.16	Cables segregated/separated from non-electrical services (528.3)	✓
8.17	Termination of cables at enclosures - indicate extent of sampling in section d of the report (section 526)	
8.17.1	Connections soundly made and under no undue strain (526.6)	✓
8.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	⚠
8.17.3	Connections of live conductors adequately enclosed (526.5)	✓
8.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓
8.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v))	✓
8.19	Suitability of accessories for external influences (512.2)	✓
8.20	Adequacy or working space/accessibility to equipment (132.12; 513.1)	✓
8.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
9.0 ISOLATION AND SWITCHING		
9.1	Isolators (Section 460; 537)	
9.1.1	Presence and condition of appropriate devices (462; 537.2.7)	✓
9.1.2	Acceptable location - state if local or remote from equipment in question (462; 537.2.7)	✓
9.1.3	Capable of being secured in the OFF position (462.3)	✓
9.1.4	Correct operation verified (643.10)	✓
9.1.5	Clearly identified by position and/or durable marking (537.2.6)	✓
9.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	✓
9.2	Switching off for mechanical maintenance (Section 464; 537.3.2)	
9.2.1	Presence and condition of appropriate devices (464.1; 527.3.2)	✓
9.2.2	Acceptable location - state if local or remote from equipment in question (537.3.2.4)	✓
9.2.3	Capable of being secured in the OFF position (462.3)	✓
9.2.4	Correct operation verified (643.10)	✓
9.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	✓
9.3	Emergency switching/stopping (465; 537.3.3)	
9.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	✓
9.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	✓
9.3.3	Correct operation verified (643.10)	✓
9.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	✓
9.4	Functional switching (section 463; 537.3.1)	
9.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	✓
9.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	✓
10.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)		
10.1	Condition of equipment in terms of IP rating etc (416.2)	✓
10.2	Equipment does not constitute a fire hazard (Section 421)	✓
10.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	✓
10.4	Suitability for the environment and external influences (512.2)	✓
10.5	Security of fixing (134.1.1)	✓
10.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	✓
10.7	Recessed luminaires (downlighters)	
10.7.1	Correct type of lamps fitted (559.3.1)	✓
10.7.2	Installed to minimize build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	✓
10.7.3	No signs of overheating to surrounding building fabric (559.4.1)	✓



Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

10.7.4	No signs of overheating to conductors/terminations (526.1)	✓
--------	--	---

11.0 PART 7 SPECIAL INSTALLATIONS OR LOCATIONS

11.01	If any special installations or locations are present, list the particular inspections applied.	N/A
-------	---	-----

12.0 Schedule of Tests

Results to be recorded on Schedule of Test Results

12.1	External earth loop impedance, Z ^e	Yes
12.2	Installation earth electrode	Yes
12.3	Prospective fault current, I _{pf}	Yes
12.4	Continuity of Earth Conductors	Yes
12.5	Continuity of Circuit Protective Conductors	Yes
12.6	Continuity of ring final circuit	Yes
12.7	Continuity of Protective Bonding Conductors	Yes
12.8	Volt drop verified	Yes

12.9	Insulation Resistance between Live Conductors	Yes
12.10	Insulation Resistance between Live Conductors & Earth	Yes
12.11	Polarity (prior to energisation)	Yes
12.12	Polarity (after energisation) including phase sequence	Yes
12.13	Earth Fault Loop Impedance	Yes
12.14	RCDs/RCBOs including selectivity	Yes
12.15	Functional testing of RCD devices	Yes
12.16	Functional testing of AFDD(s) devices	N/A

Inspector's Name:

Date:

Signature: 

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 4 Riser 7th Floor [Schneider]	Supply to distribution board is from Sub Mains(DB CL8, 7/L1)	Associated RCD(if any): BS (EN) 61009		(if applicable) Above 30mA Operating at 1 IΔn 28.8 ms 30mA or below Operating at 5 IΔn 28.8 ms Time delay (if applicable) N/A
Designation DB CL8/7-2	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Zs 0.39 Ω	No. of poles 2	
Num. of ways 4 Num. of phases 1	BS(EN) 61009 RCD/RCBO	Ipf 0.59 kA	IΔn 30	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				
Test instrument serial number(s)				
Loop impedance 080408/5657				
Insulation resistance 080408/5657				
Continuity 080408/5657				
RCD 080408/5657				

CIRCUIT DETAILS														TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	80%	80%	80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%	80%	80%
1/L1	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.69	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case **Complete only if the distribution board is not connected directly to the origin of the installation** **Characteristics at this distribution board** **Test instrument serial number(s)**

Location: Room 8 Riser 7th Floor [Schneider] Supply to distribution board is from: Sub Mains(DB CL8, 9/L1) Associated RCD(if any): BS (EN) 61009 Loop impedance: 080408/5657
 Designation: DB CL8/9-2 Sub Mains(DB CL8, 9/L1) Operating at 1 IΔn: 28.6 ms Insulation resistance: 080408/5657
 Num. of ways: 4 Num. of phases: 1 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V i_{pf}: 0.64 kA IΔn: 30 Operating at 5 IΔn: 28.5 ms Continuity: 080408/5657
 Supply polarity confirmed Phase sequence confirmed Time delay (if applicable): N/A RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Room 9 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 11/07/2022 To 11/07/2022 Date(s) live testing: 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 11/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		
Location <input type="text" value="Room 9 Riser 5th Floor [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL/6, 9/L2)"/>		
Designation <input type="text" value="DB CL6/9-2"/>		Overcurrent protective device for the distribution circuit: Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="400/230"/> V		
Num. of ways <input type="text" value="4"/> Num. of phases <input type="text" value="1"/>		BS(EN) <input type="text" value="61009 RCD/RCBO"/>		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Characteristics at this distribution board		
		Associated RCD(if any): BS (EN) <input type="text" value="61009"/> Operating at 1 I Δ n <input type="text" value="29.2"/> ms Above 30mA (if applicable)		
		Z ϕ <input type="text" value="0.40"/> Ω No. of poles <input type="text" value="2"/> 30mA or below		
		I ϕ <input type="text" value="0.58"/> kA I Δ n <input type="text" value="30"/> Operating at 5 I Δ n <input type="text" value="18.4"/> ms		
		Time delay (if applicable) <input type="text" value="N/A"/>		
		Test instrument serial number(s)		
		Loop impedance <input type="text" value="080408/5657"/>		
		Insulation resistance <input type="text" value="080408/5657"/>		
		Continuity <input type="text" value="080408/5657"/>		
		RCD <input type="text" value="080408/5657"/>		

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (\checkmark)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I Δ n ms	30mA or below 5 I Δ n ms	RCD (\checkmark)			AFDO (\checkmark)			
														r1	m	r2										Fig 8 check (\checkmark)	R1 + R2	R2
					Circuit designation																							
1/L2	Room 9 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	\checkmark	0.59	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR **110147629**



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser 4th Floor [Schneider]
 Designation: DB CL5/9-1
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 9/L1)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn 32.5 ms Above 30mA (if applicable)
 Z_s 0.44 Ω No. of poles 2 30mA or below
 I_{pf} 0.51 kA IΔn 30 Operating at 5 IΔn 18.8 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z_s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z_s (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)				
														r1	r2	r3												R1 + R2	R2		
1/L1	Room 8 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A	N/A		
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser 6th Floor [Schneider]
 Designation: DB CL7/9-1
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL7, 9/L3)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Operating at 1 IΔn 28.6 ms Above 30mA (if applicable)
 Zs 0.41 Ω No. of poles 2 30mA or below
 Ipr 0.58 kA IΔn 30 Operating at 5 IΔn 28.7 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 080408/5657
 Insulation resistance 080408/5657
 Continuity 080408/5657
 RCD 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	rn	r2												R1 + R2	R2
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)									
1/L3	Room 8 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.77	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		
Location Room 6 Riser 5th Floor [Schneider]		Supply to distribution board is from Sub Mains(DB CL/6, 8/L2)		
Designation DB CL6/8-1		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		
Num. of ways 4 Num. of phases 1		Associated RCD(if any): BS (EN) 61009 RCD/RCBO		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Characteristics at this distribution board		
		Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn 33.5 ms Above 30mA (if applicable) Zs 0.36 Ω No. of poles 2 30mA or below Ipf 0.67 kA IΔn 30 Operating at 5 IΔn 22.0 ms Time delay (if applicable) N/A		
		Test instrument serial number(s)		
		Loop impedance 080408/5657		
		Insulation resistance 080408/5657		
		Continuity 080408/5657		
		RCD 080408/5657		

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
																		R1 + R2		R2										
1/L2	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR

110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance, Company Address: Kid Glove Road, Postcode: WA3 3GR, Branch No., Scheme No., Client: UPP Residential Services Ltd, Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, Postcode: SA1 8EN

Distribution board details - Complete in every case. Complete only if the distribution board is not connected directly to the origin of the installation. Characteristics at this distribution board. Test instrument serial number(s)

CIRCUIT DETAILS TEST RESULTS

Table with columns for Circuit No. and Line No., Distribution board Designation, Type of wiring, Ref. method, No. of points, Circuit conductors csa (mm²), Maximum disconnection, Overcurrent protective devices, Breaking capacity, RCD operating, BS 7671 Max. permitted Zs, Circuit impedance Ω, Insulation resistance, Polarity, Max. Measured Zs, RCD testing, Manual test button operation.

Details of circuits and/or installed equipment vulnerable to damage when testing, Date(s) dead testing: 11/07/2022 To 11/07/2022, Date(s) live testing: 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE, Position Electrical Test Engineer, Date 11/07/2022

Signature

[Handwritten Signature]

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance Company Address: Kid Glove Road Postcode: WA3 3GR Branch No.: Scheme No.:
 Client: UPP Residential Services Ltd Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 5 Riser 5th Floor [Schneider]
 Designation: DB CL6/8
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL/6, 8/L2)
 Overcurrent protective device for the distribution circuit: Type: C Rating: 32 A Voltage: 230 V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn: 33.5 ms Above 30mA (if applicable)
 Z_s: 0.36 Ω No. of poles: 2 30mA or below
 I_{pr}: 0.64 kA IΔn: 30 Operating at 5 IΔn: 22.0 ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)				
														r1	r2	r2												R1 + R2	R2		
					80%	r1		r2	r2	R1 + R2				R2	V	M(Ω)	M(Ω)	(✓)	(✓)	(✓)	(✓)										
1/L2	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 11/07/2022 To: 11/07/2022 Date(s) live testing: 11/07/2022 To: 11/07/2022

Tested by: Name (capital letters): LIAM KIMBLE Position: Electrical Test Engineer Date: 11/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case Location: Room X Riser 2nd Floor [Schneider] Designation: DB CL3/6-1 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains(DB CL3, 6/L2) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Characteristics at this distribution board Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 29.0 ms Zs 0.45 Ω No. of poles 2 30mA or below Ipr 0.51 kA IΔn 30 Operating at 5 IΔn 28.0 ms Time delay (if applicable) N/A		Test instrument serial number(s) Loop impedance 080408/5657 Insulation resistance 080408/5657 Continuity 080408/5657 RCD 080408/5657	
---	--	---	--	---	--	---	--

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L2	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.	
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode	SA1 8EN		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location	Room 10 Riser 3rd Floor [Schneider]	Supply to distribution board is from	Sub Mains(DB CL4, 6/L3)		Associated RCD(if any): BS (EN)	61009	Above 30mA (if applicable)
Designation	DB CL4/6-1	Overcurrent protective device for the distribution circuit:	Type	C	Rating	32	A
Num. of ways	4	BS(EN)	61009 RCD/RCBO		No. of poles	2	Operating at 1 IΔn
Supply polarity confirmed	<input checked="" type="checkbox"/>	Type	C	Rating	32	A	Operating at 5 IΔn
Phase sequence confirmed	<input type="checkbox"/>	Voltage	230		V		
							Loop impedance
							080408/5657
							Insulation resistance
							080408/5657
							Continuity
							080408/5657
							RCD
							080408/5657

CIRCUIT DETAILS												TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L3	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing	Date(s) dead testing	11/07/2022	To	11/07/2022	Date(s) live testing	11/07/2022	To	11/07/2022
Tested by: Name (capital letters)	LIAM KIMBLE	Position	Electrical Test Engineer	Date	11/07/2022	Signature		

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			
Location: Room 4 Riser 5th Floor [Schneider]	Supply to distribution board is from: Sub Mains(DB CL/6, 7/L2)	Characteristics at this distribution board			
Designation: DB CL6/7-2	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn 29.4 ms Above 30mA (if applicable)			
Num. of ways: 4 Num. of phases: 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Zs 0.45 Ω No. of poles 2 30mA or below			
		Ipf 0.51 kA IΔn 30 Operating at 5 IΔn 31.6 ms			
		Time delay (if applicable) N/A			
		Test instrument serial number(s)			
		Loop impedance 080408/5657			
		Insulation resistance 080408/5657			
		Continuity 080408/5657			
		RCD 080408/5657			

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L2	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR **110147629**



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 2 Riser 4th Floor [Schneider]		Supply to distribution board is from: Sub Mains(DB CL5, 7/L1)		Associated RCD(if any): BS (EN) 61009
Designation: DB CL5/7		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type C Rating 32 A Voltage 230 V		Operating at 1 IΔn 29.4 ms (if applicable) Above 30mA
Num. of ways: 4 Num. of phases: 1		Time delay (if applicable): N/A		Operating at 5 IΔn 24.0 ms (if applicable) 30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Test instrument serial number(s)		
		Loop impedance: 080408/5657		
		Insulation resistance: 080408/5657		
		Continuity: 080408/5657		
		RCD: 080408/5657		

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L1	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.47	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing: 11/07/2022 To 11/07/2022	Date(s) live testing: 11/07/2022 To 11/07/2022
Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022			Signature
<small>Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other</small>			

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR **110147629**



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 3 Riser 4th Floor [Schneider]	Supply to distribution board is from: Sub Mains(DB CL5, 7/L1)		Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 29.4 ms	
Designation: DB CL5/7-1	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Zs 0.40 Ω No. of poles 2 30mA or below Operating at 5 IΔn 24.0 ms	
Num. of ways 4 Num. of phases 1	BS(EN) 61009 RCD/RCBO		Time delay (if applicable) N/A	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Test instrument serial number(s)	
		Loop impedance 080408/5657		Insulation resistance 080408/5657
		Continuity 080408/5657		RCD 080408/5657

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Mains Room [Schneider] Designation: MSP Num. of ways: 12 Num. of phases: 3 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input checked="" type="checkbox"/>	Supply to distribution board is from: Overcurrent protective device for the distribution circuit: BS(EN) N/A Type: N/A Rating: N/A A Voltage: N/A V	Associated RCD(if any): BS (EN) N/A Operating at 1 IΔn N/A ms Zs 0.11 Ω No. of poles N/A Ipr 4.2 kA IΔn N/A Operating at 5 IΔn N/A ms Time delay (if applicable) N/A	Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)						
														r1	rn	r2												R1 + R2	R2				
1/TP	Isolated	A	B	1	16	16	0.4	60947 MCCB	N/A	80	25	N/A	0.20	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	✓	0.14	N/A	N/A	N/A	N/A			
2/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
3/L1	Sub Mains(DB CL1)	A	B	1	16	16	5	60947 MCCB	N/A	63	25	N/A	0.25	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.14	N/A	N/A	N/A	N/A	N/A				
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
6/TP	Sub Mains(Busbar)	G	E	1	50	50	5	60947 MCCB	N/A	250	35	N/A	0.15	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.14	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
7/TP	Sub Mains(DB FFS)	G	B	1	16	16	5	60947 MCCB	N/A	63	25	N/A	0.27	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8/TP	2nd Supply	G	D	1	25	25	5	60947 MCCB	N/A	63	25	N/A	0.27	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	LIM	LIM	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
10/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR

110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 7 Riser 4th Floor [Schneider]	Supply to distribution board is from Sub Mains(DB CL5, 9/L1)		Associated RCD(if any): BS (EN) 61009	Above 30mA (if applicable) Operating at 1 IΔn 32.5 ms
Designation DB CL5/9	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Z _s 0.44 Ω No. of poles 2	30mA or below Operating at 5 IΔn 18.8 ms
Num. of ways 4 Num. of phases 1			I _{pn} 0.51 kA IΔn 30	Time delay (if applicable) N/A
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Test instrument serial number(s)
				Loop impedance 080408/5657
				Insulation resistance 080408/5657
				Continuity 080408/5657
				RCD 080408/5657

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L1	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 1 Riser 7th Floor [Schneider]		Supply to distribution board is from Sub Mains(DB CL8, 6/L1)		Associated RCD(if any): BS (EN) 61009
Designation DB CL8/6		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Operating at 1 IΔn 28.4 ms
Num. of ways 4 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 18.6 ms
				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance 080408/5657
				Insulation resistance 080408/5657
				Continuity 080408/5657
				RCD 080408/5657

CIRCUIT DETAILS													TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	rn	r2												R1 + R2	R2
1/L1	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Ground Floor Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(Busbar, 1/L1)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: DB/CL2	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 I _{Δn} : N/A ms	Insulation resistance: 080408/5756
Num. of ways: 18 Num. of phases: 1		Operating at 5 I _{Δn} : N/A ms	Continuity: 080408/5756
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Time delay (if applicable): NA	RCD: 080408/5756

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA I _{Δn}	30mA or below 5 I _{Δn}	RCD (✓)			APDD (✓)				
														r1	r _n	r2										Fig 8 (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2	V	M(Ω)	M(Ω)	ms	ms									
1/L1	Common Room Lights	A	E	1	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.36	31.2	27.9	✓	N/A	
2/L1	Bedroom Lights 2,3,4	A	E	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.27	N/A	250	LIM	>299	✓	0.47	28.9	26.8	✓	N/A	
3/L1	Bedroom Lights 5,6,7	A	E	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.51	30.0	28.7	✓	N/A	
4/L1	Bedroom Lights 1,8	A	E	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.32	N/A	250	LIM	>299	✓	0.45	29.9	22.4	✓	N/A	
5/L1	Bedroom Lights	A	E	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.41	29.8	20.4	✓	N/A	
6/L1	Ring Main Bedrooms 1,10	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.58	0.58	1.00	✓	0.41	N/A	250	LIM	>299	✓	0.37	31.4	28.9	✓	N/A	
7/L1	Ring Main Bedrooms 2,3,4	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.55	0.56	0.98	✓	0.39	N/A	250	LIM	>299	✓	0.35	37.9	22.8	✓	N/A	
8/L1	Ring Main Bedrooms 5,6	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.53	0.53	0.92	✓	0.35	N/A	250	LIM	>299	✓	0.37	34.0	27.8	✓	N/A	
9/L1	Ring Main Bedrooms 7,8,9	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.44	0.44	0.51	✓	0.24	N/A	250	LIM	>299	✓	0.44	39.8	27.8	✓	N/A	
10/L1	Kitchen Ring Main 1	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.28	0.28	0.47	✓	0.20	N/A	250	LIM	>299	✓	0.28	29.7	21.0	✓	N/A	
11/L1	Kitchen Ring Main 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.21	0.21	0.28	✓	0.12	N/A	250	LIM	>299	✓	0.27	28.9	26.9	✓	N/A	
12/L1	Hob 1	A	E	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.24	34.9	27.9	✓	N/A	
13/L1	Hob 2	A	E	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.22	29.0	27.9	✓	N/A	
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 6 Riser 3rd Floor [Schneider]
 Designation: DB CL4/8-1
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL4, 8/L3)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Operating at 1 IΔn 28.6 ms Above 30mA (if applicable)
 Z_s 0.32 Ω No. of poles 2 30mA or below
 I_{pf} 0.71 kA IΔn 30 Operating at 5 IΔn 18.7 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 080408/5657
 Insulation resistance 080408/5657
 Continuity 080408/5657
 RCD 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L3	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022
 Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR **110147629**



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name **PHS Compliance** Company Address **Kid Glove Road** Postcode **WA3 3GR** Branch No. Scheme No.
 Client **UPP Residential Services Ltd** Installation Address **Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea** Postcode **SA1 8EN**

Distribution board details - Complete in every case
 Location **Room 4 Riser 4th Floor [Schneider]**
 Designation **DB CL5/7-2**
 Num. of ways **4** Num. of phases **1**
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from **Sub Mains(DB CL5, 7/L1)**
 Overcurrent protective device for the distribution circuit: Type **C** Rating **32** A Voltage **230** V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) **61009** Above 30mA (if applicable) Operating at 1 IΔn **29.4** ms
 Z_s **0.40** Ω No. of poles **2** 30mA or below
 I_{pf} **0.59** kA IΔn **30** Operating at 5 IΔn **24.0** ms
 Time delay (if applicable) **N/A**

Test instrument serial number(s)
 Loop impedance **080408/5657**
 Insulation resistance **080408/5657**
 Continuity **080408/5657**
 RCD **080408/5657**

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)				
														r1	r2	r3												R1 + R2	R2		
1/L1	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing **11/07/2022** To **11/07/2022** Date(s) live testing **11/07/2022** To **11/07/2022**

Tested by: Name (capital letters) **LIAM KIMBLE** Position **Electrical Test Engineer** Date **11/07/2022**

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case

Location: Room 6 Riser 4th Floor [Schneider]
 Designation: DB CL5/8-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed | Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation

Supply to distribution board is from: Sub Mains (DB CL5, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board

Associated RCD(if any): BS (EN) 61009 | Operating at 1 IΔn: 38.5 ms (Above 30mA)
 Zs: 0.30 Ω | No. of poles: 2 | Operating at 5 IΔn: 20.2 ms (30mA or below)
 Ipr: 0.79 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)

Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)
														r1	rn	r2		R1 + R2	R2									
1/L1	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing | Date(s) dead testing: 11/07/2022 To 11/07/2022 | Date(s) live testing: 11/07/2022 To 11/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 11/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance Company Address: Kid Glove Road Postcode: WA3 3GR Branch No.: Scheme No.:
 Client: UPP Residential Services Ltd Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 5 Riser 7th Floor [Schneider]
 Designation: DB CL8/8
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL8, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: C Rating: 32 A Voltage: 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Operating at 1 IΔn: 28.5 ms Above 30mA (if applicable)
 Z_s: 0.37 Ω No. of poles: 2 30mA or below
 I_{pr}: 0.63 kA IΔn: 30 Operating at 5 IΔn: 28.6 ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r2	r2												R1 + R2	R2	
1/L1	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.54	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 11/07/2022 To: 11/07/2022 Date(s) live testing: 11/07/2022 To: 11/07/2022

Tested by: Name (capital letters): LIAM KIMBLE Position: Electrical Test Engineer Date: 11/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 9 Riser 2nd Floor [Schneider]		Supply to distribution board is from Sub Mains(DB CL3, 9/L2)		Associated RCD(if any): BS (EN) 61009
Designation DB CL3/9-2		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Operating at 1 IΔn 38.5 ms
Num. of ways 4 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 21.0 ms
				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance 080408/5657
				Insulation resistance 080408/5657
				Continuity 080408/5657
				RCD 080408/5657

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L2	Room 9 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Room 2 Riser 5th Floor [Schneider] Designation: DB CL6/7 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Supply to distribution board is from: Sub Mains(DB CL/6, 7/L2) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Associated RCD(if any): BS (EN) 61009 Operating at 1 I _{Δn} : 29.4 ms (Above 30mA) 30mA or below: 31.6 ms (if applicable) Z _s : 0.45 Ω No. of poles: 2 I _{pn} : 0.51 kA I _{Δn} : 30 Time delay (if applicable): N/A	Loop impedance: 080408/5657 Insulation resistance: 080408/5657 Continuity: 080408/5657 RCD: 080408/5657

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I _{Δn} ms			30mA or below 5 I _{Δn} ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L2	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 11/07/2022 To 11/07/2022 Date(s) live testing: 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser 2nd Floor [Schneider]
 Designation: DB CL3/6
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL3, 6/L2)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 29.0 ms
 Zs 0.45 Ω No. of poles 2 30mA or below
 Ipr 0.51 kA IΔn 30 Operating at 5 IΔn 28.0 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 080408/5657
 Insulation resistance 080408/5657
 Continuity 080408/5657
 RCD 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L2	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.50	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022
 Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance Company Address: Kid Glove Road Postcode: WA3 3GR Branch No.: Scheme No.:
 Client: UPP Residential Services Ltd Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Ground Floor Kitchen (Schneider)
 Designation: DB CL3
 Num. of ways: 18 Num. of phases: 1
 Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (Busbar, 5/L2)
 Overcurrent protective device for the distribution circuit: Type: gG Rating: 63 A Voltage: 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) N/A Above 30mA (if applicable) Operating at 1 IΔn: N/A ms
 Zs: 0.15 Ω No. of poles: NA 30mA or below
 Ipr: 1.59 kA IΔn: N/A Operating at 5 IΔn: N/A ms
 Time delay (if applicable): NA

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			APDD (✓)				
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2	
					80%																								
1/L2	Common Room Lights	A	B	1	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.39	N/A	250	LIM	>299	✓	0.59	30.0	19.8	✓	N/A	
2/L2	Bedroom Lights 2,3,4	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.64	N/A	250	LIM	>299	✓	0.72	28.9	20.4	✓	N/A	
3/L2	Bedroom Lights 5,6,7	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.58	30.0	18.8	✓	N/A	
4/L2	Bedroom Lights 1,8	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.40	N/A	250	LIM	>299	✓	0.63	28.9	22.8	✓	N/A	
5/L2	Bedroom Lights	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.45	N/A	250	LIM	>299	✓	0.56	28.9	24.5	✓	N/A	
6/L2	Sub Mains(DB CL3/6-1, DB CL3/6)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.48	0.48	0.65	✓	0.28	N/A	250	LIM	>299	✓	0.45	29.0	28.0	✓	N/A	
7/L2	Sub Mains(DB CL3/7, DB CL3/7-1, DB CL3/7-2)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.52	0.48	0.60	✓	0.28	N/A	250	LIM	>299	✓	0.39	28.5	27.6	✓	N/A	
8/L2	Sub Mains(DB CL3/8, DB CL3/8-1)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.35	0.38	0.53	✓	0.22	N/A	250	LIM	>299	✓	0.37	22.5	18.9	✓	N/A	
9/L2	Sub Mains(DB CL3/9-1, DB CL3/9, DB CL3/9-2)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.47	0.44	0.52	✓	0.25	N/A	250	LIM	>299	✓	0.44	38.5	21.0	✓	N/A	
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L2	Kitchen Ring Main 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.27	0.27	0.41	✓	0.17	N/A	250	LIM	>299	✓	0.27	27.4	27.0	✓	N/A	
12/L2	Kitchen Ring Main 2	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.27	0.27	0.41	N/A	0.17	N/A	250	LIM	>299	✓	0.32	32.4	23.6	✓	N/A	
13/L2	Hob 1	A	B	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.40	30.9	28.4	✓	N/A	
14/L2	Hob 2	A	E	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.35	25.4	16.4	✓	N/A	
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 11/07/2022 To: 11/07/2022 Date(s) live testing: 11/07/2022 To: 11/07/2022

Tested by: Name (capital letters): LIAM KIMBLE Position: Electrical Test Engineer Date: 11/07/2022

Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																				
Circuit No. and Line No.	Distribution board Designation		Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
	DB CL3					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Idn ms			30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)						
	Circuit designation														r1	m	r2												R1 + R2	R2				
															(Ω)	(Ω)	(Ω)												(Ω)	(Ω)				
17/L2	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 9 Riser 6th Floor [Schneider]	Supply to distribution board is from: Sub Mains(DB CL7, 9/L3)		Associated RCD(if any): BS (EN) 61009	Above 30mA (if applicable) Operating at 1 IΔn 28.6 ms
Designation: DB CL7/9-2	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Zs 0.41 Ω No. of poles 2	30mA or below Operating at 5 IΔn 28.7 ms
Num. of ways 4 Num. of phases 1			Ipf 0.58 kA IΔn 30	Time delay (if applicable) N/A
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Test instrument serial number(s)	
				Loop impedance 080408/5657
				Insulation resistance 080408/5657
				Continuity 080408/5657
				RCD 080408/5657

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2		R1 + R2	R2										
					80%	(Ω)		(V)	(M)	(M)				(M)	(M)	(M)													
1/L3	Room 9 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance
 Company Address: Kid Glove Road
 Postcode: WA3 3GR
 Branch No.:
 Scheme No.:
 Client: UPP Residential Services Ltd
 Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
 Postcode: SA1 8EN

Distribution board details - Complete in every case

Location: Room 5 Riser 2nd Floor [Schneider]
 Designation: DB CL3/8
 Num. of ways: 4
 Num. of phases: 1
 Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation

Supply to distribution board is from:
 Sub Mains(DB CL3, 8/L2)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V

Characteristics at this distribution board

Associated RCD(if any): BS (EN) 61009
 Operating at 1 IΔn: 22.5 ms (Above 30mA)
 30mA or below: 18.9 ms (if applicable)
 Zs: 0.37 Ω No. of poles: 2
 Ipf: 0.63 kA IΔn: 30
 Time delay (if applicable): N/A

Test instrument serial number(s)

Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	r2	r2												R1 + R2	R2
1/L2	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Room 4 Riser 3rd Floor [Schneider]	Supply to distribution board is from: Sub Mains(DB CL4, 7/L3)	Associated RCD(if any): BS (EN) 61009	Loop impedance: 080408/5657
Designation: DB CL4/7-2	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Operating at 1 IΔn: 28.6 ms	Insulation resistance: 080408/5657
Num. of ways: 4 Num. of phases: 1	BS(EN) 61009 RCD/RCBO	30mA or below: 22.4 ms	Continuity: 080408/5657
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Time delay (if applicable): N/A	RCD: 080408/5657

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)				
														r1	rn	r2												R1 + R2	R2		
					80%	80%		80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%	80%	80%	80%
1/L3	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.	
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode	SA1 8EN				

Distribution board details - Complete in every case Location: Room 4 Riser 6th Floor [Schneider] Designation: DB CL7/7-2 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>	Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains (DB CL7, 7/L3) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Characteristics at this distribution board Associated RCD(if any): BS (EN) 61009 Operating at 1 I Δ n: 28.4 ms (Above 30mA) Operating at 5 I Δ n: 28.7 ms (30mA or below) Z $_s$: 0.38 Ω No. of poles: 2 I $_p$: 0.60 kA I Δ n: 30 Time delay (if applicable): N/A	Test instrument serial number(s) Loop impedance: 080408/5657 Insulation resistance: 080408/5657 Continuity: 080408/5657 RCD: 080408/5657
--	--	---	---

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Z $_s$ Other (80%)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z $_s$ (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I Δ n ms			30mA or below 5 I Δ n ms	RCD (✓)	AFCD (✓)		
														r1	r2	r3												R1+R2	R2
1/L3	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 11/07/2022 To 11/07/2022 Date(s) live testing: 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Mains Room Riser [Schneider] Designation: DB FFS Num. of ways: 12 Num. of phases: 3 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input checked="" type="checkbox"/>	Supply to distribution board is from: Sub Mains(MSP, 7/TP) Overcurrent protective device for the distribution circuit: BS(EN) 60947 MCCB Type: N/A Rating: 63 A Voltage: 400/230 V	Associated RCD(if any): BS (EN) N/A Operating at 1 IΔn: N/A ms 30mA or below: N/A ms Operating at 5 IΔn: N/A ms Time delay (if applicable): N/A	Loop impedance: 080408/5657 Insulation resistance: 080408/5657 Continuity: 080408/5657 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFCD (✓)			
														r1	r2	Fig 8 check (✓)										All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2													
1/TP	Lift	O	E	1	16	16	0.4	60898 MCB	C	32	10	N/A	0.54	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	N/A	N/A	N/A	N/A
2/L1	Fire Alarm Panel	O	E	1	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.20	N/A	N/A	N/A	N/A
2/L2	Refuge Alarm	O	E	1	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.24	N/A	N/A	N/A	N/A
2/L3	Stair Lights G & 1st Floor	O	E	12	1.5	1.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	0.47	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A	
3/L1	Stair Lights 2nd & 3rd Floor	O	E	12	1.5	1.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	0.60	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A	
3/L2	Stair Lights 4th & 5th	O	E	12	1.5	1.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	0.59	N/A	250	LIM	>299	✓	0.78	N/A	N/A	N/A	N/A	
3/L3	Stair Lights 6th - 8th Floor	O	E	12	1.5	1.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A	
4/L1	ADVs Floors 1-3	O	E	6	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.30	N/A	N/A	N/A	N/A	
4/L2	ADVs Floors 4-6	O	E	6	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.36	N/A	N/A	N/A	N/A	
4/L3	ADVs Floor 7-8	O	E	4	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.33	N/A	N/A	N/A	N/A	
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 11/07/2022 To: 11/07/2022 Date(s) live testing: 11/07/2022 To: 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 11/07/2022

Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS												TEST RESULTS																		
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
	DB FFS				Circuit designation	L / N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Δn ms			30mA or below 5 Δn ms	RCD (✓)	AFFD (✓)				
													r1	m	r2	(✓)	R1 + R2	R2												
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature *Liam Kimble*

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)		
Location	Room 2 Riser 2nd Floor [Schneider]	Supply to distribution board is from	Associated RCD(if any): BS (EN) 61009		Above 30mA (if applicable)		Loop impedance	
Designation	DB CL3/7	Sub Mains(DB CL3, 7/L2)	Z _s	0.39 Ω	No. of poles	2	Operating at 1 IΔn	
Num. of ways	4	Num. of phases	1	Operating at 5 IΔn	28.5 ms	30mA or below	Insulation resistance	
Supply polarity confirmed	<input checked="" type="checkbox"/>	Phase sequence confirmed	<input type="checkbox"/>	Overcurrent protective device for the distribution circuit: Type	C	Rating	32 A	Operating at 5 IΔn
				BS(EN)	61009 RCD/RCBO	27.6 ms	Continuity	080408/5657
				Voltage	230 V	Time delay (if applicable)	RCD	080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L2	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		
Location: Riser Flat 1 Room 1 (Scheider)	Supply to distribution board is from: Sub Mains(DB CL1, 6/L1)	Characteristics at this distribution board		
Designation: DB/CL1.6.1	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) Operating at 1 I _{Δn} 29.9 ms		
Num. of ways: 1 Num. of phases: 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Z _s 0.43 Ω No. of poles N/A 30mA or below		
		I _{pf} 0.55 kA I _{Δn} 30 Operating at 5 I _{Δn} 22.0 ms		
		Time delay (if applicable) NA		
		Test instrument serial number(s)		
		Loop impedance 080408/5756		
		Insulation resistance 080408/5756		
		Continuity 080408/5756		
		RCD 080408/5756		

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I _{Δn} ms	30mA or below 5 I _{Δn} ms			RCD (✓)	AFCD (✓)				
														r1	r2	Fig 8 check (✓)										R1 + R2	R2		
1/L1	Sockets Room 1	A	E	1	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name <input type="text" value="PHS Compliance"/>	Company Address <input type="text" value="Kid Glove Road"/>	Postcode <input type="text" value="WA3 3GR"/>	Branch No. <input type="text"/>	Scheme No. <input type="text"/>
Client <input type="text" value="UPP Residential Services Ltd"/>	Installation Address <input type="text" value="Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea"/>	Postcode <input type="text" value="SA1 8EN"/>		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location <input type="text" value="Riser Flat 1 Room 3 (Schneider)"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL1, 7/L1)"/>		Associated RCD(if any): BS (EN) <input type="text" value="N/A"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="31.4"/> ms		Loop impedance <input type="text" value="080408/5756"/>	
Designation <input type="text" value="DB/CL1.7.2"/>				Zs <input type="text" value="0.40"/> Ω No. of poles <input type="text" value="N/A"/> 30mA or below		Insulation resistance <input type="text" value="080408/5756"/>	
Num. of ways <input type="text" value="1"/> Num. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="230"/> V		Ipf <input type="text" value="0.58"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="29.0"/> ms		Continuity <input type="text" value="080408/5756"/>	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) <input type="text" value="NA"/>		RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r3												R1 + R2
1/L1	Sockets Room 3	A	E	1	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.41	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser 5th Floor [Schneider]
 Designation: DB CL6/6
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL/6, 6/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 30.4 ms (Above 30mA) | 18.4 ms (30mA or below)
 Z_s: 0.34 Ω | No. of poles: 2 | I_{pn}: 0.68 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 11/07/2022 To: 11/07/2022 Date(s) live testing: 11/07/2022 To: 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 11/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR **110147629**



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case				Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 10 Riser 4th Floor [Schneider]		Supply to distribution board is from: Sub Mains(DB CL5, 6/L1)		Associated RCD(if any): BS (EN) 61009		Test instrument serial number(s) Loop impedance: 080408/5657 Insulation resistance: 080408/5657 Continuity: 080408/5657 RCD: 080408/5657
Designation: DB CL5/6-1		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Operating at 1 IΔn: 27.5 ms (Above 30mA)		
Num. of ways: 4 Num. of phases: 1		BS(EN) 61009 RCD/RCBO		30mA or below: 24.5 ms (Operating at 5 IΔn)		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable): N/A		

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	rn	r2		R1 + R2	R2											
					80%	80%		80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%	80%	80%
1/L1	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.43	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 3 Riser 7th Floor [Schneider]		Supply to distribution board is from Sub Mains(DB CL8, 7/L1)		Associated RCD(if any): BS (EN) 61009
Designation DB CL8/7-1		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Operating at 1 IΔn 28.8 ms
Num. of ways 4 Num. of phases 1				30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 28.8 ms
				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance 080408/5657
				Insulation resistance 080408/5657
				Continuity 080408/5657
				RCD 080408/5657

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.77	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.	
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode	SA1 8EN		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board			Test instrument serial number(s)				
Location	Room 6 Riser 6th Floor [Schneider]	Supply to distribution board is from	Sub Mains(DB CL7, 8/L3)			Associated RCD(if any): BS (EN)	Above 30mA (if applicable)		Loop impedance	080408/5657		
Designation	DB CL7/8-1	Overcurrent protective device for the distribution circuit: Type	C	Rating	32	A	Voltage	230	V	Insulation resistance	080408/5657	
Num. of ways	4	Num. of phases	1	Supply polarity confirmed	<input checked="" type="checkbox"/>	Phase sequence confirmed	<input type="checkbox"/>	Operating at 1 IΔn	28.0	ms	Continuity	080408/5657
								Operating at 5 IΔn	28.6	ms	RCD	080408/5657
								Time delay (if applicable)	N/A			

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L3	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location 4th Floor Kitchen (Schneider)		Supply to distribution board is from Sub Mains(Busbar, 8/L1)		Associated RCD(if any): BS (EN) N/A
Designation DB CL5		Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V		Above 30mA (if applicable) Operating at 1 IΔn N/A ms
Num. of ways 18 Num. of phases 1				30mA or below Operating at 5 IΔn N/A ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) NA
Test instrument serial number(s)				
Loop impedance 080408/5756				
Insulation resistance 080408/5756				
Continuity 080408/5756				
RCD 080408/5756				

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			APDD (✓)				
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
					80%	R1 + R2	R2																						
1/L1	Common Room Lights	A	B	1	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	✓	0.53	28.4	20.4	✓	N/A	
2/L1	Bedroom Lights 2,3,4	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.37	N/A	250	LIM	>299	✓	0.52	27.4	18.4	✓	N/A	
3/L1	Bedroom Lights 5,6,7	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.64	30.4	24.0	✓	N/A	
4/L1	Bedroom Lights 1,8	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.37	N/A	250	LIM	>299	✓	0.57	29.4	19.8	✓	N/A	
5/L1	Bedroom Lights	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.53	N/A	250	LIM	>299	✓	0.68	27.5	20.4	✓	N/A	
6/L1	Sub Mains(DB CL5/6-1, DB CL5/6)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.30	0.33	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.34	27.5	24.5	✓	N/A	
7/L1	Sub Mains(DB CL5/7, DB CL5/7-1, DB CL5/7-2)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.38	0.38	0.51	✓	0.23	N/A	250	LIM	>299	✓	0.40	29.4	24.0	✓	N/A	
8/L1	Sub Mains(DB CL5/8, DB CL5/8-1)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.28	0.31	0.36	✓	0.16	N/A	250	LIM	>299	✓	0.30	38.5	20.2	✓	N/A	
9/L1	Sub Mains(DB CL5/9, DB CL5/9-1, DB CL5/9-2)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.40	0.36	0.48	✓	0.22	N/A	250	LIM	>299	✓	0.44	32.5	18.8	✓	N/A	
10/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L1	Kitchen Ring Main 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.32	0.32	0.40	✓	0.18	N/A	250	LIM	>299	✓	0.35	32.5	22.2	✓	N/A	
12/L1	Kitchen Ring Main 2	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.29	0.25	0.34	✓	0.16	N/A	250	LIM	>299	✓	0.33	36.1	25.3	✓	N/A	
13/L1	Hob 1	A	B	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.27	29.7	17.6	✓	N/A	
14/L1	Hob 2	A	E	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.38	32.5	18.8	✓	N/A	
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																			
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
	DB CL5				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)					
	Circuit designation													r1	m	r2												R1 + R2	R2			
	80%																															
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 5 Riser 4th Floor [Schneider]	Supply to distribution board is from: Sub Mains(DB CL5, 8/L1)		Associated RCD(if any): BS (EN) 61009	Test instrument serial number(s) Loop impedance: 080408/5657 Insulation resistance: 080408/5657 Continuity: 080408/5657 RCD: 080408/5657
Designation: DB CL5/8	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Operating at 1 IΔn: 38.5 ms	
Num. of ways: 4 Num. of phases: 1	BS(EN) 61009 RCD/RCBO		30mA or below: 20.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable): N/A	

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.47	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: 4th Floor Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(Busbar, 13/L2)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: DB CL/6	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 I _{Δn} : N/A ms	Insulation resistance: 080408/5756
Num. of ways: 18 Num. of phases: 1		No. of poles: NA	Continuity: 080408/5756
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Operating at 5 I _{Δn} : N/A ms	RCD: 080408/5756
		Time delay (if applicable): NA	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I _{Δn} ms	30mA or below 5 I _{Δn} ms	RCD (✓)			AFDD (✓)				
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2	
					80%	(✓)		(✓)	(✓)	(✓)				(✓)															
1/L2	Common Room Lights	A	B	1	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.66	25.4	19.7	✓	N/A	
2/L2	Bedroom Lights 2,3,4	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.53	32.4	20.6	✓	N/A	
3/L2	Bedroom Lights 5,6,7	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.27	N/A	250	LIM	>299	✓	0.56	28.2	18.4	✓	N/A	
4/L2	Bedroom Lights 1,8	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.39	N/A	250	LIM	>299	✓	0.62	30.4	24.2	✓	N/A	
5/L2	Bedroom Lights	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.58	N/A	250	LIM	>299	✓	0.73	22.6	20.4	✓	N/A	
6/L2	Sub Mains(DB CL6/6, DB CL6/6-1)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.34	0.31	0.44	✓	0.20	N/A	250	LIM	>299	✓	0.34	30.4	18.4	✓	N/A	
7/L2	Sub Mains(DB CL6/7, DB CL6/7-1, DB CL6/7-2)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.50	0.47	0.56	✓	0.27	N/A	250	LIM	>299	✓	0.45	29.4	31.6	✓	N/A	
8/L2	Sub Mains(DB CL6/8-1, DB CL6/8)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.38	0.39	0.42	✓	0.20	N/A	250	LIM	>299	✓	0.36	33.5	22.0	✓	N/A	
9/L2	Sub Mains(DB CL6/9, DB CL6/9-1, DB CL6/9-2)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.42	0.42	0.56	✓	0.25	N/A	250	LIM	>299	✓	0.40	29.2	18.4	✓	N/A	
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L2	Kitchen Ring Main 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.40	0.40	0.50	✓	0.23	N/A	250	LIM	>299	✓	0.34	22.4	19.7	✓	N/A	
12/L2	Kitchen Ring Main 2	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.37	0.37	0.48	✓	0.21	N/A	250	LIM	>299	✓	0.40	28.3	20.4	✓	N/A	
13/L2	Hob 1	A	B	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.26	17.3	19.1	✓	N/A	
14/L2	Hob 2	A	E	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.30	16.5	17.5	✓	N/A	
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																							
Circuit No. and Line No.	Distribution board Designation		Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation									
	DB CL/6	Circuit designation				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Idn ms			30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)									
															r1	m	r2												R1 + R2	R2							
																				✓	✓	✓	✓														
17/L2	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
18/L2	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Room 10 Riser 7th Floor [Schneider]	Supply to distribution board is from: Sub Mains(DB CL8, 6/L1)	Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn: 28.4 ms (Above 30mA) 30mA or below: 18.6 ms (if applicable)	Loop impedance: 080408/5657
Designation: DB CL8/6-1	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Z _s : 0.32 Ω No. of poles: 2 I _{pf} : 0.73 kA IΔn: 30	Insulation resistance: 080408/5657
Num. of ways: 4 Num. of phases: 1		Time delay (if applicable): N/A	Continuity: 080408/5657
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>			RCD: 080408/5657

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L1	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.46	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR **110147629**



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser 5th Floor [Schneider]
 Designation: DB CL6/9-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL/6, 9/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 29.2 ms (Above 30mA) | 18.4 ms (30mA or below)
 Z_s: 0.40 Ω | No. of poles: 2 | I_{pf}: 0.58 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	r _n	r2												R1 + R2
					80%	(Ω)		(V)	(M(Ω))	(M(Ω))				(ms)	(ms)	(✓)	(✓)											
1/L2	Room 8 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.45	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 11/07/2022 To: 11/07/2022 Date(s) live testing: 11/07/2022 To: 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 11/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Ground Floor Plant Room (Schneider)	Supply to distribution board is from: Sub Mains(Busbar, 3/TP)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: DB/LL1/P	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 080408/5756
Num. of ways: 8 Num. of phases: 3		30mA or below: N/A ms	Continuity: 080408/5756
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 080408/5756
		Time delay (if applicable): NA	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	APDD (✓)		
														r1	rn	r2												R1 + R2	R2
1/L1	Ring Main Switch Room	A	E	2	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.14	0.14	0.32	N/A	0.12	N/A	250	LIM	>299	✓	0.26	34.0	22.0	✓	N/A	
1/L2	Ring Main GF Corridor	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.11	0.12	0.15	✓	0.07	N/A	250	LIM	>299	✓	0.22	28.4	18.4	✓	N/A	
1/L3	Ring Main 1F Corridor	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.63	0.64	1.01	✓	0.41	N/A	250	LIM	>299	✓	0.54	26.2	19.2	✓	N/A	
2/L1	Ring Main 2F Corridor	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.77	0.76	1.18	✓	0.49	N/A	250	LIM	>299	✓	0.63	30.4	22.0	✓	N/A	
2/L2	Ring Main 3F Corridor	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.84	0.85	1.28	✓	0.53	N/A	250	LIM	>299	✓	0.69	29.4	18.4	✓	N/A	
2/L3	Data Cab	A	E	1	4	1.5	0.4	61009 RCD/	C	16	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.30	LIM	LIM	LIM	N/A	
3/L1	Access Control	A	E	1	2.5	1.5	0.4	61009 RCD/	C	16	10	30	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.36	29.4	18.8	✓	N/A	
3/L2	Auto Door	A	E	1	2.5	1.5	0.4	61009 RCD/	C	16	10	30	1.09	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.25	32.2	19.2	✓	N/A	
3/L3	Data Cab	A	E	1	4	1.5	0.4	61009 RCD/	C	16	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.30	LIM	LIM	LIM	N/A	
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Riser Flat 1 Room 10 (Schneider)	Supply to distribution board is from: Sub Mains(DB CL1, 6/L1)	Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s)
Designation: DB/CL1.6.2	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Operating at 1 IΔn 29.9 ms (if applicable)		
Num. of ways: 1 Num. of phases: 1	BS(EN) 61009 RCD/RCBO	30mA or below		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Type C Rating 32 A Voltage 230 V	Operating at 5 IΔn 22.0 ms		
		Time delay (if applicable) NA		Loop impedance 080408/5756
				Insulation resistance 080408/5756
				Continuity 080408/5756
				RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r2												R1 + R2
					80%	Ω		Ω	Ω	Ω				Ω	Ω	Ω	Ω	Ω	Ω	Ω	Ω			Ω	Ω	Ω	Ω	Ω
1/L1	Flat 10 Sockets	A	E	1	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.46	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location Room 8 Riser 3rd Floor [Schneider]	Supply to distribution board is from Sub Mains(DB CL4, 9/L3)	Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn 28.7 ms Above 30mA (if applicable)	Loop impedance 080408/5657
Designation DB CL4/9-1	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Zs 0.40 Ω No. of poles 2 Operating at 5 IΔn 18.6 ms 30mA or below	Insulation resistance 080408/5657
Num. of ways 4 Num. of phases 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Ipf 0.58 kA IΔn 30 Time delay (if applicable) N/A	Continuity 080408/5657 RCD 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r2	r2												R1 + R2	R2	
					80%	r1		r2	r2	R1 + R2				R2	V	M(Ω)	M(Ω)	(✓)	(✓)	(✓)	(✓)									
1/L3	Room 8 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Flat 1 Room 4 (Schneider)
 Designation: DB/CL1.7.3
 Num. of ways: 1 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL1, 7/L1)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) N/A Operating at 1 IΔn 31.4 ms Above 30mA (if applicable)
 Z_s 0.40 Ω No. of poles N/A 30mA or below
 I_{pr} 0.58 kA IΔn 30 Operating at 5 IΔn 29.0 ms
 Time delay (if applicable) NA

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	r _n	r2												R1 + R2
1/L1	Sockets Room	A	E	1	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.51	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022
 Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 2 Riser 7th Floor [Schneider]	Supply to distribution board is from Sub Mains(DB CL8, 7/L1)	Associated RCD(if any): BS (EN) 61009		Test instrument serial number(s) Loop impedance 080408/5657 Insulation resistance 080408/5657 Continuity 080408/5657 RCD 080408/5657
Designation DB CL8/7	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Operating at 1 IΔn 28.8 ms		
Num. of ways 4 Num. of phases 1	BS(EN) 61009 RCD/RCBO	30mA or below		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Operating at 5 IΔn 28.8 ms		
		Time delay (if applicable) N/A		

CIRCUIT DETAILS														TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L1	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case				Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 2 Riser 6th Floor [Schneider]		Supply to distribution board is from: Sub Mains(DB CL7, 7/L3)		Associated RCD(if any): BS (EN) 61009		Test instrument serial number(s) Loop impedance: 080408/5657 Insulation resistance: 080408/5657 Continuity: 080408/5657 RCD: 080408/5657
Designation: DB CL7/7		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Operating at 1 IΔn: 28.4 ms (Above 30mA)		
Num. of ways: 4 Num. of phases: 1				30mA or below: 28.7 ms (Operating at 5 IΔn)		
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>				Time delay (if applicable): N/A		

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)				
														r1	rn	r2												R1 + R2	R2		
					80%	80%		80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%	80%		
1/L3	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 11/07/2022 To: 11/07/2022 Date(s) live testing: 11/07/2022 To: 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 11/07/2022

Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location Plant Room [Schneider]	Supply to distribution board is from Sub Mains(Busbar, 24/TP)	Associated RCD(if any): BS (EN) N/A	Loop impedance 080408/5756
Designation DB PL	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V	Operating at 1 I _{Δn} Above 30mA (if applicable) N/A ms	Insulation resistance 080408/5756
Num. of ways 12	BS(EN) 88-2 HRC	No. of poles N/A	Continuity 080408/5756
Num. of phases 3		Operating at 5 I _{Δn} Above 30mA or below 30mA or below N/A ms	RCD 080408/5756
Supply polarity confirmed <input checked="" type="checkbox"/>		Time delay (if applicable) N/A	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I _{Δn} ms	30mA or below 5 I _{Δn} ms	RCD (✓)			APDD (✓)				
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2	
					All circuits to be completed using R1R2 or R2, not both																								
1/TP	Sub Mains(DB Mech Panel)	G	E	1	16	16	0.4	60898 MCB	C	32	10	N/A	0.54	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A	
2/L1	Fan 1	O	E	1	2.5	2.5	0.4	61009 RCD/	C	16	10	30	1.09	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.24	29.3	21.3	✓	N/A	
2/L2	Fan 2	O	E	1	2.5	2.5	0.4	61009 RCD/	C	16	10	30	1.09	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.28	35.0	28.6	✓	N/A	
2/L3	Fan 3	O	E	1	2.5	2.5	0.4	61009 RCD/	C	16	10	30	1.09	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.26	38.7	28.6	✓	N/A	
3/L1	Fan 4	O	E	1	2.5	2.5	0.4	61009 RCD/	C	16	10	30	1.09	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.24	28.7	28.5	✓	N/A	
3/L2	Plant Ring	B	B	4	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.33	0.33	0.27	N/A	0.15	N/A	250	LIM	>299	✓	0.32	28.5	28.8	✓	N/A	
3/L3	Lighting Plant	B	B	8	1.5	1	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	N/A	0.32	N/A	250	LIM	>299	✓	0.49	N/A	N/A	✓	N/A	
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	Fan Contactors	D	B	4	1.5	1.5	0.4	60898 MCB	C	6	10	N/A	2.91	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.20	N/A	N/A	N/A	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 12/07/2022 To 12/07/2022 Date(s) live testing 12/07/2022 To 12/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 12/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Circuit No. and Line No.	CIRCUIT DETAILS												TEST RESULTS																									
	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation												
	DB PL				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)											
	Circuit designation	r1	m	r2	R1 + R2	R2																																
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	ISOLATED	D	B	LIM	16	16	0.4	60898 MCB	C	40	10	N/A	0.44	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance Company Address: Kid Glove Road Postcode: WA3 3GR Branch No.: Scheme No.:
 Client: UPP Residential Services Ltd Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Ground Floor Kitchen (Schneider)
 Designation: DB CL1
 Num. of ways: 18 Num. of phases: 1
 Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(MSP, 3/L1)
 Overcurrent protective device for the distribution circuit: Type: N/A Rating: 63 A Voltage: 230 V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) Operating at 1 IΔn: N/A ms
 Zs: 0.14 Ω No. of poles: NA 30mA or below
 Ipf: 1.67 kA IΔn: N/A Operating at 5 IΔn: N/A ms
 Time delay (if applicable): NA

Test instrument serial number(s)
 Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			APDD (✓)				
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2	
					All circuits to be completed using R1R2 or R2, not both																								
1/L1	Common Room Lights	A	E	1	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.32	29.9	27.9	✓	N/A	
2/L1	Bedroom Lights 2,3,4	A	E	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.49	29.8	22.0	✓	N/A	
3/L1	Bedroom Lights 5,6,7	A	E	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.52	30.1	22.4	✓	N/A	
4/L1	Bedroom Lights 1,8	A	E	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.53	28.9	28.0	✓	N/A	
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Sub Mains(DB/CL1.6.1, DB/CL1.6.2)	A	E	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.61	0.61	1.04	✓	0.43	N/A	250	LIM	>299	✓	0.43	29.9	22.0	✓	N/A	
7/L1	Sub Mains(DB/CL1.7.1, DB/CL1.7.2, DB/CL1.7.3)	A	E	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.58	0.59	0.99	✓	0.41	N/A	250	LIM	>299	✓	0.40	31.4	29.0	✓	N/A	
8/L1	Sub Mains(DB/CL1.8.1)	A	E	6	2x2.5	2x1.5	5	61009 RCD/	C	32	10	30	0.54	0.55	0.54	0.97	✓	0.38	N/A	250	LIM	>299	✓	0.38	33.7	28.7	✓	N/A	
9/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	Kitchen Ring Main 1	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.30	0.31	0.48	✓	0.21	N/A	250	LIM	>299	✓	0.32	29.8	22.0	✓	N/A	
11/L1	Kitchen Ring Main 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.22	0.21	0.29	✓	0.13	N/A	250	LIM	>299	✓	0.31	27.9	18.9	✓	N/A	
12/L1	Hob 1	A	E	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.25	31.6	29.7	✓	N/A	
13/L1	Hob 2	A	E	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.25	28.9	22.7	✓	N/A	
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 11/07/2022 To: 11/07/2022 Date(s) live testing: 11/07/2022 To: 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 11/07/2022

Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS															TEST RESULTS																		
Circuit No. and Line No.	Distribution board Designation		Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation					
	DB CL1					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)					
	Circuit designation														r1	m	r2												R1 + R2	R2			
18/L1	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 6 Riser 2nd Floor [Schneider]
 Designation: DB CL3/8-1
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL3, 8/L2)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Operating at 1 IΔn 22.5 ms Above 30mA (if applicable)
 Z_s 0.37 Ω No. of poles 2 30mA or below
 I_{pr} 0.63 kA IΔn 30 Operating at 5 IΔn 18.9 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 080408/5657
 Insulation resistance 080408/5657
 Continuity 080408/5657
 RCD 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L2	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 5 Riser 3rd Floor [Schneider]
 Designation: DB CL4/8
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL4, 8/L3)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Operating at 1 IΔn 28.6 ms Above 30mA (if applicable)
 Zs 0.32 Ω No. of poles 2 30mA or below
 Ipf 0.71 kA IΔn 30 Operating at 5 IΔn 18.7 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 080408/5657
 Insulation resistance 080408/5657
 Continuity 080408/5657
 RCD 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	rn	r2												R1 + R2	R2
1/L3	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 3 Riser 6th Floor [Schneider]		Supply to distribution board is from: Sub Mains(DB CL7, 7/L3)		Associated RCD(if any): BS (EN) 61009
Designation: DB CL7/7-1		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Operating at 1 IΔn: 28.4 ms
Num. of ways: 4 Num. of phases: 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn: 28.7 ms
				Time delay (if applicable): N/A
				Test instrument serial number(s)
				Loop impedance: 080408/5657
				Insulation resistance: 080408/5657
				Continuity: 080408/5657
				RCD: 080408/5657

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
					80%	(Ω)		(V)	(M(Ω))	(M(Ω))				(ms)	(ms)	(✓)	(✓)											
1/L3	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: 7th Floor Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(Busbar, 22/L1)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: DB CL8	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 080408/5756
Num. of ways: 18 Num. of phases: 1		No. of poles: NA	Continuity: 080408/5756
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 080408/5756
		Time delay (if applicable): NA	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)		
														r1	rn	r2												R1 + R2	R2
					80%	(Ω)		(Ω)	(Ω)	(Ω)				(Ω)															
1/L1	Common Room Lights	A	B	1	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.59	38.5	28.7	✓	N/A	
2/L1	Bedroom Lights 2,3,4	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.69	N/A	250	LIM	>299	✓	0.94	24.5	28.6	✓	N/A	
3/L1	Bedroom Lights 5,6,7	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.47	N/A	250	LIM	>299	✓	0.62	28.4	28.5	✓	N/A	
4/L1	Bedroom Lights 1,8	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.68	N/A	250	LIM	>299	✓	0.84	28.5	28.6	✓	N/A	
5/L1	Bedroom Lights	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.47	N/A	250	LIM	>299	✓	0.44	28.6	28.7	✓	N/A	
6/L1	Sub Mains(DB CL8/6-1, DB CL8/6)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.25	0.25	0.37	✓	0.16	N/A	250	LIM	>299	✓	0.32	28.4	18.6	✓	N/A	
7/L1	Sub Mains(DB CL8/7-2, DB CL8/7, DB CL8/7-1)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.30	0.30	0.44	✓	0.19	N/A	250	LIM	>299	✓	0.39	28.8	28.8	✓	N/A	
8/L1	Sub Mains(DB CL8/8-1, DB CL8/8)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.36	0.36	0.49	✓	0.21	N/A	250	LIM	>299	✓	0.37	28.5	28.6	✓	N/A	
9/L1	Sub Mains(DB CL8/9-2, DB CL8/9, DB CL8/9-1)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.34	0.35	0.51	✓	0.21	N/A	250	LIM	>299	✓	0.35	28.6	28.5	✓	N/A	
10/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L1	Kitchen Ring Main 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.26	0.26	0.38	✓	0.16	N/A	250	LIM	>299	✓	0.38	28.8	28.8	✓	N/A	
12/L1	Kitchen Ring Main 2	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.31	0.31	0.45	✓	0.19	N/A	250	LIM	>299	✓	0.35	28.6	28.7	✓	N/A	
13/L1	Hob 1	A	B	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.29	28.4	28.5	✓	N/A	
14/L1	Hob 2	A	E	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.36	28.8	28.7	✓	N/A	
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR

110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																				
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
	DB CL8				Circuit designation	L / N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)					
															r1	m	r2																
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Room 3 Riser 2nd Floor [Schneider] Designation: DB CL3/7-1 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>	Supply to distribution board is from: Sub Mains(DB CL3, 7/L2) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 28.5 ms Zs 0.39 Ω No. of poles 2 30mA or below Ipr 0.59 kA IΔn 30 Operating at 5 IΔn 27.6 ms Time delay (if applicable): N/A	Loop impedance: 080408/5657 Insulation resistance: 080408/5657 Continuity: 080408/5657 RCD: 080408/5657

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
					80%	80%		80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%
1/L2	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.49	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 11/07/2022 To 11/07/2022 Date(s) live testing: 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.	
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Room 4 Riser 2nd Floor [Schneider] Designation: DB CL3/7-2 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>	Supply to distribution board is from: Sub Mains (DB CL3, 7/L2) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 28.5 ms Z _s 0.39 Ω No. of poles 2 30mA or below I _{pf} 0.59 kA IΔn 30 Operating at 5 IΔn 27.6 ms Time delay (if applicable) N/A	Loop impedance: 080408/5657 Insulation resistance: 080408/5657 Continuity: 080408/5657 RCD: 080408/5657

CIRCUIT DETAILS														TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L2	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 11/07/2022 To 11/07/2022 Date(s) live testing: 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 11/07/2022

Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 10 Riser 6th Floor [Schneider]	Supply to distribution board is from Sub Mains(DB CL7, 6/L3)		Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 28.6 ms	
Designation DB CL7/6-1	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Z _s 0.32 Ω No. of poles 2 30mA or below I _{pf} 0.72 kA IΔn 30 Operating at 5 IΔn 28.9 ms	
Num. of ways 4 Num. of phases 1	BS(EN) 61009 RCD/RCBO		Time delay (if applicable) N/A	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Test instrument serial number(s)			
Loop impedance 080408/5657				Insulation resistance 080408/5657
Continuity 080408/5657				RCD 080408/5657

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	r _n	r2												R1 + R2
1/L3	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.56	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR **110147629**



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No. 	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location Room 6 Riser 7th Floor [Schneider] Designation DB CL8/8-1 Num. of ways 4 Num. of phases 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Supply to distribution board is from Sub Mains(DB CL8, 8/L1) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V BS(EN) 61009 RCD/RCBO	Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn 28.5 ms Above 30mA (if applicable) Zs 0.37 Ω No. of poles 2 30mA or below Ipr 0.66 kA IΔn 30 Operating at 5 IΔn 28.6 ms Time delay (if applicable) N/A	Loop impedance 080408/5657 Insulation resistance 080408/5657 Continuity 080408/5657 RCD 080408/5657

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2		R2												
1/L1	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	✓	0.83	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing **11/07/2022** To **11/07/2022** Date(s) live testing **11/07/2022** To **11/07/2022**

Tested by: Name (capital letters) **LIAM KIMBLE** Position **Electrical Test Engineer** Date **11/07/2022** Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case Location: Room 3 Riser 5th Floor [Schneider] Designation: DB CL6/7-1 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains (DB CL/6, 7/L2) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Characteristics at this distribution board Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 I _{Δn} 29.4 ms Z _s 0.45 Ω No. of poles 2 30mA or below I _{pn} 0.51 kA I _{Δn} 30 Operating at 5 I _{Δn} 31.6 ms Time delay (if applicable) N/A	Test instrument serial number(s) Loop impedance 080408/5657 Insulation resistance 080408/5657 Continuity 080408/5657 RCD 080408/5657
---	---	---	---

CIRCUIT DETAILS														TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I _{Δn} ms			30mA or below 5 I _{Δn} ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L2	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance, Company Address Kid Glove Road, Postcode WA3 3GR, Branch No., Scheme No., Client UPP Residential Services Ltd, Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, Postcode SA1 8EN. Distribution board details: Location Riser Flat 1 Room, Designation DB/CL1.8.1, Num. of ways 4, Num. of phases 1. Characteristics at this distribution board: Associated RCD (if any): BS (EN), Zs 0.38 Ohm, No. of poles N/A, Ipr 0.58 kA, lDelta n 30, Operating at 1 lDelta n 33.7 ms, Operating at 5 lDelta n 28.7 ms. Test instrument serial number(s): Loop impedance 080408/5756, Insulation resistance 080408/5756, Continuity 080408/5756, RCD 080408/5756.

Table with 2 main sections: CIRCUIT DETAILS and TEST RESULTS. CIRCUIT DETAILS columns include: Circuit No. and Line No., Distribution board Designation, Type of wiring, Ref. method, No. of points, Circuit conductors csa (mm²), Maximum disconnection, Overcurrent protective devices, Breaking capacity, RCD operating, BS 7671 Max. permitted Zs, etc. TEST RESULTS columns include: Circuit impedance Omega, Insulation resistance, Polarity, Max. Measured Zs, RCD testing, Manual test button operation. Data rows include: 1/L1 Room 1 Sockets, 2/L1 SPARE, 3/L1 SPARE, 4/L1 SPARE.

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature [Handwritten Signature]

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Ground Floor Plant Room (Schneider)	Supply to distribution board is from: Sub Mains (Busbar, 3/TP)	Associated RCD (if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: DB/LL1/L	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 080408/5756
Num. of ways: 8 Num. of phases: 3	BS (EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 080408/5756
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 080408/5756
		Time delay (if applicable): NA	

CIRCUIT DETAILS														TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)				
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2	V
					All circuits to be completed using R1R2 or R2, not both																								
1/L1	Lighting Switch Room	A	E	3	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.61	28.4	28.2	✓	N/A	
1/L2	Lighting GF Corridor	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	✓	0.63	18.6	18.0	✓	N/A	
1/L3	Lighting 1F Corridor	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.55	20.2	18.0	✓	N/A	
2/L1	Lighting 2F Corridor	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.42	18.6	17.4	✓	N/A	
2/L2	Lighting 3F Corridor	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	✓	0.55	18.5	13.2	✓	N/A	
2/L3	Bus Lighting Controller	A	E	1	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.46	28.5	17.4	✓	N/A	
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		
Location: Room 7 Riser 7th Floor [Schneider]	Supply to distribution board is from: Sub Mains(DB CL8, 9/L1)		Characteristics at this distribution board	
Designation: DB CL8/9	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn 28.6 ms (if applicable)	
Num. of ways: 4 Num. of phases: 1			Zs 0.35 Ω No. of poles 2 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipf 0.64 kA IΔn 30 Operating at 5 IΔn 28.5 ms	
			Time delay (if applicable) N/A	
Test instrument serial number(s)				
			Loop impedance 080408/5657	
			Insulation resistance 080408/5657	
			Continuity 080408/5657	
			RCD 080408/5657	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	r2	r2												R1 + R2
					80%	r1		r2	r2	R1 + R2				R2	V	M(Ω)	M(Ω)	(✓)	Zs (Ω)	N/A	N/A	N/A			N/A			
1/L1	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Ground Floor Corridor Cupboard (Schneider)	Supply to distribution board is from: Sub Mains(MSP, 6/TP)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5657
Designation: Busbar	Overcurrent protective device for the distribution circuit: BS(EN) 60947 MCCB	Operating at 1 IΔn: NA ms	Insulation resistance: 080408/5657
Num. of ways: 24	Type: N/A	Operating at 5 IΔn: NA ms	Continuity: 080408/5657
Num. of phases: 3	Rating: 250 A	Time delay (if applicable): NA	RCD: 080408/5657
Supply polarity confirmed: <input checked="" type="checkbox"/>	Voltage: 400 V		
Phase sequence confirmed: <input checked="" type="checkbox"/>			

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation					
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	APDD (✓)					
														r1	rn	r2												R1 + R2	R2			
1/L1	Sub Mains(DB/CL2)	G	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A	N/A	N/A		
1/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
2/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/TP	Sub Mains(DB/LL1/P, DB/LL1/L)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/L2	Sub Mains(DB CL3)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	✓	0.15	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	Sub Mains(DB CL4)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	Sub Mains(DB CL5)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 11/07/2022 To: 11/07/2022 Date(s) live testing: 11/07/2022 To: 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	Busbar				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)		
	Circuit designation													r1	m	r2													
10/TP	Sub Mains(DB LL2/L, DB LL2/P)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.15	N/A	N/A	N/A	N/A	
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L2	Sub Mains(DB CL/6)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.15	N/A	N/A	N/A	N/A	N/A
13/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	Sub Mains(DB CL7)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.13	N/A	N/A	N/A	N/A	N/A
17/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
19/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
20/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
21/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22/L1	Sub Mains(DB CL8)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.15	N/A	N/A	N/A	N/A	N/A
22/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
23/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24/TP	Sub Mains(DB PL)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.03	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 7 Riser 3rd Floor [Schneider]	Supply to distribution board is from: Sub Mains (DB CL4, 9/L3)		Associated RCD (if any): BS (EN) 61009	(if applicable) Above 30mA Operating at 1 IΔn 28.7 ms
Designation: DB CL4/9	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Zs 0.40 Ω No. of poles 2	
Num. of ways: 4 Num. of phases: 1	BS (EN) 61009 RCD/RCBO		Ipf 0.58 kA IΔn 30	Operating at 5 IΔn 18.6 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	Test instrument serial number(s)
				Loop impedance 080408/5657
				Insulation resistance 080408/5657
				Continuity 080408/5657
				RCD 080408/5657

CIRCUIT DETAILS													TEST RESULTS																		
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)				
														r1	rn	r2												R1 + R2	R2		
1/L3	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 10 Riser 5th Floor [Schneider]	Supply to distribution board is from Sub Mains(DB CL/6, 6/L2)		Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 30.4 ms	
Designation DB CL6/6-1	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Zs 0.34 Ω No. of poles 2 30mA or below Ipf 0.68 kA IΔn 30 Operating at 5 IΔn 18.4 ms	
Num. of ways 4 Num. of phases 1	BS(EN) 61009 RCD/RCBO		Time delay (if applicable) N/A	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Test instrument serial number(s)	
				Loop impedance 080408/5657
				Insulation resistance 080408/5657
				Continuity 080408/5657
				RCD 080408/5657

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
					80%	(Ω)	(Ω)	(Ω)	(Ω)	(Ω)				(Ω)	(Ω)	(Ω)												
1/L2	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 7 Riser 5th Floor [Schneider]
 Designation: DB CL6/9
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL/6, 9/L2)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 29.2 ms
 Zs 0.40 Ω No. of poles 2 30mA or below
 Ipr 0.58 kA IΔn 30 Operating at 5 IΔn 18.4 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 080408/5657
 Insulation resistance 080408/5657
 Continuity 080408/5657
 RCD 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L2	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Plant Room [Schneider]		Supply to distribution board is from: Sub Mains(DB PL, 1/TP)		Associated RCD(if any): BS (EN) N/A
Designation: DB Mech Panel		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 400/230 V		Above 30mA (if applicable) Operating at 1 IΔn N/A ms
Num. of ways: 6 Num. of phases: 3		Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		30mA or below Operating at 5 IΔn N/A ms
				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance: 080408/5756
				Insulation resistance: 080408/5756
				Continuity: 080408/5756
				RCD: 080408/5756

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDO (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	Press Unit	O	B	1	1.5	1.5	0.4	60898 MCB	D	6	10	N/A	1.45	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.33	N/A	N/A	N/A	N/A	
1/L2	Boiler 1	O	B	1	1.5	1.5	0.4	60898 MCB	C	4	10	N/A	4.37	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.34	N/A	N/A	N/A	N/A	
1/L3	Boiler 2	O	B	1	1.5	1.5	0.4	60898 MCB	C	4	10	N/A	4.37	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A	
2/L1	VT Pump	O	B	1	1.5	1.5	0.4	60898 MCB	D	4	10	N/A	2.18	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A	
2/L2	Heater 1	O	B	1	1.5	1.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.31	N/A	N/A	N/A	N/A	
2/L3	Heater 2	O	B	1	1.5	1.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.46	N/A	N/A	N/A	N/A	
3/L1	VT Pump 2	O	B	1	1.5	1.5	0.4	60898 MCB	D	4	10	N/A	2.18	N/A	N/A	N/A	0.27	N/A	250	LIM	>299	✓	0.43	N/A	N/A	N/A	N/A	
3/L2	Sec Pump	O	B	1	1.5	1.5	0.4	60898 MCB	D	2	10	N/A	4.37	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.39	N/A	N/A	N/A	N/A	
3/L3	Control Panel	D	B	1	16	16	0.4	60898 MCB	C	50	10	N/A	0.35	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.32	N/A	N/A	N/A	N/A	
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 12/07/2022 To 12/07/2022 Date(s) live testing 12/07/2022 To 12/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 12/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: 4th Floor Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(Busbar, 16/L3)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: DB CL7	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 080408/5756
Num. of ways: 18 Num. of phases: 1		No. of poles: NA	Continuity: 080408/5756
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 080408/5756
		Time delay (if applicable): NA	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
					80%	(Ω)		(Ω)	(Ω)	(Ω)				(Ω)														
1/L3	Common Room Lights	A	B	1	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.51	N/A	250	LIM	>299	✓	0.68	28.6	28.7	✓	N/A
2/L3	Bedroom Lights 2,3,4	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.52	28.8	28.7	✓	N/A
3/L3	Bedroom Lights 5,6,7	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.60	28.4	28.5	✓	N/A
4/L3	Bedroom Lights 1,8	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.37	N/A	250	LIM	>299	✓	0.47	28.5	28.1	✓	N/A
5/L3	Bedroom Lights	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.55	28.4	28.7	✓	N/A
6/L3	Sub Mains(DB CL7/6-1, DB CL7/6)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.27	0.27	0.38	✓	0.16	N/A	250	LIM	>299	✓	0.32	28.6	28.9	✓	N/A
7/L3	Sub Mains(DB CL7/7-2, DB CL7/7, DB CL7/7-1)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.31	0.31	0.44	✓	0.26	N/A	250	LIM	>299	✓	0.38	28.4	28.7	✓	N/A
8/L3	Sub Mains(DB CL7/8-1, DB CL7/8)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.36	0.36	0.51	✓	0.22	N/A	250	LIM	>299	✓	0.38	28.0	28.6	✓	N/A
9/L3	Sub Mains(DB CL7/9-2, DB CL7/9, DB CL7/9-1)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.36	0.36	0.52	✓	0.22	N/A	250	LIM	>299	✓	0.41	28.6	28.7	✓	N/A
10/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
11/L3	Kitchen Ring Main 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.34	0.34	0.46	✓	0.20	N/A	250	LIM	>299	✓	0.24	28.6	28.7	✓	N/A
12/L3	Kitchen Ring Main 2	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.30	0.30	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.29	2.84	28.5	✓	N/A
13/L3	Hob 1	A	B	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.32	28.6	28.0	✓	N/A
14/L3	Hob 2	A	E	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.28	28.7	28.8	✓	N/A
15/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
16/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR

110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	DB CL7				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA Δn ms	30mA or below 5 Δn ms	RCD (✓)	AFDD (✓)
															r1	m	r2											
17/L3	SPARE												N/A	N/A	N/A	N/A						N/A			N/A	N/A		
18/L3	SPARE												N/A	N/A	N/A	N/A						N/A			N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR **110147629**



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser 4TH Floor [Schneider]
 Designation: DB CL5/6
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 6/L1)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Operating at 1 IΔn 27.5 ms Above 30mA (if applicable)
 Z_s 0.34 Ω No. of poles 2 30mA or below
 I_{pr} 0.68 kA IΔn 30 Operating at 5 IΔn 24.5 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 080408/5657
 Insulation resistance 080408/5657
 Continuity 080408/5657
 RCD 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r2	r2												R1 + R2	R2	
					80%	r1		r2	r2	R1 + R2				R2	V	M(Ω)	M(Ω)	(✓)	Z _s (Ω)	ms	ms	(✓)			(✓)					
1/L2	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case Location: Room 3 Riser 3rd Floor [Schneider] Designation: DB CL4/7-1 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains(DB CL4, 7/L3) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Characteristics at this distribution board Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn 28.6 ms Above 30mA (if applicable) Z _s 0.37 Ω No. of poles 2 30mA or below I _{pn} 0.51 kA IΔn 30 Operating at 5 IΔn 22.4 ms Time delay (if applicable) N/A	Test instrument serial number(s) Loop impedance 080408/5657 Insulation resistance 080408/5657 Continuity 080408/5657 RCD 080408/5657
---	---	---	---

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L3	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.37	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022
 Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 7 Riser 2nd Floor [Schneider]
 Designation: DB CL3/9
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL3, 9/L2)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Operating at 1 IΔn 38.5 ms Above 30mA (if applicable)
 Zs 0.44 Ω No. of poles 2 30mA or below
 Ipr 0.52 kA IΔn 30 Operating at 5 IΔn 21.0 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 080408/5657
 Insulation resistance 080408/5657
 Continuity 080408/5657
 RCD 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	rn	r2												R1 + R2	R2
1/L2	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location: Plant Room [Schneider]	Designation: DB LL2/P	Num. of ways: 8	Num. of phases: 3	Supply to distribution board is from: Sub Mains (Busbar, 10/TP)	Associated RCD (if any): BS (EN) N/A	Above 30mA (if applicable): N/A ms	Loop impedance: 080408/5657
Supply polarity confirmed: <input checked="" type="checkbox"/>	Phase sequence confirmed: <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V	BS(EN) 88-2 HRC	Operating at 1 IΔn: N/A	Operating at 5 IΔn: N/A	30mA or below: N/A ms	Insulation resistance: 080408/5657
							Continuity: 080408/5657
							RCD: 080408/5657

CIRCUIT DETAILS														TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)				
					r1	rn		r2	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both				R1 + R2	R2														
1/L1	Ring 4th Floor	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	10	0.54	0.64	0.64	0.90	N/A	0.39	N/A	250	LIM	>299	✓	0.56	38.8	28.7	✓	N/A	
1/L2	Ring 5th Floor	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	10	0.54	0.59	0.59	0.86	N/A	0.36	N/A	250	LIM	>299	✓	0.60	38.7	28.7	✓	N/A	
1/L3	Ring 6th Floor	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	10	0.54	0.58	0.58	0.87	N/A	0.36	N/A	250	LIM	>299	✓	0.53	38.7	28.7	✓	N/A	
2/L1	Ring 7th Floor	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	10	0.54	0.64	0.64	0.82	N/A	0.37	N/A	250	LIM	>299	✓	0.54	38.6	28.7	✓	N/A	
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 12/07/2022 To 12/07/2022 Date(s) live testing 12/07/2022 To 12/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 12/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser 3rd Floor [Schneider]
 Designation: DB CL4/6
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL4, 6/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.6 ms (Above 30mA) | 19.4 ms (30mA or below)
 Zs: 0.32 Ω | No. of poles: 2 | Ipf: 0.72 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.49	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 11/07/2022 To 11/07/2022 Date(s) live testing: 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 11/07/2022

Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**

Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case

Location: Room 9 Riser 2nd Floor [Schneider]
 Designation: DB CL4/9-2
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation

Supply to distribution board is from: Sub Mains(DB CL4, 9/L3)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V
 BS(EN) 61009 RCD/RCBO

Characteristics at this distribution board

Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn 28.7 ms Above 30mA (if applicable)
 Z_s 0.40 Ω No. of poles 2 30mA or below
 I_{pf} 0.58 kA IΔn 30 Operating at 5 IΔn 18.6 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)

Loop impedance 080408/5657
 Insulation resistance 080408/5657
 Continuity 080408/5657
 RCD 080408/5657

CIRCUIT DETAILS													TEST RESULTS																		
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)				
														r1	r _n	r2												R1 + R2	R2		
1/L3	Room 9 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing **Date(s) dead testing** 11/07/2022 To 11/07/2022 **Date(s) live testing** 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 9 Riser 4th Floor [Schneider]	Supply to distribution board is from: Sub Mains(DB CL5, 9/L1)		Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 32.5 ms	
Designation: DB CL5/9-2	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Zs 0.44 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.51 kA IΔn 30 Operating at 5 IΔn 18.8 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
Test instrument serial number(s)				
Loop impedance 080408/5657				
Insulation resistance 080408/5657				
Continuity 080408/5657				
RCD 080408/5657				

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Room 9 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.75	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.					
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode	SA1 8EN						
Distribution board details - Complete in every case				Complete only if the distribution board is not connected directly to the origin of the installation				Characteristics at this distribution board			Test instrument serial number(s)		
Location	Riser Flat 1 Room 2 (Schneider)			Supply to distribution board is from	Sub Mains(DB CL1, 7/L1)			Associated RCD(if any): BS (EN)	N/A		Operating at 1 IΔn	Above 30mA (if applicable) 31.4 ms	
Designation	DB/CL1.7.1			Sub Mains(DB CL1, 7/L1)				Z _s	0.40 Ω		No. of poles	N/A	
Num. of ways	1			Num. of phases	1			I _{pf}	0.58 kA		IΔn	30	
Supply polarity confirmed	<input checked="" type="checkbox"/>			Phase sequence confirmed	<input type="checkbox"/>			Operating at 5 IΔn	29.0 ms		Time delay (if applicable)	NA	
Overcurrent protective device for the distribution circuit: Type				C			Rating	32 A		Voltage	230 V		
Overcurrent protective device for the distribution circuit: BS(EN)				61009 RCD/RCBO									
Loop impedance				080408/5756									
Insulation resistance				080408/5756									
Continuity				080408/5756									
RCD				080408/5756									

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation											
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)										
														r1	r _n	r2												R1 + R2	R2								
1/L1	Sockets Room 2	A	E	1	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.39	N/A	250	LIM	>299	✓	0.51	N/A	N/A	N/A	N/A									

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 2 Riser 3rd Floor [Schneider]	Supply to distribution board is from: Sub Mains(DB CL4, 7/L3)		Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 28.6 ms	
Designation: DB CL4/7	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Zs 0.37 Ω No. of poles 2 30mA or below	
Num. of ways: 4 Num. of phases: 1			Ipf 0.51 kA IΔn 30 Operating at 5 IΔn 22.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
Test instrument serial number(s)				
Loop impedance 080408/5657				
Insulation resistance 080408/5657				
Continuity 080408/5657				
RCD 080408/5657				

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL4/7	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	rn	r2												R1 + R2	R2
1/L3	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board		Test instrument serial number(s)	
Location: Room 8 Riser 2nd Floor [Schneider]		Supply to distribution board is from: Sub Mains(DB CL3, 9/L2)			Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn: 38.5 ms Above 30mA (if applicable)		Loop impedance: 080408/5657	
Designation: DB CL3/9-1		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V			Zs: 0.44 Ω No. of poles: 2 30mA or below		Insulation resistance: 080408/5657	
Num. of ways: 4 Num. of phases: 1					Ipf: 0.52 kA IΔn: 30 Operating at 5 IΔn: 21.0 ms		Continuity: 080408/5657	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>					Time delay (if applicable): N/A		RCD: 080408/5657	

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L2	Room 8 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A		
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Plant Room [Schneider]	Supply to distribution board is from: Sub Mains (Busbar, 10/TP)	Associated RCD (if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: DB LL2/L	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 080408/5756
Num. of ways: 8 Num. of phases: 3	BS (EN) 88-2 HRC gG	30mA or below: N/A ms	Continuity: 080408/5756
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 080408/5756
		Time delay (if applicable): N/A	

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)				
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2	
																		All circuits to be completed using R1R2 or R2, not both		V		M(Ω)			M(Ω)				
1/L1	Lighting Floor 4	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.24	48.5	28.5	✓	N/A	
1/L2	Lighting Floor 5	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.22	28.8	28.0	✓	N/A	
1/L3	Lighting Floor 6	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.29	38.7	28.4	✓	N/A	
2/L1	Lighting Floor 7	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.24	38.4	28.4	✓	N/A	
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 12/07/2022 To 12/07/2022 Date(s) live testing 12/07/2022 To 12/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 12/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name <input type="text" value="PHS Compliance"/>	Company Address <input type="text" value="Kid Glove Road"/>	Postcode <input type="text" value="WA3 3GR"/>	Branch No. <input type="text"/>	Scheme No. <input type="text"/>
Client <input type="text" value="UPP Residential Services Ltd"/>	Installation Address <input type="text" value="Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea"/>	Postcode <input type="text" value="SA1 8EN"/>		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location <input type="text" value="Room 5 Riser 6th Floor [Schneider]"/>	Supply to distribution board is from <input type="text" value="Sub Mains(DB CL7, 8/L3)"/>	Associated RCD(if any): BS (EN) <input type="text" value="61009"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.0"/> ms	Loop impedance <input type="text" value="080408/5657"/>
Designation <input type="text" value="DB CL7/8"/>	Overcurrent protective device for the distribution circuit: Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="230"/> V	Zs <input type="text" value="0.38"/> Ω No. of poles <input type="text" value="2"/> 30mA or below	Insulation resistance <input type="text" value="080408/5657"/>
Num. of ways <input type="text" value="4"/> Num. of phases <input type="text" value="1"/>	BS(EN) <input type="text" value="61009 RCD/RCBO"/>	Ipf <input type="text" value="0.62"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="28.6"/> ms	Continuity <input type="text" value="080408/5657"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) <input type="text" value="N/A"/>	RCD <input type="text" value="080408/5657"/>

CIRCUIT DETAILS														TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L3	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A		
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case

Location: Room 7 Riser 6th Floor [Schneider]
 Designation: DB CL7/9
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation

Supply to distribution board is from: Sub Mains (DB CL7, 9/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board

Associated RCD (if any): BS (EN) 61009 | Operating at 1 I_{Δn}: 28.6 | ms (Above 30mA)
 Z_s: 0.41 | Ω | No. of poles: 2 | Operating at 5 I_{Δn}: 28.7 | ms (30mA or below)
 I_{pf}: 0.58 | kA | I_{Δn}: 30 | ms
 Time delay (if applicable): N/A

Test instrument serial number(s)

Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I _{Δn} ms			30mA or below 5 I _{Δn} ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L3	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 11/07/2022 To 11/07/2022 Date(s) live testing: 11/07/2022 To 11/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 11/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: 4th Floor Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(Busbar, 6/L3)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: DB CL4	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 I _{Δn} : N/A ms	Insulation resistance: 080408/5756
Num. of ways: 18 Num. of phases: 1		No. of poles: NA	Continuity: 080408/5756
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Operating at 5 I _{Δn} : N/A ms	RCD: 080408/5756
		Time delay (if applicable): NA	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I _{Δn} ms			30mA or below 5 I _{Δn} ms	RCD (✓)	AFDD (✓)		
														r1	rn	r2												R1 + R2	R2
					80%	(Ω)		(Ω)	(Ω)	(Ω)				(Ω)	(Ω)														
1/L3	Common Room Lights	A	B	1	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.36	N/A	250	LIM	>299	✓	0.53	28.7	22.4	✓	N/A	
2/L3	Bedroom Lights 2,3,4	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.58	N/A	250	LIM	>299	✓	0.75	28.6	20.4	✓	N/A	
3/L3	Bedroom Lights 5,6,7	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.49	N/A	250	LIM	>299	✓	0.65	28.7	19.7	✓	N/A	
4/L3	Bedroom Lights 1,8	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.64	28.6	18.8	✓	N/A	
5/L3	Bedroom Lights	A	B	6	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.47	N/A	250	LIM	>299	✓	0.62	28.6	18.2	✓	N/A	
6/L3	Sub Mains(DB CL4/6, DB CL4/6-1)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.25	0.25	0.36	✓	0.15	N/A	250	LIM	>299	✓	0.32	28.6	19.4	✓	N/A	
7/L3	Sub Mains(DB CL4/7-2, DB CL4/7, DB CL4/7-1)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.35	0.35	0.48	✓	0.21	N/A	250	LIM	>299	✓	0.37	28.6	22.4	✓	N/A	
8/L3	Sub Mains(DB CL4/8-1, DB CL4/8)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.30	0.27	0.37	✓	0.17	N/A	250	LIM	>299	✓	0.32	28.6	18.7	✓	N/A	
9/L3	Sub Mains(DB CL4/9-2, DB CL4/9, DB CL4/9-1)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.38	0.37	0.49	✓	0.22	N/A	250	LIM	>299	✓	0.40	28.7	18.6	✓	N/A	
10/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L3	Kitchen Ring Main 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.30	0.35	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.38	28.6	19.5	✓	N/A	
12/L3	Kitchen Ring Main 2	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.37	0.37	0.45	N/A	0.21	N/A	250	LIM	>299	✓	0.35	28.6	22.4	✓	N/A	
13/L3	Hob 1	A	B	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.18	28.7	18.7	✓	N/A	
14/L3	Hob 2	A	E	1	6	2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.19	28.7	22.4	✓	N/A	
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 11/07/2022 To 11/07/2022 Date(s) live testing 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 11/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110147629



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

CIRCUIT DETAILS													TEST RESULTS																												
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation														
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Δn ms	30mA or below 5 Δn ms	RCD (✓)			AFDD (✓)																
	80%				r1	m		r2	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both																															
					R1 + R2			R2																																	
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A					
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature 

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/ EICR 110147629



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Elinor 14, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser 6TH Floor [Schneider]
 Designation: DB CL7/6
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL7, 6/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.6 ms (Above 30mA) | 30mA or below: 28.9 ms
 Zs: 0.32 Ω | No. of poles: 2 | Ipf: 0.72 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L3	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.43	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 11/07/2022 To 11/07/2022 | Date(s) live testing: 11/07/2022 To 11/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 11/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

Generic Continuation

General Conditions of the Electrical Installation:

The service head, meter and supply authority fuse are in the mains room located on the ground floor

Main Earthing Arrangements

The Main Earthing arrangement for the installation appears to be TN-C-S.

Incoming Services

The main incoming water supply appears to enter the property in the mains room of the installation. The main bond is a 50mm copper conductor with warning labels attached.

The main incoming gas supply appears to enter the property riser.

The main bond is a 50mm copper conductor with warning labels attached.

Wiring Systems.

The wiring systems utilized for final circuit wiring in the installation are PVC/PVC T&E cable (A)

Installation methods used are clipped direct or in trunking on the wall.

The final circuits are protected by BS60898MCB's as well as a BS 61009MCBs and also 60947-2MCCBs feeding breakers;

Observation notes

All information and documentation (where available) were used to help compile this report.

Circuit charts should be present for each Distribution Board providing relevant information in accordance with Regulation 514.9.1 of the BS 7671:2018.

On the distribution board schedules of circuit details cable types and sizes have been typed in as what is visible at the distribution board only.

Circuits may have been jointed with a different cable type further along the circuit

Only a percentage of the installation has been dismantled for inspection purposes. The correct connection of every conductor and link throughout the premises cannot be ensured.

Additional Comments

No access to sealed supply authority fuses therefore Characteristics of Primary Supply Protective Devices are not filled in on page 2.

A new regulation 421.1.7 has been introduced recommending the installation of Arc Fault detection devices conforming to BS EN 62606 to mitigate the risk of fire in AC final circuits of a fixed installation due to arc fault currents.

This installation has been designed and installed prior to July 2018. There is no evidence of

Over-voltage protection within the electrical installation, we recommend Surge Protective Devices be installed in order to reduce the risk of damage to the installation by external transient

Over-voltage's or switching.

Overall Assessment

In general, the installation is in a good condition but is Unsatisfactory due to the C2, F/I defects in section K, which require urgent action, with the code 3 observations requiring early attention. Assuming attention is brought to the observations and recommendations listed within section K, it is recommended a maximum 5-year period for the next inspection and test to be carried out.

Abbreviations contained in this Report: -

RHS – Right Hand Side

LHS – Left Hand Side

D/B - Distribution board.

RCD - Residual current device.

CPC - Circuit protective conductor.

FCU – Fused Connection Unit.

CSA - Cross Sectional Area.

MET – Main Earthing Terminal.

LIM – Limitation (Agreed or Operational)

MIC – Sheath of MICC cable used as CPC

SWA – Steel Wire Armouring used as CPC

MW – Metalwork used as CPC.

FP – FP200 Fire Resistant Cable.

Remarks:

DB Mech Panel Remarks:

1/L1 - Press Unit: O=YY

1/L2 - Boiler 1: O=YY

1/L3 - Boiler 2: O=YY

2/L1 - VT Pump: O=YY

2/L2 - Heater 1: O=YY

2/L3 - Heater 2: O=YY

3/L1 - VT Pump 2: O=YY

3/L2 - Sec Pump: O=YY