

Electrical Installation Condition Report

Requirements for Electrical Installations - BS 7671:2018 (IET Wiring Regulations 18th Edition)

Information for recipients:

The purpose of this report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).

The person ordering the report should have received the Original©Report and the inspector should have retained a duplicate.

The Original©Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.

Where the installation incorporates residual current devices (RCDs) there should be a notice at or near the devices stating that they should be tested every 6 months. **For safety reasons it is important that these instructions are followed.**

Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The Inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licencing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.

For items classified in Section K as C1 (“Danger Present”), **the safety of those using the installation is at risk**, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.

For items classified in Section K as C2 (“Potentially Dangerous”), **the safety of those using the installation may be at risk** and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where it has been stated in Section K that an observation requires further investigation code FI the inspection has revealed an apparent deficiency which may result on a code C1 or C2 could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons competent in such work. The recommended date by which the next inspection is due is stated in Section F of the report under ‘Recommendations’ and on label at or near to the consumer unit/distribution board.

ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR 110149172

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



A. Details of the Installation

Client	UPP Residential Services Ltd	Installation	Swansea University Bay Campus - Siwan 10
Address	First Floor 12 Arthur Street London,	Address	Reception - Ground Floor Tower Information Centre Fabian Way, Crymlyn Burrows Swansea
Postcode	EC4R 9AB	Postcode	SA1 8EN

B. Reason for Producing this Report *This form is to be used only for reporting on the condition of an existing installation.*

- Essential information requested by the client in accordance with the electricity at work regulations 1989.

Date(s) on which the inspection and testing were carried out to

C. Details of Installation which is the Subject of this Report

Description of premises Domestic Commercial Industrial Other (please specify)

Estimated age of the wiring system years

Evidence of alterations or addition Yes No Not apparent if 'Yes', estimated years

Records of installation available Yes No Records held by

Date of last inspection Electrical Installation Certificate No. or previous Inspection Report No.

D. Extent of Electrical Installation Covered by this Report:

Testing of all sub mains, lighting and power circuits, within the constraints of the agreed limitations

Agreed Limitations and Operational Limitations (Regulations 653.2)

Unable to completely isolate the installation. Unable to access the sealed supply device characteristics. Ze and Ip_f have been taken with all earthing and bonding in place. Insulation resistance testing has been carried out to regulation 643.3.3 on circuits where it was impracticable to disconnect load.

Agreed with:

The inspection and testing detailed within this report and accompanying schedule has been carried out in accordance with BS 7671: 2018 (IET Wiring Regulations) amended to

It should be noted that cables concealed within trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

E. Summary of the Condition of the Installation

General conditions of the installation (in terms of electrical safety)

Installation Details The installation approximately 50 Origin of Supply --Please see Continuation Page--

Overall assessment of the installation in terms of its suitability for continued use

SATISFACTORY *UNSATISFACTORY

*An UNSATISFACTORY assessment indicates that dangerous (code C1), or potentially dangerous (code C2), Further investigation (code FI) conditions have been identified

F. Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potential dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further Investigation required' (code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by (date)

ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR 110149172

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



G. Declaration

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company	PHS Compliance	Inspected and tested by	Authorised for issue by
Address	Kid Glove Road, Golborne, Warrington,	Name:	Liam Kimble
		Signature:	
Postcode	WA3 3GR		
Branch No.		Position:	Electrical Test Engineer
Scheme No.		Date:	22/07/2022
			Technical Auditor
			01/09/2022

EICRs are produced by a UKAS accredited inspection body, No. 0433

H. Schedule(s)

1 schedule(s) of inspection and 38 schedule(s) of test results are attached.
The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

I. Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S TN-C-S TT Other Please specify _____

Number & Type of live conductors AC DC No. of phases 3 No. of wires 4

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ 400/230 v Nominal frequency, f⁽¹⁾ 50 Hz Confirmation of supply polarity

Prospective fault current, I_{pr} ⁽²⁾ 6.0 kA External loop impedance, Z_e ⁽²⁾ 0.11 Ω

Supply Protective Device BS (EN) LIM Type LIM Rated Current LIM A

No. of Additional Supplies N/A

J. Particulars of Installation Referred to in this Report

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) _____

Location _____ Electrode resistance to earth _____ Ω

Main Protective Conductors

Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Aluminium 150 mm ²	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor	Copper 50 mm ²	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>

Main Supply Conductor Material Copper csa 150 mm²

Main Switch Location Mains Room mm²

Fuse/device rating or setting 400 A Voltage rating 400 V

If RCD main switch: Rated residual operating current I Δn N/A mA

BS(EN) 60947-2 MCCB No. of Poles 4 Current Rating 400 A

Means of Earthing

Distributors facility Installation Earth Electrode

Maximum Demand (load) LIM Amps _____ KVA _____

(connection / continuity) (✓) or Value (✓) or Value

Water installation Ω To structural steel Ω

Gas installation pipes Ω To lightning protection NA Ω

Oil installation pipes NA Ω Other Data Cab Ω

Rated time delay N/A ms Measured operating trip time N/A ms

K. Observations

Referring to the attached schedule of inspection and test results, and subject to the limitations at Section D.

- No remedial work required
- The following observations are made

Explanation of codes

C1	Danger present. Risk of Injury. Immediate remedial action required.
C2	Potentially dangerous. Urgent remedial action required.
C3	Improvement recommended.
FI	Further Investigation required without delay

Item No.	Observations	Code
1	Observation: Live conductors are incorrectly identified. Location: MDB CCT 5/TP Regulation: 514.3.1	C3
2	Observation: No IP2X protection on outside socket, casing broke could cause potential trip out of circuit Location: DB PL/P CCT 1/L1 Regulation: 416.2.1	C2
3	Observation: Hob light switches not secure to the wall Location: DB CL3 Regulation: 559.5.2	C3
4	Observation: Screws missing from DB cover, cover still secure. Location: DB LL1 Regulation: 416.2.3	C3

ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR 110149172

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



5	Observation: Minor Damage to key lock on DB, lock ring no longer present meaning lock is loose Location: DB CL3 Regulation: 416.2.3	C3
6	Observation: Minor Damage to key lock on DB, lock ring no longer present meaning lock is loose Location: DB CL2 Regulation: 416.2.3	C3
7	Observation: Double Socket not fixed securely. Location: DB CL2 CCT 11/L1 Regulation: 559.5.2	C3
8	Observation: Light switch next to bed not fixed securely. (Room 5) Location: DB CL2 CCT 3/L1 Regulation: 559.5.2	C3
9	Observation: Light switch next to bed not tight enough against wall. (Room 7) Location: DB CL2 CCT 4/L1 Regulation: 559.5.2	C3
10	Observation: Light switch next to bed not tight enough against wall. (Room 9) Location: DB CL2 CCT 5/L1 Regulation: 559.5.2	C3
11	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL1 CCT 9/L1 Regulation: 537.2.4	FI
12	Observations: There is no RCD protection in place as an additional requirement for circuits supplying socket outlets not exceeding 32A. It is recommended that 30mA RCD,s are installed to provide additional protection. This requirement can be negated for non-domestic dwellings provided that a documented risk assessment determines that RCD protection is not necessary . Location: DB LL1/P CCT 3/L2 Regulation: 411.3.3	C3
13	Observation: All untraced circuits must have their circuit designations verified. Location: DB PL/P CCT 7/TP Regulation: 514.8.1	FI

One of the following codes, as appropriate, has been allocated to each of the observations made above and/or any attached observation sheets to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1	Danger present. Risk of Injury. Immediate remedial action required.	
C2	Potentially dangerous. Urgent remedial action required.	2
C3	Improvement recommended.	1, 3, 4, 5, 6, 7, 8, 9, 10, 12
FI	Further Investigation required without delay	11, 13

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further Investigation:	Not Verified:	Limitation:	Not Applicable:
	or					

Item No.	Description	Outcome
----------	-------------	---------

1.0 External Condition Of Intake Equipment (Visual Inspection Only) Where inadequacies are encountered, it is recommended that the person ordering the report informs the appropriate authority

1.1	Service cable	
1.2	Service head	
1.3	Earthing arrangement	
1.4	Meter tails	
1.5	Metering equipment	
1.6	Isolator (where present)	

2.0 Parallel Or Switched Alternative Sources Of Supply

2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	

3.0 Automatic Disconnection Of Supply

3.1	Main earthing/bonding arrangements (411.3; Chap 54)	
3.1.1	Presence of distributors earthing arrangement (542.1.2.1; 542.1.2.2)	
3.1.2	Presence of installation earth electrode arrangement (542.1.2.3)	
3.1.3	Adequacy of earthing conductor size (542.3; 543.1.1)	
3.1.4	Adequacy of earthing conductor connections (542.3.2)	
3.1.5	Accessibility of earthing conductor connections (543.3.2)	
3.1.6	Adequacy of main protective bonding conductor sizes (544.1)	
3.1.7	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	
3.1.8	Accessibility of all protective bonding connections (543.3.2)	
3.1.9	Provision of earthing/bonding labels at all appropriate locations (514.13)	
3.2	FELV - requirements satisfied (411.7; 411.7.1)	

4.0 Other Methods Of Protection (Where any of the methods listed below are employed details should be provided on separate sheets)

4.1	Non-conducting location (418.1)	
4.2	Earth-free local equipotential bonding (418.2)	
4.3	Electrical separation (Section 413; 418.3)	
4.4	Double insulation (Section 412)	
4.5	Reinforced insulation (Section 412)	

5.0 Distribution Equipment

5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	
5.2	Security of fixing (134.1.1)	
5.3	Condition of insulation of live parts (416.1)	
5.4	Adequacy/security of barriers (416.2)	
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	
5.6	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)	
5.8	Presence and effectiveness of obstacles (417.2)	
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	
5.10	Operation of main switch(es) (functional check) (643.10)	
5.11	Manual operation of circuit-breakers and RCD(s) to prove disconnection (643.10)	
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)	
5.13	RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2)	
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBO(s) (411.3.3; 415.1)	
5.15	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	
5.17	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	
5.18	Presence of alternative supply warning notice at or near equipment, where required (514.15)	
5.19	Presence of next inspection recommendation label (514.12.1)	
5.2	Presence of other required labelling (please specify) (Section 514)	
5.21	Compatibility of protective device, base and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.4.5; 411.4.6; Sections 432; 433)	
5.22	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	
5.23	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	
5.24	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	



**Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)**

6.0 Distribution Circuits		
6.1	Identification of conductors (514.3.1)	✓
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
6.3	Condition of insulation of live parts (416.1)	✓
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. Integrity of containment (521.10.1)	✓
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	✓
6.6	Cables correctly terminated in enclosures (Section 526)	✓
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	✓
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	✓
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	✓
6.15	Cables concealed under floors, above ceilings, in walls/partitions less than 50 mm from a surface, and in partitions containing metal parts	
6.15.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202) or	✓
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.204)	✓
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
6.17	Band II cables segregated/separated from Band I cables (528.1)	✓
6.18	Cables segregated/separated from non-electrical services (528.3)	✓
6.19	Condition of circuit accessories (651.2)	✓
6.20	Suitability of circuit accessories for external influences (512.2)	✓
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
6.22	Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/record numbers and locations of items inspected (Section 526)	✓
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; 537)	✓
6.24	General condition of wiring systems (651.2)	✓
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)	✓
7.0 CONSUMER UNIT/DISTRIBUTION BOARD(S)		
7.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1)	✓
7.2	Security of fixing (134.1.1)	✓
7.3	Condition of enclosure(s) in terms of IP rating (Barriers etc) (416.2)	✓
7.4	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	✓
7.5	Enclosure/obstacles not damaged/deteriorated so as to impair safety (651.2)	✓
7.5.1	Presence and effectiveness of obstacles (417.2)	✓
7.6	Presence of main linked switch (as required by 462.1.201)	✓
7.7	Operation of main switch (functional check) (643.10)	✓
7.8	Manual operation of circuit-breakers and RCD(s) (test button) to prove disconnection (643.10)	✓
7.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	FI
7.10	Presence of RCD six-monthly test notice at or near consumer unit/distribution board (514.12.2)	✓
7.11	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	✓
7.12	Presence of alternative supply warning notice at or consumer unit/distribution board (514.15)	✓
7.13	Presence of other required labelling (Please specify) (Section 514)	✓
7.14	Compatibility of protective devices, bases and other components; correct type and ratings (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	✓
7.15	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
7.16	Protection against mechanical damage where cables enter consumer unit/distribution board (132.14.1; 522.8.1; 522.8.5; 522.8.11)	✓
7.17	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	✓
7.18	RCD(s) provided for fault protection - includes RCBO(s)(411.4.204; 411.5.2; 531.2)	✓
7.19	RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1)	✓
7.20	Confirmation of indication that SPD is functional (651.4)	✓
7.21	Confirmation that ALL conductor connections, including connections to the busbars are correctly located in terminals and are tight and secure (526.1)	✓
7.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	✓
7.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	✓
8.0 FINAL CIRCUITS		
8.1	Identification of conductors (514.3.1)	FI
8.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓



**Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)**

8.3	Condition of insulation of live parts (416.1)	✓
8.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	✓
8.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)	✓
8.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
8.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
8.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
8.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	✓
8.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓
8.10	Connected cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	✓
8.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (522.6.204)	✓
8.12	Provision of additional requirements for protection by RCD not exceeding 30 mA:	
8.12.1	For all socket-outlets of rating 32 A or less unless exempt (4.11.3.3)	C3
8.12.2	For the supply of Mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	✓
8.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	✓
8.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	✓
8.12.5	For circuits supplying luminaires within domestic (household) premises (411.3.4)	✓
8.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
8.14	Band II cables segregated/separated from Band I cables (528.1)	✓
8.15	Cables segregated/separated from communications cabling (528.2)	✓
8.16	Cables segregated/separated from non-electrical services (528.3)	✓
8.17	Termination of cables at enclosures - indicate extent of sampling in section d of the report (section 526)	
8.17.1	Connections soundly made and under no undue strain (526.6)	✓
8.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	✓
8.17.3	Connections of live conductors adequately enclosed (526.5)	✓
8.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓
8.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v))	C2
8.19	Suitability of accessories for external influences (512.2)	✓
8.20	Adequacy or working space/accessibility to equipment (132.12; 513.1)	✓
8.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
9.0 ISOLATION AND SWITCHING		
9.1	Isolators (Section 460; 537)	
9.1.1	Presence and condition of appropriate devices (462; 537.2.7)	✓
9.1.2	Acceptable location - state if local or remote from equipment in question (462; 537.2.7)	✓
9.1.3	Capable of being secured in the OFF position (462.3)	✓
9.1.4	Correct operation verified (643.10)	✓
9.1.5	Clearly identified by position and/or durable marking (537.2.6)	✓
9.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	✓
9.2	Switching off for mechanical maintenance (Section 464; 537.3.2)	
9.2.1	Presence and condition of appropriate devices (464.1; 527.3.2)	✓
9.2.2	Acceptable location - state if local or remote from equipment in question (537.3.2.4)	✓
9.2.3	Capable of being secured in the OFF position (462.3)	✓
9.2.4	Correct operation verified (643.10)	✓
9.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	✓
9.3	Emergency switching/stopping (465; 537.3.3)	
9.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	✓
9.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	✓
9.3.3	Correct operation verified (643.10)	✓
9.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	✓
9.4	Functional switching (section 463; 537.3.1)	
9.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	✓
9.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	✓
10.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)		
10.1	Condition of equipment in terms of IP rating etc (416.2)	✓
10.2	Equipment does not constitute a fire hazard (Section 421)	✓
10.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	✓
10.4	Suitability for the environment and external influences (512.2)	✓
10.5	Security of fixing (134.1.1)	✓
10.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	✓
10.7	Recessed luminaires (downlighters)	
10.7.1	Correct type of lamps fitted (559.3.1)	✓
10.7.2	Installed to minimize build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	✓

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



10.7.3	No signs of overheating to surrounding building fabric (559.4.1)	✓
10.7.4	No signs of overheating to conductors/terminations (526.1)	✓

11.0 PART 7 SPECIAL INSTALLATIONS OR LOCATIONS

11.01	If any special installations or locations are present, list the particular inspections applied.	N/A
-------	---	-----

12.0 Schedule of Tests Results to be recorded on Schedule of Test Results

12.1	External earth loop impedance, Z^e	Yes
12.2	Installation earth electrode	N/A
12.3	Prospective fault current, I_{pf}	Yes
12.4	Continuity of Earth Conductors	Yes
12.5	Continuity of Circuit Protective Conductors	Yes
12.6	Continuity of ring final circuit	Yes
12.7	Continuity of Protective Bonding Conductors	Yes
12.8	Volt drop verified	Yes

12.9	Insulation Resistance between Live Conductors	Yes
12.10	Insulation Resistance between Live Conductors & Earth	Yes
12.11	Polarity (prior to energisation)	Yes
12.12	Polarity (after energisation) including phase sequence	Yes
12.13	Earth Fault Loop Impedance	Yes
12.14	RCDs/RCBOs including selectivity	Yes
12.15	Functional testing of RCD devices	Yes
12.16	Functional testing of AFDD(s) devices	N/A

Inspector's Name:

Date:

Signature:

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Room 10 Riser [Schneider] Designation: DB CL2/6-1 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>	Supply to distribution board is from: Sub Mains(DB CL2, 6/L1) Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: C Rating: 32 A Voltage: 230 V	Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn: 28.8 ms Z _s : 0.35 Ω No. of poles: 2 I _{pf} : 0.64 kA IΔn: 30 Operating at 5 IΔn: 28.0 ms Time delay (if applicable): N/A	Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)					
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both			
1/L1	Room 10 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A		
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS													
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	Circuit designation				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fig 8 check	All circuits to be completed using R1R2 or R2, not both	Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD	A/FDO		
	DB CL2/6-1											80%	r1	m	r2	(✓)	R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)					

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 7 Riser [Schneider] Designation: DB CL1/7-2 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Supply to distribution board is from: Sub Mains (DB CL1, 7/L1) Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Associated RCD (if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms Z _d 0.40 Ω No. of poles 2 30mA or below I _{pf} 0.56 kA IΔn 30 Operating at 5 IΔn 27.0 ms Time delay (if applicable) N/A
				Test instrument serial number(s) Loop impedance 100701/4664 Insulation resistance 100701/4664 Continuity 100701/4664 RCD 100701/4664

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	Room 7 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

CIRCUIT DETAILS												TEST RESULTS																					
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation							
	DB CL1/7-2				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)						
														r1	m	r2												R1 + R2	R2				
												80%																					

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 1 Kitchen [Schneider]	Supply to distribution board is from Sub Mains(MDB, 10/L1)	Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s) Loop impedance 100701/4664 Insulation resistance 100701/4664 Continuity 100701/4664 RCD 100701/4664
Designation DB CL1	Overcurrent protective device for the distribution circuit: Type BS(EN) 60947 MCCB	Above 30mA (if applicable) Operating at 1 IΔn N/A ms		
Num. of ways 18	Rating 63 A	30mA or below Operating at 5 IΔn N/A ms		
Num. of phases 1	Voltage 230 V	Time delay (if applicable) N/A		
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>			

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	R1 + R2	R2			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	m	r2												Fig 8 check (✓)
1/L1	Common Room Lighting	A	E	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.47	28.4	22.8	✓	N/A
2/L1	Lighting Bedroom 2,3,4	A	E	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.60	N/A	250	LIM	>299	✓	0.77	28.2	29.4	✓	N/A
3/L1	Lighting Bedroom 5,6,7	A	E	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.59	N/A	250	LIM	>299	✓	0.68	28.4	18.6	✓	N/A
4/L1	Lighting Bedroom 1,8	A	E	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.55	N/A	250	LIM	>299	✓	0.72	28.8	27.2	✓	N/A
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Sub Mains(DB CL1/6, DB CL1/6-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.35	0.35	0.47	✓	0.21	N/A	250	LIM	>299	✓	0.38	38.6	29.8	✓	N/A
7/L1	Sub Mains(DB CL1/7, DB CL1/7-1, DB CL1/7-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.47	0.51	0.62	✓	0.27	N/A	250	LIM	>299	✓	0.40	28.2	27.0	✓	N/A
8/L1	Sub Mains(DB CL1/8, DB CL1/8-1, DB CL1/8-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.44	0.44	0.62	✓	0.27	N/A	250	LIM	>299	✓	0.44	40.6	31.2	✓	N/A
9/L1	Isolated	A	B	LIM	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.38	0.38	0.50	✓	0.24	N/A	250	LIM	>299	✓	LIM	LIM	LIM	LIM	N/A
10/L1	Kitchen Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.34	0.34	0.46	✓	0.20	N/A	250	LIM	>299	✓	0.32	28.6	27.2	✓	N/A
11/L1	Hob 1	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.32	28.8	27.2	✓	N/A
12/L1	Hob 2	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.37	28.4	20.2	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 21/07/2022 To 21/07/2022 Date(s) live testing 21/07/2022 To 21/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 21/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																						
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation								
	DB CL1				L/N	CPC		BS EN Number	Type No	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)								
	Circuit designation													r1	m	r2												R1 + R2	R2						
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 21/07/2022 To 21/07/2022 Date(s) live testing 21/07/2022 To 21/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 21/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XLPE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS												TEST RESULTS																				
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
	DB CL1				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)				
															r1	m	r2												R1 + R2	R2		
												80%																				

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Signature

Tested by: Name (capital letters) Position Date

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location	Room 6 Riser [Schneider]	Supply to distribution board is from	Associated RCD(if any): BS (EN) 61009		Above 30mA	Loop impedance	
Designation	DB CL3/8	Sub Mains(DB CL3, 8/L2)	Operating at 1 IΔn		28.6 ms	Insulation resistance	
Num. of ways	4	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	No. of poles		2	Continuity	
Num. of phases	1	Type B Rating 32 A Voltage	Operating at 5 IΔn		26.0 ms	RCD	
Supply polarity confirmed	<input checked="" type="checkbox"/>		Time delay (if applicable)		N/A		
Phase sequence confirmed	<input type="checkbox"/>						

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L2	Room 6 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.26	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
 BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation																		
	DB CL3/8				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)																
															r1	m	r2												R1 + R2	R2														

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 20/07/2022 To: 20/07/2022 Date(s) live testing: 20/07/2022 To: 20/07/2022

Tested by: Name (capital letters) **LIAM KIMBLE** Position **Electrical Test Engineer** Date **20/07/2022**

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance | **Company Address** Kid Glove Road | **Postcode** WA3 3GR | **Branch No.** | **Scheme No.** |
Client UPP Residential Services Ltd | **Installation Address** Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider]
 Designation: DB CL2/9
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed | Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 9/L1)
 Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO
 Type: C | Rating: 32 A | Voltage: 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.6 ms (Above 30mA)
 Z_s: 0.46 Ω | No. of poles: 2 | Operating at 5 IΔn: 26.4 ms (30mA or below)
 I_{pn}: 0.50 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 100701/4664
 Insulation resistance: 100701/4664
 Continuity: 100701/4664
 RCD: 100701/4664

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)		
														r1	m	r2										(✓)	R1 + R2
1/L1	Room 4 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing | Date(s) dead testing: 20/07/2022 To 20/07/2022 | Date(s) live testing: 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position Electrical Test Engineer | Date 20/07/2022 | Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																										
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation															
	DB CL2/9				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V			L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)												
															r1	m	r2												R1 + R2	R2										
												80%																												

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Room 7 Riser [Schneider] Designation: DB CL2/8-1 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>	Supply to distribution board is from: Sub Mains(DB CL2, 8/L1) Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: C Rating: 32 A Voltage: 230 V	Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn: 29.4 ms Z _d : 0.33 Ω No. of poles: 2 I _{pf} : 0.71 kA IΔn: 30 Operating at 5 IΔn: 29.2 ms Time delay (if applicable): N/A	Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)		
														r1	m	r2												R1 + R2	R2
1/L1	Room 7 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS												TEST RESULTS																										
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation												
	DB CL2/8-1				L	N		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)											
	Circuit designation				L/N	CPC								r1	m	r2												R1 + R2	R2									
	80%				(Ω)	(Ω)		(Ω)	(Ω)	(Ω)				(Ω)	(Ω)																							

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location: Room 5 Riser [Schneider]	Designation: DB CL1/7	Supply to distribution board is from: Sub Mains(DB CL1, 7/L1)	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Associated RCD(if any): BS (EN) 61009	Operating at 1 IΔn: 28.2 ms	Loop impedance: 100701/4664	Insulation resistance: 100701/4664
Num. of ways: 4	Num. of phases: 1	Type: B	Rating: 32 A	Voltage: 230 V	Operating at 5 IΔn: 27.0 ms	Continuity: 100701/4664	RCD: 100701/4664
Supply polarity confirmed: <input checked="" type="checkbox"/>	Phase sequence confirmed: <input type="checkbox"/>			Time delay (if applicable): N/A			

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	Room 5 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.65	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 20/07/2022 To: 20/07/2022 Date(s) live testing: 20/07/2022 To: 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR **110149172**



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																					
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation								
	DB CL1/7				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)						
															r1	m	r2												R1 + R2	R2				
												80%																						

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 4 Riser [Schneider]	Designation: DB CL3/9	Supply to distribution board is from: Sub Mains(DB CL3, 9/L2)	Associated RCD(if any): BS (EN) 61009	Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms
Num. of ways: 4	Num. of phases: 1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Z _d : 0.37 Ω	No. of poles: 2
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Type: B Rating: 32 A Voltage: V	I _{pf} : 0.60 kA	IΔn: 30
			Operating at 5 IΔn 28.0 ms	Time delay (if applicable): N/A
			Test instrument serial number(s)	
			Loop impedance	100701/4664
			Insulation resistance	100701/4664
			Continuity	100701/4664
			RCD	100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L2	Room 4 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

CIRCUIT DETAILS												TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
	DB CL3/9				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage	L/L, L/N	L/E, N/E			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)		
												80%	r1	m	r2		R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)						

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location Room 6 Riser [Schneider]	Designation DB CL2/8	Supply to distribution board is from Sub Mains(DB CL2, 8/L1)	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type C Rating 32 A Voltage 230 V	Associated RCD(if any): BS (EN) 61009	Operating at 1 IΔn 29.4 ms	Loop impedance 100701/4664	Insulation resistance 100701/4664
Num. of ways 4	Num. of phases 1			Z _d 0.33 Ω	No. of poles 2	Continuity 100701/4664	RCD 100701/4664
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>			I _{pf} 0.71 kA	IΔn 30		
					Operating at 5 IΔn 29.2 ms		
					Time delay (if applicable) N/A		

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation DB CL2/8 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	R1 + R2
1/L1	Room 6 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.65	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	Circuit designation				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	A/FDO (✓)		
	DB CL2/8											80%	r1	m	r2	(✓)	R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)					

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 9 Riser [Schneider]
 Designation: DB CL3/7-1
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL3, 7/L2)
 Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Operating at 1 I_{Δn} 28.8 ms Above 30mA (if applicable)
 Z_s 0.36 Ω No. of poles 2 30mA or below
 I_{pf} 0.64 kA I_{Δn} 30 Operating at 5 I_{Δn} 26.0 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 100701/4664
 Insulation resistance 100701/4664
 Continuity 100701/4664
 RCD 100701/4664

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I _{Δn} ms	30mA or below 5 I _{Δn} ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L2	Room 9 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																					
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation									
	Circuit designation				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)								
														r1	m	r2												R1 + R2	R2						
	DB CL3/7-1											80%																							

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) Position Date

Signature 

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location Room 1 Riser [Schneider]	Designation DB CL2/6	Supply to distribution board is from Sub Mains(DB CL2, 6/L1)	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type C Rating 32 A Voltage 230 V	Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn 28.8 ms	Operating at 5 IΔn 28.0 ms	Loop impedance 100701/4664	Insulation resistance 100701/4664
Num. of ways 4	Num. of phases 1			Z _d 0.35 Ω	No. of poles 2	Continuity 100701/4664	RCD 100701/4664
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>			I _{pf} 0.64 kA	IΔn 30		
				Time delay (if applicable) N/A			

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation DB CL2/6	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										(✓)	R1 + R2	R2
1/L1	Room 1 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS															TEST RESULTS																							
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation												
	DB CL2/6				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)										
															r1	m	r2												R1 + R2	R2								
												80%																										

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoures PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 8 Riser [Schneider]		Supply to distribution board is from Sub Mains(DB CL1, 6/L1)		Associated RCD(if any): BS (EN) 61009
Designation DB CL1/6-1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Above 30mA (if applicable) Operating at 1 IΔn 38.6 ms
Num. of ways 4 Num. of phases 1		Type B Rating 32 A Voltage 230 V		30mA or below Operating at 5 IΔn 29.8 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L1	Room 8 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation		Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	DB CL1/6-1					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)		
	Circuit designation														r1	m	r2												R1 + R2	R2

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 20/07/2022 To 20/07/2022 Date(s) live testing: 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 8 Riser [Schneider]	Designation DB CL2/7	Supply to distribution board is from Sub Mains(DB CL2, 7/L1)	Associated RCD(if any): BS (EN) 61009	Above 30mA (if applicable) Operating at 1 IΔn 26.2 ms
Num. of ways 4	Num. of phases 1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Z _d 0.37 Ω	No. of poles 2
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Type C Rating 32 A Voltage 230 V	I _{pf} 0.60 kA IΔn 30	Operating at 5 IΔn 24.0 ms
			Time delay (if applicable) N/A	Test instrument serial number(s)
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L1	Room 8 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.73	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	Circuit designation				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fig 8 check	All circuits to be completed using R1R2 or R2, not both	Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD	AFCO		
	DB CL2/7											80%	r1	m	r2	(✓)	R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)					

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name **PHS Compliance** Company Address **Kid Glove Road** Postcode **WA3 3GR** Branch No. _____ Scheme No. _____
 Client **UPP Residential Services Ltd** Installation Address **Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea** Postcode **SA1 8EN**

Distribution board details - Complete in every case
 Location **Riser 1st Floor [Schneider]**
 Designation **DB LL1/P**
 Num. of ways **8** Num. of phases **3**
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from **Sub Mains (Busbar, 2/TP)**
 Overcurrent protective device for the distribution circuit: BS(EN) **88-2 HRC** Type **gG** Rating **63** A Voltage **400/230** V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) **N/A** Above 30mA (if applicable) **N/A** ms
 Operating at 1 I Δ n **N/A** ms
 Z $_d$ **0.14** Ω No. of poles **N/A** 30mA or below
 I $_{pf}$ **3.0** kA I Δ n **N/A** Operating at 5 I Δ n **N/A** ms
 Time delay (if applicable) **N/A**

Test instrument serial number(s)
 Loop impedance **100701/4664**
 Insulation resistance **100701/4664**
 Continuity **100701/4664**
 RCD **100701/4664**

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I Δ n ms	30mA or below 5 I Δ n ms			RCD (✓)	AFDD (✓)			
														r1	r2	r3										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	G Floor Cleaner Sockets	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.76	0.76	0.95	✓	0.43	N/A	250	LIM	>299	✓	0.55	32.4	19.2	✓	N/A
1/L2	G Floor IT Hub	A	B	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.33	N/A	N/A	N/A	N/A
1/L3	1st Floor Cleaners Sockets	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.69	0.69	0.82	✓	0.38	N/A	250	LIM	>299	✓	0.56	34.2	29.0	✓	N/A
2/L1	Mag Lock G Floor	A	B	1	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	0.32	N/A	250	LIM	>299	✓	0.50	N/A	N/A	N/A	N/A	
2/L2	G Floor IT Hub	A	B	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A	
2/L3	2nd Floor Cleaners Sockets	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.84	0.88	1.04	✓	0.47	N/A	250	LIM	>299	✓	0.66	31.6	28.4	✓	N/A
3/L1	G Floor Power Assisted Door	A	B	1	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	0.26	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A	
3/L2	G Floor IT Hub Commando	A	B	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.47	N/A	N/A	N/A	N/A	
3/L3	1st Floor Mag Lock	A	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.51	N/A	N/A	N/A	N/A	
4/L1	GF Intercom	A	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A	
4/L2	IT Hub Ring	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.55	✓	0.24	N/A	250	LIM	>299	✓	0.53	32.4	29.0	✓	N/A
4/L3	2nd Floor Maglock	A	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	0.36	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A	
5/L1	G Floor Smoke Shaft AOV	O	B	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	0.26	N/A	250	LIM	>299	✓	0.51	N/A	N/A	N/A	N/A	
5/L2	GF IT Hub Tube Heater	A	B	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing **21/07/2022** To **21/07/2022** Date(s) live testing **21/07/2022** To **21/07/2022**

Tested by: Name (capital letters) **LIAM KIMBLE** Position **Electrical Test Engineer** Date **21/07/2022** Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	DB LL1/P				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)		
	Circuit designation													r1	m	r2												R1 + R2	R2
5/L3	1st Floor Smoke Shaft AOV	O	B	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.41	N/A	N/A	N/A	N/A	
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	2nd Floor Smoke Shaft AOV	O	B	N/A	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.26	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A	N/A
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	2nd Floor Stair Core AOV	O	B	N/A	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A	N/A
8/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 21/07/2022 To 21/07/2022 Date(s) live testing 21/07/2022 To 21/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 21/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS												TEST RESULTS																								
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation										
	DB LL1/P				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)								
															r1	m	r2												R1 + R2	R2						
												80%																								

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 21/07/2022 To 21/07/2022 Date(s) live testing 21/07/2022 To 21/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 21/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL1, 6/L1)	Associated RCD(if any): BS (EN) 61009		Test instrument serial number(s) Loop impedance 100701/4664 Insulation resistance 100701/4664 Continuity 100701/4664 RCD 100701/4664
Designation DB CL1/6	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Operating at 1 IΔn 38.6 ms		
Num. of ways 4	Type B Rating 32 A Voltage 230 V	Operating at 5 IΔn 29.8 ms		
Num. of phases 1		Time delay (if applicable) N/A		
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>			

CIRCUIT DETAILS													TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)				
														r1	m	r2										(✓)	R1 + R2	R2	
1/L1	Room 1 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.65	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Plant Room [Schneider]	Supply to distribution board is from: Sub Mains(Busbar, 5/TP)	Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s) Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664
Designation: DB PL/L	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC	Operating at 1 IΔn: N/A ms		
Num. of ways: 6	Type: gG Rating: 63 A Voltage: 400 V	Operating at 5 IΔn: N/A ms		
Num. of phases: 3		Time delay (if applicable): N/A		
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input checked="" type="checkbox"/>			

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										(✓)	R1 + R2	R2
1/L1	Plant Room Lighting	A	E	5	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.35	27.4	16.0	✓	N/A
1/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	Lighting Stair Case	A	E	5	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.38	28.8	27.2	✓	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 20/07/2022 To: 20/07/2022 Date(s) live testing: 20/07/2022 To: 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 20/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

CIRCUIT DETAILS												TEST RESULTS																				
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
	DB PL/L				L	N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)						
	Circuit designation				r1	m		r2	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both																						
												80%																				

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 20/07/2022 To 20/07/2022 Date(s) live testing: 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) **LIAM KIMBLE** Position **Electrical Test Engineer** Date **20/07/2022**

Signature 

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance			Company Address Kid Glove Road				Postcode WA3 3GR			Branch No.		Scheme No.							
Client UPP Residential Services Ltd			Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea				Postcode SA1 8EN												
Distribution board details - Complete in every case								Complete only if the distribution board is not connected directly to the origin of the installation					Characteristics at this distribution board				Test instrument serial number(s)		
Location		Mains Room [Schneider]						Supply to distribution board is from							(if applicable)	Loop impedance 100710/4664 Insulation resistance 100710/4664 Continuity 100710/4664 RCD 100710/4664			
Designation		MDB						Overcurrent protective device for the distribution circuit: BS(EN) N/A Type N/A Rating N/A A Voltage 400/230 V											
Num. of ways		10		Num. of phases		3		Associated RCD(if any): BS (EN)		Above 30mA			Operating at 1 IΔn N/A ms			30mA or below			
Supply polarity confirmed		<input checked="" type="checkbox"/>		Phase sequence confirmed		<input checked="" type="checkbox"/>		Z _d 0.11 Ω		No. of poles		N/A		Operating at 5 IΔn N/A ms			Time delay (if applicable) N/A		

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation							
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)						
														r1	r _m	r2		R1 + R2	R2															
					80%																													
1/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/TP	Sub Mains(DB EXT 3)	G	E	1	16	16	5	60947 MCCB	N/A	40	36	N/A	0.72	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/TP	Sub Mains(Busbar)	G	E	1	70	SWA	5	60947 MCCB	N/A	160	36	N/A	0.18	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPD	D	B	1	16	16	0.4	60947 MCCB	N/A	80	36	N/A	0.3	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	✓	0.11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	Sub Mains(DB CL1)	G	E	1	16	16	5	60947 MCCB	N/A	63	36	N/A	0.46	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	Refuge Panel	O	E	1	2.5	2.5	0.4	60947 MCCB	N/A	20	36	N/A	1.20	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
10/L3	Fire Alarm	O	E	1	2.5	2.5	0.4	60947 MCCB	N/A	20	36	N/A	1.20	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other


A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

CIRCUIT DETAILS										TEST RESULTS																									
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation									
	MDB				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)							
	Circuit designation													r1	m	r2		R1 + R2	R2																
												80%																							

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Signature 

Tested by: Name (capital letters) Position Date

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN

Distribution board details - Complete in every case Location: Room X Riser [Schneider] Designation: DB CL2/10-1 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains(DB CL2, 10/L1) Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: C Rating: 32 A Voltage: 230 V	Characteristics at this distribution board Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn: 28.8 ms (if applicable) Z _d : 0.38 Ω No. of poles: 2 30mA or below I _{pf} : 0.61 kA IΔn: 30 Operating at 5 IΔn: 27.2 ms Time delay (if applicable): N/A	Test instrument serial number(s) Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664
---	--	--	---

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)					
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2		
1/L1	Room 3 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A		
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 20/07/2022 To 20/07/2022 Date(s) live testing: 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 20/07/2022 Signature:

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS													
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														r1	m	r2											
					Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	80% (Ω)	r1	m	r2	(✓)	R1 + R2			R2	V	M(Ω)	M(Ω)	(✓)
	DB CL2/10-1																										

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Signature

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 3 Kitchen [Scheider]	Supply to distribution board is from Sub Mains(Busbar, 3/L2)	Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s) Loop impedance 100701/4664 Insulation resistance 100701/4664 Continuity 100701/4664 RCD 100701/4664
Designation DB CL3	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC	Above 30mA (if applicable) Operating at 1 IΔn N/A ms		
Num. of ways 18	Type gG Rating 63 A Voltage 230 V	30mA or below No. of poles N/A		
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Operating at 5 IΔn N/A ms		
		Time delay (if applicable) N/A		

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	m	r2												R1 + R2
1/L2	Lighting Common Room	A	E	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.35	29.6	28.8	✓	N/A
2/L2	Lighting Rooms 2,3	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.60	N/A	250	LIM	>299	✓	0.75	24.3	22.0	✓	N/A
3/L2	Lighting Rooms 4,5	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.55	N/A	250	LIM	>299	✓	0.76	29.4	27.6	✓	N/A
4/L2	Lighting Rooms 6,7	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.53	N/A	250	LIM	>299	✓	0.77	28.2	26.0	✓	N/A
5/L2	Lighting Rooms 8,9	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.40	N/A	250	LIM	>299	✓	0.63	26.4	25.4	✓	N/A
6/L2	Sub Mains(DB CL3/6-1, DB CL3/6)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.32	0.32	0.46	✓	0.20	N/A	250	LIM	>299	✓	0.38	28.8	26.0	✓	N/A
7/L2	Sub Mains(DB CL3/7-1, DB CL3/7)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.34	0.48	✓	0.20	N/A	250	LIM	>299	✓	0.36	28.8	26.0	✓	N/A
8/L2	Sub Mains(DB CL3/8-1, DB CL3/8)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.39	0.39	0.54	✓	0.23	N/A	250	LIM	>299	✓	0.40	28.6	26.0	✓	N/A
9/L2	Sub Mains(DB CL3/9-1, DB CL3/9)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.32	0.32	0.44	✓	0.19	N/A	250	LIM	>299	✓	0.37	28.8	28.0	✓	N/A
10/L2	Sub Mains(DB CL3/10, DB CL3/10-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.48	✓	0.22	N/A	250	LIM	>299	✓	0.41	28.2	28.0	✓	N/A
11/L2	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.42	0.53	✓	0.23	N/A	250	LIM	>299	✓	0.40	28.3	28.0	✓	N/A
12/L2	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.36	0.36	0.45	✓	0.20	N/A	250	LIM	>299	✓	0.37	28.9	28.0	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation		Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
	DB CL3					L/N	CPC		BS EN Number	Type No	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)	
	Circuit designation														r1	m	r2												R1 + R2
						80%																							
13/L2	Hob 1		A	B	1	10	6	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.38	32.0	29.8	✓	N/A
14/L2	Hob 2		A	B	1	10	6	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.31	28.8	25.4	✓	N/A
15/L2	Lighting Rooms 1,10		A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.38	28.8	27.2	✓	N/A
16/L2	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XLPE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																					
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation								
	DB CL3				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)						
															r1	m	r2		R1 + R2	R2															
												80%																							

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature 

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room X Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL3, 10/L2)	Associated RCD(if any): BS (EN) 61009		Test instrument serial number(s) Loop impedance 100701/4664 Insulation resistance 100701/4664 Continuity 100701/4664 RCD 100701/4664
Designation DB CL3/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Operating at 1 IΔn 28.2 ms		
Num. of ways 4	Type B Rating 32 A Voltage 230 V	Operating at 5 IΔn 28.0 ms		
Num. of phases 1		Time delay (if applicable) N/A		
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>			

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L2	Room 3 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.56	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																					
Circuit No. and Line No.	Distribution board Designation		Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation						
	DB CL3/10-1	Circuit designation				L	N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)					
																r1	m	r2												R1 + R2	R2			
												80%																						

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 20/07/2022 To: 20/07/2022 Date(s) live testing: 20/07/2022 To: 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 20/07/2022 Signature: *LIAM KIMBLE*

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 5 Riser [Schneider]		Supply to distribution board is from Sub Mains(DB CL2, 9/L1)		Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 28.6 ms
Designation DB CL2/9-1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type C Rating 32 A Voltage 230 V		Z _d 0.46 Ω No. of poles 2 30mA or below
Num. of ways 4 Num. of phases 1				I _{pf} 0.50 kA IΔn 30 Operating at 5 IΔn 26.4 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L1	Room 5 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.60	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																				
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation									
	DB CL2/9-1				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)							
														r1	m	r2												R1 + R2	R2					
	Circuit designation											80%																						

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 7 Riser [Schneider]		Supply to distribution board is from Sub Mains(DB CL3, 8/L2)		Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 28.6 ms
Designation DB CL3/8-1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage V		Z _d 0.40 Ω No. of poles 2 30mA or below
Num. of ways 4 Num. of phases 1				I _{pf} 0.56 kA IΔn 30 Operating at 5 IΔn 26.0 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L2	Room 7 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS											TEST RESULTS																												
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation														
	Circuit designation				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)												
														r1	m	r2												R1 + R2	R2										
	DB CL3/8-1											80%																											

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 9 Riser [Schneider]		Supply to distribution board is from Sub Mains(DB CL2, 7/L1)		Associated RCD(if any): BS (EN) 61009
Designation DB CL2/7-1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type C Rating 32 A Voltage 230 V		Above 30mA (if applicable) Operating at 1 IΔn 26.2 ms
Num. of ways 4 Num. of phases 1				30mA or below Operating at 5 IΔn 24.0 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										(✓)	R1 + R2	R2
1/L1	Room 9 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.69	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS										TEST RESULTS																						
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation							
	DB CL2/7-1				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)					
	Circuit designation													r1	m	r2								R1 + R2	R2							
												80%																				

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Riser G Floor [Schneider]	Supply to distribution board is from: Sub Mains(MDB, 4/TP)	Associated RCD(if any): BS (EN) N/A		Above 30mA (if applicable) ms 30mA or below ms
Designation: Busbar	Overcurrent protective device for the distribution circuit: BS(EN) 60947 MCCB	Z_d : 0.12 Ω	No. of poles: N/A	
Num. of ways: 10	Type: N/A	I_{pf} : 5.8 kA	$I_{\Delta n}$: N/A	
Num. of phases: 3	Rating: 160 A	Time delay (if applicable): N/A		
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input checked="" type="checkbox"/>	Voltage: 400 V		Test instrument serial number(s)
				Loop impedance: 100710/4664
				Insulation resistance: 100710/4664
				Continuity: 100710/4664
				RCD: 100710/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	r1	m	r2			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														R1 + R2	R2															
1/L1	Sub Mains(DB CL2)	G	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.03	N/A	250	LIM	>299	✓	0.15	N/A	N/A	N/A	N/A		
1/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
2/TP	Sub Mains(DB LL1/L, DB LL1/P)	G	E	1	25	25	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A		
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
3/L2	Sub Mains(DB CL3)	G	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.15	N/A	N/A	N/A	N/A		
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
4/TP	Lift	G	E	1	10	10	0.4	88-2 HRC	gG	32	80	N/A	0.79	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	LIM	✓	0.25	N/A	N/A	N/A	N/A		
5/TP	Sub Mains(DB PL/P, DB PL/L)	G	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A		
6/TP	MSCP	G	E	1	16	16	5	88-2 HRC	gG	20	80	N/A	2.24	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A		
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
10/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																						
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation									
	Busbar				L	N		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)							
	Circuit designation				CPC	r1		m	r2	R1 + R2				R2	80%	(Ω)																			

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Mains Room [Schneider]		Supply to distribution board is from: Sub Mains(MDB, 3/TP)		Associated RCD(if any): BS (EN) N/A
Designation: DB EXT 3		Overcurrent protective device for the distribution circuit: BS(EN) 60947 MCCB		Above 30mA (if applicable) Operating at 1 IΔn N/A ms
Num. of ways: 6		Type: Rating: 40 A Voltage: 400/230 V		30mA or below Operating at 5 IΔn N/A ms
Num. of phases: 3				Time delay (if applicable) N/A
Supply polarity confirmed <input checked="" type="checkbox"/>		Phase sequence confirmed <input checked="" type="checkbox"/>		Test instrument serial number(s)
				Loop impedance: 100701/4664
				Insulation resistance: 100701/4664
				Continuity: 100701/4664
				RCD: 100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)				
														r1	r2	r2										Fig 8 check (✓)	R1 + R2	R2	
					80%	80%	80%	80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%		
1/L1	Courtyard Lighting	G	D	4	4	4	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.63	N/A	250	LIM	>299	✓	0.80	29.4	28.0	✓	N/A	
1/L2	Cycle Store Lights	G	D	3	4	4	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.58	N/A	250	LIM	>299	✓	0.51	28.4	28.0	✓	N/A	
1/L3	Cortyard Lighting 2	G	D	4	4	4	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.62	22.6	22.0	✓	N/A	
2/L1	Cortyard Lighting 3	G	D	4	4	4	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.50	N/A	250	LIM	>299	✓	0.53	25.6	22.0	✓	N/A	
2/L2	Cycle Store Lights 2	G	D	3	4	4	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.37	N/A	250	LIM	>299	✓	0.42	27.2	28.0	✓	N/A	
2/L3	Cameras	G	D	6	2x6	2x6	0.4	61009 RCD/RCBO	C	20	10	30	0.87	N/A	N/A	N/A	N/A	0.20	N/A	LIM	LIM	LIM	✓	0.52	28.8	27.2	✓	N/A	
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	CCTV	G	D	1	6	6	0.4	61009 RCD/RCBO	C	20	10	30	0.87	N/A	N/A	N/A	N/A	0.17	N/A	LIM	LIM	LIM	✓	0.44	29.4	28.0	✓	N/A	
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XLPE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																				
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation								
	DB EXT 3				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)							
	Circuit designation									r1				m	r2	R1 + R2												R2						

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location: Room 4 Riser [Schneider]	Designation: DB CL1/8-2	Supply to distribution board is from: Sub Mains(DB CL1, 8/L1)	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Associated RCD(if any): BS (EN) 61009	Operating at 1 IΔn: 40.6 ms	Loop impedance: 100701/4664	Insulation resistance: 100701/4664
Num. of ways: 4	Num. of phases: 1	BS(EN) 61009 RCD/RCBO	Type: B Rating: 32 A Voltage: 230 V	Z _d : 0.44 Ω	No. of poles: 2	Continuity: 100701/4664	RCD: 100701/4664
Supply polarity confirmed: <input checked="" type="checkbox"/>	Phase sequence confirmed: <input type="checkbox"/>			I _{pf} : 0.51 kA	IΔn: 30		
				Operating at 5 IΔn: 31.2 ms			
				Time delay (if applicable): N/A			

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										(✓)	R1 + R2	R2
1/L1	Room 4 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.72	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 20/07/2022 To: 20/07/2022 Date(s) live testing: 20/07/2022 To: 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
	Circuit designation				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)		Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)			
	DB CL1/8-2											80%	r1	m	r2						(✓)								

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL1, 8/L1)	Associated RCD(if any): BS (EN) 61009		Test instrument serial number(s) Loop impedance 100701/4664 Insulation resistance 100701/4664 Continuity 100701/4664 RCD 100701/4664
Designation DB CL1/8-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Operating at 1 IΔn 40.6 ms		
Num. of ways 4	Type B Rating 32 A Voltage 230 V	Operating at 5 IΔn 31.2 ms		
Num. of phases 1		Time delay (if applicable) N/A		
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>			

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L1	Room 3 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS											TEST RESULTS																										
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation											
	Circuit designation				L	N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)									
															r1	m	r2												R1 + R2	R2							
	DB CL1/8-1											80%																									

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Plant Room [Schneider]		Supply to distribution board is from: Sub Mains (Busbar, 5/TP)		Associated RCD (if any): BS (EN) N/A
Designation: DB PL/P		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC gG		Above 30mA (if applicable) Operating at 1 IΔn N/A ms
Num. of ways: 8		Type: gG Rating: 63 A Voltage: 400 V		30mA or below Operating at 5 IΔn N/A ms
Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance: 100701/4664
				Insulation resistance: 100701/4664
				Continuity: 100701/4664
				RCD: 100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	Plant Room Sockets	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.24	0.24	0.44	✓	0.17	N/A	250	LIM	>299	✓	0.44	28.8	24.2	✓	N/A
1/L2	Head of Shaft AOV	O	B	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A
1/L3	Tube Heater	A	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.31	N/A	N/A	N/A	N/A
2/TP	Roof Extract Fan 1	G	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.29	N/A	N/A	N/A	N/A
3/TP	Roof Extract Fan 2	G	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.27	N/A	N/A	N/A	N/A
4/TP	Roof Extract Fan 3	G	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A
5/TP	Roof Extract Fan 4	G	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.32	N/A	N/A	N/A	N/A
6/TP	Roof Extract Fan 15	G	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.34	N/A	N/A	N/A	N/A
7/TP	Untraced	G	E	LIM	6	6	0.4	60898 MCB	C	50	10	N/A	0.35	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	N/A	N/A	N/A	N/A	N/A
8/L1	Fan Contactors	A	B	1	N/A	N/A	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.20	N/A	N/A	N/A	N/A
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																				
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation									
	DB PL/P				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)							
	Circuit designation													r1	m	r2												R1 + R2	R2					

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider] | Designation: DB CL2/10 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 10/L1)
 Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: C Rating: 32 A Voltage: 230 V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.8 ms (Above 30mA) | Operating at 5 IΔn: 27.2 ms (30mA or below)
 Z_d: 0.38 Ω | No. of poles: 2 | I_{pf}: 0.61 kA | ΔIn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 100701/4664 | Insulation resistance: 100701/4664 | Continuity: 100701/4664 | RCD: 100701/4664

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L1	Room 2 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 20/07/2022 To 20/07/2022 | Date(s) live testing: 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 20/07/2022

Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																					
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation									
	DB CL2/10				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V			L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)						
															r1	m	r2												R1 + R2	R2				
												80%																						
Details of circuits and/or installed equipment vulnerable to damage when testing													Date(s) dead testing		20/07/2022	To	20/07/2022	Date(s) live testing		20/07/2022	To	20/07/2022	Signature											
Tested by: Name (capital letters)													LIAM KIMBLE		Position			Electrical Test Engineer		Date		20/07/2022												
<small>Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other</small> <small>A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)</small>																																		

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 8 Riser [Schneider]		Supply to distribution board is from Sub Mains(DB CL3, 7/L2)		Associated RCD(if any): BS (EN) 61009
Designation DB CL3/7		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms
Num. of ways 4		Type B Rating 32 A Voltage 230 V		Operating at 5 IΔn 26.0 ms
Supply polarity confirmed <input checked="" type="checkbox"/>		Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L2	Room 8 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS											TEST RESULTS																												
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation														
	DB CL3/7				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V			L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)											
															r1	m	r2												R1 + R2	R2									
												80%																											

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 10 Riser [Schneider]		Supply to distribution board is from		Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms 30mA or below Operating at 5 IΔn 26.0 ms Time delay (if applicable) N/A
Designation DB CL3/6-1		Sub Mains(DB CL3, 6/L2)		
Num. of ways 4 Num. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				
Test instrument serial number(s)				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L2	Room 10 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS										TEST RESULTS																													
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation														
	DB CL3/6-1				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V			L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCO (✓)											
	Circuit designation				80%	r1		m	r2	R1 + R2				R2	ms	ms		(✓)	(✓)																				

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 5 Riser [Schneider]		Supply to distribution board is from Sub Mains (DB CL3, 9/L2)		Associated RCD (if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms
Designation DB CL3/9-1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage V		Z _d 0.37 Ω No. of poles 2 30mA or below
Num. of ways 4 Num. of phases 1				I _{pf} 0.60 kA IΔn 30 Operating at 5 IΔn 28.0 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL3/9-1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L2	Room 5 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.54	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																				
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation							
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Idn ms			30mA or below 5 Idn ms	RCD (✓)	AFCO (✓)							
														r1	m	r2						R1 + R2			R2									
DB CL3/9-1	Circuit designation																																	

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 20/07/2022 To 20/07/2022 Date(s) live testing: 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature Liam Kimble

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 2 Riser [Schneider]		Supply to distribution board is from Sub Mains (DB CL3, 10/L2)		Associated RCD (if any): BS (EN) 61009
Designation DB CL3/10		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.2 ms
Num. of ways 4		Type B Rating 32 A Voltage 230 V		Operating at 5 IΔn 28.0 ms
Supply polarity confirmed <input checked="" type="checkbox"/>				Time delay (if applicable) N/A
Phase sequence confirmed <input type="checkbox"/>				
				Test instrument serial number(s)
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L2	Room 2 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
	DB CL3/10				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCO (✓)			
												80%	r1	m	r2														

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Room 1 Riser [Schneider] Designation: DB CL3/6 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>	Supply to distribution board is from: Sub Mains (DB CL3, 6/L2) Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: B Rating: 32 A Voltage: 230 V	Associated RCD (if any): BS (EN) 61009 Operating at 1 IΔn: 28.8 ms Z _d : 0.38 Ω No. of poles: 2 I _{pf} : 0.59 kA IΔn: 30 Operating at 5 IΔn: 26.0 ms Time delay (if applicable): N/A	Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL3/6 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										(✓)	R1 + R2	R2
1/L2	Room 1 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.67	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

CIRCUIT DETAILS												TEST RESULTS																			
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
	DB CL3/6				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)				
	Circuit designation													r1	m	r2												R1 + R2	R2		
												80%																			

Details of circuits and/or installed equipment vulnerable to damage when testing: Date(s) dead testing: 20/07/2022 To 20/07/2022 Date(s) live testing: 20/07/2022 To 20/07/2022

Signature

Tested by: Name (capital letters) Position Date

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICA exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 6 Riser [Schneider]	Designation DB CL1/7-1	Supply to distribution board is from Sub Mains(DB CL1, 7/L1)	Associated RCD(if any): BS (EN) 61009	Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms
Num. of ways 4	Num. of phases 1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Z _d 0.40 Ω	No. of poles 2
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Type B Rating 32 A Voltage 230 V	I _{pf} 0.56 kA	IΔn 30
			Operating at 5 IΔn 27.0 ms	Time delay (if applicable) N/A
			Test instrument serial number(s)	
			Loop impedance	100701/4664
			Insulation resistance	100701/4664
			Continuity	100701/4664
			RCD	100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L1	Room 6 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

CIRCUIT DETAILS													TEST RESULTS													
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
	Circuit designation				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCO (✓)	
	DB CL1/7-1											80%	r1	m	r2	(✓)	R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)				

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: 1st Floor Riser [Schneider]	Supply to distribution board is from: Sub Mains (Busbar, 2/TP)	Associated RCD (if any): BS (EN) N/A		Test instrument serial number(s) Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664
Designation: DB LL1/L	Overcurrent protective device for the distribution circuit: BS (EN) 88-2 HRC gG	Operating at 1 IΔn: N/A ms		
Num. of ways: 6	Type: gG	Operating at 5 IΔn: N/A ms		
Num. of phases: 3	Rating: 63 A	Voltage: 400 V		
Supply polarity confirmed: <input checked="" type="checkbox"/>	Phase sequence confirmed: <input checked="" type="checkbox"/>	Time delay (if applicable): N/A		

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	r1	m			r2	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														R1 + R2	R2	80%														
1/L1	G Floor Lighting Corridor	A	B	15	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.56	N/A	250	LIM	>299	✓	0.73	28.5	12.2	✓	N/A		
1/L2	1st Floor Lighting Corridor	A	B	14	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.68	32.0	28.0	✓	N/A		
1/L3	2nd Floor Lighting Corridor	A	B	14	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.49	N/A	250	LIM	>299	✓	0.59	29.5	29.2	✓	N/A		
2/L1	G Floor Lighting Stairs	A	B	9	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.51	N/A	250	LIM	>299	✓	0.69	31.6	29.2	✓	N/A		
2/L2	1st Floor Lighting Stairs	A	B	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.57	28.4	25.4	✓	N/A		
2/L3	2nd Floor Lighting Stairs	A	B	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.72	30.6	28.0	✓	N/A		
3/L1	IT Hub Lighting	A	B	2	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.49	N/A	250	LIM	>299	✓	0.65	32.8	27.6	✓	N/A		
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L1	Bus Power Supply	A	B	1	2.5	1.5	0.4	61009 RCD/RCBO	C	16	10	30	1.09	N/A	N/A	N/A	N/A	0.27	N/A	250	LIM	>299	✓	0.45	28.2	28.0	✓	N/A		
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 21/07/2022 To 21/07/2022 Date(s) live testing 21/07/2022 To 21/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 21/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS														TEST RESULTS																								
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation											
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)										
														r1	m	r2		R1 + R2	R2																			
					Circuit designation	80% (Ω)		r1	m	r2				(✓)	R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(Ω)	ms			ms	(✓)	(✓)											
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A						

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 21/07/2022 To 21/07/2022 Date(s) live testing 21/07/2022 To 21/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 21/07/2022 Signature 

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICE exposed to touch (4G1A)



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

CIRCUIT DETAILS													TEST RESULTS																				
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation							
	DB LL1/L				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)					
															r1	m	r2												R1 + R2	R2			
															80%	(Ω)	(Ω)												(Ω)	(Ω)	(Ω)		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MISC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 2 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(Busbar, 1/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)
Designation DB CL2		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC		Operating at 1 IΔn N/A ms
Num. of ways 18 Num. of phases 1		Type gG Rating 63 A Voltage 230 V		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn N/A ms
				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	r1	m			r2	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														R1 + R2	R2	(Ω)														
1/L1	Common Room Lighting	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.55	28.4	21.2	✓	N/A		
2/L1	Lighting Bedrooms 2,3	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.84	N/A	250	LIM	>299	✓	0.96	29.6	32.4	✓	N/A		
3/L1	Lighting Bedrooms 4,5	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.71	N/A	250	LIM	>299	✓	0.88	25.4	22.4	✓	N/A		
4/L1	Lighting Bedrooms 6,7	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.58	N/A	250	LIM	>299	✓	0.64	21.4	18.8	✓	N/A		
5/L1	Lighting Bedrooms 8,9	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.65	N/A	250	LIM	>299	✓	0.79	28.6	28.0	✓	N/A		
6/L1	Sub Mains(DB CL2/6, DB CL2/6-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.36	0.36	0.44	✓	0.20	N/A	250	LIM	>299	✓	0.35	28.8	28.0	✓	N/A		
7/L1	Sub Mains(DB CL2/7, DB CL2/7-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.38	0.35	0.47	✓	0.21	N/A	250	LIM	>299	✓	0.37	26.2	24.0	✓	N/A		
8/L1	Sub Mains(DB CL2/8, DB CL2/8-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.32	0.32	0.44	✓	0.19	N/A	250	LIM	>299	✓	0.33	29.4	29.2	✓	N/A		
9/L1	Sub Mains(DB CL2/9, DB CL2/9-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.46	0.46	0.64	✓	0.28	N/A	250	LIM	>299	✓	0.46	28.6	26.4	✓	N/A		
10/L1	Sub Mains(DB CL2/10, DB CL2/10-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.30	0.30	0.40	✓	0.18	N/A	250	LIM	>299	✓	0.38	28.8	27.2	✓	N/A		
11/L1	Common Room Ring 1	A	B	12	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.56	✓	0.25	N/A	250	LIM	>299	✓	0.36	32.0	18.4	✓	N/A		
12/L1	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.35	0.35	0.44	✓	0.20	N/A	250	LIM	>299	✓	0.32	26.2	22.6	✓	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 21/07/2022 To 21/07/2022 Date(s) live testing 21/07/2022 To 21/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 21/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation		Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	DB CL2					L/N	CPC		BS EN Number	Type No	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)		
	Circuit designation														r1	m	r2												R1 + R2	R2
13/L1	Hob1		A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.30	31.6	28.9	✓	N/A	
14/L1	Hob 2		A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.34	28.5	29.4	✓	N/A	
15/L1	Lighting Bedrooms 1,10		A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.72	N/A	250	LIM	>299	✓	0.95	32.0	26.0	✓	N/A	
16/L1	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L1	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L1	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 21/07/2022 To 21/07/2022 Date(s) live testing 21/07/2022 To 21/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 21/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

CIRCUIT DETAILS												TEST RESULTS																			
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
	DB CL2				L	N		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	A/FDO (✓)			
	Circuit designation				L/N	CPC								80%	Ω	r1		m	r2						R1 + R2	R2	(ms)	(ms)	(✓)	(✓)	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110149172



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Siwan 10, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location Room 2 Riser [Schneider]	Designation DB CL1/8	Supply to distribution board is from Sub Mains(DB CL1, 8/L1)	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V	Associated RCD(if any): BS (EN) 61009	Operating at 1 IΔn 40.6 ms	Loop impedance 100701/4664	Insulation resistance 100701/4664
Num. of ways 4	Num. of phases 1			Z _d 0.44 Ω	No. of poles 2	Continuity 100701/4664	RCD 100701/4664
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>			I _{pf} 0.51 kA	IΔn 30		
					Operating at 5 IΔn 31.2 ms		
					Time delay (if applicable) N/A		

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	R1 + R2	R2
1/L1	Room 2 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS											TEST RESULTS																											
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation												
	DB CL1/8				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDO (✓)										
															r1	m	r2								R1 + R2	R2												
												80%																										

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

Generic Continuation

General Conditions of the Electrical Installation:

The service head, meter and supply authority fuse are in the mains room on the ground floor

Main Earthing Arrangements

The Main Earthing arrangement for the installation appears to be TN-C-S.

Incoming Services

The main incoming water supply appears to enter the property in the mains room. The main bond is a 50mm copper conductor with warning labels attached.

The main incoming gas supply appears to enter the property the riser.

The main bond is a 50mm copper conductor with warning labels attached.

Wiring Systems.

The wiring systems utilized for final circuit wiring in the installation are PVC/PVC T&E cable (A)

Installation methods used are clipped direct or in trunking on the wall.

The final circuits are protected by BS60898 MCB's with RCD protection provided by BS 61009

Observation notes

All information and documentation (where available) were used to help compile this report.

Circuit charts should be present for each Distribution Board providing relevant information in accordance with Regulation 514.9.1 of the BS 7671:2018.

On the distribution board schedules of circuit details cable types and sizes have been typed in as what is visible at the distribution board only.

Circuits may have been jointed with a different cable type further along the circuit

Only a percentage of the installation has been dismantled for inspection purposes. The correct connection of every conductor and link throughout the premises cannot be ensured.

Additional Comments

No access to sealed supply authority fuses therefore Characteristics of Primary Supply Protective Devices are not filled in on page 2.

A new regulation 421.1.7 has been introduced recommending the installation of Arc Fault detection devices conforming to BS EN 62606 to mitigate the risk of fire in AC final circuits of a fixed installation due to arc fault currents.

This installation has been designed and installed prior to July 2018. There is no evidence of

Over-voltage protection within the electrical installation, we recommend Surge Protective Devices be installed in order to reduce the risk of damage to the installation by external transient

Over-voltage's or switching.

Overall Assessment

In general, the installation is in a good condition but is (Un)Satisfactory due to the C2, F/I defects in section K, which require urgent action, with the code 3 observations requiring early attention. Assuming attention is brought to the observations and recommendations listed within section K, it is recommended a maximum 5-year period for the next inspection and test to be carried out.

Abbreviations contained in this Report: -

RHS – Right Hand Side

LHS – Left Hand Side

D/B - Distribution board.

RCD - Residual current device.

CPC - Circuit protective conductor.

FCU – Fused Connection Unit.

CSA - Cross Sectional Area.

MET – Main Earthing Terminal.

LIM – Limitation (Agreed or Operational)

MIC – Sheath of MICC cable used as CPC

SWA – Steel Wire Armouring used as CPC

MW – Metalwork used as CPC.

FP – FP200 Fire Resistant Cable.

Remarks:

DB LL1/P Remarks:

5/L1 - G Floor Smoke Shaft AOV: O=FP200

5/L3 - 1st Floor Smoke Shaft AOV: O=FP200

6/L3 - 2nd Floor Smoke Shaft AOV: O=FP200

7/L3 - 2nd Floor Stair Core AOV: O=FP200

MDB Remarks:

10/L2 - Refuge Panel: O=FP200

10/L3 - Fire Alarm: O=FP200

DB EXT 3 Remarks:

1/L1 - Courtyard Lighting: Via Contactor

1/L2 - Cycle Store Lights: Via Contactor

1/L3 - Courtyard Lighting 2: Via Contactor

2/L1 - Courtyard Lighting 3: Via Contactor

2/L2 - Cycle Store Lights 2: Via Contactor