

# Electrical Installation Condition Report

Requirements for Electrical Installations - BS 7671:2018+A2:2022  
(IET Wiring Regulations 18th Edition)

## Guidance for recipients:

**This report is an important and valuable document which should be retained for future reference.**

1. The purpose of this Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
2. This Report is only valid if accompanied by the Inspection Schedule(s) and the Schedule(s) of Circuit Details and Test Results.
3. The person ordering the Report should have received the original Report and the inspector should have retained a duplicate.
4. The original Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner / occupier with details of the condition of the electrical installation at the time the Report was issued.
5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
7. For items classified in Section K as **C1 (“Danger Present”)**, the safety of those using the installation is at risk, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.
8. For items classified in Section K as **C2 (“Potentially Dangerous”)**, the safety of those using the installation may be at risk and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in Section K that an observation requires further investigation **code FI** the inspection has revealed an apparent deficiency which may result in a code C1 or C2 could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
10. **For safety reasons**, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under ‘Recommendations’ and on a label at or near to the consumer unit /distribution board (where required).
11. Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked ‘T’ or ‘Test’. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. **For safety reasons it is important that this instruction is followed.**
12. Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer’s instructions shall be followed with respect to test button operation.
13. Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer’s information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.
14. Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR

2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

## A. Details of the Installation

Client	UPP Residential Services Ltd	Installation	Swansea University Bay Campus
Address	First Floor 12 Arthur Street London	Address	Reception - Ground Floor Tower Information Centre Fabian Way, Crymlyn Burrows Swansea
Postcode	EC4R 9AB	Postcode	SA1 8EN

## B. Reason for Producing this Report

*This form is to be used only for reporting on the condition of an existing installation.*

Essential information requested by the client in accordance with the electricity at work regulations 1989.

Date(s) on which the inspection and testing were carried out  to 

## C. Details of Installation which is the Subject of this Report

Description of premises Domestic  Commercial  Industrial  Other (please specify)

Estimated age of the wiring system  years

Evidence of alterations or addition Yes  No  Not apparent  if 'Yes', estimated  years

Records of installation available Yes  No  Records held by

Date of last inspection  Electrical Installation Certificate No. or previous Inspection Report No.

## D. Extent of Electrical Installation Covered by this Report:

Testing of all sub mains, lighting and power circuits, within the constraints of the agreed limitations.

### Agreed Limitations and Operational Limitations (Regulations 653.2)

Unable to access the sealed supply device characteristics. Ze and Ipf have been taken as close to the origin as possible. Insulation resistance testing has been carried out to regulation 612.3.3 on circuits where it was impracticable to disconnect load. Unable to test equipment where access is limited by height, furniture, machinery or stock.

Agreed with:  Extent of Termination Sampling: The inspection and testing detailed within this report and accompanying schedule has been carried out in accordance with BS 7671: 2018 (IET Wiring Regulations) amended to 

It should be noted that cables concealed within trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

## E. Summary of the Condition of the Installation

Overall assessment of the installation in terms of its suitability for continued use

SATISFACTORY \*UNSATISFACTORY 

General conditions of the installation (in terms of electrical safety)

The Mains Electrical Incomer is in the Ground Floor Switch Room. The Incoming Supply is TN-C-S. The 1st Item of Equipment is MPB, Sub Mains in SWA to the Rising Main Bus Bar and DB CL1, CL 2 and DB LL1.

Final circuits from Distribution Boards Installed are generally PVC/PVC T&amp;E in Trunking and on Basket Tray. The Installation is --Please see Continuation Page--

\*An UNSATISFACTORY assessment indicates that dangerous (code C1), or potentially dangerous (code C2) conditions have been identified

## F. Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potential dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further Investigation required' (code F1). Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by  (date) for the following reasons:

See Observations

## G. Declaration

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company	PHS Compliance	Inspected and tested by	Authorised for issue by
Address	Kid Glove Road, Golborne, Warrington,	Name:	Peter Hughes Nigel Carvell
Postcode	WA3 3GR	Signature:	 
Branch No.		Position:	Electrical Test Engineer Technical Auditor
Scheme No.		Date:	28/07/2023 26/09/2023

**EICRs are produced by a UKAS accredited inspection body, No. 0433**

## H. Schedule(s)

 schedule(s) of inspection and  schedule(s) of Circuit Details and Test Results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR

2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



## I. Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S  TN-C-S  TT  Other  Please specify

Number & Type of live conductors AC  DC  No. of phases  No. of wires

**Nature of Supply Parameters (Note: <sup>(1)</sup> by enquiry, <sup>(2)</sup> by enquiry or by measurement)**

Nominal voltage, U/U<sub>0</sub> <sup>(1)</sup>  V Nominal frequency, f<sup>(1)</sup>  Hz Confirmation of supply polarity

Prospective fault current, I<sub>pf</sub> <sup>(2)</sup>  kA External loop impedance, Z<sub>e</sub> <sup>(2)</sup>  Ω

Supply Protective Device BS (EN)  Type  Rated Current  A

No. of Additional Supplies

## J. Particulars of Installation Referred to in this Report

**Details of installation Earth Electrode** (where applicable) Type (e.g. rod(s), tape etc)

Location  Electrode resistance to earth  Ω

**Means of Earthing** Distributors facility  Installation Earth Electrode

Maximum Demand (load)  Amps  KVA

Main Protective Conductors	Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper	150 mm <sup>2</sup>	Continuity Verified <input checked="" type="checkbox"/>	Ω <input type="text"/>
Protective Bonding Conductor	Copper	50 mm <sup>2</sup>	Continuity Verified <input checked="" type="checkbox"/>	Ω <input type="text"/>
Connection Verified			<input checked="" type="checkbox"/>	Ω <input type="text"/>
Connection Verified			<input checked="" type="checkbox"/>	Ω <input type="text"/>

**Main Supply Conductor** Material  csa  mm<sup>2</sup> (connection / continuity) (✓) or Value (✓) or Value

**Main Switch** Location  Water installation  Ω To structural steel  Ω

**Fuse/device rating or setting** LIM  A Voltage rating  V Gas installation pipes  Ω To lightning protection  Ω

**If RCD main switch:** Rated residual operating current I Δn  mA Oil installation pipes  Ω Other   Ω

BS(EN)  No. of Poles  Current Rating  A Rated time delay  ms Measured operating trip time  ms

## K. Observations

Referring to the attached inspection schedule(s) and schedule(s) of circuit details and test results, and subject to the limitations specified at the Extent and limitations of inspection and testing Section D.

No remedial work required

The following observations are made

### Explanation of codes

<b>C1</b>	Danger present. Risk of Injury. Immediate remedial action required.
<b>C2</b>	Potentially dangerous. Urgent remedial action required.
<b>C3</b>	Improvement recommended.
<b>FI</b>	Further Investigation required without delay

Item No.	Observations	Code
1	Observation: It is recommended that Arc Fault Detection Devices (AFDD) conforming to BS EN 62606 be provided for single phase AC final circuits supplying socket-outlets with a rated current not exceeding 32A in premises other than Higher Risk Residential Buildings (HRRB), Houses in Multiple Occupation (HMO), purpose-built student accommodation and care homes. Location: All Socket Circuits Regulation: 421.1.7	C3
2	Observation: A detailed legible diagram, chart or table or equivalent form of information has not been provided in the vicinity of the distribution board indicating type and composition of circuits as well as other relevant information. Location: All DB's Regulation: 514.9.1	C3
3	Observation: Minor Damage to DB, Lock Missing Location: DB CL 2 Regulation: 416.2.3	C3
4	Observation: Minor Damage to Switch Plate. Flat 2 Kitchen Cooker Hood Switch RHS Location: DB CL 2 Cct 12 Sockets RHS Regulation: 416.2.3	C3
5	Observation: There is no label to BS 951 present at the termination of Gas Riser. Location: Gas Riser Regulation: 514.13.1	C3
6	Observation: Minor Damage to Switch Plate. Flat 3 Kitchen Cooker Hood Switch RHS Location: DB CL 3 Cct 12 Sockets RHS Regulation: 416.2.3	C3
7	Observation: Screws missing from DB cover, cover still secure. 1x Schneider Grub Tappers. Location: DB PL Regulation: 416.2.3	C3
8	Observation: Screws missing from DB cover, cover still secure. 1x Schneider Grub Tappers. Location: DB LL 3 Regulation: 416.2.3	C3

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR

2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



One of the following codes, as appropriate, has been allocated to each of the observations made above and/or any attached observation sheets to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

<b>C1</b> Danger present. Risk of Injury. Immediate remedial action required.	0
<b>C2</b> Potentially dangerous. Urgent remedial action required.	0
<b>C3</b> Improvement recommended.	8
<b>FI</b> Further Investigation required without delay	0

The above values are a total count of Observation per outcome

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671:2018+A2:2022 (IET Wiring Regulations 18<sup>th</sup> Edition)

**Outcomes**

Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further Investigation:	Not Verified:	Limitation:	Not Applicable:	Inadequacies: (Items 1.1 - 1.1.5 Only)
	or						

Item No.	Description	Outcome
----------	-------------	---------

**1.0 INTAKE EQUIPMENT (VISUAL INSPECTION ONLY);**

1.1	Service cable	
1.1.1	Service head	
1.1.2	Earthing arrangement	
1.1.3	Meter tails	
1.1.4	Metering equipment	
1.1.5	Isolator (where present)	
1.1.6	Person ordering work/dutyholder notified (Delete as appropriate) NOTE 1 Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and/or dutyholder must be informed. It is strongly recommended that the person ordering the work informs the appropriate authority. NOTE 2 For this section only, where inadequacies are found, an X should be put against the appropriate item and a comment made in Section K	
1.2	Consumer's Isolator (where present)	
1.3	Consumer's meter tails	

**2.0 PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES**

2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	

**3.0 AUTOMATIC DISCONNECTION OF SUPPLY**

3.1	<b>Main earthing/bonding arrangements (411.3; Chap 54)</b>	
3.1.1	Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)	
3.1.2	Presence of installation earth electrode arrangement (542.1.2.3)	
3.1.3	Adequacy of earthing conductor size (542.3; 543.1.1)	
3.1.4	Adequacy of earthing conductor connections (542.3.2)	
3.1.5	Accessibility of earthing conductor connections (543.3.2)	
3.1.6	Adequacy of main protective bonding conductor sizes (544.1)	
3.1.7	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	
3.1.8	Accessibility of all protective bonding connections (543.3.2)	
3.1.9	Provision of earthing/bonding labels at all appropriate locations (514.13)	
3.2	FELV - requirements satisfied (411.7; 411.7.1)	

**4.0 OTHER METHODS OF PROTECTION (where any of the methods listed below are employed details should be provided on separate sheets)**

4.1	Non-conducting location (418.1)	
4.2	Earth-free local equipotential bonding (418.2)	
4.3	Electrical separation (Section 413; 418.3)	
4.4	Double insulation (Section 412)	
4.5	Reinforced insulation (Section 412)	

**5.0 DISTRIBUTION EQUIPMENT**

5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	
5.2	Security of fixing (134.1.1)	
5.3	Condition of insulation of live parts (416.1)	
5.4	Adequacy/security of barriers (416.2)	
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	
5.6	Condition of enclosure(s) in terms of fire rating etc. (421.1.6; 421.1.201; 526.5)	
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)	
5.8	Presence and effectiveness of obstacles (417.2)	
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	
5.10	Operation of main switch(es) (functional check) (643.10)	
5.11	Manual operation of circuit-breakers RCDs and AFDDs to prove functionality (643.10)	
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)	
5.13	RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2)	
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBO(s) (411.3.3; 415.1)	
5.15	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	
5.17	Presence of alternative supply warning notice at or near equipment, where required (514.15)	
5.18	Presence of next inspection recommendation label (514.12.1)	
5.19	Presence of other required labelling (please specify) (Section 514)	

for Industrial/Commercial Premises



**Requirements for Electrical Installations  
BS7671:2018+A2:2022 (IET Wiring Regulations 18<sup>th</sup> Edition)**

5.20	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)(411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	✓
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
<b>5.0 DISTRIBUTION EQUIPMENT CONT.</b>		
5.22	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	✓
5.23	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	✓
<b>6.0 DISTRIBUTION CIRCUITS</b>		
6.1	Identification of conductors (514.3.1)	✓
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
6.3	Condition of insulation of live parts (416.1)	✓
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	✓
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	✓
6.6	Cables correctly terminated in enclosures (Section 526)	✓
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	✓
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	✓
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	✓
<b>6.15 CABLES CONCEALED UNDER FLOORS, ABOVE CEILINGS, IN WALLS/PARTITIONS LESS THAN 50 MM FROM A SURFACE, AND IN PARTITIONS CONTAINING METAL PARTS</b>		
6.15.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	▲
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.204)	▲
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
6.17	Band II cables segregated/separated from Band I cables (528.1)	✓
6.18	Cables segregated/separated from non-electrical services (528.3)	✓
6.19	Condition of circuit accessories (651.2)	✓
6.20	Suitability of circuit accessories for external influences (512.2)	✓
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
6.22	Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/ record numbers and locations of items inspected (Section 526)	✓
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; Section 537)	✓
6.24	General condition of wiring systems (651.2)	C3
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)	✓
<b>7.0 CONSUMER UNIT/DISTRIBUTION BOARD</b>		
7.1	Adequacy of working space / accessibility to consumer unit/distribution board (132.12; 513.1)	✓
7.2	Security of fixing (134.1.1)	✓
7.3	Condition of enclosure(s) in terms of IP rating (barriers etc.)(416.2)	✓
7.4	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	✓
7.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)	✓
7.5.1	Presence and effectiveness of obstacles (417.2)	✓
7.6	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	✓
7.7	Operation of main switch(es) (functional check) (643.10)	✓
7.8	Manual operation of circuit-breakers, RCD(s) and AFDD's to prove functionality (643.10)	✓
7.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	✓
7.10	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	✓
7.11	Presence of alternative supply warning notice at or near consumer unit/distribution board (514.15)	N/A
7.12	Presence of other required labelling (Please specify) Section 514)	✓
7.13	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	✓
7.14	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3))	✓
7.15	Protection against mechanical damage where cables enter distribution board (522.8.1; 522.8.5; 522.8.11)	✓
7.16	Protection against electromagnetic effects where cables enter distribution board (521.5.1)	✓
7.17	RCD(s) provided for fault protection – includes RCBO(s)(411.4.204; 411.5.2; 531.2)	N/A
7.18	RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1)	✓
7.19	Confirmation of indication that SPD is functional (651.4)	N/A
7.20	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
7.21	Adequate arrangements where a generating set operates as a switched alternative to public supply (551.6)	N/A

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671:2018+A2:2022 (IET Wiring Regulations 18<sup>th</sup> Edition)



7.22	Adequate arrangements where a generating set operates in parallel with public supply (551.7)	NA
<b>8.0 FINAL CIRCUITS</b>		
8.1	Identification of conductors (514.3.1)	✓
8.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
8.3	Condition of insulation of live parts (416.1)	✓
8.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	✓
8.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)	✓
8.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
8.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
8.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
8.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓
8.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓
8.10	Cables Concealed Under Floors, Above Ceilings Or In Walls/ Partitions, Adequately Protected Against Damage (522.3.201, 202, 203, 204)	▲
8.10.1	Installed in prescribed zones (see Section D. Extent and limitation) (522.6.201, 204)	▲
8.10.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.201; 522.6.204)	▲
<b>8.12 PROVISION OF ADDITIONAL PROTECTION/REQUIREMENTS BY 30 mA RCD</b>		
8.12.1	For all socket-outlets of rating 32 A or less unless an exception is permitted (411.3.3)	✓
8.12.2	For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	NA
8.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	✓
8.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	✓
8.12.5	Final circuits supplying luminaries within domestic (household) premises (411.3.4)	NA
8.12.6	For lighting that is accessible to the public (714.411.3.4)	NA
8.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
<b>9.0 FINAL CIRCUITS CONT.</b>		
9.14	Band II cables segregated/separated from Band I cables (528.1)	✓
9.15	Cables segregated/separated from communications cabling (528.2)	✓
9.16	Cables segregated/separated from non-electrical services (528.3)	✓
9.17	Terminations of cables at enclosures - indicate extent of sampling in Section D of the report (Section 526)	✓
9.17.1	Connection soundly made and under no undue strain (526.6)	✓
9.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	✓
9.17.3	Connections of live conductors adequately enclosed (526.5)	✓
9.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓
9.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v))	✓
9.19	Suitability of accessories for external influences (512.2)	✓
9.20	Adequacy of working space/accessibility to equipment (132.12; 513.1)	✓
9.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
<b>10.1 ISOLATOR (SECTIONS 460; 537)</b>		
10.1.1	Presence and condition of appropriate devices (Section 462; 537.2.7)	✓
10.1.2	Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7)	✓
10.1.3	Capable of being secured in the OFF position (462.3)	✓
10.1.4	Correct operation verified (643.10)	✓
10.1.5	Clearly identified by position and/or durable marking (537.2.6)	✓
10.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	✓
<b>10.2 SWITCHING OFF FOR MECHANICAL MAINTENANCE (SECTION 464; 537.3.2)</b>		
10.2.1	Presence and condition of appropriate devices (464.1; 527.3.2)	✓
10.2.2	Acceptable location – state if local or remote from equipment in question (537.3.2.4)	✓
10.2.3	Capable of being secured in the OFF position (462.3)	✓
10.2.4	Correct operation verified (643.10)	✓
10.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	✓
<b>10.3 EMERGENCY SWITCHING/STOPPING (SECTION 465; 537.3.3)</b>		
10.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	NA
10.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	NA
10.3.3	Correct operation verified (643.10)	NA
10.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	NA
<b>10.4 FUNCTIONAL SWITCHING (SECTION 463; 537.3.1)</b>		
10.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	✓
10.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	✓
<b>11.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)</b>		
11.1	Condition of equipment in terms of IP rating etc (416.2)	✓
11.2	Equipment does not constitute a fire hazard (Section 421)	✓

for Industrial/Commercial Premises



**Requirements for Electrical Installations**  
**BS7671:2018+A2:2022 (IET Wiring Regulations 18<sup>th</sup> Edition)**

11.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	✓
11.4	Suitability for the environment and external influences (512.2)	✓
11.5	Security of fixing (134.1.1)	✓
11.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	▲
<b>11.7 RECESSED LUMINAIRES (DOWNLIGHTERS)</b>		
11.7.1	Correct type of lamps fitted (559.3.1)	✓
11.7.2	Installed to minimize build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	✓
11.7.3	No signs of overheating to surrounding building fabric (559.4.1)	✓
11.7.4	No signs of overheating to conductors/terminations (526.1)	✓
<b>12.0 PART 7 SPECIAL INSTALLATIONS OR LOCATIONS</b>		
12.1	If any special installations or locations are present, list the particular inspections applied.	✓
<b>13.0 PROSUMER'S LOW VOLTAGE ELECTRICAL INSTALLATION(S)</b>		
13.1	Where the installation includes additional requirements and recommendations relating to Chapter 82, additional inspection items should be added to the checklist.	NA

Inspector's Name:

Date:

Signature: 



ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [checked] T2 [checked] T3+ [ ] N/A [ ]
Location: Main Switch Room Schneider
Designation: MPB
No. of ways: 12
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from [ ]
No. of phases: 3 BS(EN) [ ] Type [ ] Rating [ ] A
Nominal voltage: 400 V RCD BS(EN) [ ] Type [ ] Rating [ ] Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with 16 columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (BS 7671) (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω), RCD (BS EN Number, Type No., Idn (mA), Rating (A)). Rows include SPARE, Sub Mains, Refuge Panel, Fire Alarm Panel, Sub Mains, and SPD.

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>				<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>								
Location	Main Switch Room Schneider	Associated RCD (if any):	BS (EN)	N/A	Z <sub>db</sub>	0.05	Ω	Operating at IΔn	N/A	ms		
Designation	MPB	No. of ways	12	<input checked="" type="checkbox"/> Supply polarity confirmed	<input checked="" type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	8.72	kA	No. of poles	N/A	Time delay (if applicable)	N/A
No. of phases	3	SPD:	<input checked="" type="checkbox"/> Operational status confirmed	<input checked="" type="checkbox"/> Not applicable								

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation	
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	N/A	N/A	N/A	N/A	0.05	N/A	250	>999	>999	✓	0.11	N/A	N/A	N/A
6/TP	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.06	N/A	N/A	N/A
7/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	N/A	N/A	N/A	N/A	0.17	N/A	250	>999	>999	✓	0.23	N/A	N/A	N/A
10/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L3	N/A	N/A	N/A	N/A	0.19	N/A	250	>999	>999	✓	0.27	N/A	N/A	N/A
11/L1	N/A	N/A	N/A	N/A	0.04	N/A	250	>999	>999	✓	0.10	N/A	N/A	N/A
11/L2	N/A	N/A	N/A	N/A	0.02	N/A	250	>999	>999	✓	0.07	N/A	N/A	N/A
11/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	N/A	N/A	N/A	N/A	0.01	N/A	250	>999	>999	✓	0.05	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	01/08/2023	To	01/08/2023
		Date(s) live testing	01/08/2023	To	01/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position	Electrical Test Engineer	Date	01/08/2023		

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input checked="" type="checkbox"/> T2 <input checked="" type="checkbox"/> T3 <input type="checkbox"/> N/A <input type="checkbox"/> Location Flat 1 Riser RHS in Corridor Schneider Designation DB LL 1 L No. of ways 8		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(MPB, 5/TP) No. of phases 3 BS(EN) 60947 MCCB Type Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type Rating IΔn mA	
---	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Lights Corridor Flat 1	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
1/L2	Lights Corridor Flat 4	A3	B	6	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	Lights Gnd/Flr Lobby	A3	B	5	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L2	Lights Stairs 1st Floor	A3	B	7	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	Lights Mains/Comms Room	A3	B	2	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L2	Lights Corridor Flat 3	A3	B	12	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	Lights Corridor Flat 2	A3	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	Bus Power	A3	B	1	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
8/TP	SPD	D1	B	1	10	10	5	60898 MCB	C	50	10	0.35	N/A	AC	N/A	10

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Flat 1 Riser RHS in Corridor Schneider  
 Designation: DB LL 1 L

No. of ways: 8  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 3 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.11 Ω Operating at IΔn: N/A ms  
 I<sub>pr</sub>: 3.38 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation				
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2									
1/L1	N/A	N/A	N/A	N/A	0.53	N/A	250	>999	>999	✓	0.67	28.8	✓	N/A	
1/L2	N/A	N/A	N/A	N/A	0.75	N/A	250	>999	>999	✓	0.89	28.4	✓	N/A	
1/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2/L1	N/A	N/A	N/A	N/A	0.61	N/A	250	>999	>999	✓	0.75	28.8	✓	N/A	
2/L2	N/A	N/A	N/A	N/A	0.55	N/A	250	>999	>999	✓	0.69	28.0	✓	N/A	
2/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	N/A	N/A	N/A	N/A	0.49	N/A	250	>999	>999	✓	0.63	29.2	✓	N/A	
3/L2	N/A	N/A	N/A	N/A	0.57	N/A	250	>999	>999	✓	0.71	28.7	✓	N/A	
3/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L1	N/A	N/A	N/A	N/A	0.66	N/A	250	>999	>999	✓	0.79	28.6	✓	N/A	
4/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7/L3	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	✓	0.38	28.4	✓	N/A	
8/TP	N/A	N/A	N/A	N/A	0.01	N/A	250	>999	>999	✓	0.13	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 08/08/2023 To 08/08/2023  
 Date(s) live testing: 08/08/2023 To 08/08/2023

Test instrument serial number(s):

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 08/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location <input type="text" value="Electrical Riser Schneider"/> Designation <input type="text" value="Rising Bus Bar"/> No. of ways <input type="text" value="16"/>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(MPB, 6/TP)"/> No. of phases <input type="text" value="3"/> BS(EN) <input type="text" value="60947 MCCB"/> Type <input type="text"/> Rating <input type="text" value="250"/> A Nominal voltage <input type="text" value="400"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA	
---	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § <input type="text" value="80%"/> (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1/L2	Sub Mains(DB CL 3)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	Sub Mains(DB CL 4)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
3/L1	Sub Mains(DB CL 5)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	Sub Mains(DB CL 6)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	Sub Mains(DB LL 2 L, DB LL 2 P)	G2	E	1	25	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL 7)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
6/L3	Sub Mains(DB CL 8)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
7/L1	Sub Mains(DB CL 9)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L2	Sub Mains(DB CL 10)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
8/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	Sub Mains(DB LL 3 P, DB LL 3 L)	G2	E	1	25	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
10/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L3	Sub Mains(DB CL 11)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
11/L1	Sub Mains(DB CL 12)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
11/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L2	Sub Mains(DB CL 13)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
12/L3	Sub Mains(DB CL 14)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
13/TP	LIFT	G2	E	1	10	10	0.4	60947 MCCB	N/A	32	36	0.83	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (S)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § <input type="checkbox"/> 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
14/TP	Sub Mains(DB PL P, DB PL L)	G2	E	1	16	16	5	60947 MCCB	N/A	63	36	0.46	N/A	N/A	N/A	N/A
15/TP	MSCP	G2	E	1	16	16	0.4	60947 MCCB	N/A	20	36	1.34	N/A	N/A	N/A	N/A
16/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd		<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB	<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location:   
 Designation:

No. of ways:   Supply polarity confirmed  Phase sequence confirmed  
 No. of phases:  SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)   
 $Z_{db}$    $\Omega$  Operating at  $I_{\Delta n}$   ms  
 $I_{pf}$   kA No. of poles  Time delay (if applicable)

## TEST RESULTS

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)			Polarity	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation		
	Ring final circuits only			Fig 8 Check ( $\checkmark$ )	R1R2 or R2		Test voltage V			L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	All RCDs $I_{\Delta n}$ ms	RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )
	r1	r	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
1/L2	N/A	N/A	N/A	N/A	0.04	N/A	250	>999	>999	N/A	0.11	N/A	N/A	N/A
1/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	N/A	N/A	N/A	N/A	0.03	N/A	250	>999	>999	N/A	0.09	N/A	N/A	N/A
3/L1	N/A	N/A	N/A	N/A	0.03	N/A	250	>999	>999	N/A	0.09	N/A	N/A	N/A
3/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	N/A	N/A	N/A	N/A	0.03	N/A	250	>999	>999	N/A	0.10	N/A	N/A	N/A
4/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	N/A	N/A	N/A	N/A	0.04	N/A	250	>999	>999	N/A	0.11	N/A	N/A	N/A
6/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	N/A	N/A	N/A	N/A	0.03	N/A	250	N/A	N/A	N/A	0.10	N/A	N/A	N/A
6/L3	N/A	N/A	N/A	N/A	0.03	N/A	250	N/A	N/A	N/A	0.10	N/A	N/A	N/A
7/L1	N/A	N/A	N/A	N/A	0.03	N/A	250	>999	>999	N/A	0.11	N/A	N/A	N/A
7/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L2	N/A	N/A	N/A	N/A	0.03	N/A	250	>999	>999	N/A	0.11	N/A	N/A	N/A
8/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	N/A	N/A	N/A	N/A	0.04	N/A	250	>999	>999	N/A	0.12	N/A	N/A	N/A
10/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L3	N/A	N/A	N/A	N/A	0.05	N/A	250	>999	>999	N/A	0.14	N/A	N/A	N/A
11/L1	N/A	N/A	N/A	N/A	0.03	N/A	250	>999	>999	N/A	0.09	N/A	N/A	N/A
11/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L2	N/A	N/A	N/A	N/A	0.03	N/A	250	>999	>999	N/A	0.11	N/A	N/A	N/A
12/L3	N/A	N/A	N/A	N/A	0.03	N/A	250	>999	>999	N/A	0.11	N/A	N/A	N/A
13/TP	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	LIM	LIM	N/A	N/A	N/A
14/TP	N/A	N/A	N/A	N/A	0.05	N/A	250	>999	>999	N/A	0.12	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing:  To   
 Date(s) live testing:  To

Test instrument serial number(s):

Loop impedance:  Insulation resistance:  Continuity:  RCD:  E/Electrode:

Tested by: Name (capital letters)  Signature:

Position:  Date:





**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 2 Kitchen Schneider Designation DB CL 2 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(MPB, 11/L2) No. of phases 1 BS(EN) 60947 MCCB Type Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L1	Lights Rooms 1,2	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L1	Lights Rooms 5,6,7	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L1	Lights Rooms 4,3	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L1	SPARE															
6/L1	Sub Mains(DB CL 2/7, DB CL 2/5, DB CL 2/6)	A3	B	8	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L1	Sub Mains(DB CL 2/2, DB CL 2/1)	A3	B	8	2.5	1.5	5	61009 RCD/RCBO	C	16	10	1.09	61009	AC	30	16
8/L1	Sub Mains(DB CL 2/4, DB CL 2/3)	A3	B	8	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L1	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L1	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L1	Sockets Kitchen LHS	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L1	Sockets Kitchen RHS	A3	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L1	Auto Doors	A3	B	4	2.5	1.5	0.4	61009 RCD/RCBO	C	16	10	1.09	61009	AC	30	16
14/L1	Sockets Store Room	A3	B	2	2.5	1.5	0.4	61009 RCD/RCBO	C	16	10	1.09	61009	AC	30	16
15/L1	Additional Sockets room 7	A3	B	4	2.5	1.5	0.4	61009 RCD/RCBO	C	16	10	1.09	61009	AC	30	16
16/L1	SPARE															
17/L1	SPARE															
18/L1	SPARE															

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 2 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 2	Z <sub>db</sub>	0.07 Ω Operating at IΔn _____ ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	3.08 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation		
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)				L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1				N/A	0.31		250	>999	>999	✓	0.44	28.2	✓	N/A
2/L1				N/A	0.44		250	>999	>999	✓	0.63	28.8	✓	N/A
3/L1				N/A	0.26		250	>999	>999	✓	0.52	28.6	✓	N/A
4/L1				N/A	0.51		250	>999	>999	✓	0.74	28.2	✓	N/A
5/L1	N/A	N/A	N/A	N/A						N/A			N/A	N/A
6/L1	0.31	0.32	0.48	✓	0.20		250	>999	>999	✓	0.29	28.6	✓	N/A
7/L1				N/A	0.21		250	>999	>999	✓	0.34	28.6	✓	N/A
8/L1	0.43	0.42	0.70	✓	0.28		250	>999	>999	✓	0.38	28.4	✓	N/A
9/L1				N/A	0.14		250	>999	>999	✓	0.23	28.8	✓	N/A
10/L1				N/A	0.12		250	>999	>999	✓	0.21	28.0	✓	N/A
11/L1	0.28	0.29	0.44	✓	0.18		250	>999	>999	✓	0.31	28.8	✓	N/A
12/L1	0.30	0.30	0.45	✓	0.19		250	>999	>999	✓	0.29	28.6	✓	N/A
13/L1				N/A	0.27		250	>999	>999	✓	0.36	28.6	✓	N/A
14/L1				N/A	0.22		250	>999	>999	✓	0.31	28.8	✓	N/A
15/L1				N/A	0.31		250	>999	>999	✓	0.40	28.4	✓	N/A
16/L1	N/A	N/A	N/A	N/A						N/A			N/A	N/A
17/L1	N/A	N/A	N/A	N/A						N/A			N/A	N/A
18/L1	N/A	N/A	N/A	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	02/08/2023	To	02/08/2023
		Date(s) live testing	02/08/2023	To	02/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position	Electrical Test Engineer	Date	02/08/2023		

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 1 Kitchen Schneider Designation DB CL 1 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(MPB, 11/L1) No. of phases 1 BS(EN) 60947 MCCB Type Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating Idn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Idn (mA)	Rating (A)
1/L2	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L2	Lights Rooms 1, 2, 3	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L2	Lights Rooms 4, 5, 6	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL 1/3, DB CL 1/1, DB CL 1/2)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L2	Sub Mains(DB CL 1/6, DB CL 1/4, DB CL 1/5)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
8/L2	Cooker	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	Sockets Kitchen LHS	A3	B	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L2	Sockets Kitchen RHS	A3	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 1 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 1	Z <sub>db</sub>	0.10 Ω Operating at IΔn _____ ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	2.35 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation			
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.47	N/A	250	>999	>999	✓	0.59	28.4	✓	N/A
2/L2	N/A	N/A	N/A	N/A	0.65	N/A	250	>999	>999	✓	0.78	28.8	✓	N/A
3/L2	N/A	N/A	N/A	N/A	0.70	N/A	250	>999	>999	✓	0.82	28.2	✓	N/A
4/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	0.18	0.17	0.29	✓	0.12	N/A	250	>999	>999	✓	0.23	28.6	✓	N/A
7/L2	0.25	0.26	0.39	✓	0.16	N/A	250	>999	>999	✓	0.29	29.2	✓	N/A
8/L2	N/A	N/A	N/A	N/A	0.13	N/A	250	>999	>999	✓	0.25	28.0	✓	N/A
9/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	0.33	0.32	0.52	✓	0.21	N/A	250	>999	>999	✓	0.35	28.4	✓	N/A
11/L2	0.28	0.29	0.46	✓	0.18	N/A	250	>999	>999	✓	0.30	28.8	✓	N/A
12/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	01/08/2023	To	01/08/2023
		Date(s) live testing	01/08/2023	To	01/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position	Electrical Test Engineer	Date	01/08/2023		

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 1, 6/L2)"/>		
Location <input type="text" value="Room 1 Riser Schneider"/>	No. of phases <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A		
Designation <input type="text" value="DB CL 1/1"/>	Nominal voltage <input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA		
No. of ways <input type="text" value="1"/>			

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (s) (BS 7671)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs (Ω) Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 1 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Client Postcode</b> EC4R 9AB
<b>Installation Postcode</b> SA1 8EN	

**Distribution board details - Complete in every case**

Location: Room 1 Riser Schneider  
Designation: DB CL 1/1

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub>: 0.23 Ω Operating at IΔn: 28.6 ms  
I<sub>pr</sub>: 0.99 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2	Test voltage	L/L, L/N	L/E, N/E			All RCDs IΔn ms	RCD	A.F.D.D	
	r1	r	r2		R1 + R2	R2	V	M(Ω)				M(Ω)	(✓)	(✓)
1/L2	N/A	N/A	N/A	N/A	0.35	N/A	250	>999	>999	✓	0.62	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 01/08/2023 To 01/08/2023  
Date(s) live testing: 01/08/2023 To 01/08/2023

Test instrument serial number(s):

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature: [Handwritten Signature]  
Position: Electrical Test Engineer Date: 01/08/2023



for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1, T2, T3, N/A
Location: Room 2 Riser Schneider
Designation: DB CL 1/2
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 1, 6/L2)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> UPP Residential Services Ltd		<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Client Postcode</b> EC4R 9AB	<b>Installation Postcode</b> SA1 8EN	

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location <input type="text" value="Room 2 Riser Schneider"/>	Associated RCD (if any): BS (EN) <input type="text" value="N/A"/>		
Designation <input type="text" value="DB CL 1/2"/>	$Z_{db}$ <input type="text" value="0.23"/>	$\Omega$	Operating at $I\Delta n$ <input type="text" value="28.6"/>
No. of ways <input type="text" value="1"/> <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	$I_{pr}$ <input type="text" value="0.99"/>		kA No. of poles <input type="text" value="N/A"/> Time delay (if applicable) <input type="text" value="N/A"/>
No. of phases <input type="text" value="1"/> SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable			

**TEST RESULTS**

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)			Polarity	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing	Manual test button operation			
	Ring final circuits only			Fig 8 check ( $\checkmark$ )	Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )			All RCDs $I\Delta n$ ms	RCD	AFDD		
	r1	r2	r3								( $\checkmark$ )	( $\checkmark$ )	( $\checkmark$ )	
1/L2	N/A	N/A	N/A	N/A	0.46	N/A	250	>999	>999	$\checkmark$	0.73	N/A	N/A	N/A

**Details of circuits and/or installed equipment vulnerable to damage when testing**

Date(s) dead testing  To

Date(s) live testing  To

Test instrument serial number(s)

Loop impedance  Insulation resistance  Continuity  RCD  E/Electrode

Tested by: Name (capital letters)  Signature

Position  Date



ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 3 Riser Schneider
Designation: DB CL 1/3
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 1, 6/L2)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A IDn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (BS 7671), Overcurrent protective devices, Breaking capacity, BS 7671 Max. permitted Zs, RCD details, etc.

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd, Client Address: First Floor, 12 Arthur Street London, Client Postcode: EC4R 9AB, Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, Installation Postcode: SA1 8EN

Distribution board details - Complete in every case. Location: Room 3 Riser Schneider, Designation: DB CL 1/3, No. of ways: 1, No. of phases: 1, SPD: Not applicable, Complete only if the distribution board is not connected directly to the origin of the installation

TEST RESULTS

Table with 15 columns: Circuit No. and Line, Ring final circuits only (r1, m, r2), Fig 8 check, R1R2 or R2 (R1+R2, R2), Test voltage (V), L/L, L/N (M(Ω)), L/E, N/E (M(Ω)), Polarity, Max. Measured Zs (Ω), RCD testing (All RCDs IΔn ms), Manual test button operation (RCD (✓), AFDD (✓)). Row 1: 1/L2, N/A, N/A, N/A, N/A, 0.34, N/A, 250, >999, >999, ✓, 0.60, N/A, N/A, N/A.

Details of circuits and/or installed equipment vulnerable to damage when testing, Date(s) dead testing: 01/08/2023 To 01/08/2023, Date(s) live testing: 01/08/2023 To 01/08/2023, Test instrument serial number(s): 102133109, Loop impedance: 102133109, Insulation resistance: 102133109, Continuity: 102133109, RCD: 102133109, E/Electrode: 102133109, Tested by: Name (capital letters) PETER HUGHES, Position: Electrical Test Engineer, Date: 01/08/2023, Signature: [Handwritten Signature]

*for Industrial/Commercial Premises*



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
SPD Details: Type(s)*	T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit:	Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 1, 7/L2)"/>
Location	<input type="text" value="Room 4 Riser Schneider"/>	No. of phases	<input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A
Designation	<input type="text" value="DB CL 1/4"/>	Nominal voltage	<input type="text" value="400"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA
No. of ways	<input type="text" value="1"/>		

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 4 Sockets	A3	B	8	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 §: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Client Postcode</b> EC4R 9AB
<b>Installation Postcode</b> SA1 8EN	

**Distribution board details - Complete in every case**

Location: Room 4 Riser Schneider  
Designation: DB CL 1/4

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed

No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub>: 0.29 Ω Operating at I $\Delta$ n 29.2 ms  
I<sub>pr</sub>: 0.79 kA No. of poles N/A Time delay (if applicable) N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> ( $\Omega$ )	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N			L/E, N/E	All RCDs I $\Delta$ n ms	RCD	AFFD
	r1	m	r2		R1 + R2	R2		M( $\Omega$ )			M( $\Omega$ )		(✓)	(✓)
1/L2	N/A	N/A	N/A	N/A	0.22	N/A	250	>999	>999	✓	0.54	N/A	N/A	N/A

**Details of circuits and/or installed equipment vulnerable to damage when testing**

Date(s) dead testing: 01/08/2023 To 01/08/2023  
Date(s) live testing: 01/08/2023 To 01/08/2023

Test instrument serial number(s):  
Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature: *Peter Hughes*  
Position: Electrical Test Engineer Date: 01/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<p><b>Distribution board details - Complete in every case</b></p> <p>SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/></p> <p>Location <input type="text" value="Room 5 Riser Schneider"/></p> <p>Designation <input type="text" value="DB CL 1/5"/></p> <p>No. of ways <input type="text" value="1"/></p>	<p><b>Complete only if the distribution board is not connected directly to the origin of the installation</b></p> <p>Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 1, 7/L2)"/></p> <p>No. of phases <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A</p> <p>Nominal voltage <input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA</p>
--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § <input type="text" value="80%"/> (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 5 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

---

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

*for Industrial/Commercial Premises*

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location   
 Designation

No. of ways   Supply polarity confirmed  Phase sequence confirmed  
 No. of phases  SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)   
 Z<sub>db</sub>  Ω Operating at IΔn  ms  
 I<sub>pf</sub>  kA No. of poles  Time delay (if applicable)

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)				Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation	
	Ring final circuits only			R1R2 or R2	Test voltage	L/L, L/N	L/E, N/E	All RCDs IΔn ms	RCD (✓)			AFDD (✓)		
	r1	r <sub>m</sub>	r2											
1/L2	N/A	N/A	N/A	N/A	0.58	N/A	250	>999	>999	✓	0.93	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing  To   
 Date(s) live testing  To

Test instrument serial number(s)

Loop impedance  Insulation resistance  Continuity  RCD  E/Electrode

Tested by: Name (capital letters)  Signature   
 Position  Date

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 6 Riser Schneider
Designation: DB CL 1/6
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 1, 7/L2)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with 14 columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating (A)). Row 1: 1/L2 Room 6 Sockets, A3, B, 6, 2.5, 1.5, 0.4, 60898 MCB, B, 10, 10, 3.49, N/A, N/A, N/A, N/A.

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

[Empty box for wiring type notes]

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> UPP Residential Services Ltd			<b>Installation Address</b>		
<b>Client Address</b> First Floor, 12 Arthur Street London			Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		
<b>Client Postcode</b> EC4R 9AB		<b>Installation Postcode</b> SA1 8EN			

**Distribution board details - Complete in every case**

Location: Room 6 Riser Schneider  
 Designation: DB CL 1/6  
 No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.29  $\Omega$  Operating at I $\Delta$ n: 29.2 ms  
 I<sub>pr</sub>: 0.79 kA No. of poles: N/A Time delay (if applicable): N/A

## TEST RESULTS

Circuit No. and Line	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> ( $\Omega$ )	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 check ( $\checkmark$ )	R1R2 or R2	Test voltage  V	L/L, L/N  M( $\Omega$ )	L/E, N/E  M( $\Omega$ )			All RCDs I $\Delta$ n  ms	RCD  ( $\checkmark$ )	AFDD  ( $\checkmark$ )	
	r1	r	r2											R1 + R2
1/L2	N/A	N/A	N/A	N/A	0.25	N/A	250	>999	>999	$\checkmark$	0.58	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing:

Date(s) dead testing: 01/08/2023 To 01/08/2023  
 Date(s) live testing: 01/08/2023 To 01/08/2023

Test instrument serial number(s): \_\_\_\_\_  
 Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:   
 Position: Electrical Test Engineer Date: 01/08/2023



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
SPD Details: Type(s)*	T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit:	Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 2, 6/L1)"/>
Location	<input type="text" value="Room 5 Riser Schneider"/>	No. of phases	<input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A
Designation	<input type="text" value="DB CL 2/5"/>	Nominal voltage	<input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value=""/> Idn mA
No. of ways	<input type="text" value="1"/>		

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § <input type="text" value="80%"/> (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Idn (mA)	Rating (A)
1/L1	Room 5 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

---

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd		<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b>	First Floor, 12 Arthur Street London		<b>Client Postcode</b>	EC4R 9AB	
			<b>Installation Postcode</b>	SA1 8EN	

**Distribution board details - Complete in every case**

Location  Room 5 Riser Schneider

Designation  DB CL 2/5

No. of ways  1  Supply polarity confirmed  Phase sequence confirmed

No. of phases  1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)  N/A

Z<sub>db</sub>  0.29 Ω Operating at I $\Delta$ n  28.6 ms

I<sub>pf</sub>  0.79 kA No. of poles  N/A Time delay (if applicable)  N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation	
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				All RCDs I $\Delta$ n ms	RCD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.14	N/A	250	>999	>999	✓	0.45	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing  01/08/2023 To  01/08/2023

Date(s) live testing  01/08/2023 To  01/08/2023

Test instrument serial number(s)

Loop impedance  102133109 Insulation resistance  102133109 Continuity  102133109 RCD  102133109 E/Electrode  102133109

Tested by: Name (capital letters)  PETER HUGHES Signature

Position  Electrical Test Engineer Date  01/08/2023

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

**Client Name** UPP Residential Services Ltd  
**Client Address** First Floor, 12 Arthur Street London  
**Client Postcode** EC4R 9AB  
**Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea  
**Postcode** SA1 8EN

**Distribution board details - Complete in every case**  
 SPD Details: Type(s)\* T1  T2  T3  N/A   
 Location Room 6 Riser Schneider  
 Designation DB CL 2/6  
 No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**  
 Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 2, 6/L1)  
 No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
 Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating Idn mA

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Idn (mA)	Rating (A)
1/L1	Room 6 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

FT/EICR 2670000213307



<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Client Postcode</b> EC4R 9AB	<b>Installation Postcode</b> SA1 8EN

<b>Distribution board details - Complete in every case</b>						<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>						
Location	Room 6 Riser Schneider					Associated RCD (if any):	BS (EN) N/A					
Designation	DB CL 2/6					Z <sub>db</sub>	0.29	Ω	Operating at IΔn	28.6	ms	
No. of ways	1	<input checked="" type="checkbox"/> Supply polarity confirmed		<input type="checkbox"/> Phase sequence confirmed		I <sub>pr</sub>	0.78	kA	No. of poles	N/A	Time delay (if applicable)	N/A
No. of phases	1	SPD: <input type="checkbox"/> Operational status confirmed		<input checked="" type="checkbox"/> Not applicable								

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation	
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r2	r3		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.29	N/A	250	>999	>999	✓	0.63	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing						Date(s) dead testing	01/08/2023	To	01/08/2023						
						Date(s) live testing	01/08/2023	To	01/08/2023						
Test instrument serial number(s)						Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109	RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES					Signature									
Position	Electrical Test Engineer				Date	01/08/2023									

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London		
<b>Client Postcode</b>	EC4R 9AB	<b>Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location <input type="text" value="Room 7 Riser Schneider"/> Designation <input type="text" value="DB CL 2/7"/> No. of ways <input type="text" value="1"/>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 2, 6/L1)"/> No. of phases <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A Nominal voltage <input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text"/> IΔn mA
---	---

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method <sup>j</sup> :	No. of points served	Circuit conductors <sup>c</sup> (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Z <sub>s</sub> <sup>§</sup> (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 7 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Z<sub>s</sub> column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 7 Riser Schneider  
Designation: DB CL 2/7

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub>: 0.29 Ω Operating at I $\Delta$ n: 28.6 ms  
I<sub>pr</sub>: 0.79 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation				
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V				L/L, L/N	L/E, N/E	All RCDs I $\Delta$ n ms	RCD	AFDD
	r1	r2	r3		R1 + R2	R2					M(Ω)	M(Ω)		(✓)	(✓)
1/L1	N/A	N/A	N/A	N/A	0.10	N/A	250	>999	>999	✓	0.38	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 01/08/2023 To: 01/08/2023  
Date(s) live testing: 01/08/2023 To: 01/08/2023

Test instrument serial number(s)

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters): PETER HUGHES Signature: [Signature]  
Position: Electrical Test Engineer Date: 01/08/2023

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 1 Riser Schneider
Designation: DB CL 2/1
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 2, 7/L1)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type C Rating 16 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating [ ] Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with 15 columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (BS 7671) (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω), RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location:   
 Designation:   
 No. of ways:   Supply polarity confirmed  Phase sequence confirmed  
 No. of phases:  SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)   
 Z<sub>db</sub>  Ω    Operating at IΔn  ms  
 I<sub>pr</sub>  kA    No. of poles     Time delay (if applicable)

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation		
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	All RCDs IΔn ms		RCD (✓)	AFDD (✓)
	r1	r	r2								R1 + R2	R2		
1/L1	N/A	N/A	N/A	N/A	0.17	N/A	250	>999	>999	✓	0.53	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing:  To   
 Date(s) live testing:  To

Test instrument serial number(s):

Loop impedance:     Insulation resistance:     Continuity:     RCD:     E/Electrode:

Tested by: Name (capital letters)     Position     Date     Signature



# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Room 2 Riser Schneider Designation DB CL 2/2 No. of ways 1		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 2, 7/L1) No. of phases 1 BS(EN) 61009 RCD/RCBO Type C Rating 16 A Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating <input type="text"/> IΔn mA	
--	--	---	--

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD				
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)	
1/L1	Room 2 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	80%	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



*for Industrial/Commercial Premises*

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

**Distribution board details - Complete in every case**  
SPD Details: Type(s)\* T1  T2  T3  N/A   
Location Room 4 Riser Schneider  
Designation DB CL 2/4  
No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**  
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 2, 8/L1)  
No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating IDn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (kA)	BS 7671 Max. permitted Zs Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Idn (mA)	Rating (A)
1/L1	Room 4 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

*for Industrial/Commercial Premises*


Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>
Location <input type="text" value="Room 4 Riser Schneider"/>	Associated RCD (if any): BS (EN) <input type="text" value="N/A"/>
Designation <input type="text" value="DB CL 2/4"/>	Z <sub>db</sub> <input type="text" value="0.38"/> Ω    Operating at I $\Delta$ n <input type="text" value="28.4"/> ms
No. of ways <input type="text" value="1"/> <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub> <input type="text" value="0.63"/> kA    No. of poles <input type="text" value="N/A"/> Time delay (if applicable) <input type="text" value="N/A"/>
No. of phases <input type="text" value="1"/> SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable	

**TEST RESULTS**

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> ( $\Omega$ )	RCD testing All RCDs I $\Delta$ n ms	Manual test button operation			
	Ring final circuits only			R1R2 or R2	Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )				RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )		
	r1	r <sub>m</sub>	r2										R1 + R2	R2
1/L1	N/A	N/A	N/A	N/A	0.20	N/A	250	>999	>999	$\checkmark$	0.61	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing					Date(s) dead testing <input type="text" value="01/08/2023"/> To <input type="text" value="01/08/2023"/>				
<input style="width:100%;" type="text"/>					Date(s) live testing <input type="text" value="01/08/2023"/> To <input type="text" value="01/08/2023"/>				
Test instrument serial number(s)									
Loop impedance	<input type="text" value="102133109"/>	Insulation resistance	<input type="text" value="102133109"/>	Continuity	<input type="text" value="102133109"/>	RCD	<input type="text" value="102133109"/>	E/Electrode	<input type="text" value="102133109"/>
Tested by: Name (capital letters)	<input type="text" value="PETER HUGHES"/>			Signature					
Position	<input type="text" value="Electrical Test Engineer"/>	Date	<input type="text" value="01/08/2023"/>						

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Postcode</b> SA1 8EN
<b>Client Postcode</b> EC4R 9AB	

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3†  N/A

Location Room 3 Riser Schneider

Designation DB CL 2/3

No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 2, 8/L1)

No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A

Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating Δn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method ‡	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Δn (mA)	Rating (A)
1/L1	Room 3 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

---

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd		<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB	<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		
Location	Room 3 Riser Schneider		Associated RCD (if any):	BS (EN)	N/A
Designation	DB CL 2/3		Z <sub>db</sub>	0.38	Ω    Operating at IΔn    28.4    ms
No. of ways	1	<input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	0.61	kA    No. of poles    N/A    Time delay (if applicable)    N/A
No. of phases	1	SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable			

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation	
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFDD (✓)
	r1	r2	r3		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.10	N/A	250	>999	>999	✓	0.48	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: \_\_\_\_\_

Date(s) dead testing: 01/08/2023 To 01/08/2023  
Date(s) live testing: 01/08/2023 To 01/08/2023

Test instrument serial number(s): \_\_\_\_\_

Loop impedance: 102133109    Insulation resistance: 102133109    Continuity: 102133109    RCD: 102133109    E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES    Signature:

Position: Electrical Test Engineer    Date: 01/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 3 Kitchen Schneider Designation DB CL 3 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 1/L2) No. of phases 1 BS(EN) 60947 MCCB Type Rating 63 A Nominal voltage 230 V RCD BS(EN) N/A Type Rating N/A IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L2	Lights Rooms 1,2, 3	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L2	Lights Rooms 6,7, 8	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L2	Lights Rooms 4,5	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL 3/1, DB CL 3/2, DB CL 3/3)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L2	Sub Mains(DB CL 3/8, DB CL 3/6, DB CL 3/7)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
8/L2	Sub Mains(DB CL 3/4, DB CL 3/5)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L2	Sockets Kitchen LHS	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L2	Sockets Kitchen RHS	A3	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L2	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L2	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 3 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 3	Z <sub>db</sub>	0.11 Ω Operating at IΔn N/A ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	2.16 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation			
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.53	N/A	250	>999	>999	✓	0.66	28.0	✓	N/A
2/L2	N/A	N/A	N/A	N/A	0.64	N/A	250	>999	>999	✓	0.78	28.8	✓	N/A
3/L2	N/A	N/A	N/A	N/A	0.69	N/A	250	>999	>999	✓	0.83	28.6	✓	N/A
4/L2	N/A	N/A	N/A	N/A	0.59	N/A	250	>999	>999	✓	0.72	28.2	✓	N/A
5/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	0.31	0.32	0.48	✓	0.20	N/A	250	>999	>999	✓	0.33	28.6	✓	N/A
7/L2	0.37	0.38	0.58	✓	0.24	N/A	250	>999	>999	✓	0.36	28.6	✓	N/A
8/L2	0.43	0.42	0.70	✓	0.28	N/A	250	>999	>999	✓	0.40	28.4	✓	N/A
9/L2	0.28	0.29	0.44	✓	0.18	N/A	250	>999	>999	✓	0.31	28.8	✓	N/A
10/L2	0.30	0.30	0.45	✓	0.19	N/A	250	>999	>999	✓	0.33	28.0	✓	N/A
11/L2	N/A	N/A	N/A	N/A	0.14	N/A	250	>999	>999	✓	0.27	28.8	✓	N/A
12/L2	N/A	N/A	N/A	N/A	0.12	N/A	250	>999	>999	✓	0.25	28.6	✓	N/A
13/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	02/08/2023	To	02/08/2023
		Date(s) live testing	02/08/2023	To	02/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES		Signature		
Position	Electrical Test Engineer	Date	02/08/2023		



# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>
SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 3, 6/L2)
Location Room 1 Riser Schneider	No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Designation DB CL 3/1	Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating <input type="checkbox"/> IΔn mA
No. of ways 1	

SCHEDULE OF CIRCUIT DETAILS																
Circuit No. and Line	Circuit designation	Type of wiring	Ref. method ‡	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 1 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street, London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 1 Riser Schneider
Designation: DB CL 3/1
No. of ways: 1
No. of phases: 1
Associated RCD (if any): BS (EN) N/A
Zdb: 0.33
Ipr: 0.69 kA

TEST RESULTS

Table with 16 columns: Circuit No. and Line, Ring final circuits only (r1, r2), R1R2 or R2, Test voltage (V), L/L, L/N, L/E, N/E, Polarity, Max. Measured Zs (Ω), RCD testing (ms), Manual test button operation (RCD, AFDD). Row 1: 1/L2, N/A, N/A, N/A, N/A, 0.23, N/A, 250, >999, >999, ✓, 0.59, N/A, N/A, N/A.

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 01/08/2023 To 01/08/2023
Date(s) live testing: 01/08/2023 To 01/08/2023
Test instrument serial number(s):
Loop impedance: 102133109, Insulation resistance: 102133109, Continuity: 102133109, RCD: 102133109, E/Electrode: 102133109
Tested by: Name (capital letters): PETER HUGHES, Signature: [Handwritten Signature], Position: Electrical Test Engineer, Date: 01/08/2023

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3  N/A

Location

Designation

No. of ways

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from

No. of phases  BS(EN)  Type  Rating  A

Nominal voltage  V RCD BS(EN)  Type  Rating  IΔn mA

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 2 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

for Industrial/Commercial Premises

Requirements for Electrical Installations  
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 2 Riser Schneider  
 Designation: DB CL 3/2

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.33 Ω Operating at I<sub>Δn</sub>: 28.6 ms  
 I<sub>pf</sub>: 0.67 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation			
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V			L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs I <sub>Δn</sub> ms	RCD (✓)	AFDD (✓)
	r1	r2	r3		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.25	N/A	250	>999	>999	✓	0.61	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing:

Date(s) dead testing: 01/08/2023 To 01/08/2023  
 Date(s) live testing: 01/08/2023 To 01/08/2023

Test instrument serial number(s):

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 01/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London		<b>Postcode</b>
<b>Client Postcode</b>	EC4R 9AB		

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3  N/A

Location Room 3 Riser Schneider

Designation DB CL 3/3

No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 3, 6/L2)

No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A

Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating  IΔn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 3 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

for *Industrial/Commercial Premises*

Requirements for Electrical Installations  
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Client Postcode</b> EC4R 9AB
	<b>Installation Postcode</b> SA1 8EN

**Distribution board details - Complete in every case**

Location   
 Designation

No. of ways   Supply polarity confirmed  Phase sequence confirmed  
 No. of phases  SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**


Associated RCD (if any): BS (EN)   
 $Z_{db}$    $\Omega$  Operating at  $I\Delta n$   ms  
 $I_{pr}$   kA No. of poles  Time delay (if applicable)

**TEST RESULTS**

Circuit No. and Line	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing All RCDs $I\Delta n$ ms	Manual test button operation		
	Ring final circuits only			$E_{ig}$ check ( $\checkmark$ )	R1R2 or R2		Test voltage V	L/L, L/N M( $\Omega$ )				L/E, N/E M( $\Omega$ )	RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )
	r1	m	r2		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.21	N/A	250	>999	>999	$\checkmark$	0.57	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing  
  
 Date(s) dead testing  To   
 Date(s) live testing  To

Test instrument serial number(s)  
 Loop impedance  Insulation resistance  Continuity  RCD  E/Electrode

Tested by: Name (capital letters)  Signature   
 Position  Date

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3 N/A
Location: Room 4 Riser Schneider
Designation: DB CL 3/4
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 3, 8/L2)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating IΔn mA

SCHEDULE OF CIRCUIT DETAILS

Table with 14 columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω), RCD (BS EN Number, Type No., IΔn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b> Location <input type="text" value="Room 4 Riser Schneider"/> Designation <input type="text" value="DB CL 3/4"/> No. of ways <input type="text" value="1"/> <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed No. of phases <input type="text" value="1"/> SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Associated RCD (if any): BS (EN) <input type="text" value="N/A"/> Z <sub>db</sub> <input type="text" value="0.40"/> Ω Operating at IΔn <input type="text" value="28.4"/> ms I <sub>pf</sub> <input type="text" value="0.58"/> kA No. of poles <input type="text" value="N/A"/> Time delay (if applicable) <input type="text" value="N/A"/>	
--	--	--	--

TEST RESULTS

Circuit No. and Line	Circuit impedance Ω			Fig 8 check (✓)	R1R2 or R2		Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation	
	Ring final circuits only				Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)			AFDD (✓)		
	r1	m	r2										R1 + R2	R2
1/L2	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	✓	0.69	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing <input type="text"/>						Date(s) dead testing <input type="text" value="01/08/2023"/> To <input type="text" value="01/08/2023"/>			
Test instrument serial number(s) <input type="text"/>						Date(s) live testing <input type="text" value="01/08/2023"/> To <input type="text" value="01/08/2023"/>			
Loop impedance	<input type="text" value="102133109"/>	Insulation resistance	<input type="text" value="102133109"/>	Continuity	<input type="text" value="102133109"/>	RCD	<input type="text" value="102133109"/>	E/Electrode	<input type="text" value="102133109"/>
Tested by: Name (capital letters)	<input type="text" value="PETER HUGHES"/>			Signature					
Position	<input type="text" value="Electrical Test Engineer"/>	Date	<input type="text" value="01/08/2023"/>						





for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name, Client Address, Client Postcode, Installation Address, Postcode

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location, Designation, No. of ways
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device, Supply to distribution board is from
No. of phases, BS(EN), Type, Rating, A
Nominal voltage, V, RCD BS(EN), Type, Rating, IΔn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors (L/N, CPC), Maximum disconnection time (S), Overcurrent protective devices (BS EN Number, Type No., Rating), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., IΔn, Rating)

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Client Postcode</b> EC4R 9AB
<b>Installation Postcode</b> SA1 8EN	

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location <input type="text" value="Room 5 Riser Schneider"/>	Associated RCD (if any): BS (EN) <input type="text" value="N/A"/>	Z <sub>db</sub> <input type="text" value="0.40"/> Ω	Operating at IΔn <input type="text" value="28.4"/> ms
Designation <input type="text" value="DB CL 3/5"/>			
No. of ways <input type="text" value="1"/> <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub> <input type="text" value="0.58"/> kA No. of poles <input type="text" value="N/A"/>		Time delay (if applicable) <input type="text" value="N/A"/>
No. of phases <input type="text" value="1"/> SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable			

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation			
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V			L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.25	N/A	250	>999	>999	✓	0.68	N/A	N/A	N/A
2/L2	N/A	N/A	N/A	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing					Date(s) dead testing <input type="text" value="01/08/2023"/> To <input type="text" value="01/08/2023"/>				
<input style="width:100%;" type="text"/>					Date(s) live testing <input type="text" value="01/08/2023"/> To <input type="text" value="01/08/2023"/>				
Test instrument serial number(s)									
Loop impedance	<input type="text" value="102133109"/>	Insulation resistance	<input type="text" value="102133109"/>	Continuity	<input type="text" value="102133109"/>	RCD	<input type="text" value="102133109"/>	E/Electrode	<input type="text" value="102133109"/>
Tested by: Name (capital letters)				<input type="text" value="PETER HUGHES"/>	Signature				
Position				<input type="text" value="Electrical Test Engineer"/>	Date		<input type="text" value="01/08/2023"/>		

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London		<b>Postcode</b>
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>				<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			
SPD Details: Type(s)*	T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit:		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 3, 7/L2)"/>			
Location	<input type="text" value="Room 6 Riser Schneider"/>	No. of phases	<input type="text" value="1"/>	BS(EN)	<input type="text" value="61009 RCD/RCBO"/>	Type	<input type="text" value="B"/>
Designation	<input type="text" value="DB CL 3/6"/>	Nominal voltage	<input type="text" value="230"/>	V	RCD BS(EN)	<input type="text" value="N/A"/>	Rating
No. of ways	<input type="text" value="1"/>				Type	<input type="text" value="N/A"/>	Rating
							Δn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD				
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)	
1/L2	Room 6 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	80%	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>
Location: Room 6 Riser Schneider	Associated RCD (if any): BS (EN) N/A
Designation: DB CL 3/6	Z <sub>db</sub> : 0.36 Ω Operating at I $\Delta$ n: 28.6 ms
No. of ways: 1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub> : 0.68 kA No. of poles: N/A Time delay (if applicable): N/A
No. of phases: 1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable	

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation	
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				All RCDs I $\Delta$ n ms	RCD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.23	N/A	250	>999	>999	✓	0.63	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 01/08/2023 To: 01/08/2023

Date(s) live testing: 01/08/2023 To: 01/08/2023

Test instrument serial number(s):

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 01/08/2023

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd  
Client Address: First Floor, 12 Arthur Street London  
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea  
Client Postcode: EC4R 9AB  
Postcode: SA1 8EN  
Distribution board details - Complete in every case  
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]  
Location: Room 7 Riser Schneider  
Designation: DB CL 3/7  
No. of ways: 1  
Complete only if the distribution board is not connected directly to the origin of the installation  
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 3, 7/L2)  
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating [ ] Idn mA

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other 80% Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Idn (mA)	Rating (A)
1/L2	Room 7 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Room 8 Riser Schneider Designation DB CL 3/8 No. of ways 1		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 3, 7/L2) No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating In mA
--	--	---

SCHEDULE OF CIRCUIT DETAILS																
Circuit No. and Line	Circuit designation	Type of wiring	Ref. method <small>j.i.</small>	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § <input type="checkbox"/> 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	In (mA)	Rating (A)
1/L2	Room 8 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd		<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB	<b>Installation Postcode</b>	SA1 8EN
<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		
Location	Room 8 Riser Schneider		Associated RCD (if any):	BS (EN) N/A	
Designation	DB CL 3/8		Z <sub>db</sub>	Ω Operating at IΔn 28.6 ms	
No. of ways	1	<input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub>	0.68 kA No. of poles N/A Time delay (if applicable) N/A	
No. of phases	1	SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable			

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation			
	Ring final circuits only			R1R2 or R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			All RCDs IΔn ms	RCD (✓)	AFDD (✓)		
	r1	r <sub>m</sub>	r2										R1 + R2	R2
1/L2	N/A	N/A	N/A	N/A	0.29	N/A	250	>999	>999	✓	0.68	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing					Date(s) dead testing		01/08/2023 To 01/08/2023		
					Date(s) live testing		01/08/2023 To 01/08/2023		
					Test instrument serial number(s)				
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109	RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES				Signature				
Position	Electrical Test Engineer	Date	01/08/2023						



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 4 Kitchen Schneider Designation DB CL 4 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 2/L3) No. of phases 1 BS(EN) Type Rating A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L3	Lights Rooms 1, 2	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L3	Lights Rooms 3, 4	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L3	Lights Rooms 5, 6	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L3	Lights Rooms 7, 8	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
6/L3	Sub Mains(DB CL 4/2, DB CL 4/1)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L3	Sub Mains(DB CL 4/4, DB CL 4/3)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
8/L3	Sub Mains(DB CL 4/8, DB CL 4/7)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L3	Sub Mains(DB CL 4/6, DB CL 4/5)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L3	Sockets Kitchen LHS	A3	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L3	Sockets Kitchen RHS	A3	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L3	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L3	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 4 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 4	Z <sub>db</sub>	0.09 Ω Operating at IΔn _____ ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	2.57 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation				
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2									
1/L3	N/A	N/A	N/A	N/A	0.49	N/A	250	>999	>999	✓	0.63	28.6	✓	N/A	
2/L3	N/A	N/A	N/A	N/A	0.66	N/A	250	>999	>999	✓	0.79	28.8	✓	N/A	
3/L3	N/A	N/A	N/A	N/A	0.59	N/A	250	>999	>999	✓	0.75	28.6	✓	N/A	
4/L3	N/A	N/A	N/A	N/A	0.57	N/A	250	>999	>999	✓	0.67	28.2	✓	N/A	
5/L3	N/A	N/A	N/A	N/A	0.68	N/A	250	>999	>999	✓	0.79	28.4	✓	N/A	
6/L3	0.35	0.34	0.55	✓	0.23	N/A	250	>999	>999	✓	0.37	28.6	✓	N/A	
7/L3	0.41	0.40	0.67	✓	0.27	N/A	250	>999	>999	✓	0.38	28.2	✓	N/A	
8/L3	0.39	0.37	0.60	✓	0.25	N/A	250	>999	>999	✓	0.36	28.4	✓	N/A	
9/L3	0.45	0.46	0.72	✓	0.29	N/A	250	>999	>999	✓	0.40	28.8	✓	N/A	
10/L3	0.28	0.28	0.44	✓	0.18	N/A	250	>999	>999	✓	0.29	28.9	✓	N/A	
11/L3	0.33	0.31	0.47	✓	0.20	N/A	250	>999	>999	✓	0.31	28.0	✓	N/A	
12/L3	N/A	N/A	N/A	N/A	0.14	N/A	250	>999	>999	✓	0.26	29.2	✓	N/A	
13/L3	N/A	N/A	N/A	N/A	0.12	N/A	250	>999	>999	✓	0.23	28.6	✓	N/A	
14/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	02/08/2023	To	02/08/2023
		Date(s) live testing	02/08/2023	To	02/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position		Electrical Test Engineer		Date	
		02/08/2023			

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

## for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Postcode</b> SA1 8EN
<b>Client Postcode</b> EC4R 9AB	

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Room 1 Riser Schneider Designation DB CL 4/1 No. of ways 1	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 4, 6/L3) No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA
--	--

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 1 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Client Postcode</b> EC4R 9AB	<b>Installation Postcode</b> SA1 8EN

**Distribution board details - Complete in every case**

Location Room 1 Riser Schneider  
Designation DB CL 4/1

No. of ways 1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub> 0.37  $\Omega$  Operating at I $\Delta$ n 28.6 ms  
I<sub>pr</sub> 0.62 kA No. of poles N/A Time delay (if applicable) N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> ( $\Omega$ )	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 check ( $\checkmark$ )	R1R2 or R2		Test voltage V	L/L, L/N M( $\Omega$ )			L/E, N/E M( $\Omega$ )	All RCDs I $\Delta$ n ms	RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L3	N/A	N/A	N/A	N/A	0.23	N/A	250	>999	>999	$\checkmark$	0.62	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing 01/08/2023 To 01/08/2023  
Date(s) live testing 01/08/2023 To 01/08/2023

Test instrument serial number(s)

Loop impedance 102133109 Insulation resistance 102133109 Continuity 102133109 RCD 102133109 E/Electrode 102133109

Tested by: Name (capital letters) PETER HUGHES Signature Position Electrical Test Engineer Date 01/08/2023

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 2 Riser Schneider
Designation: DB CL 4/2
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 4, 6/L3)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location:

Designation:

No. of ways:   Supply polarity confirmed  Phase sequence confirmed

No. of phases:  SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)

Z<sub>db</sub>:  Ω Operating at IΔn  ms

I<sub>pf</sub>:  kA No. of poles:  Time delay (if applicable):

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N			L/E, N/E	All RCDs IΔn ms	RCD	AFDD
	r1	r <sub>m</sub>	r2		R1 + R2	R2		M(Ω)			M(Ω)		(✓)	(✓)
1/L3	N/A	N/A	N/A	N/A	0.20	N/A	250	>999	>999	✓	0.59	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing:  To:

Date(s) live testing:  To:

Test instrument serial number(s)

Loop impedance:  Insulation resistance:  Continuity:  RCD:  E/Electrode:

Tested by: Name (capital letters)  Signature:

Position:  Date:

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 3 Riser Schneider
Designation: DB CL 4/3
No. of ways: 1

SCHEDULE OF CIRCUIT DETAILS

Table with 14 columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω), RCD (BS EN Number, Type No., In (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 3 Riser Schneider  
 Designation: DB CL 4/3

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.38 Ω Operating at IΔn: 28.2 ms  
 I<sub>pr</sub>: 0.60 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation			
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V			L/L, L/N	L/E, N/E	All RCDs IΔn ms	RCD	AFDD
	r1	r <sub>m</sub>	r2		R1 + R2	R2				M(Ω)	M(Ω)		(✓)	(✓)
1/L3	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	✓	0.67	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 02/08/2023 To 02/08/2023  
 Date(s) live testing: 02/08/2023 To 02/08/2023

Test instrument serial number(s)

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature: *Peter Hughes*  
 Position: Electrical Test Engineer Date: 02/08/2023



ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 4 Riser Schneider
Designation: DB CL 4/4
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 4, 7/L3)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω) (80%), RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Client Postcode: EC4R 9AB
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 4 Riser Schneider
Designation: DB CL 4/4
No. of ways: 1
No. of phases: 1
SPD: [ ] Operational status confirmed [x] Not applicable
Complete only if the distribution board is not connected directly to the origin of the installation
Associated RCD (if any): BS (EN) N/A
Zdb: 0.38
Operating at IΔn: 28.2 ms
Ipf: 0.61 kA No. of poles: N/A Time delay (if applicable): N/A

TEST RESULTS

Table with 15 columns: Circuit No. and Line, Ring final circuits only (r1, m, r2), Fig 8 check, R1R2 or R2 (R1+R2, R2), Insulation resistance (Test voltage, L/L, L/N, L/E, N/E), Polarity, Max. Measured Zs, RCD testing (All RCDs IΔn), Manual test button operation (RCD, AFDD). Row 1/L3 shows N/A for r1, m, r2; Fig 8 check N/A; R1+R2 0.19, R2 N/A; Test voltage 250V; L/L, L/N >999MΩ; L/E, N/E >999MΩ; Polarity ✓; Max. Measured Zs 0.59Ω; All RCDs IΔn N/A; RCD N/A; AFDD N/A.

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 02/08/2023 To 02/08/2023
Date(s) live testing: 02/08/2023 To 02/08/2023
Test instrument serial number(s):
Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109
Tested by: Name (capital letters) PETER HUGHES Signature: [Handwritten Signature]
Position: Electrical Test Engineer Date: 02/08/2023

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 5 Riser Schneider
Designation: DB CL 4/5
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 4, 9/L3)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (BS 7671), Overcurrent protective devices, Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD, Rating (A).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd, Client Address: First Floor, 12 Arthur Street London, Client Postcode: EC4R 9AB, Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, Installation Postcode: SA1 8EN

Distribution board details - Complete in every case. Location: Room 5 Riser Schneider, Designation: DB CL 4/5, No. of ways: 1, No. of phases: 1, SPD: Not applicable, Complete only if the distribution board is not connected directly to the origin of the installation: Associated RCD: N/A, Zdb: 0.40, Operating at IΔn: 28.8 ms, Ipr: 0.57 kA, No. of poles: N/A, Time delay: N/A

TEST RESULTS

Table with columns: Circuit No. and Line, Circuit impedance Ω (Ring final circuits only: r1, r, r2; R1R2 or R2: R1+R2, R2), Insulation resistance (Record lower reading): Test voltage V, L/L, L/N M(Ω), L/E, N/E M(Ω), Polarity, Max. Measured Zs (Ω), RCD testing: All RCDs IΔn ms, Manual test button operation: RCD (✓), AFDD (✓). Row 1/L3: N/A, N/A, N/A, N/A, 0.23, N/A, 250, >999, >999, ✓, 0.68, N/A, N/A, N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: [Empty], Date(s) dead testing: 02/08/2023 To 02/08/2023, Date(s) live testing: 02/08/2023 To 02/08/2023, Test instrument serial number(s): [Empty], Loop impedance: 102133109, Insulation resistance: 102133109, Continuity: 102133109, RCD: 102133109, E/Electrode: 102133109, Tested by: Name (capital letters): PETER HUGHES, Position: Electrical Test Engineer, Date: 02/08/2023, Signature: [Handwritten Signature]

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 6 Riser Schneider
Designation: DB CL 4/6
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 4, 9/L3)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating), and others.

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Room 6 Riser Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 4/6	Z <sub>db</sub>	0.40 Ω Operating at IΔn 28.8 ms
No. of ways	1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	0.56 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)				Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation	
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms			RCD (✓)	AFDD (✓)	
	r1	r <sub>m</sub>	r2											
1/L3	N/A	N/A	N/A	N/A	0.19	N/A	250	>999	>999	✓	0.64	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing 02/08/2023 To 02/08/2023	
		Date(s) live testing 02/08/2023 To 02/08/2023	
Test instrument serial number(s)	Loop impedance 102133109	Insulation resistance 102133109	Continuity 102133109
		RCD 102133109	E/Electrode 102133109
Tested by: Name (capital letters)	PETER HUGHES		Signature
Position	Electrical Test Engineer	Date	02/08/2023

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3 N/A
Location: Room 7 Riser Schneider
Designation: DB CL 4/7
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 4, 8/L3)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) L/N, CPC, Maximum disconnection time (s), Overcurrent protective devices BS EN Number, Type No., Rating (A), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD BS EN Number, Type No., IΔn (mA), Rating (A)

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 7 Riser Schneider
Designation: DB CL 4/7
No. of ways: 1
No. of phases: 1
SPD: [ ] Operational status confirmed [x] Not applicable
Associated RCD (if any): BS (EN) N/A
Zdb: 0.36
Operating at IΔn: 28.4 ms
Ipf: 0.63 kA
No. of poles: N/A
Time delay (if applicable): N/A

TEST RESULTS

Table with columns: Circuit No. and Line, Circuit impedance Ω (Ring final circuits only: r1, m, r2; R1R2 or R2: R1+R2, R2), Insulation resistance (Record lower reading): Test voltage V, L/L, L/N M(Ω), L/E, N/E M(Ω), Polarity, Max. Measured Zs (Ω), RCD testing: All RCDs IΔn ms, Manual test button operation: RCD (✓), AFDD (✓). Row 1: 1/L3, N/A, N/A, N/A, N/A, 0.23, N/A, 250, >999, >999, ✓, 0.61, N/A, N/A, N/A.

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 02/08/2023 To 02/08/2023
Date(s) live testing: 02/08/2023 To 02/08/2023
Test instrument serial number(s)
Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109
Tested by: Name (capital letters): PETER HUGHES Signature: [Signature]
Position: Electrical Test Engineer Date: 02/08/2023



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR **2670000213307**

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Room 8 Riser Schneider Designation DB CL 4/8 No. of ways 1			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 4, 8/L3) No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA		
--	--	--	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 8 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 8 Riser Schneider  
 Designation: DB CL 4/8  
 No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.36 Ω Operating at I $\Delta$ n 28.4 ms  
 I<sub>pr</sub>: 0.63 kA No. of poles N/A Time delay (if applicable) N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs I $\Delta$ n ms	Manual test button operation		
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)				L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L3	N/A	N/A	N/A	N/A	0.20	N/A	250	>999	>999	✓	0.58	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing 02/08/2023 To 02/08/2023  
 Date(s) live testing 02/08/2023 To 02/08/2023

Test instrument serial number(s)

Loop impedance 102133109 Insulation resistance 102133109 Continuity 102133109 RCD 102133109 E/Electrode 102133109

Tested by: Name (capital letters) PETER HUGHES Signature

Position Electrical Test Engineer Date 02/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 5 Kitchen Schneider Designation DB CL 5 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 3/L1) No. of phases 1 BS(EN) Type Rating A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L1	Lights Rooms 1,2, 3	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L1	Lights Rooms 7, 8	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L1	Lights Rooms 4, 5	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Sub Mains(DB CL 5/3, DB CL 5/1, DB CL 5/2)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L1	Sub Mains(DB CL 5/8, DB CL 5/6, DB CL 5/7)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	16
8/L1	Sub Mains(DB CL 5/5, DB CL 5/4)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L1	Sockets Kitchen LHS	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L1	Sockets Kitchen RHS	A3	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L1	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L1	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 5 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 5	Z <sub>db</sub>	0.09 Ω Operating at IΔn _____ ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	2.62 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation			
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.31	N/A	250	>999	>999	✓	0.44	28.6	✓	N/A
2/L1	N/A	N/A	N/A	N/A	0.44	N/A	250	>999	>999	✓	0.63	28.2	✓	N/A
3/L1	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	✓	0.52	28.4	✓	N/A
4/L1	N/A	N/A	N/A	N/A	0.51	N/A	250	>999	>999	✓	0.74	28.2	✓	N/A
5/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	0.31	0.32	0.48	✓	0.20	N/A	250	>999	>999	✓	0.29	28.6	✓	N/A
7/L1	0.33	0.34	0.52	✓	0.21	N/A	250	>999	>999	✓	0.34	28.8	✓	N/A
8/L1	0.43	0.42	0.70	✓	0.28	N/A	250	>999	>999	✓	0.39	28.4	✓	N/A
9/L1	0.28	0.29	0.44	✓	0.18	N/A	250	>999	>999	✓	0.31	28.8	✓	N/A
10/L1	0.30	0.30	0.45	✓	0.19	N/A	250	>999	>999	✓	0.29	28.6	✓	N/A
11/L1	N/A	N/A	N/A	N/A	0.14	N/A	250	>999	>999	✓	0.23	28.4	✓	N/A
12/L1	N/A	N/A	N/A	N/A	0.12	N/A	250	>999	>999	✓	0.21	28.6	✓	N/A
13/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	02/08/2023	To	02/08/2023
		Date(s) live testing	02/08/2023	To	02/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES		Signature		
Position	Electrical Test Engineer	Date	02/08/2023		

for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



**Client Name** UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea  
**Client Address** First Floor, 12 Arthur Street London **Postcode** SA1 8EN  
**Client Postcode** EC4R 9AB

**Distribution board details - Complete in every case**  
 SPD Details: Type(s)\* T1  T2  T3  N/A   
 Location Room 1 Riser Schneider  
 Designation DB CL 5/1  
 No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**  
 Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 5, 6/L1)  
 No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
 Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § (Ω) 80%	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 1 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 1 Riser Schneider  
 Designation: DB CL 5/1  
 No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.29 Ω Operating at I<sub>Δn</sub>: 28.6 ms  
 I<sub>pf</sub>: 0.79 kA No. of poles: N/A Time delay (if applicable): N/A

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs I <sub>Δn</sub> ms	Manual test button operation		
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFDD (✓)	
	r1	r2	r3											
				R1 + R2	R2									
1/L1	N/A	N/A	N/A	N/A	0.27	N/A	250	>999	>999	✓	0.58	N/A	N/A	N/A

**Details of circuits and/or installed equipment vulnerable to damage when testing**  
 Date(s) dead testing: 02/08/2023 To 02/08/2023  
 Date(s) live testing: 02/08/2023 To 02/08/2023

Test instrument serial number(s):  
 Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature: [Signature]  
 Position: Electrical Test Engineer Date: 02/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Room 2 Riser Schneider Designation DB CL 5/2 No. of ways 1		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 5, 6/L1) No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
--	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD				
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)	
1/L1	Room 2 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	80%	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 2 Riser Schneider
Designation: DB CL 5/2
No. of ways: 1
No. of phases: 1
SPD: Operational status confirmed
Complete only if the distribution board is not connected directly to the origin of the installation
Associated RCD (if any): BS (EN)
Zdb: 0.29
Ipf: 0.77 kA

TEST RESULTS

Table with 15 columns: Circuit No. and Line, Ring final circuits only (r1, m, r2), Fig 8 check, R1R2 or R2, Test voltage, L/L, L/N, L/E, N/E, Polarity, Max. Measured Zs, RCD testing, Manual test button operation. Row 1/L1 shows test results for a single circuit.

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 02/08/2023 To 02/08/2023
Date(s) live testing: 02/08/2023 To 02/08/2023
Test instrument serial number(s)
Loop impedance: 102133109
Insulation resistance: 102133109
Continuity: 102133109
RCD: 102133109
E/Electrode: 102133109
Tested by: Name (capital letters): PETER HUGHES
Position: Electrical Test Engineer
Date: 02/08/2023
Signature: [Handwritten Signature]





for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 3 Riser Schneider
Designation: DB CL 5/3
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 5, 6/L1)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A IDn mA

SCHEDULE OF CIRCUIT DETAILS

Table with 14 columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s) (BS 7671), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω) (80%), RCD (BS EN Number, Type No., IDn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd		<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB	<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 3 Riser Schneider  
Designation: DB CL 5/3

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub>: 0.29 Ω Operating at I<sub>Δn</sub>: 28.6 ms  
I<sub>pf</sub>: 0.79 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	All RCDs I <sub>Δn</sub> ms	RCD (✓)	AFDD (✓)
	r1	m	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.23	N/A	250	>999	>999	✓	0.55	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 02/08/2023 To 02/08/2023  
Date(s) live testing: 02/08/2023 To 02/08/2023

Test instrument serial number(s)

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters): PETER HUGHES Position: Electrical Test Engineer Date: 02/08/2023

Signature:

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



**Client Name** UPP Residential Services Ltd      **Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea

**Client Address** First Floor, 12 Arthur Street London      **Postcode** SA1 8EN

**Client Postcode** EC4R 9AB

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3+  N/A

Location

Designation

No. of ways

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from

No. of phases  BS(EN)  Type  Rating  A

Nominal voltage  V RCD BS(EN)  Type  Rating  IΔn mA

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § <input type="text" value="80%"/> (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 4 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 4 Riser Schneider
Designation: DB CL 5/4
No. of ways: 1
No. of phases: 1
Associated RCD: BS (EN) N/A
Zdb: 0.39 Ohms
Ipf: 0.58 kA

TEST RESULTS

Table with 15 columns: Circuit No. and Line, Ring final circuits only (r1, m, r2), Fig 8 check, R1R2 or R2 (R1+R2, R2), Test voltage (V), Insulation resistance (M(Omega)), L/L, L/N (M(Omega)), L/E, N/E (M(Omega)), Polarity, Max. Measured Zs (Ohms), RCD testing (All RCDs Idn ms), Manual test button operation (RCD, AFDD).

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 02/08/2023 To 02/08/2023
Date(s) live testing: 02/08/2023 To 02/08/2023
Test instrument serial number(s):
Loop impedance: 102133109
Insulation resistance: 102133109
Continuity: 102133109
RCD: 102133109
E/Electrode: 102133109
Tested by: Name (capital letters): PETER HUGHES
Position: Electrical Test Engineer
Date: 02/08/2023
Signature: [Handwritten Signature]

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 6 Riser Schneider
Designation: DB CL 5/6
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 5, 7/L1)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω), RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

**Client Name** UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea

**Client Address** First Floor, 12 Arthur Street London **Postcode** SA1 8EN

**Client Postcode** EC4R 9AB

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3+  N/A

Location Room 5 Riser Schneider

Designation DB CL 5/5

No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 5, 8/L1)

No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A

Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method <sup>j</sup> :	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (s) (BS 7671)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 5 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 §: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR **2670000213307**

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Client Postcode</b> EC4R 9AB
<b>Installation Postcode</b> SA1 8EN	

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>
Location: Room 5 Riser Schneider	Associated RCD (if any): BS (EN) N/A
Designation: DB CL 5/5	Z <sub>db</sub> : 0.39 Ω Operating at I <sub>Δn</sub> : 28.4 ms
No. of ways: 1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub> : 0.58 kA No. of poles: N/A Time delay (if applicable): N/A
No. of phases: 1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable	

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation			
	Ring final circuits only			R1R2 or R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				All RCDs I <sub>Δn</sub> ms	RCD (✓)	AFDD (✓)	
	r1	r2	r3											
1/L1	N/A	N/A	N/A	N/A	0.31	N/A	250	>999	>999	✓	0.73	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing	Date(s) dead testing: 02/08/2023 To 02/08/2023
	Date(s) live testing: 02/08/2023 To 02/08/2023
Test instrument serial number(s)	
Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109	
Tested by: Name (capital letters): PETER HUGHES Signature: [Signature]	
Position: Electrical Test Engineer Date: 02/08/2023	



for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street, London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3 [ ] N/A [x]
Location: Room 7 Riser Schneider
Designation: DB CL 5/7
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 5, 7/L1)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating (A)). Row 1: 1/L1, Room 7 Sockets, A3, B, 6, 2.5/1.5, 0.4, 60898 MCB, B, 10, 10, 3.49, N/A, N/A, N/A, N/A.

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

for Industrial/Commercial Premises

Requirements for Electrical Installations  
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address	First Floor, 12 Arthur Street London	Client Postcode	EC4R 9AB
Installation Postcode	SA1 8EN		

**Distribution board details - Complete in every case**

Location: Room 7 Riser Schneider  
 Designation: DB CL 5/7

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.34 Ω Operating at IΔn: 28.8 ms  
 I<sub>prf</sub>: 0.67 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation		
	Ring final circuits only			Eg & R check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.30	N/A	250	>999	>999	✓	0.67	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 02/08/2023 To: 02/08/2023  
 Date(s) live testing: 02/08/2023 To: 02/08/2023

Test instrument serial number(s):  
 Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:   
 Position: Electrical Test Engineer Date: 02/08/2023

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		
SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>		Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 5, 7/L1)"/>		
Location: <input type="text" value="Room 8 Riser Schneider"/>		No. of phases: <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type: <input type="text" value="B"/> Rating: <input type="text" value="32"/> A		
Designation: <input type="text" value="DB CL 5/8"/>		Nominal voltage: <input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type: <input type="text" value="N/A"/> Rating: <input type="text" value="N/A"/> IΔn mA		
No. of ways: <input type="text" value="1"/>				

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other <input type="text" value="80%"/> Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 8 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 6 Kitchen Schneider Designation DB CL 6 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 4/L1) No. of phases 1 BS(EN) Type Rating A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L1	Lights Rooms 1,2	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L1	Lights Rooms 3, 4	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L1	Lights Rooms 5, 6	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L1	Lights Rooms 7, 8	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
6/L1	Sub Mains(DB CL 6/2, DB CL 6/1)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L1	Sub Mains(DB CL 6/4, DB CL 6/3)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
8/L1	Sub Mains(DB CL 6/8, DB CL 6/7)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L1	Sub Mains(DB CL 6/5, DB CL 6/6)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L1	Sockets Kitchen LHS	A3	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L1	Sockets Kitchen RHS	A3	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L1	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L1	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 6 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 6	Z <sub>db</sub>	0.10 Ω Operating at IΔn _____ ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	2.27 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation			
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.53	N/A	250	>999	>999	✓	0.67	28.6	✓	N/A
2/L1	N/A	N/A	N/A	N/A	0.64	N/A	250	>999	>999	✓	0.76	28.8	✓	N/A
3/L1	N/A	N/A	N/A	N/A	0.66	N/A	250	>999	>999	✓	0.79	28.6	✓	N/A
4/L1	N/A	N/A	N/A	N/A	0.69	N/A	250	>999	>999	✓	0.82	28.2	✓	N/A
5/L1	N/A	N/A	N/A	N/A	0.58	N/A	250	>999	>999	✓	0.70	28.4	✓	N/A
6/L1	0.35	0.34	0.55	✓	0.23	N/A	250	>999	>999	✓	0.34	28.6	✓	N/A
7/L1	0.41	0.40	0.67	✓	0.27	N/A	250	>999	>999	✓	0.39	28.2	✓	N/A
8/L1	0.39	0.37	0.60	✓	0.25	N/A	250	>999	>999	✓	0.36	28.4	✓	N/A
9/L1	0.45	0.46	0.72	✓	0.29	N/A	250	>999	>999	✓	0.41	28.8	✓	N/A
10/L1	0.28	0.28	0.44	✓	0.18	N/A	250	>999	>999	✓	0.30	28.9	✓	N/A
11/L1	0.33	0.31	0.47	✓	0.20	N/A	250	>999	>999	✓	0.32	28.0	✓	N/A
12/L1	N/A	N/A	N/A	N/A	0.13	N/A	250	>999	>999	✓	0.25	29.2	✓	N/A
13/L1	N/A	N/A	N/A	N/A	0.12	N/A	250	>999	>999	✓	0.24	28.6	✓	N/A
14/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	02/08/2023	To	02/08/2023
		Date(s) live testing	02/08/2023	To	02/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position		Electrical Test Engineer		Date	
				02/08/2023	

for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3+ <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location <input type="text" value="Room 1 Riser Schneider"/> Designation <input type="text" value="DB CL 6/1"/> No. of ways <input type="text" value="1"/>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 6, 6/L1)"/> No. of phases <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A Nominal voltage <input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA	
--	--	---	--

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method <small>:j</small>	No. of points served	Circuit conductors <small>csa (mm²)</small>		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs <small>Other Other §</small> 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 1 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 1 Riser Schneider  
 Designation: DB CL 6/1

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 $Z_{db}$ : 0.34  $\Omega$  Operating at  $I_{\Delta n}$ : 28.6 ms  
 $I_{pf}$ : 0.66 kA No. of poles: N/A Time delay (if applicable): N/A

## TEST RESULTS

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)			Polarity	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing	Manual test button operation			
	Ring final circuits only			Fig 8 Check ( $\checkmark$ )	R1R2 or R2		Test voltage V			L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	All RCDs $I_{\Delta n}$ ms	RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )
	r1	r	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.19	N/A	250	>999	>999	$\checkmark$	0.55	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 02/08/2023 To 02/08/2023  
 Date(s) live testing: 02/08/2023 To 02/08/2023

Test instrument serial number(s):  
 Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature: [Signature]  
 Position: Electrical Test Engineer Date: 02/08/2023



ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1, T2, T3, N/A
Location: Room 2 Riser Schneider
Designation: DB CL 6/2
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 6, 6/L1)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns for Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm^2), Maximum disconnection time (BS 7671), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
<b>Installation Postcode</b>	SA1 8EN		

**Distribution board details - Complete in every case**

Location: Room 2 Riser Schneider  
Designation: DB CL 6/2

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed

No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub> 0.34 Ω Operating at I<sub>Δn</sub> 28.6 ms  
 I<sub>pf</sub> 0.67 kA No. of poles N/A Time delay (if applicable) N/A

TEST RESULTS

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation		
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V			L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs I <sub>Δn</sub> ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.23	N/A	250	>999	>999	✓	0.61	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing 03/08/2023 To 03/08/2023  
 Date(s) live testing 03/08/2023 To 03/08/2023

Test instrument serial number(s)

Loop impedance 102133109 Insulation resistance 102133109 Continuity 102133109 RCD 102133109 E/Electrode 102133109

Tested by: Name (capital letters) PETER HUGHES Signature

Position Electrical Test Engineer Date 03/08/2023

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

**Client Name** UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea

**Client Address** First Floor, 12 Arthur Street London **Postcode** SA1 8EN

**Client Postcode** EC4R 9AB

---

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3  N/A

Location Room 3 Riser Schneider

Designation DB CL 6/3

No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 6, 7/L1)

No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A

Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD				
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)	
1/L1	Room 3 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	80%	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**FT/EICR **2670000213307**

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 3 Riser Schneider  
Designation: DB CL 6/3

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub>: 0.39 Ω Operating at I<sub>Δn</sub>: 28.2 ms  
I<sub>pf</sub>: 0.58 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N			L/E, N/E	All RCDs I <sub>Δn</sub> ms	RCD	AFDD
	r1	m	r2		R1 + R2	R2		M(Ω)			M(Ω)		(✓)	(✓)
1/L1	N/A	N/A	N/A	N/A	0.25	N/A	250	>999	>999	✓	0.68	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 03/08/2023 To 03/08/2023  
Date(s) live testing: 03/08/2023 To 03/08/2023

Test instrument serial number(s)

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters): PETER HUGHES Signature: *Peter Hughes*  
Position: Electrical Test Engineer Date: 03/08/2023

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3 N/A
Location: Room 4 Riser Schneider
Designation: DB CL 6/4
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 6, 7/L1)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm^2) L/N, CPC, Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., IΔn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

for Industrial/Commercial Premises

Requirements for Electrical Installations  
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 4 Riser Schneider  
 Designation: DB CL 6/4

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 $Z_{db}$  0.39  $\Omega$  Operating at  $I_{\Delta n}$  28.2 ms  
 $I_{pf}$  0.58 kA No. of poles N/A Time delay (if applicable) N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 check ( $\checkmark$ )	R1R2 or R2		Test voltage V	L/L, L/N			L/E, N/E	All RCDs $I_{\Delta n}$ ms	RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )
	r1	m	r2		R1 + R2	R2		M( $\Omega$ )			M( $\Omega$ )			
1/L1	N/A	N/A	N/A	N/A	0.24	N/A	250	>999	>999	$\checkmark$	0.66	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 03/08/2023 To 03/08/2023  
 Date(s) live testing: 03/08/2023 To 03/08/2023

Test instrument serial number(s)

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature   
 Position: Electrical Test Engineer Date: 03/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

**FT/EICR 2670000213307**

*for Industrial/Commercial Premises*



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3  N/A

Location: Room 5 Riser Schneider

Designation: DB CL 6/5

No. of ways: 1

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 6, 9/L1)

No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A

Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 5 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.

t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)

:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.

§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Client Postcode: EC4R 9AB
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 5 Riser Schneider
Designation: DB CL 6/5
No. of ways: 1
No. of phases: 1
SPD: Operational status confirmed
Complete only if the distribution board is not connected directly to the origin of the installation
Associated RCD (if any): BS (EN) N/A
Zdb: 0.41 Ohm
Operating at IΔn: 28.8 ms
Ipf: 0.55 kA
No. of poles: N/A
Time delay (if applicable): N/A

TEST RESULTS

Table with columns: Circuit No. and Line, Circuit impedance Ω (Ring final circuits only, R1R2 or R2), Insulation resistance (Record lower reading), Polarity, Max. Measured Zs (Ω), RCD testing, Manual test button operation. Row 1/L1 contains test data.

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 03/08/2023 To 03/08/2023
Date(s) live testing: 03/08/2023 To 03/08/2023
Test instrument serial number(s)
Loop impedance: 102133109
Insulation resistance: 102133109
Continuity: 102133109
RCD: 102133109
E/Electrode: 102133109
Tested by: Name (capital letters): PETER HUGHES
Position: Electrical Test Engineer
Date: 03/08/2023
Signature: [Handwritten Signature]





**for Industrial/Commercial Premises**

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	<input type="text" value="UPP Residential Services Ltd"/>	<b>Installation Address</b>	<input type="text" value="Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea"/>
<b>Client Address</b>	<input type="text" value="First Floor, 12 Arthur Street London"/>		<b>Postcode</b>
<b>Client Postcode</b>	<input type="text" value="EC4R 9AB"/>		

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>
SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 6, 9/L1)"/>
Location <input type="text" value="Room 6 Riser Schneider"/>	No. of phases <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A
Designation <input type="text" value="DB CL 6/6"/>	Nominal voltage <input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA
No. of ways <input type="text" value="1"/>	

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § <input type="text" value="80%"/> (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 6 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b> UPP Residential Services Ltd		<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b> First Floor, 12 Arthur Street London		<b>Client Postcode</b> EC4R 9AB	<b>Installation Postcode</b> SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location <input style="width: 300px;" type="text"/> Room 6 Riser Schneider	Associated RCD (if any):	BS (EN)	<input style="width: 150px;" type="text"/> N/A
Designation <input style="width: 300px;" type="text"/> DB CL 6/6	Z <sub>db</sub> <input style="width: 100px;" type="text"/> 0.41 Ω	Operating at IΔn	<input style="width: 100px;" type="text"/> 28.8 ms
No. of ways <input style="width: 50px;" type="text"/> 1	<input checked="" type="checkbox"/> Supply polarity confirmed	<input type="checkbox"/> Phase sequence confirmed	
No. of phases <input style="width: 50px;" type="text"/> 1	SPD: <input type="checkbox"/> Operational status confirmed	<input checked="" type="checkbox"/> Not applicable	I <sub>pr</sub> <input style="width: 50px;" type="text"/> 0.56 kA
		No. of poles	<input style="width: 50px;" type="text"/> N/A
		Time delay (if applicable)	<input style="width: 50px;" type="text"/> N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)				Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation	
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			All RCDs IΔn ms	RCD (✓)	AFDD (✓)	
	r1	r	r2		R1 + R2	R2									
1/L1	N/A	N/A	N/A	N/A	0.25	N/A	250	>999	>999	✓	0.68	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing				Date(s) dead testing <input style="width: 100px;" type="text"/> 03/08/2023 To <input style="width: 100px;" type="text"/> 03/08/2023	
				Date(s) live testing <input style="width: 100px;" type="text"/> 03/08/2023 To <input style="width: 100px;" type="text"/> 03/08/2023	
Test instrument serial number(s)					
Loop impedance	<input style="width: 100px;" type="text"/> 102133109	Insulation resistance	<input style="width: 100px;" type="text"/> 102133109	Continuity	<input style="width: 100px;" type="text"/> 102133109
		RCD	<input style="width: 100px;" type="text"/> 102133109	E/Electrode	<input style="width: 100px;" type="text"/> 102133109
Tested by: Name (capital letters)		<input style="width: 200px;" type="text"/> PETER HUGHES		Signature	
Position		<input style="width: 200px;" type="text"/> Electrical Test Engineer		Date <input style="width: 100px;" type="text"/> 03/08/2023	

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location <input type="text" value="Room 7 Riser Schneider"/> Designation <input type="text" value="DB CL 6/7"/> No. of ways <input type="text" value="1"/>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 6, 8/L1)"/> No. of phases <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A Nominal voltage <input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IDn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other <input type="checkbox"/> Other § <input type="checkbox"/> <input type="text" value="80%"/> (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 7 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
<b>Installation Postcode</b>	SA1 8EN		

**Distribution board details - Complete in every case**

Location:  Designation:

No. of ways:   Supply polarity confirmed  Phase sequence confirmed

No. of phases:  SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)

Z<sub>db</sub>:  Ω Operating at I<sub>Δn</sub>:  ms

I<sub>pr</sub>:  kA No. of poles:  Time delay (if applicable):

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs I <sub>Δn</sub> ms	Manual test button operation			
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2	Test voltage V	L/L, L/N M(Ω)				L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)	
	r1	m	r2											R1 + R2
1/L1	N/A	N/A	N/A	N/A	0.30	N/A	250	>999	>999	✓	0.71	N/A	N/A	N/A

**Details of circuits and/or installed equipment vulnerable to damage when testing**

Date(s) dead testing:  To:

Date(s) live testing:  To:

Test instrument serial number(s):

Loop impedance:  Insulation resistance:  Continuity:  RCD:  E/Electrode:

Tested by: Name (capital letters)  Signature:

Position:  Date:

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location <input type="text" value="Room 8 Riser Schneider"/>	Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 6, 8/L1)"/>		
Designation <input type="text" value="DB CL 6/8"/>	No. of phases <input type="text" value="1"/>	BS(EN) <input type="text" value="61009 RCD/RCBO"/>	Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A
No. of ways <input type="text" value="1"/>	Nominal voltage <input type="text" value="400"/> V RCD BS(EN) <input type="text" value="N/A"/>		Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA

SCHEDULE OF CIRCUIT DETAILS																
Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 8 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd; Client Address: First Floor, 12 Arthur Street, London; Installation Address: Swansea University Bay Campus; Client Postcode: EC4R 9AB; Installation Postcode: SA1 8EN

Distribution board details: Location: Room 8 Riser Schneider; Designation: DB CL 6/8; No. of ways: 1; Supply polarity confirmed; No. of phases: 1; SPD: Not applicable; Complete only if the distribution board is not connected directly to the origin of the installation

TEST RESULTS

Table with columns: Circuit No. and Line, Circuit impedance Ω, Insulation resistance (Record lower reading), Polarity, Max. Measured Zs (Ω), RCD testing, Manual test button operation. Row 1/L1 contains test data.

Details of circuits and/or installed equipment vulnerable to damage when testing; Test instrument serial number(s); Loop impedance; Insulation resistance; Continuity; RCD; E/Electrode; Tested by: Name (capital letters), Position, Date; Signature

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 7 Kitchen Schneider Designation DB CL 7 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 6/L2) No. of phases 1 BS(EN) Type Rating A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L2	Lights Rooms 1,2, 3	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L2	Lights Rooms 6,7, 8	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L2	Lights Rooms 4,5	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL 7/3, DB CL 7/1, DB CL 7/2)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L2	Sub Mains(DB CL 7/8, DB CL 7/6, DB CL 7/7)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
8/L2	Sub Mains(DB CL 7/5, DB CL 7/4)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L2	Sockets Kitchen LHS	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L2	Sockets Kitchen RHS	A3	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L2	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L2	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 7 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 7	Z <sub>db</sub>	0.10 Ω Operating at IΔn N/A ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	2.21 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation			
	Ring final circuits only			Efig 8 check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.47	N/A	250	>999	>999	✓	0.61	28.2	✓	N/A
2/L2	N/A	N/A	N/A	N/A	0.66	N/A	250	>999	>999	✓	0.78	28.6	✓	N/A
3/L2	N/A	N/A	N/A	N/A	0.59	N/A	250	>999	>999	✓	0.72	28.6	✓	N/A
4/L2	N/A	N/A	N/A	N/A	0.50	N/A	250	>999	>999	✓	0.62	28.8	✓	N/A
5/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	0.31	0.32	0.48	✓	0.20	N/A	250	>999	>999	✓	0.33	28.6	✓	N/A
7/L2	0.37	0.38	0.58	✓	0.24	N/A	250	>999	>999	✓	0.35	28.6	✓	N/A
8/L2	0.43	0.42	0.70	✓	0.28	N/A	250	>999	>999	✓	0.39	28.4	✓	N/A
9/L2	0.28	0.29	0.44	✓	0.18	N/A	250	>999	>999	✓	0.30	28.8	✓	N/A
10/L2	0.30	0.30	0.45	✓	0.19	N/A	250	>999	>999	✓	0.33	28.0	✓	N/A
11/L2	N/A	N/A	N/A	N/A	0.12	N/A	250	>999	>999	✓	0.24	28.8	✓	N/A
12/L2	N/A	N/A	N/A	N/A	0.13	N/A	250	>999	>999	✓	0.25	28.4	✓	N/A
13/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	03/08/2023	To	03/08/2023
		Date(s) live testing	03/08/2023	To	03/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position	Electrical Test Engineer	Date	03/08/2023		



# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> <input style="width:95%;" type="text" value="UPP Residential Services Ltd"/> <b>Client Address</b> <input style="width:95%;" type="text" value="First Floor, 12 Arthur Street London"/> <b>Client Postcode</b> <input style="width:95%;" type="text" value="EC4R 9AB"/>	<b>Installation Address</b> <input style="width:95%;" type="text" value="Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea"/> <b>Postcode</b> <input style="width:95%;" type="text" value="SA1 8EN"/>
--	---

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location <input style="width:95%;" type="text" value="Room 1 Riser Schneider"/> Designation <input style="width:95%;" type="text" value="DB CL 7/1"/> No. of ways <input style="width:95%;" type="text" value="1"/>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input style="width:95%;" type="text" value="Sub Mains(DB CL 7, 6/L2)"/> No. of phases <input style="width:95%;" type="text" value="1"/> BS(EN) <input style="width:95%;" type="text" value="61009 RCD/RCBO"/> Type <input style="width:95%;" type="text" value="B"/> Rating <input style="width:95%;" type="text" value="32"/> A Nominal voltage <input style="width:95%;" type="text" value="230"/> V RCD BS(EN) <input style="width:95%;" type="text" value="N/A"/> Type <input style="width:95%;" type="text" value="N/A"/> Rating <input style="width:95%;" type="text" value="N/A"/> Idn mA
---	--

SCHEDULE OF CIRCUIT DETAILS																
Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 1 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Client Postcode: EC4R 9AB
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 1 Riser Schneider
Designation: DB CL 7/1
No. of ways: 1
No. of phases: 1
SPD: Operational status confirmed
Not applicable
Complete only if the distribution board is not connected directly to the origin of the installation
Associated RCD (if any): BS (EN) N/A
Zdb: 0.33
Operating at Idn: 28.6 ms
Ipf: 0.68 kA
No. of poles: N/A
Time delay (if applicable): N/A

TEST RESULTS

Table with 15 columns: Circuit No. and Line, Ring final circuits only (r1, m, r2), Fig 8 check, R1R2 or R2 (R1+R2, R2), Insulation resistance (Test voltage, L/L, L/N, L/E, N/E), Polarity, Max. Measured Zs, RCD testing, Manual test button operation (RCD, AFDD).

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 01/08/2023 To 01/08/2023
Date(s) live testing: 01/08/2023 To 01/08/2023
Test instrument serial number(s)
Loop impedance: 102133109
Insulation resistance: 102133109
Continuity: 102133109
RCD: 102133109
E/Electrode: 102133109
Tested by: Name (capital letters): PETER HUGHES
Position: Electrical Test Engineer
Date: 01/08/2023
Signature: [Handwritten Signature]

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307



*for Industrial/Commercial Premises*

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>				<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			
SPD Details: Type(s)*	T1 <input type="checkbox"/>	T2 <input type="checkbox"/>	T3† <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit:	Supply to distribution board is from	Sub Mains(DB CL 7, 6/L2)
Location	Room 2 Riser Schneider			No. of phases	1	BS(EN)	61009 RCD/RCBO
Designation	DB CL 7/2			Type	B	Rating	32
No. of ways	1			Nominal voltage	230	RCD BS(EN)	N/A
				Type	N/A	Rating	N/A
				IΔn	mA		

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 2 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

---

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
<b>Installation Postcode</b>	SA1 8EN		

**Distribution board details - Complete in every case**

Location: Room 2 Riser Schneider  
Designation: DB CL 7/2

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 $Z_{db}$  0.33  $\Omega$  Operating at  $I_{\Delta n}$  28.6 ms  
 $I_{pf}$  0.67 kA No. of poles N/A Time delay (if applicable) N/A

## TEST RESULTS

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)					Polarity	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing All RCDs $I_{\Delta n}$ ms	Manual test button operation	
	Ring final circuits only			Fig 8 Check ( $\checkmark$ )	R1R2 or R2		Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )				RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )
	r1	r	r2		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.20	N/A	250	>999	>999	$\checkmark$	0.55	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 01/08/2023 To 01/08/2023  
Date(s) live testing: 01/08/2023 To 01/08/2023

Test instrument serial number(s):  
Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 01/08/2023







for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
<b>Installation Postcode</b>	SA1 8EN		

**Distribution board details - Complete in every case**

Location: Room 4 Riser Schneider  
Designation: DB CL 7/4

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed

No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub>: 0.39 Ω Operating at I<sub>Δn</sub>: 28.4 ms  
I<sub>pr</sub>: 0.58 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs I <sub>Δn</sub> ms	Manual test button operation			
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	m	r2		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	✓	0.68	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 02/08/2023 To 02/08/2023  
Date(s) live testing: 02/08/2023 To 02/08/2023

Test instrument serial number(s)

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature: *[Signature]*

Position: Electrical Test Engineer Date: 02/08/2023



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b>	First Floor, 12 Arthur Street London		<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB			

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3  N/A

Location

Designation

No. of ways

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from

No. of phases  BS(EN)  Type  Rating  A

Nominal voltage  V RCD BS(EN)  Type  Rating  IDn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § <input type="text" value="80%"/> (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 5 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 5 Riser Schneider  
 Designation: DB CL 7/5

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 $Z_{db}$ : 0.39  $\Omega$  Operating at  $I_{\Delta n}$ : 28.4 ms  
 $I_{pr}$ : 0.57 kA No. of poles: N/A Time delay (if applicable): N/A

## TEST RESULTS

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)			Polarity	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing All RCDs $I_{\Delta n}$ ms	Manual test button operation			
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N	L/E, N/E	RCD (✓)	AFDD (✓)
	r1	r	r2		R1 + R2	R2					M( $\Omega$ )	M( $\Omega$ )		
1/L2	N/A	N/A	N/A	N/A	0.23	N/A	250	>999	>999	✓	0.68	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 03/08/2023 To 03/08/2023  
 Date(s) live testing: 03/08/2023 To 03/08/2023

Test instrument serial number(s):  
 Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 03/08/2023

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 6 Riser Schneider
Designation: DB CL 7/6
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 7, 7/L2)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with 14 columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω), RCD (BS EN Number, Type No., Idn (mA), Rating (A)). Row 1: 1/L2, Room 6 Sockets, A3, B, 6, 2.5, 1.5, 0.4, 60898 MCB, B, 10, 10, 3.49, N/A, N/A, N/A, N/A.

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd, Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea

Distribution board details - Complete in every case. Location: Room 6 Riser Schneider, Designation: DB CL 7/6. Associated RCD: BS (EN) N/A, Zdb: 0.35, Operating at Idn: 28.6 ms.

TEST RESULTS

Table with columns for Circuit No. and Line, Circuit impedance, Insulation resistance, RCD testing, and Manual test button operation. Row 1/L2 shows results for ring final circuits.

Details of circuits and/or installed equipment vulnerable to damage when testing. Date(s) dead testing: 02/08/2023. Date(s) live testing: 02/08/2023. Test instrument serial number(s): 102133109. Tested by: PETER HUGHES, Date: 02/08/2023.

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 7 Riser Schneider
Designation: DB CL 7/7
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 7, 7/L2)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 7 Riser Schneider  
Designation: DB CL 7/7  
No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 $Z_{db}$ : 0.35  $\Omega$  Operating at  $I\Delta n$ : 28.6 ms  
 $I_{pr}$ : 0.65 kA No. of poles: N/A Time delay (if applicable): N/A

## TEST RESULTS

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)			Polarity	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation		
	Ring final circuits only			$R_{1R2}$ or $R_2$	Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )			All RCDs $I\Delta n$ ms		RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )	
	r1	m	r2							Fig 8 check ( $\checkmark$ )	R1 + R2			R2
1/L2	N/A	N/A	N/A	N/A	0.30	N/A	250	>999	>999	$\checkmark$	0.68	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: [Blank]

Date(s) dead testing: 03/08/2023 To 03/08/2023  
Date(s) live testing: 03/08/2023 To 03/08/2023Test instrument serial number(s): [Blank]  
Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109Tested by: Name (capital letters): PETER HUGHES Signature: [Signature]  
Position: Electrical Test Engineer Date: 03/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

**Distribution board details - Complete in every case**  
SPD Details: Type(s)\* T1  T2  T3†  N/A

Location: Room 8 Riser Schneider  
Designation: DB CL 7/8  
No. of ways: 1

**Complete only if the distribution board is not connected directly to the origin of the installation**  
Overcurrent protective device for the distribution circuit: Supply to distribution board is from: Sub Mains(DB CL 7, 7/L2)  
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
Nominal voltage: 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method ‡	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 8 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

*for Industrial/Commercial Premises*

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location   
 Designation   
 No. of ways   Supply polarity confirmed  Phase sequence confirmed  
 No. of phases  SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)   
 Z<sub>db</sub>  Ω Operating at IΔn  ms  
 I<sub>pr</sub>  kA No. of poles  Time delay (if applicable)

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation			
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V			L/L, L/N	L/E, N/E	All RCDs IΔn ms	RCD	AFDD
	r1	r	r2		R1 + R2	R2				M(Ω)	M(Ω)		(✓)	(✓)
1/L2	N/A	N/A	N/A	N/A	0.29	N/A	250	>999	>999	✓	0.65	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing  To   
 Date(s) live testing  To

Test instrument serial number(s)

Loop impedance  Insulation resistance  Continuity  RCD  E/Electrode

Tested by: Name (capital letters)  Signature

Position  Date



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 8 Kitchen Schneider Designation DB CL 8 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 6/L3) No. of phases 1 BS(EN) 60947 MCCB Type N/A Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L3	Lights Rooms 5, 6	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L3	Lights Rooms 3, 4	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L3	Lights Rooms 1, 2	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L3	Lights Rooms 7, 8	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
6/L3	Sub Mains(DB CL 8/2, DB CL 8/1)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L3	Sub Mains(DB CL 8/4, DB CL 8/3)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
8/L3	Sub Mains(DB CL 8/8, DB CL 8/7)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L3	Sub Mains(DB CL 8/6, DB CL 8/5)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L3	Sockets Kitchen LHS	A3	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L3	Sockets Kitchen RHS	A3	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L3	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L3	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 8 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 8	Z <sub>db</sub>	0.10 Ω Operating at IΔn N/A ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	2.21 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation				
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2									
1/L3	N/A	N/A	N/A	N/A	0.46	N/A	250	>999	>999	✓	0.59	29.0	✓	N/A	
2/L3	N/A	N/A	N/A	N/A	0.66	N/A	250	>999	>999	✓	0.79	28.6	✓	N/A	
3/L3	N/A	N/A	N/A	N/A	0.59	N/A	250	>999	>999	✓	0.75	28.8	✓	N/A	
4/L3	N/A	N/A	N/A	N/A	0.57	N/A	250	>999	>999	✓	0.67	28.2	✓	N/A	
5/L3	N/A	N/A	N/A	N/A	0.68	N/A	250	>999	>999	✓	0.79	28.4	✓	N/A	
6/L3	0.35	0.34	0.55	✓	0.23	N/A	250	>999	>999	✓	0.35	28.6	✓	N/A	
7/L3	0.41	0.40	0.67	✓	0.27	N/A	250	>999	>999	✓	0.39	28.2	✓	N/A	
8/L3	0.39	0.37	0.60	✓	0.25	N/A	250	>999	>999	✓	0.35	28.4	✓	N/A	
9/L3	0.45	0.46	0.72	✓	0.29	N/A	250	>999	>999	✓	0.41	28.8	✓	N/A	
10/L3	0.28	0.28	0.44	✓	0.18	N/A	250	>999	>999	✓	0.30	28.9	✓	N/A	
11/L3	0.33	0.31	0.47	✓	0.20	N/A	250	>999	>999	✓	0.33	28.0	✓	N/A	
12/L3	N/A	N/A	N/A	N/A	0.12	N/A	250	>999	>999	✓	0.24	28.4	✓	N/A	
13/L3	N/A	N/A	N/A	N/A	0.11	N/A	250	>999	>999	✓	0.22	28.2	✓	N/A	
14/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	02/08/2023	To	02/08/2023
		Date(s) live testing	02/08/2023	To	02/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position		Electrical Test Engineer		Date	
				02/08/2023	

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

**Client Name** UPP Residential Services Ltd  
**Client Address** First Floor, 12 Arthur Street London  
**Client Postcode** EC4R 9AB  
**Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea  
**Postcode** SA1 8EN

**Distribution board details - Complete in every case**  
 SPD Details: Type(s)\* T1  T2  T3  N/A   
 Location Room 1 Riser Schneider  
 Designation DB CL 8/1  
 No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**  
 Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 8, 6/TP)  
 No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
 Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method <sup>j</sup> :	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other <sup>§</sup> 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 1 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>					
Location	Room 1 Riser Schneider	Associated RCD (if any):	BS (EN)	N/A			
Designation	DB CL 8/1	Z <sub>db</sub>	0.35 Ω	Operating at I $\Delta$ n	28.6 ms		
No. of ways	1	<input checked="" type="checkbox"/>	Supply polarity confirmed	<input type="checkbox"/>	Phase sequence confirmed		
No. of phases	1	SPD:	<input type="checkbox"/>	Operational status confirmed	<input checked="" type="checkbox"/>	Not applicable	
		I <sub>pr</sub>	0.65 kA	No. of poles	N/A	Time delay (if applicable)	N/A

## TEST RESULTS

Circuit No. and Line	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> ( $\Omega$ )	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 check ( $\checkmark$ )	R1R2 or R2		Test voltage V	L/L, L/N M( $\Omega$ )			L/E, N/E M( $\Omega$ )	All RCDs I $\Delta$ n ms	RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L3	N/A	N/A	N/A	N/A	0.19	N/A	250	>999	>999	$\checkmark$	0.57	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	01/08/2023	To	01/08/2023
Test instrument serial number(s)		Date(s) live testing	01/08/2023	To	01/08/2023
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES		Signature		
Position	Electrical Test Engineer	Date	01/08/2023		

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 2 Riser Schneider
Designation: DB CL 8/2
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 8, 6/TP)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR **2670000213307**

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b> <b>Client Address</b>	UPP Residential Services Ltd First Floor, 12 Arthur Street London	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Postcode</b>	EC4R 9AB	<b>Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Room 3 Riser Schneider Designation DB CL 8/3 No. of ways 1	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 8, 7/TP) No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA
---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †:‡	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 3 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**



*for Industrial/Commercial Premises*

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location  Room 3 Riser Schneider  
Designation  DB CL 8/3  
No. of ways  1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases  1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)  N/A  
Z<sub>db</sub>  0.39  $\Omega$  Operating at I $\Delta$ n  28.2 ms  
I<sub>pr</sub>  0.58 kA No. of poles  N/A Time delay (if applicable)  N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)				Polarity	Max. Measured Z <sub>s</sub> ( $\Omega$ )	RCD testing	Manual test button operation		
	Ring final circuits only			Efig 8 Check ( $\checkmark$ )	R1R2 or R2		Test voltage V	L/L, L/N M( $\Omega$ )			L/E, N/E M( $\Omega$ )	All RCDs I $\Delta$ n ms	RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )
	r1	r	r2		R1 + R2	R2								
1/L3	N/A	N/A	N/A	N/A	0.27	N/A	250	>999	>999	$\checkmark$	0.68	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing  02/08/2023 To  02/08/2023  
Date(s) live testing  02/08/2023 To  02/08/2023

Test instrument serial number(s)

Loop impedance  102133109 Insulation resistance  102133109 Continuity  102133109 RCD  102133109 E/Electrode  102133109

Tested by: Name (capital letters)  PETER HUGHES Signature

Position  Electrical Test Engineer Date  02/08/2023



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR **2670000213307**

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London		<b>Postcode</b>
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
SPD Details: Type(s)*	T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 8, 7/TP)"/>	
Location	<input type="text" value="Room 4 Riser Schneider"/>	No. of phases	<input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A
Designation	<input type="text" value="DB CL 8/4"/>	Nominal voltage	<input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IDn mA
No. of ways	<input type="text" value="1"/>		

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IDn (mA)	Rating (A)
1/L3	Room 4 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London		<b>Postcode</b>
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 8, 9/TP)"/>		
Location <input type="text" value="Room 5 Riser Schneider"/>	No. of phases	<input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A	
Designation <input type="text" value="DB CL 8/5"/>	Nominal voltage	<input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA	
No. of ways <input type="text" value="1"/>			

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 5 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Client Postcode: EC4R 9AB
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 5 Riser Schneider
Designation: DB CL 8/5
No. of ways: 1
No. of phases: 1
Associated RCD (if any): BS (EN) N/A
Zdb: 0.41 Ohms
Operating at IΔn: 28.8 ms
Ipf: 0.56 kA
No. of poles: N/A
Time delay (if applicable): N/A

TEST RESULTS

Table with columns for Circuit No. and Line, Circuit impedance (r1, r2), Insulation resistance (Test voltage, L/L, L/E), Polarity, Max. Measured Zs, RCD testing (ms), and Manual test button operation (RCD, AFDD). Row 1/L3 is populated with data.

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 03/08/2023 To 03/08/2023
Date(s) live testing: 03/08/2023 To 03/08/2023
Test instrument serial number(s):
Loop impedance: 102133109
Insulation resistance: 102133109
Continuity: 102133109
RCD: 102133109
E/Electrode: 102133109
Tested by: Name (capital letters): PETER HUGHES
Position: Electrical Test Engineer
Date: 03/08/2023
Signature: [Signature]

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Room 6 Riser Schneider Designation DB CL 8/6 No. of ways 1		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 8, 9/TP) No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
---	--	--	--

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other <sup>§</sup> (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 6 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd; Client Address: First Floor, 12 Arthur Street London; Client Postcode: EC4R 9AB; Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea; Installation Postcode: SA1 8EN

Distribution board details - Complete in every case. Location: Room 6 Riser Schneider; Designation: DB CL 8/6; No. of ways: 1; Supply polarity confirmed; No. of phases: 1; SPD: Operational status confirmed; Complete only if the distribution board is not connected directly to the origin of the installation. Associated RCD: BS (EN); Zdb: 0.41 Ohms; Operating at IΔn: 28.8 ms; Ipr: 0.56 kA; No. of poles: N/A; Time delay: N/A

TEST RESULTS

Table with columns: Circuit No. and Line, Circuit impedance Ω (Ring final circuits only: r1, m, r2; Fig 8 check), Insulation resistance (Record lower reading: Test voltage V, L/L, L/N M(Ω), L/E, N/E M(Ω)), Polarity, Max. Measured Zs (Ω), RCD testing (All RCDs IΔn ms), Manual test button operation (RCD, AFDD). Row 1/L3: N/A, N/A, N/A, N/A, 0.23, N/A, 250, >999, >999, ✓, 0.67, N/A, N/A, N/A

Details of circuits and/or installed equipment vulnerable to damage when testing; Date(s) dead testing: 01/08/2023 To 01/08/2023; Date(s) live testing: 01/08/2023 To 01/08/2023; Test instrument serial number(s): 102133109; Loop impedance: 102133109; Insulation resistance: 102133109; Continuity: 102133109; RCD: 102133109; E/Electrode: 102133109; Tested by: Name (capital letters): PETER HUGHES; Position: Electrical Test Engineer; Date: 01/08/2023; Signature: [Handwritten Signature]

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 7 Riser Schneider
Designation: DB CL 8/7
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 8, 8/TP)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (BS 7671), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 7 Riser Schneider  
Designation: DB CL 8/7

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub> 0.35 Ω Operating at IΔn 28.4 ms  
I<sub>pr</sub> 0.64 kA No. of poles N/A Time delay (if applicable) N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation		
	Ring final circuits only			R1R2 or R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)				AFDD (✓)		
	r1	r <sub>m</sub>	r2										R1 + R2	R2
1/L3	N/A	N/A	N/A	N/A	0.27	N/A	250	>999	>999	✓	0.64	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 03/08/2023 To 03/08/2023  
Date(s) live testing: 03/08/2023 To 03/08/2023

Test instrument serial number(s):  
Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature: *[Signature]*  
Position: Electrical Test Engineer Date: 03/08/2023



ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1, T2, T3, N/A
Location: Room 8 Riser Schneider
Designation: DB CL 8/8
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 8, 8/TP)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 400 V RCD BS(EN) N/A Type N/A Rating N/A IDn mA

SCHEDULE OF CIRCUIT DETAILS table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors (L/N, CPC), Maximum disconnection time, Overcurrent protective devices (BS EN Number, Type No., Rating), Breaking capacity, BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., IDn, Rating).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Room 8 Riser Schneider	Associated RCD (if any): BS (EN)	N/A
Designation	DB CL 8/8	Z <sub>db</sub>	0.35 Ω Operating at IΔn 28.4 ms
No. of ways	1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub>	0.64 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation			
	Ring final circuits only			R1R2 or R2	Test voltage	L/L, L/N M(Ω)	L/E, N/E M(Ω)			All RCDs IΔn	RCD	AFDD		
	r1	m	r2							(✓)	ms	(✓)	(✓)	
1/L3	N/A	N/A	N/A	N/A	0.29	N/A	250	>999	>999	✓	0.69	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	02/08/2023	To	02/08/2023
		Date(s) live testing	02/08/2023	To	02/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)			PETER HUGHES		
Position			Electrical Test Engineer		
Date			02/08/2023		
Signature					

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 9 Kitchen Schneider Designation DB CL 9 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 7/L1) No. of phases 1 BS(EN) 60947 MCCB Type N/A Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L1	Lights Rooms 1,2, 3	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L1	Lights Rooms 6,7, 8	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L1	Lights Rooms 4,5	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Sub Mains(DB CL 9/1, DB CL 9/2, DB CL 9/3)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L1	Sub Mains(DB CL 9/8, DB CL 9/6, DB CL 9/7)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
8/L1	Sub Mains(DB CL 9/4, DB CL 9/5)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L1	Sockets Kitchen LHS	A3	B	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L1	Sockets Kitchen RHS	A3	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L1	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L1	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Flat 9 Kitchen Schneider  
 Designation: DB CL 9  
 No. of ways: 18  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.11 Ω Operating at IΔn: N/A ms  
 I<sub>pf</sub>: 2.13 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation				
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2									
1/L1	N/A	N/A	N/A	N/A	0.47	N/A	250	>999	>999	✓	0.60	28.2	✓	N/A	
2/L1	N/A	N/A	N/A	N/A	0.66	N/A	250	>999	>999	✓	0.79	28.6	✓	N/A	
3/L1	N/A	N/A	N/A	N/A	0.59	N/A	250	>999	>999	✓	0.74	28.6	✓	N/A	
4/L1	N/A	N/A	N/A	N/A	0.50	N/A	250	>999	>999	✓	0.63	28.8	✓	N/A	
5/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L1	0.36	0.37	0.55	✓	0.23	N/A	250	>999	>999	✓	0.36	28.6	✓	N/A	
7/L1	0.37	0.38	0.58	✓	0.24	N/A	250	>999	>999	✓	0.38	28.6	✓	N/A	
8/L1	0.28	0.27	0.44	✓	0.18	N/A	250	>999	>999	✓	0.31	28.4	✓	N/A	
9/L1	0.28	0.29	0.44	✓	0.18	N/A	250	>999	>999	✓	0.30	28.8	✓	N/A	
10/L1	0.30	0.30	0.45	✓	0.19	N/A	250	>999	>999	✓	0.33	28.0	✓	N/A	
11/L1	N/A	N/A	N/A	N/A	0.14	N/A	250	>999	>999	✓	0.17	28.8	✓	N/A	
12/L1	N/A	N/A	N/A	N/A	0.11	N/A	250	>999	>999	✓	0.23	28.4	✓	N/A	
13/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
14/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 03/08/2023 To 03/08/2023  
 Date(s) live testing: 03/08/2023 To 03/08/2023

Test instrument serial number(s):

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature: *Peter Hughes*  
 Position: Electrical Test Engineer Date: 03/08/2023

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3t N/A
Location: Room 1 Riser Schneider
Designation: DB CL 9/1
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 9, 6/TP)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (BS 7671), Overcurrent protective devices, Breaking capacity, BS 7671 Max. permitted Zs, RCD, BS EN Number, Type No., In (mA), Rating (A).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd		<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB	<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>						<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>					
Location	Room 1 Riser Schneider					Associated RCD (if any):	BS (EN)	N/A			
Designation	DB CL 9/1					Z <sub>db</sub>	0.36	Ω	Operating at IΔn	28.6 ms	
No. of ways	1	<input checked="checked" type="checkbox"/> Supply polarity confirmed	<input type="checkbox"/> Phase sequence confirmed			I <sub>pr</sub>	0.64	kA	No. of poles	N/A	
No. of phases	1	SPD:	<input type="checkbox"/> Operational status confirmed	<input checked="checked" type="checkbox"/> Not applicable			Time delay (if applicable)		N/A		

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation	
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	m	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.23	N/A	250	>999	>999	✓	0.62	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing					Date(s) dead testing	01/08/2023	To	01/08/2023	
					Date(s) live testing	01/08/2023	To	01/08/2023	
Test instrument serial number(s)									
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109	RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES				Signature				
Position	Electrical Test Engineer	Date	01/08/2023						

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

**FT/EICR 2670000213307**

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>				<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			
SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3+ <input type="checkbox"/> N/A <input checked="" type="checkbox"/>				Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 9, 6/TP)			
Location Room 2 Riser Schneider				No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A			
Designation DB CL 9/2				Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA			
No. of ways 1							

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method i:j:k	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (S) (BS 7671)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 2 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ;: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 2 Riser Schneider  
 Designation: DB CL 9/2

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed

No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 $Z_{db}$ : 0.36  $\Omega$  Operating at  $I\Delta n$ : 28.6 ms  
 $I_{pr}$ : 0.63 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)			Polarity	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing All RCDs $I\Delta n$ ms	Manual test button operation			
	Ring final circuits only			Fig 8 Check ( $\checkmark$ )	R1R2 or R2		Test voltage V				L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )
	r1	r	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.20	N/A	250	>999	>999	$\checkmark$	0.58	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 03/08/2023 To 03/08/2023  
 Date(s) live testing: 03/08/2023 To 03/08/2023

Test instrument serial number(s)

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature: *Peter Hughes*

Position: Electrical Test Engineer Date: 03/08/2023





















**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

**Client Name** UPP Residential Services Ltd  
**Client Address** First Floor, 12 Arthur Street London  
**Client Postcode** EC4R 9AB  
**Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea  
**Postcode** SA1 8EN

**Distribution board details - Complete in every case**  
 SPD Details: Type(s)\* T1  T2  T3  N/A   
 Location Room 7 Riser Schneider  
 Designation DB CL 9/7  
 No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**  
 Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 9, 7/TP)  
 No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
 Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 7 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location

Designation

No. of ways   Supply polarity confirmed  Phase sequence confirmed

No. of phases  SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)

Z<sub>db</sub>  Ω Operating at IΔn  ms

I<sub>pr</sub>  kA No. of poles  Time delay (if applicable)

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)				Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation	
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N	L/E, N/E			All RCDs IΔn ms	RCD	AFDD
	r1	r2	r3		R1 + R2	R2		M(Ω)	M(Ω)				(✓)	(✓)
1/L1	N/A	N/A	N/A	N/A	0.24	N/A	250	>999	>999	✓	0.67	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing  To

Date(s) live testing  To

Test instrument serial number(s)

Loop impedance  Insulation resistance  Continuity  RCD  E/Electrode

Tested by: Name (capital letters)  Signature

Position  Date

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 8 Riser Schneider
Designation: DB CL 9/8
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 9, 7/TP)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 400 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with 14 columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω), RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> UPP Residential Services Ltd		<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b> First Floor, 12 Arthur Street London		<b>Client Postcode</b> EC4R 9AB	<b>Installation Postcode</b> SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		
<b>Location</b> Room 8 Riser Schneider	<b>Associated RCD (if any):</b> BS (EN) N/A	<b>Z<sub>db</sub></b> 0.38 Ω	<b>Operating at IΔn</b> 28.6 ms	
<b>Designation</b> DB CL 9/8	<b>No. of ways</b> 1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	<b>I<sub>pr</sub></b> 0.61 kA	<b>No. of poles</b> N/A	<b>Time delay (if applicable)</b> N/A
<b>No. of phases</b> 1	<b>SPD:</b> <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable			

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N			L/E, N/E	All RCDs IΔn ms	RCD	AFDD
	r1	m	r2		R1 + R2	R2		M(Ω)			M(Ω)		(✓)	(✓)
1/L1	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	✓	0.69	N/A	N/A	N/A

<b>Details of circuits and/or installed equipment vulnerable to damage when testing</b>		<b>Date(s) dead testing</b> 04/08/2023 <b>To</b> 04/08/2023	
<input type="text"/>		<b>Date(s) live testing</b> 04/08/2023 <b>To</b> 04/08/2023	
<b>Test instrument serial number(s)</b>			
<b>Loop impedance</b> 102133109	<b>Insulation resistance</b> 102133109	<b>Continuity</b> 102133109	<b>RCD</b> 102133109 <b>E/Electrode</b> 102133109
<b>Tested by: Name (capital letters)</b> PETER HUGHES		<b>Signature</b>	
<b>Position</b> Electrical Test Engineer	<b>Date</b> 04/08/2023		

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 10 Kitchen Schneider Designation DB CL 10 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 8/L2) No. of phases 1 BS(EN) 60947 MCCB Type N/A Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L2	Lights Rooms 8, 7	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L2	Lights Rooms 3, 4	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L2	Lights Rooms 5, 6	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L2	Lights Rooms 1, 2	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
6/L2	Sub Mains(DB CL 10/2, DB CL 10/1)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L2	Sub Mains(DB CL 10/4, DB CL 10/3)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
8/L2	Sub Mains(DB CL 10/7, DB CL 10/8)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L2	Sub Mains(DB CL 10/6, DB CL 10/5)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L2	Sockets Kitchen LHS	A3	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L2	Sockets Kitchen RHS	A3	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L2	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L2	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 10 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 10	Z <sub>db</sub>	0.11 Ω Operating at IΔn N/A ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	2.06 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation				
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2									
1/L2	N/A	N/A	N/A	N/A	0.47	N/A	250	>999	>999	✓	0.60	28.8	✓	N/A	
2/L2	N/A	N/A	N/A	N/A	0.69	N/A	250	>999	>999	✓	0.83	28.8	✓	N/A	
3/L2	N/A	N/A	N/A	N/A	0.65	N/A	250	>999	>999	✓	0.78	28.4	✓	N/A	
4/L2	N/A	N/A	N/A	N/A	0.55	N/A	250	>999	>999	✓	0.68	28.2	✓	N/A	
5/L2	N/A	N/A	N/A	N/A	0.52	N/A	250	>999	>999	✓	0.64	28.4	✓	N/A	
6/L2	0.35	0.34	0.55	✓	0.23	N/A	250	>999	>999	✓	0.36	28.6	✓	N/A	
7/L2	0.41	0.40	0.67	✓	0.27	N/A	250	>999	>999	✓	0.39	28.2	✓	N/A	
8/L2	0.39	0.37	0.60	✓	0.25	N/A	250	>999	>999	✓	0.37	28.4	✓	N/A	
9/L2	0.45	0.46	0.72	✓	0.29	N/A	250	>999	>999	✓	0.42	28.8	✓	N/A	
10/L2	0.28	0.28	0.44	✓	0.18	N/A	250	>999	>999	✓	0.31	28.9	✓	N/A	
11/L2	0.33	0.31	0.47	✓	0.20	N/A	250	>999	>999	✓	0.33	28.6	✓	N/A	
12/L2	N/A	N/A	N/A	N/A	0.13	N/A	250	>999	>999	✓	0.24	28.2	✓	N/A	
13/L2	N/A	N/A	N/A	N/A	0.13	N/A	250	>999	>999	✓	0.25	28.6	✓	N/A	
14/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	04/08/2023	To	04/08/2023
		Date(s) live testing	04/08/2023	To	04/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES		Signature		
Position	Electrical Test Engineer	Date	04/08/2023		

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 1 Riser Schneider
Designation: DB CL 10/1
No. of ways: 2
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 10, 6/TP)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (BS 7671) (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω) (80%), RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 1 Riser Schneider  
 Designation: DB CL 10/1

No. of ways: 2  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.36 Ω Operating at I<sub>Δn</sub>: 28.6 ms  
 I<sub>pr</sub>: 0.64 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs I <sub>Δn</sub> ms	Manual test button operation			
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	m	r2		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.23	N/A	250	>999	>999	✓	0.63	N/A	N/A	N/A
2/L2	N/A	N/A	N/A	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 01/08/2023 To 01/08/2023  
 Date(s) live testing: 01/08/2023 To 01/08/2023

Test instrument serial number(s)

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters): PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 01/08/2023



for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3t N/A
Location: Room 2 Riser Schneider
Designation: DB CL 10/2
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 10, 6/TP)
No. of phases: 3 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A IDn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., IDn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location: Room 2 Riser Schneider	Associated RCD (if any): BS (EN)	N/A
Designation: DB CL 10/2	Z <sub>db</sub> : 0.36 Ω	Operating at IΔn: 28.6 ms
No. of ways: 1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub> : 0.63 kA	No. of poles: N/A
No. of phases: 3 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable	Time delay (if applicable): N/A	

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation		
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)				L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/TP	N/A	N/A	N/A	N/A	0.25	N/A	250	>999	>999	✓	0.62	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 01/08/2023 To 01/08/2023  
Date(s) live testing: 01/08/2023 To 01/08/2023

Test instrument serial number(s):

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters): PETER HUGHES Signature: [Signature]  
Position: Electrical Test Engineer Date: 01/08/2023

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 3 Riser Schneider
Designation: DB CL 10/3
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 10, 7/TP)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω), RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

**Client Name** UPP Residential Services Ltd  
**Client Address** First Floor, 12 Arthur Street London  
**Client Postcode** EC4R 9AB  
**Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea  
**Installation Postcode** SA1 8EN

**Distribution board details - Complete in every case**  
Location Room 3 Riser Schneider  
Designation DB CL 10/3  
No. of ways 1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**  
Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub> 0.39 Ω Operating at IΔn 28.2 ms  
I<sub>pr</sub> 0.59 kA No. of poles N/A Time delay (if applicable) N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation	
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N	L/E, N/E			All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r	r2		R1 + R2	R2		M(Ω)	M(Ω)					
1/L2	N/A	N/A	N/A	N/A	0.22	N/A	250	>999	>999	✓	0.66	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing:

Date(s) dead testing 04/08/2023 To 04/08/2023  
Date(s) live testing 04/08/2023 To 04/08/2023

Test instrument serial number(s)

Loop impedance 102133109 Insulation resistance 102133109 Continuity 102133109 RCD 102133109 E/Electrode 102133109

Tested by: Name (capital letters) PETER HUGHES Signature   
Position Electrical Test Engineer Date 04/08/2023

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>				<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			
SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>				Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 10, 7/TP)			
Location Room 4 Riser Schneider				No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A			
Designation DB CL 10/4				Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA			
No. of ways 1							

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD				
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)	
1/L2	Room 4 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	80%	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 4 Riser Schneider  
Designation: DB CL 10/4

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed

No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A

Z<sub>db</sub>: 0.39  $\Omega$  Operating at I $\Delta$ n: 28.2 ms

I<sub>pf</sub>: 0.58 kA No. of poles: N/A Time delay (if applicable): N/A

TEST RESULTS

Circuit No. and Line	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> ( $\Omega$ )	RCD testing All RCDs I $\Delta$ n ms	Manual test button operation	
	Ring final circuits only			Fig 8 check ( $\checkmark$ )	R1R2 or R2		Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )				RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )
	r1	r2	r3		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.25	N/A	250	>999	>999	$\checkmark$	0.65	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 01/08/2023 To 01/08/2023  
Date(s) live testing: 01/08/2023 To 01/08/2023

Test instrument serial number(s)

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 01/08/2023

for Industrial/Commercial Premises



Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

**Client Name** UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea

**Client Address** First Floor, 12 Arthur Street London **Postcode** SA1 8EN

**Client Postcode** EC4R 9AB

**Distribution board details - Complete in every case**  
 SPD Details: Type(s)\* T1  T2  T3  N/A   
 Location Room 5 Riser Schneider  
 Designation DB CL 10/5  
 No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**  
 Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 10, 9/TP)  
 No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
 Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § 80% (Ω)	RCD				
					L/N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)	
1/L2	Room 5 Sockets	A3	B	6	2.5	1.5	0.4	60898	MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 5 Riser Schneider  
 Designation: DB CL 10/5  
 No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.42 Ω Operating at IΔn: 28.8 ms  
 I<sub>pr</sub>: 0.55 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation	
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.27	N/A	250	>999	>999	✓	0.72	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 04/08/2023 To 04/08/2023  
 Date(s) live testing: 04/08/2023 To 04/08/2023

Test instrument serial number(s):  
 Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters): PETER HUGHES Signature: *[Handwritten Signature]*  
 Position: Electrical Test Engineer Date: 04/08/2023



for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1, T2, T3, N/A
Location: Room 6 Riser Schneider
Designation: DB CL 10/6
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 10, 9/TP)
No. of phases: 1, BS(EN) 61009 RCD/RCBO, Type B, Rating 32 A
Nominal voltage: 230 V, RCD BS(EN) N/A, Type N/A, Rating N/A, Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) L/N, CPC, Maximum disconnection time (s), Overcurrent protective devices BS EN Number, Type No., Rating (A), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD BS EN Number, Type No., Idn (mA), Rating (A)

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

**Client Name** UPP Residential Services Ltd  
**Client Address** First Floor, 12 Arthur Street London  
**Client Postcode** EC4R 9AB  
**Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea  
**Postcode** SA1 8EN

**Distribution board details - Complete in every case**  
 SPD Details: Type(s)\* T1  T2  T3  N/A   
 Location Room 7 Riser Schneider  
 Designation DB CL 10/7  
 No. of ways 1  
**Complete only if the distribution board is not connected directly to the origin of the installation**  
 Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 10, 8/TP)  
 No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
 Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method <sup>i,j</sup>	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other <sup>§</sup>	RCD				
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Idn (mA)	Rating (A)	
1/L2	Room 7 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	80%	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



*for Industrial/Commercial Premises*

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd		<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB	<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>				
Location	Room 7 Riser Schneider	Associated RCD (if any):	BS (EN)	N/A		
Designation	DB CL 10/7	Z <sub>db</sub>	Ω	Operating at IΔn	28.4 ms	
No. of ways	1	<input checked="" type="checkbox"/>	Supply polarity confirmed	<input type="checkbox"/>	Phase sequence confirmed	
No. of phases	1	SPD:	<input type="checkbox"/>	Operational status confirmed	<input checked="" type="checkbox"/>	Not applicable
		I <sub>pr</sub>	0.62 kA	No. of poles	N/A	
		Time delay (if applicable)	N/A			

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation	
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N	L/E, N/E			All RCDs IΔn ms	RCD	AFDD
	r1	r <sub>m</sub>	r2		R1 + R2	R2		M(Ω)	M(Ω)				(✓)	(✓)
1/L2	N/A	N/A	N/A	N/A	0.29	N/A	250	>999	>999	✓	0.69	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	04/08/2023	To	04/08/2023
		Date(s) live testing	04/08/2023	To	04/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
RCD	102133109	E/Electrode	102133109		
Tested by: Name (capital letters)	PETER HUGHES			Signature	
Position	Electrical Test Engineer	Date	04/08/2023		

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Postcode</b> SA1 8EN
<b>Client Postcode</b> EC4R 9AB	

<b>Distribution board details - Complete in every case</b>				<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			
SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>				Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 10, 8/TP)"/>			
Location <input type="text" value="Room 8 Riser Schneider"/>				No. of phases <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A			
Designation <input type="text" value="DB CL 10/8"/>				Nominal voltage <input type="text" value="400"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA			
No. of ways <input type="text" value="1"/>							

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method ∴	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 8 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ∴ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		
Location	Room 8 Riser Schneider	Associated RCD (if any):	BS (EN)	N/A
Designation	DB CL 10/8	Z <sub>db</sub>	0.37 Ω	Operating at I <sub>Δn</sub>
No. of ways	1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed			
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable	I <sub>pf</sub>	0.63 kA	No. of poles
		N/A Time delay (if applicable) N/A		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation			
	Ring final circuits only			E Fig 8 check (✓)	R1R2 or R2		Test voltage V			L/L, L/N	L/E, N/E	All RCDs I <sub>Δn</sub> ms	RCD	AFDD
	r1	r <sub>m</sub>	r2		R1 + R2	R2				M(Ω)	M(Ω)		(✓)	(✓)
1/L2	N/A	N/A	N/A	N/A	0.24	N/A	250	>999	>999	✓	0.63	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing		04/08/2023	To	04/08/2023
		Date(s) live testing		04/08/2023	To	04/08/2023
Test instrument serial number(s)						
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109	RCD
						E/Electrode
						102133109
Tested by: Name (capital letters)			PETER HUGHES		Signature	
Position			Electrical Test Engineer		Date	
					04/08/2023	

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 11 Kitchen Schneider Designation DB CL 11 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 10/L3) No. of phases 1 BS(EN) 60947 MCCB Type N/A Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
---	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L3	Lights Rooms 1, 2, 3	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L3	Lights Rooms 6, 7, 8	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L3	Lights Rooms 4, 5	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	Sub Mains(DB CL 11/3, DB CL 11/1, DB CL 11/2)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L3	Sub Mains(DB CL 11/8, DB CL 11/6, DB CL 11/7)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	16
8/L3	Sub Mains(DB CL 11/5, DB CL 11/4)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L3	Sockets Kitchen LHS	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L3	Sockets Kitchen RHS	A3	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L3	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L3	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 11 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 11	Z <sub>db</sub>	0.14 Ω Operating at IΔn N/A ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	1.62 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation			
	Ring final circuits only			Efig 8 check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L3	N/A	N/A	N/A	N/A	0.37	N/A	250	>999	>999	✓	0.53	28.6	✓	N/A
2/L3	N/A	N/A	N/A	N/A	0.48	N/A	250	>999	>999	✓	0.64	28.2	✓	N/A
3/L3	N/A	N/A	N/A	N/A	0.55	N/A	250	>999	>999	✓	0.72	28.4	✓	N/A
4/L3	N/A	N/A	N/A	N/A	0.50	N/A	250	>999	>999	✓	0.66	28.2	✓	N/A
5/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	0.31	0.32	0.48	✓	0.20	N/A	250	>999	>999	✓	0.37	28.6	✓	N/A
7/L3	0.33	0.34	0.52	✓	0.21	N/A	250	>999	>999	✓	0.39	28.8	✓	N/A
8/L3	0.30	0.28	0.47	✓	0.19	N/A	250	>999	>999	✓	0.36	28.4	✓	N/A
9/L3	0.28	0.29	0.44	✓	0.18	N/A	250	>999	>999	✓	0.34	28.8	✓	N/A
10/L3	0.30	0.30	0.45	✓	0.19	N/A	250	>999	>999	✓	0.35	28.6	✓	N/A
11/L3	N/A	N/A	N/A	N/A	0.10	N/A	250	>999	>999	✓	0.26	28.4	✓	N/A
12/L3	N/A	N/A	N/A	N/A	0.14	N/A	250	>999	>999	✓	0.29	28.6	✓	N/A
13/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	02/08/2023	To	02/08/2023
		Date(s) live testing	02/08/2023	To	02/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES		Signature		
Position	Electrical Test Engineer	Date	02/08/2023		



# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3  N/A

Location

Designation

No. of ways

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from

No. of phases  BS(EN)  Type  Rating  A

Nominal voltage  V RCD BS(EN)  Type  Rating  Idn mA

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Idn (mA)	Rating (A)
1/L3	Room 1 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Client Postcode: EC4R 9AB
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 1 Riser Schneider
Designation: DB CL 11/1
No. of ways: 1
No. of phases: 1
SPD: Operational status confirmed
Complete only if the distribution board is not connected directly to the origin of the installation
Associated RCD (if any): BS (EN) N/A
Zdb: 0.37 Ohm
Operating at Idn: 28.6 ms
Ipf: 0.62 kA
No. of poles: N/A
Time delay (if applicable): N/A

TEST RESULTS

Table with 15 columns: Circuit No. and Line, Ring final circuits only (r1, m, r2), Fig 8 Check, R1R2 or R2 (R1+R2, R2), Test voltage (V), L/L, L/N (M(Ohm)), L/E, N/E (M(Ohm)), Polarity, Max. Measured Zs (Ohm), RCD testing (All RCDs Idn ms), Manual test button operation (RCD, AFDD).

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 02/08/2023 To 02/08/2023
Date(s) live testing: 02/08/2023 To 02/08/2023
Test instrument serial number(s)
Loop impedance: 102133109
Insulation resistance: 102133109
Continuity: 102133109
RCD: 102133109
E/Electrode: 102133109
Tested by: Name (capital letters) PETER HUGHES
Signature: [Handwritten Signature]
Position: Electrical Test Engineer
Date: 02/08/2023

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 2 Riser Schneider
Designation: DB CL 11/2
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 11, 6/L3)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with 15 columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s) (BS 7671), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω) (80%), RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd; Client Address: First Floor, 12 Arthur Street London; Client Postcode: EC4R 9AB; Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea; Installation Postcode: SA1 8EN

Distribution board details - Complete in every case; Location: Room 2 Riser Schneider; Designation: DB CL 11/2; No. of ways: 1; No. of phases: 1; SPD: Not applicable; Complete only if the distribution board is not connected directly to the origin of the installation; Associated RCD: N/A; Zdb: 0.37; Operating at IΔn: 28.6; Ipr: 0.60 kA; No. of poles: N/A; Time delay: N/A

TEST RESULTS

Table with columns: Circuit No. and Line, Circuit impedance Ω (Ring final circuits only, R1R2 or R2), Insulation resistance (Record lower reading), Polarity, Max. Measured Zs (Ω), RCD testing, Manual test button operation. Row 1: 1/L3, N/A, N/A, N/A, N/A, 0.21, N/A, 250, >999, >999, ✓, 0.60, N/A, N/A, N/A.

Details of circuits and/or installed equipment vulnerable to damage when testing; Date(s) dead testing: 03/08/2023 To 03/08/2023; Date(s) live testing: 03/08/2023 To 03/08/2023; Test instrument serial number(s); Loop impedance: 102133109; Insulation resistance: 102133109; Continuity: 102133109; RCD: 102133109; E/Electrode: 102133109; Tested by: Name (capital letters): PETER HUGHES; Position: Electrical Test Engineer; Date: 03/08/2023; Signature: [Handwritten Signature]

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London		
<b>Client Postcode</b>	EC4R 9AB		
		<b>Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 11, 6/L3)"/>	
Location	<input type="text" value="Room 3 Riser Schneider"/>	No. of phases	1
Designation	<input type="text" value="DB CL 11/3"/>	BS(EN)	61009 RCD/RCBO
No. of ways	<input type="text" value="1"/>	Type	B
		Rating	32
		Nominal voltage	230
		V	
		RCD BS(EN)	N/A
		Type	N/A
		Rating	N/A
		IΔn	mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method ‡	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § <input type="text" value="80%"/> (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 3 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

for Industrial/Commercial Premises  
 Requirements for Electrical Installations  
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 3 Riser Schneider  
 Designation: DB CL 11/3

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.37 Ω Operating at I<sub>Δn</sub>: 28.6 ms  
 I<sub>pr</sub>: 0.63 kA No. of poles: N/A Time delay (if applicable): N/A

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)				Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation	
	Ring final circuits only			R1R2 or R2	Test voltage	L/L, L/N	L/E, N/E	All RCDs I <sub>Δn</sub> ms	RCD (✓)			AFDD (✓)		
	r1	r <sub>m</sub>	r2										R1R2 or R2	
				R1 + R2	R2									
1/L3	N/A	N/A	N/A	N/A	0.25	N/A	250	>999	>999	✓	0.66	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing:  

Date(s) dead testing: 02/08/2023 To 02/08/2023  
 Date(s) live testing: 02/08/2023 To 02/08/2023

Test instrument serial number(s):  

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters): PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 02/08/2023

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 4 Riser Schneider
Designation: DB CL 11/4
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 11, 8/L3)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s) (BS 7671), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω) (80%), RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results





# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>
SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 11, 8/L3)
Location Room 5 Riser Schneider	No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Designation DB CL 11/5	Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA
No. of ways 1	

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 5 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 5 Riser Schneider  
Designation: DB CL 11/5

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub>: 0.36 Ω Operating at I<sub>Δn</sub>: 28.4 ms  
I<sub>pr</sub>: 0.64 kA No. of poles: N/A Time delay (if applicable): N/A

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation			
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N				L/E, N/E	All RCDs I <sub>Δn</sub> ms	RCD	AFDD
	r1	r2	r3		R1 + R2	R2		M(Ω)				M(Ω)		(✓)	(✓)
1/L3	N/A	N/A	N/A	N/A	0.30	N/A	250	>999	>999	✓	0.67	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing: [ ]

Date(s) dead testing: 01/08/2023 To 01/08/2023  
Date(s) live testing: 01/08/2023 To 01/08/2023

Test instrument serial number(s): [ ]

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 01/08/2023

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Room 6 Riser Schneider Designation DB CL 11/6 No. of ways 1		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 11, 7/L3) No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other <input type="checkbox"/> Other <input type="checkbox"/>	RCD				
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Idn (mA)	Rating (A)	
1/L3	Room 6 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	80%	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b> UPP Residential Services Ltd <b>Client Address</b> First Floor, 12 Arthur Street London <b>Client Postcode</b> EC4R 9AB	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea <b>Postcode</b> SA1 8EN
---	---

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location <input type="text" value="Room 7 Riser Schneider"/> Designation <input type="text" value="DB CL 11/7"/> No. of ways <input type="text" value="1"/>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 11, 7/L3)"/> No. of phases <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A Nominal voltage <input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA
--	--

SCHEDULE OF CIRCUIT DETAILS																
Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 7 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR **2670000213307**

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Client Postcode</b> EC4R 9AB
<b>Installation Postcode</b> SA1 8EN	

<b>Distribution board details - Complete in every case</b> Location <input type="text" value="Room 7 Riser Schneider"/> Designation <input type="text" value="DB CL 11/7"/> No. of ways <input type="text" value="1"/> <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed No. of phases <input type="text" value="1"/> SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Associated RCD (if any): BS (EN) <input type="text" value="N/A"/> Z <sub>db</sub> <input type="text" value="0.39"/> Ω Operating at I <sub>Δn</sub> <input type="text" value="28.8"/> ms I <sub>pf</sub> <input type="text" value="0.59"/> kA No. of poles <input type="text" value="N/A"/> Time delay (if applicable) <input type="text" value="N/A"/>
---	--

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation			
	Ring final circuits only			R1R2 or R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			All RCDs I <sub>Δn</sub> ms	RCD (✓)	AFDD (✓)		
	r1	r <sub>m</sub>	r2										R1 + R2	R2
1/L3	N/A	N/A	N/A	N/A	0.27	N/A	250	>999	>999	✓	0.71	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing  To

Date(s) live testing  To

Test instrument serial number(s)

Loop impedance  Insulation resistance  Continuity  RCD  E/Electrode

Tested by: Name (capital letters)  Signature

Position  Date

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name, Client Address, Installation Address, Postcode, Client Postcode

Distribution board details - Complete in every case
SPD Details, Location, Designation, No. of ways

Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device, Supply to distribution board, No. of phases, Nominal voltage

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors, Maximum disconnection time, Overcurrent protective devices, Breaking capacity, BS 7671 Max. permitted Zs, RCD details.

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results.
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd, Client Address: First Floor, 12 Arthur Street London, Client Postcode: EC4R 9AB, Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, Installation Postcode: SA1 8EN

TEST RESULTS

Table with columns for Circuit No and Line, Circuit impedance Ω (r1, r2), Insulation resistance (Test voltage, M(Ω)), Polarity, Max Measured Zs (Ω), RCD testing (All RCDs IΔn ms), and Manual test button operation (RCD, AFDD).

Details of circuits and/or installed equipment vulnerable to damage when testing, Test instrument serial number(s), Loop impedance, Insulation resistance, Continuity, RCD, E/Electrode, Tested by: Name, Position, Date, Signature.



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 12 Kitchen Schneider Designation DB CL 12 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 11/L1) No. of phases 1 BS(EN) 60947 MCCB Type N/A Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
---	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L1	Lights Rooms 1, 2	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L1	Lights Rooms 3, 4	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L1	Lights Rooms 5, 6	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L1	Lights Rooms 7, 8	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
6/L1	Sub Mains(DB CL 12/2, DB CL 12/1)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L1	Sub Mains(DB CL 12/4, DB CL 12/3)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
8/L1	Sub Mains(DB CL 12/7, DB CL 12/8)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L1	Sub Mains(DB CL 12/6, DB CL 12/5)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L1	Sockets Kitchen LHS	A3	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L1	Sockets Kitchen RHS	A3	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L1	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L1	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Flat 12 Kitchen Schneider  
 Designation: DB CL 12

No. of ways: 18  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.09 Ω Operating at IΔn N/A ms  
 I<sub>pf</sub>: 2.58 kA No. of poles N/A Time delay (if applicable) N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation				
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2									
1/L1	N/A	N/A	N/A	N/A	0.46	N/A	250	>999	>999	✓	0.59	29.0	✓	N/A	
2/L1	N/A	N/A	N/A	N/A	0.66	N/A	250	>999	>999	✓	0.79	28.6	✓	N/A	
3/L1	N/A	N/A	N/A	N/A	0.59	N/A	250	>999	>999	✓	0.75	28.8	✓	N/A	
4/L1	N/A	N/A	N/A	N/A	0.57	N/A	250	>999	>999	✓	0.67	28.2	✓	N/A	
5/L1	N/A	N/A	N/A	N/A	0.68	N/A	250	>999	>999	✓	0.79	28.4	✓	N/A	
6/L1	0.35	0.34	0.55	✓	0.23	N/A	250	>999	>999	✓	0.35	28.6	✓	N/A	
7/L1	0.41	0.40	0.67	✓	0.27	N/A	250	>999	>999	✓	0.39	28.2	✓	N/A	
8/L1	0.39	0.37	0.60	✓	0.25	N/A	250	>999	>999	✓	0.35	28.4	✓	N/A	
9/L1	0.45	0.46	0.72	✓	0.29	N/A	250	>999	>999	✓	0.41	28.8	✓	N/A	
10/L1	0.28	0.28	0.44	✓	0.18	N/A	250	>999	>999	✓	0.30	28.9	✓	N/A	
11/L1	0.33	0.31	0.47	✓	0.20	N/A	250	>999	>999	✓	0.33	28.0	✓	N/A	
12/L1	N/A	N/A	N/A	N/A	0.12	N/A	250	>999	>999	✓	0.24	28.4	✓	N/A	
13/L1	N/A	N/A	N/A	N/A	0.11	N/A	250	>999	>999	✓	0.22	28.2	✓	N/A	
14/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 02/08/2023 To 02/08/2023  
 Date(s) live testing: 02/08/2023 To 02/08/2023

Test instrument serial number(s):

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 02/08/2023

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



**Client Name** UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea

**Client Address** First Floor, 12 Arthur Street London **Postcode** SA1 8EN

**Client Postcode** EC4R 9AB

**Distribution board details - Complete in every case**  
 SPD Details: Type(s)\* T1  T2  T3  N/A   
 Location Room 1 Riser Schneider  
 Designation DB CL 12/1  
 No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**  
 Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 12, 6/L1)  
 No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
 Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

SCHEDULE OF CIRCUIT DETAILS																
Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 1 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 §: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
			<b>Installation Postcode</b>
			SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 1 Riser Schneider  
Designation: DB CL 12/1

No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub> Ω Operating at I $\Delta$ n 28.6 ms  
I<sub>pr</sub> kA No. of poles N/A Time delay (if applicable) N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> ( $\Omega$ )	RCD testing	Manual test button operation			
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V			L/L, L/N	L/E, N/E	All RCDs I $\Delta$ n ms	RCD	AFDD
	r1	r <sub>m</sub>	r2		R1 + R2	R2				M( $\Omega$ )	M( $\Omega$ )		(✓)	(✓)
1/L1	N/A	N/A	N/A	N/A	0.23	N/A	250	>999	>999	✓	0.62	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 02/08/2023 To 02/08/2023  
Date(s) live testing: 02/08/2023 To 02/08/2023

Test instrument serial number(s):

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 02/08/2023

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 2 Riser Schneider
Designation: DB CL 12/2
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 12, 6/L1)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (BS 7671) (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω) (80%), RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>
Location: Room 2 Riser Schneider	Associated RCD (if any): BS (EN) N/A
Designation: DB CL 12/2	Z <sub>db</sub> : _____ Ω Operating at IΔn: 28.6 ms
No. of ways: 1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub> : _____ kA No. of poles: N/A Time delay (if applicable): N/A
No. of phases: 1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable	

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation		
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)				L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.20	N/A	250	>999	>999	✓	0.58	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	03/08/2023	To	03/08/2023
		Date(s) live testing	03/08/2023	To	03/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
RCD	102133109	E/Electrode	102133109		
Tested by: Name (capital letters)	PETER HUGHES		Signature <i>P. Hughes</i>		
Position	Electrical Test Engineer	Date	03/08/2023		

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 3 Riser Schneider
Designation: DB CL 12/3
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 12, 7/L1)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with 14 columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω), RCD (BS EN Number, Type No., Idn (mA), Rating (A)). Row 1: 1/L1, Room 3 Sockets, A3, B, 6, 2.5, 1.5, 0.4, 60898 MCB, B, 10, 10, 3.49, N/A, N/A, N/A, N/A.

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Client Postcode: EC4R 9AB
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 3 Riser Schneider
Designation: DB CL 12/3
No. of ways: 1
No. of phases: 1
Associated RCD (if any): BS (EN) N/A
Operating at IΔn: 28.6 ms

TEST RESULTS

Table with 15 columns: Circuit No. and Line, Ring final circuits only (r1, m, r2), Fig 8 check, R1R2 or R2 (R1+R2, R2), Test voltage (V), Insulation resistance (L/L, L/N, L/E, N/E), Polarity, Max. Measured Zs (Ω), RCD testing (All RCDs IΔn ms), Manual test button operation (RCD, AFDD).

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 01/08/2023 To 01/08/2023
Date(s) live testing: 01/08/2023 To 01/08/2023
Test instrument serial number(s):
Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109
Tested by: Name (capital letters): PETER HUGHES Signature: [Signature]
Position: Electrical Test Engineer Date: 01/08/2023



ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3 [ ] N/A [x]
Location: Room 4 Riser Schneider
Designation: DB CL 12/4
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 12, 7/L1)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with 15 columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (BS 7671) (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω) (80%), RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

for Industrial/Commercial Premises  
Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Room 4 Riser Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 12/4	Z <sub>db</sub>	Ω Operating at IΔn 28.4 ms
No. of ways	1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub>	kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation		
	Ring final circuits only			R1R2 or R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms			RCD (✓)	AFDD (✓)		
	r1	r <sub>m</sub>	r2										R1 + R2	R2
1/L1	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	✓	0.68	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 04/08/2023 To 04/08/2023  
Date(s) live testing: 04/08/2023 To 04/08/2023

Test instrument serial number(s)

Loop impedance 102133109 Insulation resistance 102133109 Continuity 102133109 RCD 102133109 E/Electrode 102133109

Tested by: Name (capital letters) PETER HUGHES Signature

Position: Electrical Test Engineer Date: 04/08/2023

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 5 Riser Schneider
Designation: DB CL 12/5
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 12, 9/L1)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Client Postcode: EC4R 9AB
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 5 Riser Schneider
Designation: DB CL 12/5
No. of ways: 1
No. of phases: 1
Associated RCD (if any): BS (EN) N/A
Operating at IΔn: 28.4 ms

TEST RESULTS

Table with columns: Circuit No. and Line, Circuit impedance Ω, Insulation resistance (Record lower reading), Polarity, Max. Measured Zs (Ω), RCD testing, Manual test button operation. Row 1/L1 contains test data.

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 03/08/2023 To 03/08/2023
Date(s) live testing: 03/08/2023 To 03/08/2023
Test instrument serial number(s):
Loop impedance: 102133109
Insulation resistance: 102133109
Continuity: 102133109
RCD: 102133109
E/Electrode: 102133109
Tested by: Name (capital letters) PETER HUGHES
Signature: [Signature]
Position: Electrical Test Engineer
Date: 03/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3  N/A

Location: Room 6 Riser Schneider

Designation: DB CL 12/6

No. of ways: 1

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 12, 9/L1)

No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A

Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (kA)	BS 7671 Max. permitted Zs Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 6 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Client Postcode: EC4R 9AB
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 6 Riser Schneider
Designation: DB CL 12/6
No. of ways: 1
No. of phases: 1
Supply polarity confirmed: [checked]
Phase sequence confirmed: [ ]
SPD: [ ] Operational status confirmed [ ] Not applicable [checked]

Complete only if the distribution board is not connected directly to the origin of the installation
Associated RCD (if any): BS (EN) N/A
Zdb: 0.0 Ohms
Operating at Idn: 28.6 ms
Ipr: 0.0 kA
No. of poles: N/A
Time delay (if applicable): N/A

TEST RESULTS

Table with 15 columns: Circuit No and Line, Ring final circuits only (r1, m, r2), Fig 8 Check, R1R2 or R2 (R1+R2, R2), Insulation resistance (Test voltage, L/L, L/N, L/E, N/E), Polarity, Max Measured Zs, RCD testing (All RCDs Idn), Manual test button operation (RCD, AFDD). Row 1/L1 contains test results.

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 02/08/2023 To 02/08/2023
Date(s) live testing: 02/08/2023 To 02/08/2023
Test instrument serial number(s): 102133109
Loop impedance: 102133109
Insulation resistance: 102133109
Continuity: 102133109
RCD: 102133109
E/Electrode: 102133109
Tested by: Name (capital letters) PETER HUGHES
Position: Electrical Test Engineer
Date: 02/08/2023
Signature: [Handwritten Signature]

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



**Client Name** UPP Residential Services Ltd  
**Client Address** First Floor, 12 Arthur Street London  
**Client Postcode** EC4R 9AB

**Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea  
**Postcode** SA1 8EN

**Distribution board details - Complete in every case**  
 SPD Details: Type(s)\* T1  T2  T3  N/A   
 Location Room 7 Riser Schneider  
 Designation DB CL 12/7  
 No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**  
 Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 12, 8/L1)  
 No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
 Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Room 7 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 §: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd			<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB	<b>Installation Postcode</b>	SA1 8EN		

<b>Distribution board details - Complete in every case</b>				<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			
Location	Room 7 Riser Schneider			Associated RCD (if any):	BS (EN)	N/A	
Designation	DB CL 12/7			Z <sub>db</sub>	Ω	Operating at I <sub>Δn</sub>	28.4 ms
No. of ways	1	<input checked="" type="checkbox"/>	Supply polarity confirmed	<input type="checkbox"/>	Phase sequence confirmed		
No. of phases	1	SPD:	<input type="checkbox"/>	Operational status confirmed	<input checked="" type="checkbox"/>	Not applicable	
		I <sub>pr</sub>	0. kA	No. of poles	N/A		
		Time delay (if applicable)	N/A				

## TEST RESULTS

Circuit No and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			All RCDs I <sub>Δn</sub> ms	RCD (✓)	AFDD (✓)	
	r1	r <sub>m</sub>	r2											
1/L1	N/A	N/A	N/A	N/A	0.30	N/A	250	>999	>999	✓	0.71	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing		03/08/2023	To	03/08/2023
		Date(s) live testing		03/08/2023	To	03/08/2023
Test instrument serial number(s)						
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109	RCD
E/Electrode	102133109					
Tested by: Name (capital letters)	PETER HUGHES			Signature		
Position	Electrical Test Engineer		Date	03/08/2023		



ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 8 Riser Schneider
Designation: DB CL 12/8
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 12, 8/L1)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Room 8 Riser Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 12/8	Z <sub>db</sub>	0. <input type="text"/> Ω Operating at IΔn <input type="text"/> ms
No. of ways	1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub>	0. <input type="text"/> kA No. of poles <input type="text"/> Time delay (if applicable) <input type="text"/>
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation		
	Ring final circuits only			E1g8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)				L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r2	r3		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.29	N/A	250	>999	>999	✓	0.67	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing		02/08/2023	To	02/08/2023			
		Date(s) live testing		02/08/2023	To	02/08/2023			
Test instrument serial number(s)									
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109	RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES			Signature					
Position	Electrical Test Engineer	Date	02/08/2023						

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 13 Kitchen Schneider Designation DB CL 13 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 12/L2) No. of phases 1 BS(EN) 60947 MCCB Type N/A Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
---	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L2	Lights Rooms 1,2, 3	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L2	Lights Rooms 6,7, 8	A3	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L2	Lights Rooms 4,5	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL 13/3, DB CL 13/1, DB CL 13/2)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L2	Sub Mains(DB CL 13/8, DB CL 13/6, DB CL 13/7)	A3	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
8/L2	Sub Mains(DB CL 13/5, DB CL 13/4)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L2	Sockets Kitchen LHS	A3	B	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L2	Sockets Kitchen RHS	A3	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L2	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L2	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 13 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 13	Z <sub>db</sub>	0.11 Ω Operating at IΔn N/A ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	2.18 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation				
	Ring final circuits only			E <sub>fig 8</sub> check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2									
1/L2	N/A	N/A	N/A	N/A	0.50	N/A	250	>999	>999	✓	0.63	28.6	✓	N/A	
2/L2	N/A	N/A	N/A	N/A	0.62	N/A	250	>999	>999	✓	0.76	28.4	✓	N/A	
3/L2	N/A	N/A	N/A	N/A	0.57	N/A	250	>999	>999	✓	0.71	28.6	✓	N/A	
4/L2	N/A	N/A	N/A	N/A	0.53	N/A	250	>999	>999	✓	0.67	29.2	✓	N/A	
5/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L2	0.40	0.38	0.66	✓	0.27	N/A	250	>999	>999	✓	0.41	28.6	✓	N/A	
7/L2	0.45	0.46	0.71	✓	0.29	N/A	250	>999	>999	✓	0.43	28.6	✓	N/A	
8/L2	0.31	0.31	0.49	✓	0.20	N/A	250	>999	>999	✓	0.34	28.4	✓	N/A	
9/L2	0.28	0.29	0.44	✓	0.18	N/A	250	>999	>999	✓	0.29	28.2	✓	N/A	
10/L2	0.30	0.30	0.45	✓	0.19	N/A	250	>999	>999	✓	0.32	29.0	✓	N/A	
11/L2	N/A	N/A	N/A	N/A	0.12	N/A	250	>999	>999	✓	0.25	28.8	✓	N/A	
12/L2	N/A	N/A	N/A	N/A	0.12	N/A	250	>999	>999	✓	0.24	28.8	✓	N/A	
13/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
14/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	06/08/2023	To	06/08/2023
		Date(s) live testing	06/08/2023	To	06/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position		Electrical Test Engineer		Date	
		06/08/2023			

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 1 Riser Schneider
Designation: DB CL 13/1
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 13, 6/L2)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²) (L/N, CPC), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs (Ω) (80%), RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



**Client Name** UPP Residential Services Ltd  
**Client Address** First Floor, 12 Arthur Street London  
**Client Postcode** EC4R 9AB  
**Installation Address** Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea  
**Postcode** SA1 8EN

**Distribution board details - Complete in every case**  
 SPD Details: Type(s)\* T1  T2  T3†  N/A   
 Location Room 2 Riser Schneider  
 Designation DB CL 13/2  
 No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**  
 Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 13, 6/L2)  
 No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A  
 Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD				
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)	
1/L2	Room 2 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	80%	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location:   
 Designation:

No. of ways:   Supply polarity confirmed  Phase sequence confirmed  
 No. of phases:  SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)   
 $Z_{db}$    $\Omega$  Operating at  $I_{\Delta n}$   ms  
 $I_{pr}$   kA No. of poles  Time delay (if applicable)

## TEST RESULTS

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)			Polarity	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing All RCDs $I_{\Delta n}$ ms	Manual test button operation			
	Ring final circuits only			$R1R2$ or $R2$	Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )				RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )		
	r1	r	r2										$R1 + R2$	$R2$
1/L2	N/A	N/A	N/A	N/A	0.20	N/A	250	>999	>999	$\checkmark$	0.55	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing:  To:   
 Date(s) live testing:  To:

Test instrument serial number(s):

Loop impedance:  Insulation resistance:  Continuity:  RCD:  E/Electrode:

Tested by: Name (capital letters)  Signature   
 Position  Date



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London		<b>Postcode</b>
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Room 3 Riser Schneider Designation DB CL 13/3 No. of ways 1		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 13, 6/L2) No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IDn mA	
---	--	---	--

SCHEDULE OF CIRCUIT DETAILS																
Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other <input type="checkbox"/> Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 3 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Room 3 Riser Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 13/3	Z <sub>db</sub>	0.41 Ω
No. of ways	1	Operating at IΔn	28.6 ms
No. of phases	1	SPD:	<input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable
		I <sub>pr</sub>	kA No. of poles N/A
		Time delay (if applicable)	N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation		
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N			L/E, N/E	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	m	r2		R1 + R2	R2		M(Ω)			M(Ω)			
1/L2	N/A	N/A	N/A	N/A	0.23	N/A	250	>999	>999	✓	0.55	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	06/08/2023	To	06/08/2023
		Date(s) live testing	06/08/2023	To	06/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES		Signature		
Position	Electrical Test Engineer	Date	06/08/2023		

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London		<b>Postcode</b>
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>				<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			
SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>				Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 13, 8/L2)"/>			
Location <input type="text" value="Room 4 Riser Schneider"/>				No. of phases <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A			
Designation <input type="text" value="DB CL 13/4"/>				Nominal voltage <input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA			
No. of ways <input type="text" value="1"/>							

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method <i>:j:</i>	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other <input type="text" value="80%"/> <i>§</i>	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 4 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Client Postcode: EC4R 9AB
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 4 Riser Schneider
Designation: DB CL 13/4
No. of ways: 1
No. of phases: 1
Supply polarity confirmed, SPD: Not applicable
Complete only if the distribution board is not connected directly to the origin of the installation
Associated RCD: BS (EN) N/A
Zdb: 0.34 Ohm, Operating at IΔn: 28.4 ms
Ipf: kA, No. of poles: N/A, Time delay: N/A

TEST RESULTS

Table with 15 columns: Circuit No. and Line, Ring final circuits only (r1, m, r2), Fig 8 check, R1R2 or R2, Test voltage, L/L, L/N, L/E, N/E, Polarity, Max. Measured Zs, RCD testing, Manual test button operation. Row 1: 1/L2, N/A, N/A, N/A, N/A, 0.25, N/A, 250, >999, >999, ✓, 0.65, N/A, N/A, N/A.

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 06/08/2023 To 06/08/2023
Date(s) live testing: 06/08/2023 To 06/08/2023
Test instrument serial number(s):
Loop impedance: 102133109, Insulation resistance: 102133109, Continuity: 102133109, RCD: 102133109, E/Electrode: 102133109
Tested by: Name (capital letters): PETER HUGHES, Signature: [Signature], Date: 06/08/2023
Position: Electrical Test Engineer

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>
SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 13, 8/L2)
Location Room 5 Riser Schneider	No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Designation DB CL 13/5	Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA
No. of ways 1	

SCHEDULE OF CIRCUIT DETAILS																
Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 5 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
:j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

# ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>
Location: Room 5 Riser Schneider	Associated RCD (if any): BS (EN) N/A
Designation: DB CL 13/5	Z <sub>db</sub> : 0.34 Ω Operating at IΔn: 28.4 ms
No. of ways: 1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub> : 0.56 kA No. of poles: N/A Time delay (if applicable): N/A
No. of phases: 1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable	

## TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation		
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)				L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r2	r3		R1 + R2	R2								
1/L2	N/A	N/A	N/A	N/A	0.19	N/A	250	>999	>999	✓	0.64	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing			Date(s) dead testing	06/08/2023	To	06/08/2023			
Date(s) live testing			06/08/2023	To	06/08/2023				
Test instrument serial number(s)									
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109	RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES		Signature						
Position	Electrical Test Engineer	Date	06/08/2023						

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> <input style="width: 95%;" type="text" value="UPP Residential Services Ltd"/> <b>Client Address</b> <input style="width: 95%;" type="text" value="First Floor, 12 Arthur Street London"/> <b>Client Postcode</b> <input style="width: 80%;" type="text" value="EC4R 9AB"/>	<b>Installation Address</b> <input style="width: 98%;" type="text" value="Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea"/> <b>Postcode</b> <input style="width: 80%;" type="text" value="SA1 8EN"/>
---	---

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3+ <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location <input style="width: 95%;" type="text" value="Room 6 Riser Schneider"/> Designation <input style="width: 95%;" type="text" value="DB CL 13/6"/> No. of ways <input style="width: 40%;" type="text" value="1"/>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input style="width: 95%;" type="text" value="Sub Mains(DB CL 13, 7/L2)"/> No. of phases <input style="width: 30%;" type="text" value="1"/> BS(EN) <input style="width: 20%;" type="text" value="61009 RCD/RCBO"/> Type <input style="width: 30%;" type="text" value="B"/> Rating <input style="width: 30%;" type="text" value="32"/> A Nominal voltage <input style="width: 30%;" type="text" value="230"/> V RCD BS(EN) <input style="width: 20%;" type="text" value="N/A"/> Type <input style="width: 30%;" type="text" value="N/A"/> Rating <input style="width: 30%;" type="text" value="N/A"/> IΔn mA
---	--

SCHEDULE OF CIRCUIT DETAILS																
Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L2	Room 6 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Client Postcode</b> EC4R 9AB
	<b>Installation Postcode</b> SA1 8EN

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>
Location Room 6 Riser Schneider	Associated RCD (if any): BS (EN) N/A
Designation DB CL 13/6	Z <sub>db</sub> 0.43 Ω Operating at IΔn 28.6 ms
No. of ways 1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub> kA No. of poles N/A Time delay (if applicable) N/A
No. of phases 1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable	

TEST RESULTS

Circuit No and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation		
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFDD (✓)	
	r1	m	r2											R1 + R2
1/L2	N/A	N/A	N/A	N/A	0.19	N/A	250	>999	>999	✓	0.60	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing			Date(s) dead testing	06/08/2023	To	06/08/2023				
			Date(s) live testing	06/08/2023	To	06/08/2023				
Test instrument serial number(s)	Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109	RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES			Signature		<i>Peter Hughes</i>		Date		06/08/2023
Position	Electrical Test Engineer									







ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 T2 T3+ N/A
Location: Room 8 Riser Schneider
Designation: DB CL 13/8
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 13, 7/L2)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (s), Overcurrent protective devices (BS EN Number, Type No., Rating (A)), Breaking capacity (KA), BS 7671 Max. permitted Zs, RCD (BS EN Number, Type No., Idn (mA), Rating (A)).

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
.j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 14 Kitchen Schneider Designation DB CL 14 No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 12/L3) No. of phases 1 BS(EN) 60947 MCCB Type N/A Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
---	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Lights Kitchen	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L3	Lights Rooms 1, 2	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L3	Lights Rooms 3, 4	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/L3	Lights Rooms 5, 6	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
5/L3	Lights Rooms 7, 8	A3	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
6/L3	Sub Mains(DB CL 14/2, DB CL 14/1)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
7/L3	Sub Mains(DB CL 14/4, DB CL 14/3)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
8/L3	Sub Mains(DB CL 14/8, DB CL 14/7)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
9/L3	Sub Mains(DB CL 14/6, DB CL 14/5)	A3	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
10/L3	Sockets Kitchen LHS	A3	B	7	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
11/L3	Sockets Kitchen RHS	A3	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
12/L3	Cooker LHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
13/L3	Cooker RHS	A3	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 14 Kitchen Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 14	Z <sub>db</sub>	0.11 Ω Operating at IΔn N/A ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	2.03 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation				
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2									
1/L3	N/A	N/A	N/A	N/A	0.51	N/A	250	>999	>999	✓	0.65	28.6	✓	N/A	
2/L3	N/A	N/A	N/A	N/A	0.63	N/A	250	>999	>999	✓	0.77	28.9	✓	N/A	
3/L3	N/A	N/A	N/A	N/A	0.62	N/A	250	>999	>999	✓	0.79	28.2	✓	N/A	
4/L3	N/A	N/A	N/A	N/A	0.59	N/A	250	>999	>999	✓	0.73	28.2	✓	N/A	
5/L3	N/A	N/A	N/A	N/A	0.71	N/A	250	>999	>999	✓	0.83	28.4	✓	N/A	
6/L3	0.33	0.33	0.53	✓	0.22	N/A	250	>999	>999	✓	0.34	28.4	✓	N/A	
7/L3	0.35	0.36	0.57	✓	0.23	N/A	250	>999	>999	✓	0.35	28.2	✓	N/A	
8/L3	0.37	0.37	0.59	✓	0.25	N/A	250	>999	>999	✓	0.37	28.4	✓	N/A	
9/L3	0.36	0.34	0.55	✓	0.23	N/A	250	>999	>999	✓	0.36	28.4	✓	N/A	
10/L3	0.29	0.29	0.45	✓	0.18	N/A	250	>999	>999	✓	0.29	28.6	✓	N/A	
11/L3	0.31	0.32	0.47	✓	0.20	N/A	250	>999	>999	✓	0.34	28.8	✓	N/A	
12/L3	N/A	N/A	N/A	N/A	0.12	N/A	250	>999	>999	✓	0.25	29.2	✓	N/A	
13/L3	N/A	N/A	N/A	N/A	0.13	N/A	250	>999	>999	✓	0.26	28.0	✓	N/A	
14/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	06/08/2023	To	06/08/2023
		Date(s) live testing	06/08/2023	To	06/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position		Electrical Test Engineer		Date	
		06/08/2023			

# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location <input type="text" value="Room 1 Riser Schneider"/> Designation <input type="text" value="DB CL 14/1"/> No. of ways <input type="text" value="1"/>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 14, 6/L3)"/> No. of phases <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A Nominal voltage <input type="text" value="230"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA	
--	--	--	--

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD				
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)	
1/L3	Room 1 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	80%	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results





**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3+ <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Room 2 Riser Schneider Designation DB CL 14/2 No. of ways 1		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 14, 6/L3) No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IDn mA	
--	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method ∴	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Idn (mA)	Rating (A)
1/L3	Room 2 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ∴: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Client Postcode: EC4R 9AB
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 2 Riser Schneider
Designation: DB CL 14/2
No. of ways: 1
No. of phases: 1
SPD: Operational status confirmed
Not applicable
Complete only if the distribution board is not connected directly to the origin of the installation
Associated RCD (if any): BS (EN) N/A
Zdb: 0.34 Ohm
Operating at IΔn: 28.4 ms
Ipf: 0.67 kA
No. of poles: N/A
Time delay (if applicable): N/A

TEST RESULTS

Table with columns: Circuit No. and Line, Circuit impedance Ohm, Insulation resistance (Record lower reading), Polarity, Max. Measured Zs (Ohm), RCD testing, Manual test button operation. Row 1: 1/L3, N/A, N/A, N/A, N/A, 0.23, N/A, 250, >999, >999, checkmark, 0.59, N/A, N/A, N/A.

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 06/08/2023 To 06/08/2023
Date(s) live testing: 06/08/2023 To 06/08/2023
Test instrument serial number(s):
Loop impedance: 102133109
Insulation resistance: 102133109
Continuity: 102133109
RCD: 102133109
E/Electrode: 102133109
Tested by: Name (capital letters): PETER HUGHES
Signature: [Signature]
Position: Electrical Test Engineer
Date: 06/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b>	First Floor, 12 Arthur Street London		<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB			

<b>Distribution board details - Complete in every case</b>				<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			
SPD Details: Type(s)*		T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3+ <input type="checkbox"/> N/A <input checked="" type="checkbox"/>		Overcurrent protective device for the distribution circuit:		Supply to distribution board is from	
Location		Room 3 Riser Schneider		No. of phases		1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A	
Designation		DB CL 14/3		Nominal voltage		230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
No. of ways		1					

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 3 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	80% 3.49 (Ω)	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location  Associated RCD (if any): BS (EN)

Designation  Z<sub>db</sub>  Ω Operating at IΔn  ms

No. of ways   Supply polarity confirmed  Phase sequence confirmed

No. of phases  SPD:  Operational status confirmed  Not applicable

I<sub>pf</sub>  kA No. of poles  Time delay (if applicable)

**Complete only if the distribution board is not connected directly to the origin of the installation**

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation			
	Ring final circuits only			E <sub>fig 8</sub> check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L3	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	✓	0.64	N/A	N/A	N/A

**Details of circuits and/or installed equipment vulnerable to damage when testing**

Date(s) dead testing  To

Date(s) live testing  To

Test instrument serial number(s)

Loop impedance  Insulation resistance  Continuity  RCD  E/Electrode

Tested by: Name (capital letters)  Signature

Position  Date

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

**FT/EICR 2670000213307**

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b> First Floor, 12 Arthur Street London	<b>Postcode</b> SA1 8EN
<b>Client Postcode</b> EC4R 9AB	

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3  N/A

Location

Designation

No. of ways

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from

No. of phases  BS(EN)  Type  Rating  A

Nominal voltage  V RCD BS(EN)  Type  Rating  IΔn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method <sup>j:</sup>	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other <sup>§</sup>	RCD				
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)	
1/L3	Room 4 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	80%	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b> UPP Residential Services Ltd		<b>Installation Address</b> Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	
<b>Client Address</b> First Floor, 12 Arthur Street London		<b>Client Postcode</b> EC4R 9AB	<b>Installation Postcode</b> SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 4 Riser Schneider  
 Designation: DB CL 14/4  
 No. of ways: 1  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 $Z_{db}$ : 0.35  $\Omega$  Operating at  $I\Delta n$ : 28.2 ms  
 $I_{pr}$ : 0.65 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance $\Omega$				Insulation resistance (Record lower reading)			Polarity	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing All RCDs $I\Delta n$ ms	Manual test button operation			
	Ring final circuits only			Fig 8 check ( $\checkmark$ )	R1R2 or R2		Test voltage V				L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )
	r1	r	r2		R1 + R2	R2								
1/L3	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	$\checkmark$	0.62	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing					Date(s) dead testing: 06/08/2023 To: 06/08/2023
					Date(s) live testing: 06/08/2023 To: 06/08/2023
Test instrument serial number(s)	Loop impedance: 102133109	Insulation resistance: 102133109	Continuity: 102133109	RCD: 102133109	E/Electrode: 102133109
Tested by: Name (capital letters)	PETER HUGHES			Signature:	
Position: Electrical Test Engineer	Date: 06/08/2023				

ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Client Address: First Floor, 12 Arthur Street London
Postcode: SA1 8EN
Client Postcode: EC4R 9AB

Distribution board details - Complete in every case
SPD Details: Type(s)\* T1 [ ] T2 [ ] T3+ [ ] N/A [x]
Location: Room 5 Riser Schneider
Designation: DB CL 14/5
No. of ways: 1
Complete only if the distribution board is not connected directly to the origin of the installation
Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 14, 9/L3)
No. of phases: 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A
Nominal voltage: 230 V RCD BS(EN) N/A Type N/A Rating N/A Idn mA

SCHEDULE OF CIRCUIT DETAILS

Table with 13 main columns: Circuit No. and Line, Circuit designation, Type of wiring, Ref. method, No. of points served, Circuit conductors csa (mm²), Maximum disconnection time (BS 7671), Overcurrent protective devices, Breaking capacity, BS 7671 Max. permitted Zs, RCD, and Rating (A). Row 1: 1/L3, Room 5 Sockets, A3, B, 6, 2.5, 1.5, 0.4, 60898 MCB, B, 10, 10, 3.49, N/A, N/A, N/A, N/A.

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results





# ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR **2670000213307**



**for Industrial/Commercial Premises**

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<p><b>Distribution board details - Complete in every case</b></p> <p>SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3+ <input type="checkbox"/> N/A <input checked="" type="checkbox"/></p> <p>Location <input style="width:100%;" type="text" value="Room 6 Riser Schneider"/></p> <p>Designation <input style="width:100%;" type="text" value="DB CL 14/6"/></p> <p>No. of ways <input style="width:100%;" type="text" value="1"/></p>	<p><b>Complete only if the distribution board is not connected directly to the origin of the installation</b></p> <p>Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input style="width:100%;" type="text" value="Sub Mains(DB CL 14, 9/L3)"/></p> <p>No. of phases <input style="width:100%;" type="text" value="1"/> BS(EN) <input style="width:100%;" type="text" value="61009 RCD/RCBO"/> Type <input style="width:100%;" type="text" value="B"/> Rating <input style="width:100%;" type="text" value="32"/> A</p> <p>Nominal voltage <input style="width:100%;" type="text" value="230"/> V RCD BS(EN) <input style="width:100%;" type="text" value="N/A"/> Type <input style="width:100%;" type="text" value="N/A"/> Rating <input style="width:100%;" type="text" value="N/A"/> Idn mA</p>
--	---

## SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § (Ω)	RCD				
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)	
1/L3	Room 6 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 §: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		
Location	Room 6 Riser Schneider	Associated RCD (if any):	BS (EN)	N/A
Designation	DB CL 14/6	Z <sub>db</sub>	0.36	Ω
No. of ways 1		Operating at IΔn 28.4 ms		
<input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed		I <sub>pr</sub>	0.65	kA
No. of phases 1		No. of poles		N/A
SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		Time delay (if applicable) N/A		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation		
	Ring final circuits only			R1R2 or R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms			RCD (✓)	AFDD (✓)		
	r1	m	r2					Fig 8 check (✓)			R1 + R2	R2		
1/L3	N/A	N/A	N/A	N/A	0.24	N/A	250	>999	>999	✓	0.63	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing 06/08/2023 To 06/08/2023	
		Date(s) live testing 06/08/2023 To 06/08/2023	
Test instrument serial number(s)			
Loop impedance	102133109	Insulation resistance	102133109
Continuity	102133109	RCD	102133109
E/Electrode	102133109		
Tested by: Name (capital letters)	PETER HUGHES	Signature	
Position	Electrical Test Engineer	Date	06/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

**Distribution board details - Complete in every case**

SPD Details: Type(s)\* T1  T2  T3+  N/A

Location Room 7 Riser Schneider

Designation DB CL 14/7

No. of ways 1

**Complete only if the distribution board is not connected directly to the origin of the installation**

Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(DB CL 14, 8/L3)

No. of phases 1 BS(EN) 61009 RCD/RCBO Type B Rating 32 A

Nominal voltage 230 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 7 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT - Test Results

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name: UPP Residential Services Ltd
Client Address: First Floor, 12 Arthur Street London
Installation Address: Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
Installation Postcode: SA1 8EN

Distribution board details - Complete in every case
Location: Room 7 Riser Schneider
Designation: DB CL 14/7
No. of ways: 1
No. of phases: 1
SPD: Operational status confirmed
Not applicable

TEST RESULTS

Table with 15 columns: Circuit No. and Line, Ring final circuits only (r1, m, r2), Fig 8 check, R1R2 or R2 (R1+R2, R2), Test voltage (V), Insulation resistance (M(Ω)), Polarity, Max. Measured Zs (Ω), RCD testing (ms), Manual test button operation (RCD, AFDD). Row 1/L3 shows results for a live circuit.

Details of circuits and/or installed equipment vulnerable to damage when testing
Date(s) dead testing: 06/08/2023 To 06/08/2023
Date(s) live testing: 06/08/2023 To 06/08/2023
Test instrument serial number(s): 102133109
Tested by: Name (capital letters) PETER HUGHES, Position Electrical Test Engineer, Date 06/08/2023

## ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location <input type="text" value="Room 8 Riser Schneider"/> Designation <input type="text" value="DB CL 14/8"/> No. of ways <input type="text" value="1"/>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB CL 14, 8/L3)"/> No. of phases <input type="text" value="1"/> BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="B"/> Rating <input type="text" value="32"/> A Nominal voltage <input type="text" value="400"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="N/A"/> IΔn mA
--	--

### SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § <input type="text" value="80%"/> (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L3	Room 8 Sockets	A3	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	3.49	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

---

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Room 8 Riser Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB CL 14/8	Z <sub>db</sub>	0.37 Ω Operating at IΔn 28.4 ms
No. of ways	1 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub>	0.64 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation		
	Ring final circuits only			E <sub>fig 8</sub> check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	m	r2		R1 + R2	R2									
				N/A			N/A	N/A	N/A				N/A	N/A	N/A
1/L3	N/A	N/A	N/A	N/A	0.25	N/A	250	>999	>999	✓	0.64	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	06/08/2023	To	06/08/2023
		Date(s) live testing	06/08/2023	To	06/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)	PETER HUGHES			Signature	
Position	Electrical Test Engineer	Date	06/08/2023		

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input checked="" type="checkbox"/> T2 <input checked="" type="checkbox"/> T3 <input type="checkbox"/> N/A <input type="checkbox"/> Location Plant Room Schneider Designation DB PL P No. of ways 18		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 14/TP) No. of phases 3 BS(EN) 60947 MCCB Type N/A Rating 63 A Nominal voltage V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
--	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Sockets Plant Room	D1	B	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
1/L2	Tubular Heater	A3	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
1/L3	Head of Shaft AOV	Q2	B	1	2.5	2.5	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
2/TP	Fan 6	G2	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
3/TP	Fan 7	G2	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
4/TP	Fan 8	G2	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
5/TP	Fan 9	G2	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
6/TP	Fan 10	G2	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
7/TP	Fan 5	G2	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
8/TP	Fan 4	G2	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
9/TP	Fan 2	G2	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
10/TP	Fan 3	G2	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
11/TP	Fan 1	G2	E	1	2.5	SWA	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
12/L1	Fan Control Cct	D1	B	1	2.5	2.5	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
12/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/TP	SPD	D1	B	1	16	16	5	60898 MCB	C	50	10	0.35	N/A	N/A	N/A	N/A
14/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Plant Room Schneider  
Designation: DB PL P

No. of ways: 18  Supply polarity confirmed  Phase sequence confirmed

No. of phases: 3 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A

Z<sub>db</sub>: 0.12 Ω Operating at IΔn N/A ms

I<sub>pf</sub>: 3.43 kA No. of poles N/A Time delay (if applicable) N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation	
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1	0.28	0.27	0.36	✓	0.16	N/A	250	>999	>999	✓	0.30	28.4	✓	N/A
1/L2	N/A	N/A	N/A	N/A	0.14	N/A	250	>999	>999	✓	0.29	N/A	N/A	N/A
1/L3	N/A	N/A	N/A	N/A	0.08	N/A	250	>999	>999	✓	0.23	N/A	N/A	N/A
2/TP	N/A	N/A	N/A	N/A	0.25	N/A	250	>999	>999	✓	0.40	N/A	N/A	N/A
3/TP	N/A	N/A	N/A	N/A	0.22	N/A	250	>999	>999	✓	0.37	N/A	N/A	N/A
4/TP	N/A	N/A	N/A	N/A	0.24	N/A	250	>999	>999	✓	0.39	N/A	N/A	N/A
5/TP	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	✓	0.41	N/A	N/A	N/A
6/TP	N/A	N/A	N/A	N/A	0.23	N/A	250	>999	>999	✓	0.38	N/A	N/A	N/A
7/TP	N/A	N/A	N/A	N/A	0.29	N/A	250	>999	>999	✓	0.42	N/A	N/A	N/A
8/TP	N/A	N/A	N/A	N/A	0.28	N/A	250	>999	>999	✓	0.41	N/A	N/A	N/A
9/TP	N/A	N/A	N/A	N/A	0.31	N/A	250	>999	>999	✓	0.45	N/A	N/A	N/A
10/TP	N/A	N/A	N/A	N/A	0.30	N/A	250	>999	>999	✓	0.44	N/A	N/A	N/A
11/TP	N/A	N/A	N/A	N/A	0.34	N/A	250	>999	>999	✓	0.47	N/A	N/A	N/A
12/L1	N/A	N/A	N/A	N/A	0.09	N/A	250	>999	>999	✓	0.24	N/A	N/A	N/A
12/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/TP	N/A	N/A	N/A	N/A	0.01	N/A	250	>999	>999	✓	0.14	N/A	N/A	N/A
14/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 07/08/2023 To 07/08/2023  
Date(s) live testing: 07/08/2023 To 07/08/2023

Test instrument serial number(s):

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature: *Peter Hughes*

Position: Electrical Test Engineer Date: 07/08/2023



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input checked="" type="checkbox"/> T2 <input checked="" type="checkbox"/> T3 <input type="checkbox"/> N/A <input type="checkbox"/> Location Plant Room Schneider Designation DB PL L No. of ways 6		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 14/TP) No. of phases 3 BS(EN) 60947 MCCB Type N/A Rating 63 A Nominal voltage 400 V RCD BS(EN) Type Rating N/A IΔn mA	
---	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Lights Plant Room	D1	B	4	1.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
1/L2	Lights Stairs	D1	B	2	1.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Plant Room Schneider	Associated RCD (if any):	BS (EN)
Designation	DB PL L	Z <sub>db</sub>	0.12 Ω Operating at IΔn N/A ms
No. of ways	6 <input checked="" type="checkbox"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub>	3.43 kA No. of poles Time delay (if applicable)
No. of phases	3 SPD: <input checked="" type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation	
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.40	N/A	250	>999	>999	✓	0.54	28.2	✓	N/A
1/L2	N/A	N/A	N/A	N/A	0.33	N/A	250	>999	>999	✓	0.47	28.6	✓	N/A
1/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	07/08/2023	To	07/08/2023
		Date(s) live testing	07/08/2023	To	07/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position	Electrical Test Engineer	Date	07/08/2023		

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 11 Room 1 Riser Designation DB LL 3 P No. of ways 8		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 9/TP) No. of phases 3 BS(EN) 60947 MCCB Type N/A Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
--	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Sockets Cleaners 5th Floor	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
1/L2	Sockets Cleaners 6th Floor	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	Smoke Shaft AOD 5th Floor	O2	B	1	2.5	2.5	0.4	60898 MCB	C	16	10	1.09	N/A	N/A	N/A	N/A
2/L2	Smoke Shaft AOD 6th Floor	O2	B	1	2.5	2.5	0.4	60898 MCB	C	16	10	1.09	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L2	Head of Stairs AOV	O2	B	1	2.5	2.5	0.4	60898 MCB	C	16	10	1.09	N/A	N/A	N/A	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 11 Room 1 Riser	Associated RCD (if any):	BS (EN) N/A
Designation	DB LL 3 P	Z <sub>db</sub>	0.12 Ω Operating at IΔn N/A ms
No. of ways	8 <input checked="" type="checkbox"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	3.29 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	3 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation	
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1	0.72	0.71	1.16	✓	0.47	N/A	250	>999	>999	✓	0.61	28.0	✓	N/A
1/L2	0.85	0.87	1.35	✓	0.55	N/A	250	>999	>999	✓	0.71	28.8	✓	N/A
1/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	N/A	N/A	N/A	N/A	0.28	N/A	250	>999	>999	✓	0.42	N/A	N/A	N/A
2/L2	N/A	N/A	N/A	N/A	0.33	N/A	250	>999	>999	✓	0.48	N/A	N/A	N/A
2/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L2	N/A	N/A	N/A	N/A	0.36	N/A	250	>999	>999	✓	0.51	N/A	N/A	N/A
5/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	07/08/2023	To	07/08/2023
		Date(s) live testing	07/08/2023	To	07/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position	Electrical Test Engineer	Date	07/08/2023		

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 11 Room 1 Riser Designation DB LL 3 L No. of ways 6		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 9/TP) No. of phases 3 BS(EN) 60947 MCCB Type N/A Rating 63 A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
--	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Lights Corridor 5th Floor Flat 12	A3	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
1/L2	Lights Corridor 6th Floor Flat 14	A3	B	6	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	Lights Stairs 5th Floor	A3	B	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L2	Lights Stairs 6th Floor	A3	B	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	Lights Corridor 5th Floor Flat 11	A3	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L2	Lights Corridor 6th Floor Flat 13	A3	B	10	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Flat 11 Room 1 Riser  
Designation: DB LL 3 L

No. of ways: 6  Supply polarity confirmed  Phase sequence confirmed  
No. of phases: 3 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
Z<sub>db</sub>: 0.12 Ω Operating at IΔn: N/A ms  
I<sub>pr</sub>: 3.29 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation			
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.49	N/A	250	>999	>999	✓	0.65	28.2	✓	N/A
1/L2	N/A	N/A	N/A	N/A	0.46	N/A	250	>999	>999	✓	0.59	28.8	✓	N/A
1/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	N/A	N/A	N/A	N/A	0.63	N/A	250	>999	>999	✓	0.78	28.4	✓	N/A
2/L2	N/A	N/A	N/A	N/A	0.74	N/A	250	>999	>999	✓	0.88	28.0	✓	N/A
2/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	N/A	N/A	N/A	N/A	0.53	N/A	250	>999	>999	✓	0.67	28.8	✓	N/A
3/L2	N/A	N/A	N/A	N/A	0.63	N/A	250	>999	>999	✓	0.79	28.2	✓	N/A
3/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 07/08/2023 To 07/08/2023  
Date(s) live testing: 07/08/2023 To 07/08/2023

Test instrument serial number(s):

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature: *Peter Hughes*  
Position: Electrical Test Engineer Date: 07/08/2023

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 7 Room 1 Riser Schneider Designation DB LL 2 P No. of ways 8		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 5/TP) No. of phases 3 BS(EN) Type Rating A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method :j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Cleaners Sockets 2nd Floor	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
1/L2	Cleaners Sockets 3rd Floor	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
1/L3	Cleaners Sockets 4th Floor	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
2/L1	Smoke Shaft AOD 2nd Floor	O2	B	1	2.5	2.5	0.4	60898 MCB	C	16	10	1.09	N/A	N/A	N/A	N/A
2/L2	Smoke Shaft AOD 3rd Floor	O2	B	1	2.5	2.5	0.4	60898 MCB	C	16	10	1.09	N/A	N/A	N/A	N/A
2/L3	Smoke Shaft AOD 4th Floor	O2	B	1	2.5	2.5	0.4	60898 MCB	C	16	10	1.09	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 :j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Flat 7 Room 1 Riser Schneider  
 Designation: DB LL 2 P

No. of ways: 8  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 3 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.11 Ω Operating at IΔn \_\_\_\_\_ ms  
 I<sub>pf</sub>: 3.38 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation	
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1	0.79	0.77	1.29	✓	0.52	N/A	250	>999	>999	✓	0.68	28.0	✓	N/A
1/L2	0.66	0.64	1.06	✓	0.43	N/A	250	>999	>999	✓	0.57	28.2	✓	N/A
1/L3	0.81	0.80	1.31	✓	0.53	N/A	250	>999	>999	✓	0.65	28.6	✓	N/A
2/L1	N/A	N/A	N/A	N/A	0.31	N/A	250	>999	>999	✓	0.45	28.4	✓	N/A
2/L2	N/A	N/A	N/A	N/A	0.28	N/A	250	>999	>999	✓	0.41	28.2	✓	N/A
2/L3	N/A	N/A	N/A	N/A	0.33	N/A	250	>999	>999	✓	0.45	28.8	✓	N/A
3/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 08/08/2023 To 08/08/2023  
 Date(s) live testing: 08/08/2023 To 08/08/2023

Test instrument serial number(s): \_\_\_\_\_

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 08/08/2023



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Flat 7 Room 1 Riser Schneider Designation DB LL 2 L No. of ways 6		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(Rising Bus Bar, 5/TP) No. of phases 3 BS(EN) Type Rating A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method	No. of points served	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Lights Corridor 2nd Flr Flat 6	A3	B	6	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
1/L2	Lights Corridor 3rd Flr Flat 8	A3	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
1/L3	Lights Corridor 4th Flr Flat 10	A3	B	6	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L1	Lights Stairs 2nd Flr	A3	B	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L2	Lights Stairs 3rd Flr	A3	B	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
2/L3	Lights Stairs 4th Flr	A3	B	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L1	Lights Corridor 2nd Flr Flat 5	A3	B	10	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L2	Lights Corridor 3rd Flr Flat 7	A3	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
3/L3	Lights Corridor 4th Flr Flat 9	A3	B	10	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	1.75	61009	AC	30	10
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Flat 7 Room 1 Riser Schneider	Associated RCD (if any):	BS (EN) N/A
Designation	DB LL 2 L	Z <sub>db</sub>	0.11 Ω Operating at IΔn _____ ms
No. of ways	6 <input checked="" type="checkbox"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	3.38 kA No. of poles N/A Time delay (if applicable) N/A
No. of phases	3 SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation	
	Ring final circuits only			Fig 8 Check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFDD (✓)
	r1	r2	r3		R1 + R2	R2								
1/L1	N/A	N/A	N/A	N/A	0.59	N/A	250	>999	>999	✓	0.64	28.4	✓	N/A
1/L2	N/A	N/A	N/A	N/A	0.68	N/A	250	>999	>999	✓	0.82	28.8	✓	N/A
1/L3	N/A	N/A	N/A	N/A	0.83	N/A	250	>999	>999	✓	0.97	29.0	✓	N/A
2/L1	N/A	N/A	N/A	N/A	0.57	N/A	250	>999	>999	✓	0.71	29.4	✓	N/A
2/L2	N/A	N/A	N/A	N/A	0.52	N/A	250	>999	>999	✓	0.66	28.6	✓	N/A
2/L3	N/A	N/A	N/A	N/A	0.64	N/A	250	>999	>999	✓	0.77	28.6	✓	N/A
3/L1	N/A	N/A	N/A	N/A	0.58	N/A	250	>999	>999	✓	0.73	28.8	✓	N/A
3/L2	N/A	N/A	N/A	N/A	0.51	N/A	250	>999	>999	✓	0.65	28.2	✓	N/A
3/L3	N/A	N/A	N/A	N/A	0.66	N/A	250	>999	>999	✓	0.79	28.4	✓	N/A
4/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	08/08/2023	To	08/08/2023
		Date(s) live testing	08/08/2023	To	08/08/2023
Test instrument serial number(s)					
Loop impedance	102133109	Insulation resistance	102133109	Continuity	102133109
		RCD	102133109	E/Electrode	102133109
Tested by: Name (capital letters)		PETER HUGHES		Signature	
Position	Electrical Test Engineer	Date	08/08/2023		

**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 2670000213307

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Postcode</b>	SA1 8EN
<b>Client Postcode</b>	EC4R 9AB		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input checked="" type="checkbox"/> T2 <input checked="" type="checkbox"/> T3 <input type="checkbox"/> N/A <input type="checkbox"/> Location Flat 1 Riser RHS in Corridor Schneider Designation DB LL 1 P No. of ways 8		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from Sub Mains(MPB, 5/TP) No. of phases 3 BS(EN) Type Rating A Nominal voltage 400 V RCD BS(EN) N/A Type N/A Rating N/A IΔn mA	
---	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method j:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (s)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Cleaners Sockets Grd Floor	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
1/L2	CDO Socket Comms Room 1	A3	B	1	4	1.5	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
1/L3	Cleaners Sockets 1st Floor	A3	B	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
2/L1	Access Control Gnd Flr	A3	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
2/L2	CDO Socket Comms Room 1	A3	B	1	4	1.5	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
2/L3	Smoke Shaft AOD 1st Flr	O2	B	1	4	1.5	0.4	60898 MCB	C	16	10	1.09	N/A	N/A	N/A	N/A
3/L1	Auto Front Door	A3	B	2	2.5	1.5	0.4	60898 MCB	C	16	10	1.09	N/A	N/A	N/A	N/A
3/L2	CDO Socket Comms Room 3	A3	B	1	4	1.5	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	Powered Doors Gnd Flr	A3	B	2	2.5	1.5	0.4	60898 MCB	C	16	10	1.09	N/A	N/A	N/A	N/A
4/L2	Sockets Mains/Comms Room	A3	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	1.09	61009	AC	30	32
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	Intercom Gnd Flr	A3	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
5/L2	Tubular Heater Mains/Comms Room	A3	B	1	4	1.5	0.4	60898 MCB	B	16	10	2.18	N/A	N/A	N/A	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Smoke Shaft AOD Gnd Flr	O2	B	1	2.5	2.5	0.4	60898 MCB	C	16	10	1.09	N/A	N/A	N/A	N/A
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 2670000213307

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	UPP Residential Services Ltd	<b>Installation Address</b>	Swansea University Bay Campus, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
<b>Client Address</b>	First Floor, 12 Arthur Street London	<b>Client Postcode</b>	EC4R 9AB
		<b>Installation Postcode</b>	SA1 8EN

**Distribution board details - Complete in every case**

Location: Flat 1 Riser RHS in Corridor Schneider  
 Designation: DB LL 1 P

No. of ways: 8  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 3 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) N/A  
 Z<sub>db</sub>: 0.11 Ω Operating at IΔn: N/A ms  
 I<sub>pr</sub>: 3.38 kA No. of poles: N/A Time delay (if applicable): N/A

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing	Manual test button operation				
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	All RCDs IΔn ms	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2									
1/L1	0.44	0.42	0.70	✓	0.29	N/A	250	>999	>999	✓	0.43	28.6	✓	N/A	
1/L2	N/A	N/A	N/A	N/A	0.28	N/A	250	>999	>999	✓	0.42	N/A	N/A	N/A	
1/L3	0.41	0.41	0.65	✓	0.27	N/A	250	>999	>999	✓	0.41	28.2	✓	N/A	
2/L1	N/A	N/A	N/A	N/A	0.31	N/A	250	>999	>999	✓	0.45	N/A	N/A	N/A	
2/L2	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	✓	0.40	N/A	N/A	N/A	
2/L3	N/A	N/A	N/A	N/A	0.25	N/A	250	>999	>999	✓	0.39	N/A	N/A	N/A	
3/L1	N/A	N/A	N/A	N/A	0.29	N/A	250	>999	>999	✓	0.46	N/A	N/A	N/A	
3/L2	N/A	N/A	N/A	N/A	0.27	N/A	250	>999	>999	✓	0.41	N/A	N/A	N/A	
3/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L1	N/A	N/A	N/A	N/A	0.26	N/A	250	>999	>999	✓	0.40	N/A	N/A	N/A	
4/L2	0.49	0.50	0.82	✓	0.33	N/A	250	>999	>999	✓	0.47	28.8	✓	N/A	
4/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/L1	N/A	N/A	N/A	N/A	0.24	N/A	250	>999	>999	✓	0.37	N/A	N/A	N/A	
5/L2	N/A	N/A	N/A	N/A	0.30	N/A	250	>999	>999	✓	0.43	N/A	N/A	N/A	
5/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L1	N/A	N/A	N/A	N/A	0.20	N/A	250	>999	>999	✓	0.32	N/A	N/A	N/A	
6/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8/L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8/L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8/L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: 08/08/2023 To 08/08/2023  
 Date(s) live testing: 08/08/2023 To 08/08/2023

Test instrument serial number(s):

Loop impedance: 102133109 Insulation resistance: 102133109 Continuity: 102133109 RCD: 102133109 E/Electrode: 102133109

Tested by: Name (capital letters) PETER HUGHES Signature:

Position: Electrical Test Engineer Date: 08/08/2023



## Generic Continuation

### General Conditions of the Electrical Installation:

showing little sign of age (wear and tear) from where alterations/refurbishments have taken place, and is suitable for use within the environment its installed.

The Main Earth Terminal is in the Main Switch Room, Bonding connections are made here 150mm<sup>2</sup> G/Y from Cut Out. Water Bonding Connection is in the Main Switch Room 50mm<sup>2</sup> G/Y. The Gas is Bonded in the Gas Riser in the Lobby 50mm<sup>2</sup> G/Y. The Dry Riser is Bonded in the Dry Riser in the Lobby 50mm<sup>2</sup> G/Y.

### Limitations

A new regulation 421.1.7 has been introduced recommending the installation of Arc Fault detection devices conforming to BS EN 62606 to mitigate the risk of fire in AC final circuits of a fixed installation due to arc fault currents.

This installation has been designed and installed prior to July 2018. There is no evidence of over voltage protection within the electrical installation, we recommend Type 2 Surge Protective Devices be installed at the origin to reduce the risk of damage to the installation by external transient overvoltage's or switching.

Where there is no access to equipment at high level, insulation Resistance testing has been carried out were possible and visually inspected and recorded.

Where Circuits have Suspected Electronics Susceptible to Damage by High Voltage Insulation Testing Equipment, Insulation Tests have not been carried out.

External Outside lights, Visual Inspection Only due to Height, lights at soffit level.

### Abbreviations:-

MSP = Main Switch Panel  
DB = Electrical Distribution Board  
SWA = Steel Wired Armoured  
RCD = Residual Current Device  
mA = Milliamps  
Zs = Earth Fault Loop Impedance  
PVC = Polyvinyl Chloride  
RHS = Right Hand Side  
LHS = Left Hand Side  
CCTV = Closed Circuit Television  
ATM = Automatic Teller Machine  
EPOS = Electronic Point of Sale Systems  
FA = Fire Alarm  
IA = Intruder/Security System  
H&V = Heating and Ventilation Systems  
LT = Low Temperature  
HT = High Temperature

### Remarks:

#### DB LL 2 P Remarks:

2/L1 - Smoke Shaft AOD 2nd Floor: All Cable Type O2 in DB are FP200

#### DB LL 1 P Remarks:

2/L3 - Smoke Shaft AOD 1st Flr: All Cable Type O2 in DB are FP200