

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - MSP

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Mains Room [Schneider]		Supply to distribution board is from:		Associated RCD (if any): BS (EN) N/A
Num. of ways: 12 No. of phases: 3		Overcurrent protective device for the distribution circuit: Type: Rating: A Voltage:		Operating at 1 IΔn: N/A ms (if applicable)
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input checked="" type="checkbox"/>				Operating at 5 IΔn: N/A ms (if applicable)
				Loop impedance: 080408/5756
				Insulation resistance: 080408/5756
				Continuity: 080408/5756
				RCD: 080408/5756

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation MSP Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	BS EN Number	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) 80%
					L/N	CPC			Type No.	Rating (A)			
1/TP	SPD	D	B	1	50	50	0.4	60947 MCCB	N/A	160	35	N/A	LIM
2/TP	Sub Mains(BB 1)	F	E	1	70	SWA	5	60947 MCCB	N/A	160	35	N/A	LIM
3/TP	Water Booster Pump	F	E	1	6	6	0.4	60947 MCCB	N/A	32	25	N/A	LIM
4/L1	Disabled Refuge Panel	O	E	1	2.5	2.5	0.4	60947 MCCB	N/A	16	25	N/A	LIM
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	Sub Mains(BB 2)	F	E	1	50	SWA	5	60947 MCCB	N/A	160	35	N/A	LIM
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/L1	SPARE	F	E	1	16	16	5	60947 MCCB	N/A	63	35	N/A	LIM
9/L2	Sub Mains(DB EXT2)	F	E	1	16	16	5	60947 MCCB	N/A	40	25	N/A	LIM
9/L3	Fire Alarm Panel	O	E	1	2.5	2.5	0.4	60947 MCCB	N/A	16	25	N/A	LIM
10/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - BB 1

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="G Floor [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(MSP, 2/TP)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text"/> ms 30mA or below Operating at 5 IΔn <input type="text"/> ms Time delay (if applicable) <input type="text"/>
Num. of ways <input type="text" value="24"/> No. of phases <input type="text" value="3"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="60947 MCCB"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="160"/> A Voltage <input type="text"/>		
Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				
				Test instrument serial number(s)
				Loop impedance <input type="text" value="080408/5756"/>
				Insulation resistance <input type="text" value="080408/5756"/>
				Continuity <input type="text" value="080408/5756"/>
				RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="BB 1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	BS EN Number	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other <input type="text" value="80%"/> (Ω)
					L / N	GPC			Type No.	Rating (A)			
1/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/TP	Sub Mains(DB LL1/P, DB LL1/L)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Sub Mains(DB CL1)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	Sub Mains(DB CL3)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L3	Sub Mains(DB CL7)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
11/L1	Sub Mains(DB CL6)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
11/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A



CIRCUIT DETAILS													
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	BS EN Number	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
	BB 1				Circuit designation	L / N			CPC	Type No.			
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	Sub Mains(DB CL9)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
19/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
19/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
19/L3	Sub Mains(DB CL13)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
20/L1	Sub Mains(DB CL12)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
20/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
20/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
21/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22/L1	Lift	A	E	1	6	6	0.4	88-2 HRC	gG	16	80	N/A	1.94
22/L2	Sub Mains(DB CL15)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
22/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
23/TP	Sub Mains(DB LL2/L, DB LL2/P)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
24/TP	Sub Mains(DB PL)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB LL1/L

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Data Cab Room [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(BB 1, 2/TP)"/>		Associated RCD(if any): BS (EN) <input type="text" value="N/A"/> Above 30mA (if applicable) <input type="text" value="N/A"/> ms Operating at 1 IΔn 30mA or below Operating at 5 IΔn <input type="text" value="N/A"/> ms Time delay (if applicable) <input type="text" value="N/A"/> ms
Num. of ways <input type="text" value="12"/> No. of phases <input type="text" value="3"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="88-2 HRC"/>		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Type <input type="text" value="gG"/> Rating <input type="text" value="63"/> A Voltage <input type="text"/>		
Test instrument serial number(s)				
Loop impedance <input type="text" value="080408/5756"/>				
Insulation resistance <input type="text" value="080408/5756"/>				
Continuity <input type="text" value="080408/5756"/>				
RCD <input type="text" value="080408/5756"/>				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB LL1/L"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	G Floor Lighting 1	A	B	15	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
1/L2	G Floor Lighting 2	A	B	15	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
1/L3	G Floor Lighting 3	A	B	30	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L1	1st Floor Lights	A	B	17	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L2	1st Floor Lights 2	A	B	18	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L3	2nd Floor Lights	A	B	17	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L1	2nd Floor Lights 2	A	B	18	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L2	G Floor stairs + Lobby	A	B	24	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	Lighting Controller	A	B	1	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L2	1st Floor Lighting Stair + Lobby	A	B	18	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L3	2nd Floor Lighting Stair + Lobby	A	B	16	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L1	2nd Floor Lighting Corridor	A	B	18	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L2	G Floor Lighting Corridor	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L3	1st Floor Lighting Corridor	A	B	15	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB LL1/P

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Data Cab Room [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(BB 1, 2/TP)"/>		Associated RCD(if any): BS (EN) <input type="text" value="N/A"/> Above 30mA (if applicable) <input type="text" value="N/A"/> ms Operating at 1 IΔn <input type="text" value="N/A"/> ms 30mA or below <input type="text" value="N/A"/> ms Operating at 5 IΔn <input type="text" value="N/A"/> ms Time delay (if applicable) <input type="text" value="N/A"/> ms
Num. of ways <input type="text" value="12"/> No. of phases <input type="text" value="3"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="88-2 HRC"/>		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Type <input type="text" value="gG"/> Rating <input type="text" value="63"/> A Voltage <input type="text"/>		
		Z _s <input type="text" value="0.15"/> Ω No. of poles <input type="text" value="N/A"/>		
		I _{pf} <input type="text" value="2.98"/> kA IΔn <input type="text" value="N/A"/>		Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB LL1/P"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Gorund Corridor Ring	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
1/L2	1st Corridor Ring	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
1/L3	2nd Corridor Ring	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
2/L1	ADV G Floor	O	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L2	ADV G Floor	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L3	1st Floor ADV	O	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L1	1st Floor ADV 2	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L2	1st Floor ADV 3	O	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L3	2nd Floor ADV	O	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L1	2nd Floor ADV 2	O	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L2	2nd Floor ADV 3	O	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L3	Access Control	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L1	Auto Door	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	16	10	30	1.09
5/L2	Mag Lock	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L3	Disabled Alarm	A	B	1	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
6/L1	G Floor Ring Common Room	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
6/L2	Tank Room Ring	A	B	4	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
6/L3	Auto Door	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	16	10	30	1.09
7/L1	Hand Dry	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	16	10	30	1.09
7/L2	Mag Lock	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB LL1/P

FT/EICR 110148423



CIRCUIT DETAILS													
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	BS EN Number	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
	DB LL1/P				Circuit designation	L/N			CPC	Type No.			
8/L1	G Floor Ring Corridor 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
8/L2	2nd Floor Ring Corridor 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
8/L3	1st Floor Ring Corridor 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
9/L1	2nd Floor Stairs and Lobby Ring	A	B	12	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
9/L2	G Floor Stairs and Lobby Ring	A	B	12	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
9/L3	1st Floor Stairs and Lobby Ring	A	B	12	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
10/L1	Commando 1	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	16	10	30	1.09
10/L2	Commando 2	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	16	10	30	1.09
10/L3	Mag Lock 1st Floor	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
11/L1	Mag Lock 2nd Floor	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
11/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - BB 2

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: G Floor Service Riser [Schneider]		Supply to distribution board is from: Sub Mains(MSP, 7/TP)		Associated RCD(if any): BS (EN) N/A
Num. of ways: 24 No. of phases: 3		Overcurrent protective device for the distribution circuit: BS(EN) 60947 MCCB		Operating at 1 IΔn: N/A ms (if applicable)
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Type: N/A Rating: 160 A Voltage:		Operating at 5 IΔn: N/A ms (if applicable)
				Test instrument serial number(s)
				Loop impedance: 080408/5756
				Insulation resistance: 080408/5756
				Continuity: 080408/5756
				RCD: 080408/5756

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation BB 2 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	BS EN Number	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) 80%
					L/N	CPC			Type No.	Rating (A)			
1/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	Sub Mains(DB CL2)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL5)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	Sub Mains(DB CL4)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L1	Sub Mains(DB CL8)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
11/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A



CIRCUIT DETAILS													
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	BS EN Number	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
	BB 2				Circuit designation	L / N			CPC	Type No.			
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	Sub Mains(DB CL11)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	Sub Mains(DB CL10)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
17/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
19/L1	Sub Mains(DB CL14)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
19/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
19/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
20/TP	Lift	F	E	1	6	6	0.4	88-2 HRC	gG	16	80	N/A	1.94
21/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
23/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
23/L2	Sub Mains(DB CL16)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62
23/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24/L3	Sub Mains(DB CL17)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL1

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 1 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 1, 6/L1)		Associated RCD(if any): BS (EN) N/A
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC		Operating at 1 IΔn N/A ms (if applicable)
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage		30mA or below N/A ms
				Time delay (if applicable) N/A
				Test instrument serial number(s)
				Loop impedance 080408/5756
				Insulation resistance 080408/5756
				Continuity 080408/5756
				RCD 080408/5756

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L1	Lighting Room 1,3,5	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L1	Lighting Rooms 2,4,6	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L1	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Sub Mains(DB CL1/6-2, DB CL1/6, DB CL1/6-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
7/L1	Sub Mains(DB CL1/7-2, DB CL1/7, DB CL1/7-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L1	Sub Mains(DB CL1/8-1, DB CL1/8)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L1	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
10/L1	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
11/L1	Hob1	A	B	2	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
12/L1	Hob 2	A	B	2	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB EXT2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location: Mains Room [Schneider]		Supply to distribution board is from: Sub Mains(MSP, 9/L2)			Associated RCD(if any): BS (EN) N/A	
Num. of ways: 10 No. of phases: 1		Overcurrent protective device for the distribution circuit: BS(EN) 60947 MCCB			Operating at 1 IΔn: N/A ms (if applicable)	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type: N/A Rating: 40 A Voltage:			Above 30mA (if applicable)	
					30mA or below	
					Time delay (if applicable): N/A	
					Loop impedance: 080408/5756	
					Insulation resistance: 080408/5756	
					Continuity: 080408/5756	
					RCD: 080408/5756	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB EXT2 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) 80%
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	CCTV	G	D	3	4	4	0.4	60898 MCB	B	10	10	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	O/S Lighting 1	G	D	3	6	6	0.4	60898 MCB	C	10	10	N/A	1.75
4/L2	O/S Lighting 2	G	D	4	6	6	0.4	60898 MCB	C	10	10	N/A	1.75
5/L2	O/S Lighting 3	G	D	6	6	6	0.4	60898 MCB	C	10	10	N/A	1.75
6/L2	O/S Lighting 4	G	D	5	6	6	0.4	60898 MCB	C	10	10	N/A	1.75
7/L2	SPD	D	B	1	16	16	0.4	60898 MCB	C	63	10	N/A	0.28
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location Flat 2 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 2, 2/L1)			Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) Operating at 1 IΔn N/A ms	
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC Type gG Rating 63 A Voltage			Z _s 0.15 Ω No. of poles N/A 30mA or below I _{pr} 1.6 kA IΔn N/A Operating at 5 IΔn N/A ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>					Time delay (if applicable) N/A	
Test instrument serial number(s)						
Loop impedance 080408/5756						
Insulation resistance 080408/5756						
Continuity 080408/5756						
RCD 080408/5756						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL2 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Common Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L1	Lighting Rooms 7,8,9	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L1	Lighting Rooms 4,5,6	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L1	Lighting Rooms 2,3	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L1	Lighting Rooms 1,10	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	Sub Mains(DB CL2/7-1, DB CL2/7)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L1	Sub Mains(DB CL2/8-1, DB CL2/8)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L1	Sub Mains(DB CL2/9-2, DB CL2/9, DB CL2/9-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
10/L1	Sub Mains(DB CL2/10-2, DB CL2/10, DB CL2/10-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
11/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L1	Common Ring 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L1	Common Room Ring 2	A	B	5	2x1.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
14/L1	Hob 1	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
15/L1	Hob 2	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL5

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location Flat 5 [Schneider]		Supply to distribution board is from Sub Mains(BB 2, 6/L2)			Associated RCD(if any): BS (EN) Above 30mA (if applicable) N/A Operating at 1 IΔn N/A ms	
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC Type gG Rating 63 A Voltage			30mA or below (if applicable) Z _s 0.14 Ω No. of poles N/A I _{pr} 1.7 kA IΔn N/A Operating at 5 IΔn N/A ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>					Time delay (if applicable) N/A	
					Test instrument serial number(s) Loop impedance 080408/5756 Insulation resistance 080408/5756 Continuity 080408/5756 RCD 080408/5756	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL5 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L2	Lighting Rooms 4,6,8	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L2	Lighting Rooms 3,5,7	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L2	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL5/6, DB CL5/6-1, DB CL5/6-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
7/L2	Sub Mains(DB CL5/7, DB CL5/7-1, DB CL5/7-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L2	Sub Mains(DB CL5/8, DB CL5/8-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
11/L2	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
12/L2	Hob 1	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L2	Hob 2	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL4

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location Flat 4 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 2, 7/L3)			Associated RCD(if any): BS (EN) N/A	
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC			Operating at 1 IΔn N/A ms (if applicable)	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage			30mA or below N/A ms	
					Time delay (if applicable) N/A	
					Loop impedance 080408/5756	
					Insulation resistance 080408/5756	
					Continuity 080408/5756	
					RCD 080408/5756	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL4 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Common Room Ligths	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L3	Lighting Room 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L3	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L3	Sub Mains(DB CL4/4, DB CL4/4-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
5/L3	Sub Mains(DB CL4/5, DB CL4/5-1, DB CL4/5-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	Common Room Ring	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
8/L3	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
9/L3	Hob 1	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
10/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL8

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location Flat 8 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 2, 11/L1)		Associated RCD(if any): BS (EN) N/A		Loop impedance 080408/5756
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC		Operating at 1 IΔn N/A ms (if applicable)		Insulation resistance 080408/5756
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage		Zs 0.14 Ω No. of poles N/A		Continuity 080408/5756
				Ipr 1.7 kA IΔn N/A		RCD 080408/5756
				Time delay (if applicable) N/A		

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL8 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L1	Lighting Rooms 4,6,8	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L1	Lighting Rooms 3,5,7	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L1	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Sub Mains(DB CL8/6, DB CL8/6-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
7/L1	Sub Mains(DB CL8/7, DB CL8/7-1, DB CL8/7-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L1	Sub Mains(DB CL8/8, DB CL8/8-1, DB CL8/8-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
11/L1	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
12/L1	Hob 1	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L1	Hob 2	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL11

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 11 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 2, 15/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn N/A ms 30mA or below Operating at 5 IΔn N/A ms Time delay (if applicable) N/A
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage		
		Z _s 0.15 Ω No. of poles N/A		
		I _{pr} 1.22 kA IΔn N/A		Test instrument serial number(s) Loop impedance 080408/5756 Insulation resistance 080408/5756 Continuity 080408/5756 RCD 080408/5756

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL11 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω) 80%
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L2	Lighting Rooms 4,6,8	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L2	Lighting Rooms 3,5,7	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L2	Lighting Room 1,2	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL11/6, DB CL11/6-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
7/L2	Sub Mains(DB CL11/7, DB CL11/7-1, DB CL11/7-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L2	Sub Mains(DB CL11/8, DB CL11/8-1, DB CL11/8-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	Common Room Sockets 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
11/L2	Common Room Sockets 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
12/L2	Hob1	A	B	1	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L2	Hob 2	A	B	1	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL10

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 10 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 2, 16/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn N/A ms 30mA or below Operating at 5 IΔn N/A ms Time delay (if applicable) N/A
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage		
Test instrument serial number(s)				
Loop impedance 080408/5756				
Insulation resistance 080408/5756				
Continuity 080408/5756				
RCD 080408/5756				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL10 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L3	Lighting Rooms 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L3	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L3	Sub Mains(DB CL10/4, DB CL10/4-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
5/L3	Sub Mains(DB CL10/5, DB CL10/5-1, DB CL10/5-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
8/L3	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
9/L3	Hob	A	B	1	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
10/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL16

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location Flat 16 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 2, 23/L2)		Associated RCD(if any): BS (EN) N/A		Loop impedance 080408/5756
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC		Operating at 1 IΔn N/A ms (if applicable)		Insulation resistance 080408/5756
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage		Zs 0.14 Ω No. of poles N/A		Continuity 080408/5756
				Ipr 1.88 kA IΔn N/A		RCD 080408/5756
				Time delay (if applicable) N/A		

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL16 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L2	Room Lights 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L2	Room Lights 1,2	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L2	Sub Mains(DB CL16/4-1, DB CL16/4)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
5/L2	Sub Mains(DB CL16/5-2, DB CL16/5, DB CL16/5-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
8/L2	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
9/L2	Hob	A	B	1	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL17

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 17 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 2, 24/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn N/A ms 30mA or below Operating at 5 IΔn N/A ms Time delay (if applicable) N/A
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage		
				Test instrument serial number(s)
				Loop impedance 080408/5756
				Insulation resistance 080408/5756
				Continuity 080408/5756
				RCD 080408/5756

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL17 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L3	Lighting Room 3,5,7	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L3	Lighting Rooms 4,6,8	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L3	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	Sub Mains(DB CL17/6-1, DB CL17/6)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
7/L3	Sub Mains(DB CL17/7-2, DB CL17/7, DB CL17/7-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L3	Sub Mains(DB CL17/8-2, DB CL17/8, DB CL17/8-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L3	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
11/L3	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
12/L3	Hob 1	A	B	2	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L3	Hob 2	A	B	2	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL2/7-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.			
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN				
Distribution board details - Complete in every case				Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location <input type="text" value="Room 10 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL2, 7/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/>		Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.2"/> ms		Loop impedance <input type="text" value="080408/5756"/>	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/>		30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="24.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="230"/>		Time delay (if applicable) <input type="text"/>				Continuity <input type="text" value="080408/5756"/>	
								RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL2/7-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 10 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL2/8

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL2, 8/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Operating at 1 IΔn <input type="text" value="28.8"/> ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="230"/>		30mA or below Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms
				Time delay (if applicable) <input type="text"/>
				Test instrument serial number(s)
				Loop impedance <input type="text" value="080408/5756"/>
				Insulation resistance <input type="text" value="080408/5756"/>
				Continuity <input type="text" value="080408/5756"/>
				RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL2/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL2/9

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL2, 9/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 I _{Δn} <input type="text" value="29.4"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.39"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="230"/>			Time delay (if applicable) <input type="text"/>	
Test instrument serial number(s)						
Loop impedance <input type="text" value="080408/5756"/>						
Insulation resistance <input type="text" value="080408/5756"/>						
Continuity <input type="text" value="080408/5756"/>						
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL2/9"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL2/9-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL2, 9/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="29.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="230"/>			Z _s <input type="text" value="0.39"/> Ω No. of poles <input type="text"/> 30mA or below	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="28.8"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL2/9-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL2/9-2

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 6 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL2, 9/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)
Num. of ways <input type="text" value="4"/>	No. of phases <input type="text" value="1"/>	Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>	Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="230"/>	Operating at 1 I _{Δn} <input type="text" value="29.4"/> ms
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) <input type="text"/>		30mA or below
				Operating at 5 I _{Δn} <input type="text" value="28.8"/> ms
				Loop impedance <input type="text" value="080408/5756"/>
				Insulation resistance <input type="text" value="080408/5756"/>
				Continuity <input type="text" value="080408/5756"/>
				RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL2/9-2"/>	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 6 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL2/10

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 7 Riser [Schneider]		Supply to distribution board is from Sub Mains(DB CL2, 10/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn 27.4 ms 30mA or below Operating at 5 IΔn 26.9 ms Time delay (if applicable)
Num. of ways 4 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type C Rating 32 A Voltage 230		
		Z _s 0.44 Ω No. of poles 30 I _{pr} kA IΔn 30		
				Test instrument serial number(s)
				Loop impedance 080408/5756
				Insulation resistance 080408/5756
				Continuity 080408/5756
				RCD 080408/5756

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL2/10 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL2/10-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 8 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL2, 10/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="27.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="230"/>			Z _s <input type="text" value="0.44"/> Ω No. of poles <input type="text"/> 30mA or below	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="26.9"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL2/10-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL2/10-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 9 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL2, 10/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="27.4"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.44"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="26.9"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="230"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL2/10-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other <input type="text" value="80%"/> (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 9 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL1/6

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL1, 6/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.4"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="18.4"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL1/6"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL1/6-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL1, 6/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="18.4"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL1/6-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL1/6-2

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 6 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL1, 6/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>	Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>	Operating at 1 I _{Δn} <input type="text" value="28.4"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>	Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/>	30mA or below	Insulation resistance <input type="text" value="080408/5756"/>
		I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/>	Operating at 5 I _{Δn} <input type="text" value="18.4"/> ms	Continuity <input type="text" value="080408/5756"/>
		Time delay (if applicable) <input type="text"/>		RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL1/6-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 6 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL1/7-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 3 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL1, 7/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="26.4"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL1/7-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL1/7-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL1, 7/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="26.4"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL1/7-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL1/8

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 7 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL1, 8/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="32.0"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="230"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL1/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL1/8-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 8 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL1, 8/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="32.0"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="230"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL1/8-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL3

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 3 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 1, 7/L2)		Associated RCD(if any): BS (EN) <input type="checkbox"/> Above 30mA (if applicable) <input type="checkbox"/> ms Operating at 1 IΔn <input type="checkbox"/> ms 30mA or below <input type="checkbox"/> ms Operating at 5 IΔn <input type="checkbox"/> ms Time delay (if applicable) <input type="checkbox"/> ms
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage		
		Z _s 0.14 Ω No. of poles N/A		
		I _{pr} 1.72 kA IΔn N/A		Test instrument serial number(s) Loop impedance 080408/5756 Insulation resistance 080408/5756 Continuity 080408/5756 RCD 080408/5756

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL3 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L2	Lighting Room 1,3,5	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L2	Lighting Room 2,4,6	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L2	Lighting Room 7,8	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL3/6, DB CL3/6-1, DB CL3/6-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
7/L2	Sub Mains(DB CL3/7, DB CL3/7-1, DB CL3/7-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L2	Sub Mains(DB CL3/8, DB CL3/8-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
11/L2	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
12/L2	Hob 1	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L2	Hob 2	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL7

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location Flat 7 [Schneider]		Supply to distribution board is from Sub Mains(BB 1, 10/L3)			Associated RCD(if any): BS (EN) N/A	
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC			Operating at 1 IΔn N/A ms (if applicable)	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage			30mA or below 1.5 kA IΔn N/A Operating at 5 IΔn N/A ms	
					Time delay (if applicable) N/A	
					Test instrument serial number(s)	
					Loop impedance 080408/5756	
					Insulation resistance 080408/5756	
					Continuity 080408/5756	
					RCD 080408/5756	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL7 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L3	Lighting Rooms 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L3	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L3	Sub Mains(DB CL7/4, DB CL7/4-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
5/L3	Sub Mains(DB CL7/5, DB CL7/5-1, DB CL7/5-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	Common Room Ring	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
8/L3	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
9/L3	Hob	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
10/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL6

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location Flat 6 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 1, 11/L1)			Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) Operating at 1 IΔn N/A ms	
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC Type gG Rating 63 A Voltage			30mA or below (if applicable) Operating at 5 IΔn N/A ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>					Time delay (if applicable) N/A	
					Test instrument serial number(s) Loop impedance 080408/5756 Insulation resistance 080408/5756 Continuity 080408/5756 RCD 080408/5756	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL6 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω) 80%
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L1	Lighting Rooms 1,3,5	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L1	Lighting Rooms 2,4,6	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L1	Lighting Room 7,8	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Sub Mains(DB CL6/6, DB CL6/6-1, DB CL6/6-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
7/L1	Sub Mains(DB CL6/7, DB CL6/7-1, DB CL6/7-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L1	Sub Mains(DB CL6/8, DB CL6/8-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
11/L1	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
12/L1	Hob1	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L1	Hob 2	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL9

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location Flat 9 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 1, 15/L2)			Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) ms	
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC			Operating at 1 IΔn N/A ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage			30mA or below (if applicable) ms	
					Time delay (if applicable) N/A	
					Loop impedance 080408/5756	
					Insulation resistance 080408/5756	
					Continuity 080408/5756	
					RCD 080408/5756	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL9 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L2	Lighting Rooms 1,3,5	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L2	Lighting Rooms 2,4,6	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L2	Lighting Room 7,8	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL9/6-1, DB CL9/6, DB CL9/6-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
7/L2	Sub Mains(DB CL9/7, DB CL9/7-1, DB CL9/7-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L2	Sub Mains(DB CL9/8, DB CL9/8-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
11/L2	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
12/L2	Hob 1	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L2	Hob 2	A	B	1	10	6	0.4	61009 RCD/RC	C	32	10	30	0.54
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL13

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location Flat 13 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 1, 19/L3)			Associated RCD(if any): BS (EN) N/A	
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC			Operating at 1 IΔn N/A ms (if applicable)	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage			30mA or below 1.04 kA IΔn N/A Operating at 5 IΔn N/A ms	
					Time delay (if applicable) N/A	
					Test instrument serial number(s)	
					Loop impedance 080408/5756	
					Insulation resistance 080408/5756	
					Continuity 080408/5756	
					RCD 080408/5756	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL13 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L3	Lighting Rooms 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L3	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L3	Sub Mains(DB CL13/4-1, DB CL13/4)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
5/L3	Sub Mains(DB CL13/5-2, DB CL13/5, DB CL13/5-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
8/L3	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
9/L3	Hob	A	B	1	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
10/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL12

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 12 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 1, 20/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn N/A ms 30mA or below Operating at 5 IΔn N/A ms Time delay (if applicable) N/A
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC		
Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage		
Test instrument serial number(s)				
Loop impedance 080408/5756				
Insulation resistance 080408/5756				
Continuity 080408/5756				
RCD 080408/5756				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL12 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Common Room Lights	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L1	Lighting Rooms 1,3,5	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L1	Lighting Rooms 2,4,6	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L1	Lighting Rooms 7,8	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Sub Mains(DB CL12/6-2, DB CL12/6, DB CL12/6-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
7/L1	Sub Mains(DB CL12/7-2, DB CL12/7, DB CL12/7-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L1	Sub Mains(DB CL12/8-1, DB CL12/8)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	Common Room Sockets	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
11/L1	Common Room Sockets 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
12/L1	Hob 1	A	B	1	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L1	Hob 2	A	B	1	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL15

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 15 Kitchen [Schnieder]		Supply to distribution board is from Sub Mains(BB 1, 22/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn N/A ms 30mA or below Operating at 5 IΔn N/A ms Time delay (if applicable) N/A
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type gG Rating 63 A Voltage		
		Z _s 0.14 Ω No. of poles N/A		
Test instrument serial number(s)				
Loop impedance 080408/5756				
Insulation resistance 080408/5756				
Continuity 080408/5756				
RCD 080408/5756				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL15 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L2	Lighting Rooms 1,3,5	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L2	Lighting 2,4,6	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L2	Lighting 7,8	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL15/6-2, DB CL15/6, DB CL15/6-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
7/L2	Sub Mains(DB CL15/7-2, DB CL15/7, DB CL15/7-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L2	Sub Mains(DB CL15/8-1, DB CL15/8)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
11/L2	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
12/L2	Hob 1	A	B	1	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L2	Hob 2	A	B	1	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB LL2/L

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Plant Room [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(BB 1, 23/TP)"/>		Associated RCD(if any): BS (EN) <input type="text" value="N/A"/> Above 30mA (if applicable) <input type="text" value="N/A"/> ms
Num. of ways <input type="text" value="12"/> No. of phases <input type="text" value="3"/>	Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="88-2 HRC"/>	Type <input type="text" value="gG"/> Rating <input type="text" value="63"/> A Voltage <input type="text" value=""/>		Operating at 1 IΔn <input type="text" value="N/A"/> ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Z _s <input type="text" value="0.18"/> Ω No. of poles <input type="text" value="N/A"/>		30mA or below (if applicable) <input type="text" value="N/A"/> ms
		I _{pn} <input type="text" value="2.6"/> kA IΔn <input type="text" value="N/A"/>		Operating at 5 IΔn <input type="text" value="N/A"/> ms
		Time delay (if applicable) <input type="text" value="N/A"/>		
Test instrument serial number(s)				
Loop impedance <input type="text" value="080408/5756"/>				
Insulation resistance <input type="text" value="080408/5756"/>				
Continuity <input type="text" value="080408/5756"/>				
RCD <input type="text" value="080408/5756"/>				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB LL2/L"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	3rd Floor Lighting East	A	B	18	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
1/L2	3rd Floor Lighting West	A	B	17	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
1/L3	4th Floor Lighting West	A	B	17	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L1	4th Floor Lighting East	A	B	18	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L2	5th Floor Lighting West	A	B	17	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L3	5th Floor Lighting East	A	B	18	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L1	3rd Floor Lighting North	A	B	18	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L2	Stairs And Lobby 3rd Floor	A	B	16	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L3	Stairs And Lobby 4th Floor	A	B	16	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	Stairs And Lobby 5th Floor	A	B	16	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L3	4th Floor Lighting North	A	B	18	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L1	5th Floor Lighting North	A	B	18	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB LL2/L

FT/EICR **110148423**



CIRCUIT DETAILS

Circuit No and Line No.	Distribution board Designation DB LL2/L Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	BS EN Number	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)
					L/N	CPC			Type No.	Rating (A)			
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB PL

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Plant Room Roof [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(BB 1, 24/TP)"/>			Associated RCD(if any): BS (EN) <input type="text" value="N/A"/> Above 30mA (if applicable) <input type="text" value="N/A"/> ms	
Num. of ways <input type="text" value="24"/> No. of phases <input type="text" value="3"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="88-2 HRC"/> Type <input type="text" value="gG"/> Rating <input type="text" value="63"/> A Voltage <input type="text" value=""/>			Operating at 1 IΔn <input type="text" value="N/A"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>					30mA or below <input type="text" value="N/A"/> ms	
					Time delay (if applicable) <input type="text" value="N/A"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB PL"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	EXT Fan 1	A	B	1	2.5	2.5	0.4	61009 RCD/RC	C	16	10	30	1.09
1/L2	EXT Fan 2	A	B	1	2.5	2.5	0.4	61009 RCD/RC	C	16	10	30	1.09
1/L3	EXT Fan 3	A	B	1	2.5	2.5	0.4	61009 RCD/RC	C	16	10	30	1.09
2/L1	EXT Fan 4	A	B	1	2.5	2.5	0.4	61009 RCD/RC	C	16	10	30	1.09
2/L2	EXT Fan 5	A	B	1	2.5	2.5	0.4	61009 RCD/RC	C	16	10	30	1.09
2/L3	EXT Fan 6	A	B	1	2.5	2.5	0.4	61009 RCD/RC	C	16	10	30	1.09
3/L1	EXT Fan 7	A	B	1	2.5	2.5	0.4	61009 RCD/RC	C	16	10	30	1.09
3/L2	EXT Fan 8	A	B	1	2.5	2.5	0.4	61009 RCD/RC	C	16	10	30	1.09
3/L3	EXT Fan 9	A	B	1	2.5	2.5	0.4	61009 RCD/RC	C	16	10	30	1.09
4/L1	EXT Fan 10	A	B	1	2.5	2.5	0.4	61009 RCD/RC	C	16	10	30	1.09
4/L2	EXT Fan 11	A	B	1	2.5	2.5	0.4	61009 RCD/RC	C	16	10	30	1.09
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	Plant Ring	A	B	4	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	10	0.54
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Plant Room Lights	A	B	4	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	Sub Mains(DB Mech)	A	B	1	10	6	5	60898 MCB	C	32	10	N/A	0.54
8/L1	Contactoer	D	B	1	2.5	2.5	0.4	60898 MCB	B	10	10	N/A	3.49
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB PL

FT/EICR 110148423



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB PL	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	BS EN Number	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)
	Circuit designation				L/N	CPC			Type No.	Rating (A)			
8/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
19/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
20/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
21/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
23/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24/TP	SPD	D	B	1	16	16	0.4	60898 MCB	C	40	10	N/A	0.44

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB LL2/P

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Plant Room Roof [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(BB 1, 23/TP)"/>		Associated RCD(if any): BS (EN) <input type="text" value="N/A"/> Above 30mA (if applicable) <input type="text" value="N/A"/> ms Operating at 1 IΔn 30mA or below Operating at 5 IΔn <input type="text" value="N/A"/> ms Time delay (if applicable) <input type="text" value="N/A"/> ms
Num. of ways <input type="text" value="12"/> No. of phases <input type="text" value="3"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="88-2 HRC gG"/>		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Type <input type="text" value="gG"/> Rating <input type="text" value="63"/> A Voltage <input type="text" value="400"/>		
Test instrument serial number(s)				
Loop impedance <input type="text" value="080408/5756"/>				
Insulation resistance <input type="text" value="080408/5756"/>				
Continuity <input type="text" value="080408/5756"/>				
RCD <input type="text" value="080408/5756"/>				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB LL2/P"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Corridor Sockets 3rd Floor	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
1/L2	Corridor Sockets 4th Floor	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
1/L3	Corridor Sockets 5th Floor	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
2/L1	3rd Floor AOV 1	O	B	1	2.5	2.5	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L2	3rd Floor AOV 2	O	B	1	2.5	2.5	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L3	3rd Floor AOV 3	O	B	1	2.5	2.5	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L1	4th Floor AOV 1	O	B	1	2.5	2.5	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L2	4th Floor AOV 2	O	B	1	2.5	2.5	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L3	4th Floor AOV 3	O	B	1	2.5	2.5	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L1	5th Floor AOV 1	O	B	1	2.5	2.5	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L2	5th Floor AOV 2	O	B	1	2.5	2.5	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L3	AOV Plant Room	O	B	1	2.5	2.5	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L1	5th Floor AOV 3	O	B	1	2.5	2.5	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	Sockets Corridor 3rd Floor 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
7/L2	Sockets Corridor 4th Floor 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
7/L3	Sockets Corridor 5th Floor 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
8/L1	Lobby and Store Store Sockets 3rd Floor	A	B	12	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB LL2/P



CIRCUIT DETAILS													
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other
	Circuit designation				L/N	CPC		BS EN Number	Type No.	Rating (A)			
8/L2	Lobby and Store Store Sockets 4th Floor	A	B	12	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54
8/L3	Lobby and Store Store Sockets 5th Floor	A	B	12	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	Maglock 3rd Floor	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
10/L2	Maglock 4th Floor	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
10/L3	Maglock 5th Floor	A	B	1	2.5	1.5	0.4	61009 RCD/RC	C	10	10	30	1.75
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB

Mech

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Plant Room Roof [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB PL, 7/TP)"/>		Associated RCD(if any): BS (EN) <input type="text" value="N/A"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="N/A"/> ms 30mA or below Z _s <input type="text" value="0.22"/> Ω No. of poles <input type="text" value="N/A"/> I _{pn} <input type="text" value="2.0"/> kA IΔn <input type="text" value="N/A"/> Operating at 5 IΔn <input type="text" value="N/A"/> ms Time delay (if applicable) <input type="text" value="N/A"/> ms
Num. of ways <input type="text" value="6"/> No. of phases <input type="text" value="3"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="60898 MCB"/>		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		
				Test instrument serial number(s)
				Loop impedance <input type="text" value="080408/5756"/>
				Insulation resistance <input type="text" value="080408/5756"/>
				Continuity <input type="text" value="080408/5756"/>
				RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB Mech"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Pressurisation Unit	O	B	1	1.5	1.5	0.4	60898 MCB	D	6	6	N/A	1.45
1/L2	Boiler 1	O	B	1	1.5	1.5	0.4	60898 MCB	C	4	6	N/A	4.37
1/L3	Boiler 2	O	B	1	1.5	1.5	0.4	60898 MCB	C	4	6	N/A	4.37
2/L1	VT Secondary Pump 1	O	B	1	1.5	1.5	0.4	60898 MCB	D	4	6	N/A	2.18
2/L2	Heater 1	O	B	1	1.5	1.5	0.4	60898 MCB	C	10	6	N/A	1.75
2/L3	Heater 2	O	B	1	1.5	1.5	0.4	60898 MCB	C	10	6	N/A	1.75
3/L1	VT Secondary Pump 2	O	B	1	1.5	1.5	0.4	60898 MCB	D	4	6	N/A	2.18
3/L2	Residential HWS Secondary Pump	O	B	1	1.5	1.5	0.4	60898 MCB	D	2	6	N/A	4.37
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	Control Panel	F	C	1	16	16	0.4	N/A	N/A	50	10	N/A	7.28
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL17/6



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 1 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL17, 6/L3)"/>		Associated RCD(if any): BS (EN) <input type="text" value=""/> Above 30mA (if applicable)		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Operating at 1 I _{Δn} <input type="text" value="28.4"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value=""/>		Z _s <input type="text" value="0.34"/> Ω No. of poles <input type="text" value=""/> 30mA or below		Continuity <input type="text" value="080408/5756"/>
				I _{pf} <input type="text" value="0.75"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="27.9"/> ms		RCD <input type="text" value="080408/5756"/>
				Time delay (if applicable) <input type="text" value=""/>		

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL17/6"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL17/6-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL17, 6/L3)"/>			Associated RCD(if any): BS (EN) <input type="text" value=""/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 I _{Δn} <input type="text" value="28.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value=""/>			Z _s <input type="text" value="0.34"/> Ω No. of poles <input type="text" value=""/> 30mA or below	
					I _{pn} <input type="text" value="N/A"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="27.9"/> ms	
					Time delay (if applicable) <input type="text" value=""/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL17/6-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other <input type="text" value="80%"/> (Ω)
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL17/7

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 3 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL17, 7/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 I Δ n <input type="text" value="26.4"/> ms
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z $_d$ <input type="text" value="0.34"/> Ω No. of poles <input type="text"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		I $_{pn}$ <input type="text" value="0.61"/> kA I Δ n <input type="text" value="30"/> Operating at 5 I Δ n <input type="text" value="27.2"/> ms
				Time delay (if applicable) <input type="text"/>
				Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL17/7"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z $_s$ Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL17/7-1

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.	
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board	
Location <input type="text" value="Room 5 Riser [Schneider]"/> Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL17, 7/L3)"/> Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Associated RCD(if any): BS (EN) <input type="text"/> Operating at 1 I _{Δn} <input type="text" value="26.4"/> ms Above 30mA (if applicable) Z _s <input type="text" value="0.34"/> Ω No. of poles <input type="text"/> I _{pn} <input type="text" value="0.61"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="27.2"/> ms 30mA or below Time delay (if applicable) <input type="text"/>	Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL17/7-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other <input type="text" value="80%"/> (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL17/7-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 7 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL17, 7/L3)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="26.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.34"/> Ω No. of poles <input type="text"/>	
					I _{pn} <input type="text" value="0.61"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL17/7-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL17/8

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL17, 8/L3)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Z _s <input type="text" value="0.39"/> Ω No. of poles <input type="text"/> 30mA or below	
					I _{pn} <input type="text" value="0.61"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="22.5"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL17/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL17/8-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 6 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL17, 8/L3)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.39"/> Ω No. of poles <input type="text"/>	
					I _{pn} <input type="text" value="0.61"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="22.5"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL17/8-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room X Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL17/8-2

FT/EICR 110148423



Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.			
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode	SA1 8EN				
Distribution board details - Complete in every case			Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board			Test instrument serial number(s)		
Location			Supply to distribution board is from			Associated RCD(if any): BS (EN)			Loop impedance		
Room 8 Riser [Schneider]			Sub Mains(DB CL17, 8/L3)			Above 30mA (if applicable)			080408/5756		
Num. of ways			Overcurrent protective device for the distribution circuit:			Operating at 1 IΔn			Insulation resistance		
4			BS(EN) 61009 RCD/RCBO			28.2 ms			080408/5756		
No. of phases			Type			30mA or below			Continuity		
1			C			Zs			080408/5756		
Supply polarity confirmed <input checked="" type="checkbox"/>			Rating			Ipf			RCD		
Phase sequence confirmed <input type="checkbox"/>			32 A			0.39 Ω			080408/5756		
			Voltage			No. of poles					
						30					
						Operating at 5 IΔn					
						22.5 ms					
						Time delay (if applicable)					

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL17/8-2	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL16/4

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.		
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN			
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board			
Location <input type="text" value="Room 1 Riser [Schneider]"/> Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL16, 4/L2)"/> Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Associated RCD(if any): BS (EN) <input type="text"/> Operating at 1 IΔn <input type="text" value="28.8"/> ms Above 30mA (if applicable) 30mA or below Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/> I _{pn} <input type="text" value="0.58"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="22.4"/> ms Time delay (if applicable) <input type="text"/>		Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL16/4"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL16/4-1

FT/EICR 110148423



Company Name <input type="text" value="PHS Compliance"/>	Company Address <input type="text" value="Kid Glove Road"/>	Postcode <input type="text" value="WA3 3GR"/>	Branch No. <input type="text"/>	Scheme No. <input type="text"/>	
Client <input type="text" value="UPP Residential Services Ltd"/>	Installation Address <input type="text" value="Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea"/>		Postcode <input type="text" value="SA1 8EN"/>		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board	
Location <input type="text" value="Room X Riser [Schneider]"/> Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL16, 4/L2)"/> Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Associated RCD(if any): BS (EN) <input type="text"/> Operating at 1 I _{Δn} <input type="text" value="28.8"/> ms Above 30mA (if applicable) Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/> I _{pn} <input type="text" value="0.58"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="22.4"/> ms 30mA or below Time delay (if applicable) <input type="text"/>	Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL16/4-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other <input type="text" value="80%"/> (Ω)
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL16/5

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room X Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL16, 5/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Z _s <input type="text" value="0.39"/> Ω No. of poles <input type="text"/> 30mA or below	
					I _{pn} <input type="text" value="0.62"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="22.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL16/5"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL16/5-1



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.	
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board			Test instrument serial number(s)
Location <input type="text" value="Room X Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL16, 5/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)			Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Operating at 1 IΔn <input type="text" value="27.2"/> ms			Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Z _s <input type="text" value="0.39"/> Ω No. of poles <input type="text"/> 30mA or below			Continuity <input type="text" value="080408/5756"/>
				I _{pn} <input type="text" value="0.62"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="22.2"/> ms			RCD <input type="text" value="080408/5756"/>
				Time delay (if applicable) <input type="text"/>			

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL16/5-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room X Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL16/5-2



Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.			
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea				Postcode	SA1 8EN			
Distribution board details - Complete in every case			Complete only if the distribution board is not connected directly to the origin of the installation				Characteristics at this distribution board			Test instrument serial number(s)	
Location			Supply to distribution board is from				Associated RCD(if any): BS (EN)			Loop impedance	
Room 5 Riser [Schneider]			Sub Mains(DB CL16, 5/L2)				Above 30mA (if applicable)			080408/5756	
Num. of ways			Overcurrent protective device for the distribution circuit:				Operating at 1 I _{Δn}			Insulation resistance	
4			BS(EN) 61009 RCD/RCBO				27.2 ms			080408/5756	
No. of phases			Type				30mA or below			Continuity	
1			C				Z _s 0.39 Ω			080408/5756	
Supply polarity confirmed <input checked="" type="checkbox"/>			Rating				I _{pn} 0.62 kA			RCD	
Phase sequence confirmed <input type="checkbox"/>			32 A				Operating at 5 I _{Δn}			080408/5756	
			Voltage				Time delay (if applicable)				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL16/5-2	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL15/6

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL15, 6/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="27.6"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> 30mA or below	
					I _{pn} <input type="text" value="0.79"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL15/6"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL15/6-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL15, 6/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/>		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Operating at 1 IΔn <input type="text" value="27.6"/> ms (if applicable)		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
				I _{pn} <input type="text" value="0.79"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		RCD <input type="text" value="080408/5756"/>
				Time delay (if applicable) <input type="text"/>		

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL15/6-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL15/6-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea				Postcode SA1 8EN
Distribution board details - Complete in every case			Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board	
Location <input type="text" value="Room 6 Riser [Schneider]"/> Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Supply to distribution board is from <input type="text" value="Sub Mains(DB CL15, 6/L2)"/> Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Associated RCD(if any): BS (EN) <input type="text"/> Operating at 1 IΔn <input type="text" value="27.6"/> ms Above 30mA (if applicable) Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> I _{pn} <input type="text" value="0.79"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms 30mA or below Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL15/6-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 6 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL15/7



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.	
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board	
Location <input type="text" value="Room 1 Riser [Schneider]"/> Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL15, 7/L2)"/> Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Associated RCD(if any): BS (EN) <input type="text"/> Operating at 1 IΔn <input type="text" value="28.8"/> ms (if applicable) Above 30mA 30mA or below Operating at 5 IΔn <input type="text" value="27.2"/> ms Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/> I _{pn} <input type="text" value="0.80"/> kA IΔn <input type="text" value="30"/> Time delay (if applicable) <input type="text"/>	Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL15/7"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL15/7-1

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 3 Riser [Schneider]		Supply to distribution board is from Sub Mains(DB CL15, 7/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms 30mA or below Operating at 5 IΔn 27.2 ms
Num. of ways 4 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type C Rating 32 A Voltage		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Test instrument serial number(s)
				Loop impedance 080408/5756
				Insulation resistance 080408/5756
				Continuity 080408/5756
				RCD 080408/5756

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL15/7-1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) 80%
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL15/7-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.			
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN				
Distribution board details - Complete in every case				Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL15, 7/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/>		Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/>		30mA or below I _{pn} <input type="text" value="0.80"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>				Continuity <input type="text" value="080408/5756"/>	
								RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL15/7-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL15/8

FT/EICR 110148423



Company Name <input type="text" value="PHS Compliance"/>	Company Address <input type="text" value="Kid Glove Road"/>	Postcode <input type="text" value="WA3 3GR"/>	Branch No. <input type="text"/>	Scheme No. <input type="text"/>
Client <input type="text" value="UPP Residential Services Ltd"/>	Installation Address <input type="text" value="Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea"/>			Postcode <input type="text" value="SA1 8EN"/>
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 7 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL15, 8/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="30.2"/> ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		30mA or below Operating at 5 IΔn <input type="text" value="27.2"/> ms
				Time delay (if applicable) <input type="text"/>
Test instrument serial number(s)				
Loop impedance <input type="text" value="080408/5756"/>				
Insulation resistance <input type="text" value="080408/5756"/>				
Continuity <input type="text" value="080408/5756"/>				
RCD <input type="text" value="080408/5756"/>				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL15/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL15/8-1



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 8 Riser [Schneider]		Supply to distribution board is from Sub Mains(DB CL15, 8/L2)		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 I _{Δn} 30.2 ms 30mA or below Operating at 5 I _{Δn} 27.2 ms Z _s 0.30 Ω No. of poles <input type="text"/> I _{pn} 0.85 kA I _{Δn} 30 Time delay (if applicable) <input type="text"/>
Num. of ways 4 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type C Rating 32 A Voltage <input type="text"/>		
Test instrument serial number(s)				
Loop impedance 080408/5756				
Insulation resistance 080408/5756				
Continuity 080408/5756				
RCD 080408/5756				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL15/8-1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL14

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location Flat 14 Kitchen [Schneider]		Supply to distribution board is from Sub Mains(BB 2, 19/L1)			Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) Operating at 1 IΔn N/A ms	
Num. of ways 18 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC gG Type gG Rating 32 A Voltage 230			30mA or below (if applicable) Operating at 5 IΔn N/A ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>					Time delay (if applicable) N/A	
					Test instrument serial number(s) Loop impedance 080408/5756 Insulation resistance 080408/5756 Continuity 080408/5756 RCD 080408/5756	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL14 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
2/L1	Lighting Rooms 4,6,8	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
3/L1	Lighting Rooms 3,5,7	A	B	12	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
4/L1	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/RC	C	10	10	30	1.75
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Sub Mains(DB CL14/6-1, DB CL14/6)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
7/L1	Sub Mains(DB CL14/7-2, DB CL14/7, DB CL14/7-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
8/L1	Sub Mains(DB CL14/8-2, DB CL14/8, DB CL14/8-1)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54
9/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	Common Room Ring 1	A	B	10	2X2.5	2X1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
11/L1	Common Room Ring 2	A	B	10	2X2.5	2X1.5	0.4	61009 RCD/RC	C	32	10	30	0.54
12/L1	Hob 1	A	B	1	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
13/L1	Hob 2	A	B	1	6	2.5	0.4	61009 RCD/RC	C	32	10	30	0.54
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL14/6

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 1 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL14, 6/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/>		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.4"/> ms		Continuity <input type="text" value="080408/5756"/>
				Time delay (if applicable) <input type="text"/>		RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL14/6"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL14/6-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL14, 6/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL14/6-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL14/7

FT/EICR 110148423



Company Name <input type="text" value="PHS Compliance"/>	Company Address <input type="text" value="Kid Glove Road"/>	Postcode <input type="text" value="WA3 3GR"/>	Branch No. <input type="text"/>	Scheme No. <input type="text"/>
Client <input type="text" value="UPP Residential Services Ltd"/>	Installation Address <input type="text" value="Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea"/>		Postcode <input type="text" value="SA1 8EN"/>	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room X Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL14, 7/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/>
Num. of ways <input type="text" value="4"/>	No. of phases <input type="text" value="1"/>	Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>	Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>	Operating at 1 I _{Δn} <input type="text" value="28.8"/> ms
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) <input type="text"/>		Above 30mA (if applicable) 30mA or below Operating at 5 I _{Δn} <input type="text" value="27.2"/> ms
				Test instrument serial number(s)
				Loop impedance <input type="text" value="080408/5756"/>
				Insulation resistance <input type="text" value="080408/5756"/>
				Continuity <input type="text" value="080408/5756"/>
				RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL14/7"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL14/7-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 6 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL14, 7/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> 30mA or below	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL14/7-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 6 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL14/7-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 8 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL14, 7/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL14/7-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL14/8

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR		Branch No.		Scheme No.			
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea				Postcode SA1 8EN					
Distribution board details - Complete in every case				Complete only if the distribution board is not connected directly to the origin of the installation				Characteristics at this distribution board			
Location <input type="text" value="Room 3 Riser [Schneider]"/>				Supply to distribution board is from <input type="text" value="Sub Mains(DB CL14, 8/L1)"/>				Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)			
Num. of ways <input type="text" value="4"/>		No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>				Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>	
Supply polarity confirmed <input checked="" type="checkbox"/>		Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>				30mA or below		Insulation resistance <input type="text" value="080408/5756"/>	
								Z _s <input type="text" value="0.34"/> Ω		Continuity <input type="text" value="080408/5756"/>	
								I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/>		RCD <input type="text" value="080408/5756"/>	
								Operating at 5 IΔn <input type="text" value="27.2"/> ms			
								Time delay (if applicable) <input type="text"/>			

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL14/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other <input type="text" value="80%"/> (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL14/8-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL14, 8/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.34"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL14/8-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL14/8-2



Company Name <input type="text" value="PHS Compliance"/>	Company Address <input type="text" value="Kid Glove Road"/>	Postcode <input type="text" value="WA3 3GR"/>	Branch No. <input type="text"/>	Scheme No. <input type="text"/>
Client <input type="text" value="UPP Residential Services Ltd"/>	Installation Address <input type="text" value="Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea"/>	Postcode <input type="text" value="SA1 8EN"/>		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 7 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL14, 8/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Operating at 1 I _{Δn} <input type="text" value="28.8"/> ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="400/230"/>		30mA or below
		Time delay (if applicable) <input type="text"/>		Operating at 5 I _{Δn} <input type="text" value="27.2"/> ms
				Test instrument serial number(s)
				Loop impedance <input type="text" value="080408/5756"/>
				Insulation resistance <input type="text" value="080408/5756"/>
				Continuity <input type="text" value="080408/5756"/>
				RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL14/8-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL13/4

FT/EICR 110148423



Company Name <input type="text" value="PHS Compliance"/>	Company Address <input type="text" value="Kid Glove Road"/>	Postcode <input type="text" value="WA3 3GR"/>	Branch No. <input type="text"/>	Scheme No. <input type="text"/>
Client <input type="text" value="UPP Residential Services Ltd"/>	Installation Address <input type="text" value="Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea"/>	Postcode <input type="text" value="SA1 8EN"/>		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 1 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL13, 4/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Operating at 1 I _{Δn} <input type="text" value="29.2"/> ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		30mA or below (if applicable)
				Loop impedance <input type="text" value="080408/5756"/>
				Insulation resistance <input type="text" value="080408/5756"/>
				Continuity <input type="text" value="080408/5756"/>
				RCD <input type="text" value="080408/5756"/>
				Time delay (if applicable) <input type="text"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL13/4"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL13/4-1

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL13, 4/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>	Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>	Operating at 1 IΔn <input type="text" value="29.2"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>	Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/>	30mA or below	Insulation resistance <input type="text" value="080408/5756"/>
		I _{pn} <input type="text" value="0.64"/> kA IΔn <input type="text" value="30"/>	Operating at 5 IΔn <input type="text" value="27.2"/> ms	Continuity <input type="text" value="080408/5756"/>
		Time delay (if applicable) <input type="text"/>		RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL13/4-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL13/5

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.	
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board	
Location <input type="text" value="Room 3 Riser [Schneider]"/> Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL13, 5/L3)"/> Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Associated RCD(if any): BS (EN) <input type="text"/> Operating at 1 I _{Δn} <input type="text" value="28.8"/> ms Above 30mA (if applicable) Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> I _{pn} <input type="text" value="0.62"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="27.2"/> ms 30mA or below (if applicable) Time delay (if applicable) <input type="text"/>	Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL13/5"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL13/5-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL13, 5/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> 30mA or below I _{pn} <input type="text" value="0.64"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL13/5-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL13/5-2



Company Name <input type="text" value="PHS Compliance"/>	Company Address <input type="text" value="Kid Glove Road"/>	Postcode <input type="text" value="WA3 3GR"/>	Branch No. <input type="text"/>	Scheme No. <input type="text"/>
Client <input type="text" value="UPP Residential Services Ltd"/>	Installation Address <input type="text" value="Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea"/>		Postcode <input type="text" value="SA1 8EN"/>	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL13, 5/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		30mA or below Operating at 5 IΔn <input type="text" value="27.2"/> ms
				Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL13/5-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) <input type="text" value="80%"/>
					L/N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL12/6

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.	
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board	
Location <input type="text" value="Room 1 Riser [Schneider]"/> Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL12, 6/L1)"/> Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Associated RCD(if any): BS (EN) <input type="text"/> Operating at 1 I _{Δn} <input type="text" value="28.6"/> ms Above 30mA (if applicable) Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="27.2"/> ms 30mA or below (if applicable) Time delay (if applicable) <input type="text"/>	Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL12/6"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL12/6-1

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.	
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea		Postcode SA1 8EN		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board	
Location <input type="text" value="Room 3 Riser [Schneider]"/> Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL12, 6/L1)"/> Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Associated RCD(if any): BS (EN) <input type="text"/> Operating at 1 IΔn <input type="text" value="28.6"/> ms Above 30mA (if applicable) 30mA or below Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms Time delay (if applicable) <input type="text"/>	Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL12/6-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL12/6-2

FT/EICR 110148423



Company Name <input type="text" value="PHS Compliance"/>		Company Address <input type="text" value="Kid Glove Road"/>		Postcode <input type="text" value="WA3 3GR"/>	Branch No. <input type="text"/>	Scheme No. <input type="text"/>		
Client <input type="text" value="UPP Residential Services Ltd"/>		Installation Address <input type="text" value="Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea"/>				Postcode <input type="text" value="SA1 8EN"/>		
Distribution board details - Complete in every case			Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 5 Riser [Schneider]"/>			Supply to distribution board is from <input type="text" value="Sub Mains(DB CL12, 6/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) <input type="text"/>		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>			Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.6"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		RCD <input type="text" value="080408/5756"/>
						Time delay (if applicable) <input type="text"/>		

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL12/6-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL12/7

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL12, 7/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 I _{Δn} <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="27.0"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL12/7"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL12/7-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL12, 7/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/> I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.0"/> ms Time delay (if applicable) <input type="text"/>	
Test instrument serial number(s)						
Loop impedance <input type="text" value="080408/5756"/>						
Insulation resistance <input type="text" value="080408/5756"/>						
Continuity <input type="text" value="080408/5756"/>						
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL12/7-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL12/7-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 6 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL12, 7/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/>	No. of phases <input type="text" value="1"/>	Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/>	
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Type <input type="text" value="C"/>	Rating <input type="text" value="32"/> A	Voltage <input type="text"/>	30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.0"/> ms	
		Time delay (if applicable) <input type="text"/>			Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL12/7-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 6 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL12/8

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 7 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL12, 8/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.31"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL12/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL12/8-1

FT/EICR 110148423



Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location <input type="text" value="Room 8 Riser [Schneider]"/> Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Supply to distribution board is from <input type="text" value="Sub Mains(DB CL12, 8/L1)"/> Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>	Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms Zs <input type="text" value="0.31"/> Ω No. of poles <input type="text"/> 30mA or below Ipr <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms Time delay (if applicable) <input type="text"/>	Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL12/8-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL11/6

FT/EICR 110148423



Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case Location <input type="text" value="Room 1 Riser [Schneider]"/> Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from <input type="text" value="Sub Mains(DB CL11, 6/L2)"/> Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>	Characteristics at this distribution board Associated RCD(if any): BS (EN) <input type="text"/> Operating at 1 IΔn <input type="text" value="28.8"/> ms Above 30mA (if applicable) 2 30mA or below Z _s <input type="text" value="0.35"/> Ω No. of poles <input type="text"/> I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms Time delay (if applicable) <input type="text"/>	Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>
---	--	---	---

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL11/6"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other <input type="text" value="80%"/> (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL11/6-1

FT/EICR 110148423



Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.		
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea				Postcode	SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Room 2 Riser [Schneider] Num. of ways: 4 No. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>	Supply to distribution board is from: Sub Mains(DB CL11, 6/L2) Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: C Rating: 32 A Voltage:	Associated RCD(if any): BS (EN) Operating at 1 IΔn: 28.8 ms (Above 30mA) 2 (30mA or below) Z _s : 0.35 Ω No. of poles: I _{pr} : kA IΔn: 30 Operating at 5 IΔn: 27.2 ms Time delay (if applicable):	Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL11/6-1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL11/7

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 3 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL11, 7/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 I _{Δn} <input type="text" value="28.5"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL11/7"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL11/7-1

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL11, 7/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/>
Num. of ways <input type="text" value="4"/>	No. of phases <input type="text" value="1"/>	Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>	Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>	Operating at 1 I _{Δn} <input type="text" value="28.5"/> ms
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) <input type="text"/>		Above 30mA (if applicable)
				30mA or below
				Operating at 5 I _{Δn} <input type="text" value="27.2"/> ms
				Loop impedance <input type="text" value="080408/5756"/>
				Insulation resistance <input type="text" value="080408/5756"/>
				Continuity <input type="text" value="080408/5756"/>
				RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL11/7-1"/>	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL11/7-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 7 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL11, 7/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.5"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL11/7-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL11/8

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL11, 8/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL11/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL11/8-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 6 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL11, 8/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/>		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		Continuity <input type="text" value="080408/5756"/>
				Time delay (if applicable) <input type="text"/>		RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL11/8-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 6 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL11/8-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 8 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL11, 8/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL11/8-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL10/4

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 1 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL10, 4/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 I _{Δn} <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="28.0"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL10/4"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL10/4-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL10, 4/L3)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="28.0"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
Test instrument serial number(s)						
Loop impedance <input type="text" value="080408/5756"/>						
Insulation resistance <input type="text" value="080408/5756"/>						
Continuity <input type="text" value="080408/5756"/>						
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL10/4-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL10/5

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 3 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL10, 5/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="26.4"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/>		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="22.0"/> ms		Continuity <input type="text" value="080408/5756"/>
				Time delay (if applicable) <input type="text"/>		RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL10/5"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL10/5-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL10, 5/L3)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="26.4"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="22.0"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
Test instrument serial number(s)						
Loop impedance <input type="text" value="080408/5756"/>						
Insulation resistance <input type="text" value="080408/5756"/>						
Continuity <input type="text" value="080408/5756"/>						
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL10/5-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL10/5-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL10, 5/L3)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="26.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="22.0"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL10/5-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL9/6

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 1 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL9, 6/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Z _s <input type="text" value="0.45"/> Ω No. of poles <input type="text"/> 30mA or below	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL9/6"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL9/6-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 3 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL9, 6/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 I _{Δn} <input type="text" value="28.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.45"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL9/6-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL9/6-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL9, 6/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.45"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL9/6-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL9/7

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL9, 7/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/>		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		Continuity <input type="text" value="080408/5756"/>
				Time delay (if applicable) <input type="text"/>		RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL9/7"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL9/7-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL9, 7/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL9/7-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL9/7-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 6 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL9, 7/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 I _{Δn} <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.42"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
Test instrument serial number(s)						
Loop impedance <input type="text" value="080408/5756"/>						
Insulation resistance <input type="text" value="080408/5756"/>						
Continuity <input type="text" value="080408/5756"/>						
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL9/7-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 6 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL9/8

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 7 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL9, 8/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
Test instrument serial number(s)						
Loop impedance <input type="text" value="080408/5756"/>						
Insulation resistance <input type="text" value="080408/5756"/>						
Continuity <input type="text" value="080408/5756"/>						
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL9/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL9/8-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 8 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL9, 8/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
Test instrument serial number(s)						
Loop impedance <input type="text" value="080408/5756"/>						
Insulation resistance <input type="text" value="080408/5756"/>						
Continuity <input type="text" value="080408/5756"/>						
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL9/8-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL8/6

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 1 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL8, 6/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.44"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="26.4"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL8/6"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL8/6-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL8, 6/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.44"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="26.4"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL8/6-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL8/7

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 3 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL8, 7/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.52"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL8/7"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL8/7-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL8, 7/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.52"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL8/7-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL8/7-2



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 7 Riser [Schneider]		Supply to distribution board is from Sub Mains(DB CL8, 7/L1)		Associated RCD(if any): BS (EN)
Num. of ways 4 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Above 30mA (if applicable) Operating at 1 I _{Δn} 28.8 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type C Rating 32 A Voltage		30mA or below I _{pr} kA I _{Δn} 30 Operating at 5 I _{Δn} 27.2 ms
				Time delay (if applicable)
Test instrument serial number(s)				
Loop impedance 080408/5756				
Insulation resistance 080408/5756				
Continuity 080408/5756				
RCD 080408/5756				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL8/7-2 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) 80%
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL8/8

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL8, 8/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="24.0"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL8/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL8/8-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 6 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL8, 8/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="24.0"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL8/8-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 6 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL8/8-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 8 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL8, 8/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="24.0"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL8/8-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL7/4

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 1 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL7, 4/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL7/4"/>	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL7/4-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL7, 4/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL7/4-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL7/5

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room X Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL7, 5/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Operating at 1 IΔn <input type="text" value="28.8"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Z _s <input type="text" value="0.44"/> Ω No. of poles <input type="text"/> 30mA or below		Continuity <input type="text" value="080408/5756"/>
				I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="18.2"/> ms		RCD <input type="text" value="080408/5756"/>
				Time delay (if applicable) <input type="text"/>		

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL7/5"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL7/5-1

FT/EICR 110148423



Company Name <input type="text" value="PHS Compliance"/>	Company Address <input type="text" value="Kid Glove Road"/>	Postcode <input type="text" value="WA3 3GR"/>	Branch No. <input type="text"/>	Scheme No. <input type="text"/>
Client <input type="text" value="UPP Residential Services Ltd"/>	Installation Address <input type="text" value="Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea"/>			Postcode <input type="text" value="SA1 8EN"/>
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL7, 5/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="18.2"/> ms
				Time delay (if applicable) <input type="text"/>
				Test instrument serial number(s)
				Loop impedance <input type="text" value="080408/5756"/>
				Insulation resistance <input type="text" value="080408/5756"/>
				Continuity <input type="text" value="080408/5756"/>
				RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL7/5-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL7/5-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.	
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea				Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL7, 5/L3)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.44"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="18.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
							RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL7/5-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL6/6

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 1 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL6, 6/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="24.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.44"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL6/6"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL6/6-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 3 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL6, 6/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 I _{Δn} <input type="text" value="24.2"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.44"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
Test instrument serial number(s)						
Loop impedance <input type="text" value="080408/5756"/>						
Insulation resistance <input type="text" value="080408/5756"/>						
Continuity <input type="text" value="080408/5756"/>						
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL6/6-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL6/6-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL6, 6/L1)"/>		Associated RCD(if any): BS (EN) <input type="text" value=""/> Above 30mA (if applicable)		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Operating at 1 I _{Δn} <input type="text" value="24.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value=""/>		Z _s <input type="text" value="0.44"/> Ω No. of poles <input type="text" value=""/> 30mA or below		Continuity <input type="text" value="080408/5756"/>
				I _{pr} <input type="text" value=""/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="27.2"/> ms		RCD <input type="text" value="080408/5756"/>
				Time delay (if applicable) <input type="text" value=""/>		

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL6/6-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL6/7

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL6, 7/L1)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 I _{Δn} <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.37"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="29.4"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL6/7"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL6/7-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL6, 7/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 I _{Δn} <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.37"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="29.4"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL6/7-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL6/7-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 6 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL6, 7/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.37"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="29.4"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL6/7-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 6 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL6/8

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 7 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL6, 8/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.34"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="22.5"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL6/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL6/8-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 8 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL6, 8/L1)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.34"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="22.5"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL6/8-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L1	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL5/6

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL5, 6/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL5/6"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL5/6-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 6 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL5, 6/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
Test instrument serial number(s)						
Loop impedance <input type="text" value="080408/5756"/>						
Insulation resistance <input type="text" value="080408/5756"/>						
Continuity <input type="text" value="080408/5756"/>						
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL5/6-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 6 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL5/6-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 8 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL5, 6/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL5/6-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL5/7

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 3 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL5, 7/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="26.4"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="29.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL5/7"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL5/7-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL5, 7/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="26.4"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="29.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL5/7-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL5/7-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 7 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL5, 7/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="26.4"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/>		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="29.2"/> ms		Continuity <input type="text" value="080408/5756"/>
				Time delay (if applicable) <input type="text"/>		RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL5/7-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL5/8

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.	
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board		
Location <input type="text" value="Room 1 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL5, 8/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)		
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below		
					Z _d <input type="text" value="0.32"/> Ω No. of poles <input type="text"/>		
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="29.2"/> ms		
					Time delay (if applicable) <input type="text"/>		
				Test instrument serial number(s)			
				Loop impedance <input type="text" value="080408/5756"/>			
				Insulation resistance <input type="text" value="080408/5756"/>			
				Continuity <input type="text" value="080408/5756"/>			
				RCD <input type="text" value="080408/5756"/>			

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL5/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other <input type="text" value="80%"/> (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL5/8-1

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL5, 8/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Operating at 1 IΔn <input type="text" value="28.8"/> ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		30mA or below
				Z _s <input type="text" value="0.32"/> Ω No. of poles <input type="text"/>
				I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="29.2"/> ms
				Time delay (if applicable) <input type="text"/>
Test instrument serial number(s)				
Loop impedance <input type="text" value="080408/5756"/>				
Insulation resistance <input type="text" value="080408/5756"/>				
Continuity <input type="text" value="080408/5756"/>				
RCD <input type="text" value="080408/5756"/>				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL5/8-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL4/4

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 1 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL4, 4/L3)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL4/4"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL4/4-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 2 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL4, 4/L3)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.38"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL4/4-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL4/5

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 3 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL4, 5/L3)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL4/5"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL4/5-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL4, 5/L3)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL4/5-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL4/5-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 5 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL4, 5/L3)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="27.2"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL4/5-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L3	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL3/6

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 1 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL3, 6/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="26.2"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.36"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="22.4"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL3/6"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 1 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL3/6-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 3 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL3, 6/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 I _{Δn} <input type="text" value="26.2"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below I _{pr} <input type="text"/> kA I _{Δn} <input type="text" value="30"/> Operating at 5 I _{Δn} <input type="text" value="22.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>					Time delay (if applicable) <input type="text"/>	
Test instrument serial number(s)						
Loop impedance <input type="text" value="080408/5756"/>						
Insulation resistance <input type="text" value="080408/5756"/>						
Continuity <input type="text" value="080408/5756"/>						
RCD <input type="text" value="080408/5756"/>						

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL3/6-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) <input type="text" value="80%"/>
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 3 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL3/6-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location: Room 5 Riser [Schneider]		Supply to distribution board is from: Sub Mains(DB CL3, 6/L2)			Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Num. of ways: 4 No. of phases: 1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO			Operating at 1 IΔn 26.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type: C Rating: 32 A Voltage:			30mA or below (if applicable)	
					Zs 0.36 Ω No. of poles: Ipr 30 kA IΔn 30 Operating at 5 IΔn 22.4 ms	
					Time delay (if applicable):	
					Test instrument serial number(s): Loop impedance 080408/5756 Insulation resistance 080408/5756 Continuity 080408/5756 RCD 080408/5756	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL3/6-2 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 5 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL3/7

FT/EICR 110148423



Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 2 Riser [Schneider]		Supply to distribution board is from Sub Mains(DB CL3, 7/L2)		Associated RCD(if any): BS (EN) [] Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms
Num. of ways 4 No. of phases 1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Z _s 0.40 Ω No. of poles [] 30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type C Rating 32 A Voltage []		I _{pr} [] kA IΔn 30 Operating at 5 IΔn 25.4 ms
				Time delay (if applicable) []
Test instrument serial number(s)				
Loop impedance 080408/5756				
Insulation resistance 080408/5756				
Continuity 080408/5756				
RCD 080408/5756				

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB CL3/7 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 2 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL3/7-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 4 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL3, 7/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="25.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL3/7-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 4 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL3/7-2

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)
Location <input type="text" value="Room 6 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL3, 7/L2)"/>		Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms		Loop impedance <input type="text" value="080408/5756"/>
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>		Z _s <input type="text" value="0.40"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="25.4"/> ms		Insulation resistance <input type="text" value="080408/5756"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>		Time delay (if applicable) <input type="text"/>		Continuity <input type="text" value="080408/5756"/>
						RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL3/7-2"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 6 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL3/8

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 7 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL3, 8/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable)	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			30mA or below	
					Z _s <input type="text" value="0.37"/> Ω No. of poles <input type="text"/>	
					I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="25.4"/> ms	
					Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s)	
					Loop impedance <input type="text" value="080408/5756"/>	
					Insulation resistance <input type="text" value="080408/5756"/>	
					Continuity <input type="text" value="080408/5756"/>	
					RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL3/8"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 7 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ELECTRICAL INSTALLATION CONDITION REPORT \Circuit Chart - DB CL3/8-1

FT/EICR 110148423



Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus, Swansea Bay Campus, Building Bere, Fabian Way, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board	
Location <input type="text" value="Room 8 Riser [Schneider]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL3, 8/L2)"/>			Associated RCD(if any): BS (EN) <input type="text"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="28.8"/> ms	
Num. of ways <input type="text" value="4"/> No. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/>			Z _s <input type="text" value="0.37"/> Ω No. of poles <input type="text"/> 30mA or below I _{pr} <input type="text"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="25.4"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text"/>			Time delay (if applicable) <input type="text"/>	
					Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation <input type="text" value="DB CL3/8-1"/> Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)
					L / N	CPC		BS EN Number	Type No.	Rating (A)			
1/L2	Room 8 Sockets	A	B	8	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A