

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT

Client: Grwp Gwalia Cyf

Address: Ty Gwalia
 7-13 The Kingsway
 Swansea
 West Glamorgan

Postcode: SA1 5JN

B. PURPOSE OF THE REPORT

Purpose for which this report is required: Periodic inspection & Test only.

Date(s) on which inspection and testing were carried out: 17th December 2018

C. DETAILS OF THE INSTALLATION

Occupier: Tenant

Address: Block C Flat 1
 Ty Beck House,
 Sketty Road,
 Uplands,
 Swansea, Postcode: SA2 0NH

Estimated age of the electrical installation: 25 years Evidence of alterations or additions If yes, estimated age 5 years

Date of previous inspection: N/A Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: N/A

Records of installation available: No Records held by: N/A

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
 Main DB and associated circuits only.

Agreed limitations (including the reasons), if any, on the inspection and testing:
 Audio circuits,
 Heating control circuits,
 Telecommunication circuits,
 Attic voids

Agreed with: Client

Operational limitations including the reasons (see page No. N/A)
 None.

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
 All in working order.

Summary of the condition of the installation continued on additional pages? No Yes Specify page

Overall assessment of the installation: **SATISFACTORY** ~~UNSATISFACTORY~~ * An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

F. OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

Referring to the attached schedules of inspection and test results, and subject to the limitations at D:

There are no items adversely affecting electrical safety N/A or The following observations and recommendations for action are made

Item No	Observations	Code †
1	Main DB - For inspections carried out after 1 January 2016 - Presence of a consumer unit or similar switchgear made from combustible material (e.g. plastic) that is not inside a non-combustible enclosure and which is Located under wooden staircase	C3
2	Circuit 1 - Absence of RCD protection for cables installed at a depth of less than 50 mm from a surface of a wall or partition where the cables do not incorporate an earthed metallic covering, are not enclosed in earthed metalwork, or are not mechanically protected against penetration by nails and the like.	C3
3	Circuit 2 - Absence of RCD protection for cables installed at a depth of less than 50 mm from a surface of a wall or partition where the cables do not incorporate an earthed metallic covering, are not enclosed in earthed metalwork, or are not mechanically protected against penetration by nails and the like.	C3
4	Circuit 2 - Absence of RCD protection for circuits of a location containing a bath or shower where satisfactory supplementary bonding is present	C3

Additional Pages? No Yes Specify page

† One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action:

- Code C1** "Danger Present" Risk of injury. Immediate remedial action required.
- Code C2** "Potentially dangerous" Urgent remedial action required.
- Code C3** "Improvement recommended".
- Code F1** "Further investigation required without delay".

Please see the 'Guidance for Recipients' regarding the Classification codes.

Immediate remedial action required for items:

Urgent remedial action required for items:

Further investigation required without delay for items:

Improvement recommended for items:

G. DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described on page 1 (see C), having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (see F) and the attached schedules (see H), provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing (see D).

I/We further declare that in my/our judgement, the overall assessment of the installation in terms of its suitability for continued use is

SATISFACTORY ~~UNSATISFACTORY~~

(see F) at the time the inspection was carried out, and that it should be further inspected as recommended (see I).

* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (F1) is required

INSPECTION, TESTING AND ASSESSMENT BY:

Signature

Name (CAPITALS) DEAN HOBDAY

Position Electrician

Date: 17/12/2018

REPORT REVIEWED AND CONFIRMED BY:

Signature

Name (CAPITALS) RICHARD DAVIES

(Registered Qualified Supervisor for the Approved Contractor at J)

Date: 17/12/2018

H. SCHEDULES AND ADDITIONAL PAGES

Schedule of Inspection: Page(s) No 4,5,6

Additional pages, including data sheets for additional source(s): Page No(s)

Schedule of Test Results for the Installation: Page No(s)

Schedule of Circuit Details for the Installation: Page No(s)

The pages identified are an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.

Original (To the person ordering the work)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

5 Years

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or F1 (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading Title: A & R Electrical Wales Ltd

Address: 15 Alder Road
Cimla
Neath
Glam

Postcode: SA11 3NY

Telephone number: 01639 775810

Email Address: office@aandreelectrical.co.uk

Enrolment number: 040640

(Essential information)

Branch number: 001



K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System Type(s)		Number and Type of Live Conductors		Nature of Supply Parameters		Characteristics of Primary Supply Overcurrent Protective Device(s)	
TN-S	<input type="checkbox"/>	a.c.	<input checked="" type="checkbox"/>	Nominal Voltage(s), $U^{(1)}$	N/A V	$U_0^{(1)}$	230 V
TN-C-S	<input checked="" type="checkbox"/>	1-phase (2 wire)	<input type="checkbox"/>	Nominal frequency, $f^{(1)}$	50 Hz	Number of sources	1
TT	<input type="checkbox"/>	2-phase (3 wire)	<input type="checkbox"/>	Prospective fault current, $I_{pf}^{(2)(3)}$	0.90 kA	External earth fault loop impedance, $Z_e^{(3)(4)}$	0.27 Ω
		3-phase (3 wire)	<input type="checkbox"/>	Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one source, record the higher or highest value (4) by measurement		BS(EN)	BS 1361 Fuse HBC Domestic Type
		3-phase (4 wire)	<input type="checkbox"/>			Type	2
		Other (please state)				Rated current	100 A
						Short-circuit capacity	16.5 kA
						Confirmation of supply polarity	<input checked="" type="checkbox"/> <input type="checkbox"/>

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of Earthing		Details of Installation Earth Electrode (where applicable)		Earthing and protective bonding conductors		Bonding of extraneous-conductive-parts (✓)	
Distributor's facility:	<input checked="" type="checkbox"/>	Type: (eg rod(s), tape etc)	N/A	Location:	N/A	Water service	<input checked="" type="checkbox"/>
Installation earth electrode:	<input type="checkbox"/>	Electrode resistance, R_A :	N/A (Ω)	Method of measurement:	N/A	Oil service	<input type="checkbox"/>
						Gas Service	<input checked="" type="checkbox"/>
						Structural steel	<input type="checkbox"/>
						Lightning protection	<input type="checkbox"/>
						Other (Specify)	<input type="checkbox"/>
Main Switch/Switch-Fuse/Circuit-Breaker/RCD				Earthing conductor		Main protective bonding conductors	
Type: BS(EN)	BS EN 60947-	Voltage rating	230 V	Conductor material	Copper	Conductor material	Copper
No of Poles	2	Rated current, I_n	100 A	Conductor csa	10.0 mm ²	Conductor csa	10.0 mm ²
Primary supply conductors (material)	Copper	RCD operating current, $I_{\Delta n}^*$	N/A mA	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)
Primary supply conductors (csa)	16.0 mm ²	Rated time delay*	N/A ms				
		RCD operating time (at $I_{\Delta n}$)*	N/A ms				

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment†		
1.1	Service cable	✓	
1.2	Service head	✓	
1.3	Distributor's earthing arrangement	✓	
1.4	Meter tails - Distributor/Consumer	✓	
1.5	Metering equipment	✓	
1.6	Means of main isolation (where present)	✓	
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
3.0	Earthing and bonding arrangements		
3.1	Presence and condition of distributor's earthing arrangement	✓	
3.2	Presence and condition of earth electrode connection	N/A	
3.3	Confirmation of adequate earthing conductor size	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	
3.6	Accessibility and condition of main protective bonding conductor connections	✓	
3.7	Accessibility and condition of other protective bonding connections	✓	
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	

Item	Description	Outcome*	Location reference
4.0	Consumer unit(s)		
4.1	Adequacy of working space or access to consumer unit	✓	
4.2	Security of fixing	✓	
4.3	Condition of enclosure(s) in terms of IP rating	✓	
4.4	Condition of enclosure(s) in terms of fire rating	C3	
4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	
4.6	Presence of linked main switch	✓	
4.7	Operation of main switch (functional check)	✓	
4.8	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	
4.9	Correct identification of circuits and protective devices	✓	
4.10	Presence of RCD test notice at or near consumer unit	✓	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓	
4.12	Presence of alternative or additional supply warning notice at or near consumer unit	N/A	
4.13	Presence of replacement next inspection recommendation label	✓	
4.14	Presence of other required labelling (please specify)	N/A	
4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
4.16	Single-pole switching or protective devices in the line conductors only	✓	
4.17	Protection against mechanical damage where cables enter consumer unit	✓	
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	N/A	
4.19	RCDs provided for fault protection - includes RCBOs	✓	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 ✗ indicates a limitation
 N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state FI (to determine whether danger or potential danger exists)
 Outcome Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.
 † Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.
 This report is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

Original (To the person ordering the work)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
4.20	RCDs provided for additional protection - includes RCBOs	✓	
4.21	Confirmation of indication that SPD is functional	N/A	
4.22	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓	
5.0 Distribution/final circuits			
5.1	Identification of conductors	✓	
5.2	Cables correctly supported throughout their length	LIM	
5.3	Condition of insulation of live parts	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	N/A	
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓	
5.6	Adequacy of protective devices; type and rated current for fault protection	✓	
5.7	Presence and adequacy of circuit protective conductors	✓	
5.8	Co-ordination between conductors and overload protective devices	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓	
5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage		
	installed in prescribed zones (see Section D. Extent and limitations)	N/A	
	incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the	N/A	

Item	Description	Outcome*	Location reference
5.11	Provision of additional protection by RCD not exceeding 30 mA		
	⚡ for all socket-outlets of rating 20 A or less	✓	
	⚡ for mobile equipment not exceeding a rating of 32A for use outdoors	✓	
	⚡ for cables installed in walls or partitions at a depth of less than 50 mm	C3	
	⚡ for cables installed in walls / partitions containing metal parts regardless of depth	C3	
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	LIM	
5.13	Band II cables segregated/separated from Band I cables	LIM	
5.14	Cables segregated/separated from communications cabling	LIM	
5.15	Cables segregated/separated from non-electrical services	LIM	
5.16	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
	• Connections soundly made and under no undue strain	✓	
	• No basic insulation of a conductor visible outside enclosures	✓	
	• Connections of live conductors adequately enclosed	✓	
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓	
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	
5.18	Suitability of accessories for external influences	✓	
5.19	Adequacy of working space / accessibility to equipment	✓	
5.20	Single-pole devices for switching or protection in line conductors only	✓	

6.0 Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)

Notes: Switching devices designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI+ (to determine whether danger or potential danger exists)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
6.1	In general		
	presence and condition of appropriate devices	✓	
	correct operation verified	✓	
6.2	For isolation and switching for mechanical maintenance only		
	capable of being secured in the OFF position where appropriate	N/A	
	acceptable location - state if local or remote from equipment being controlled where appropriate	N/A	
	clearly identified by position and/or durable marking(s)	N/A	
6.3	For isolation only		
	warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.0	Current-using equipment (Permanently connected)		
7.1	Condition of equipment in terms of IP rating	✓	
7.2	Equipment does not constitute a fire hazard	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety	✓	
7.4	Suitability for the environment and external influences	✓	
7.5	Security of fixing	✓	
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire List number and location of luminaires inspected. (Separate page)	LIM	
7.7	Recessed luminaires (downlighters)		
	correct type of lamps fitted	N/A	
	installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	N/A	
	no signs of overheating to surrounding building fabric	✓	

Item	Description	Outcome*	Location reference
	no signs of overheating to conductors/terminations	✓	
8.0	Location(s) containing a bath or shower		
8.1	Additional protection by RCD not exceeding 30 mA		
	for low voltage circuits serving the location	C3	
	for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	C3	
8.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	N/A	
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓	
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	
8.7	Suitability of equipment for installation in a particular zone	✓	
9.0	Other special installations or locations - Part 7s		
9.1	List all other special installations or locations present, if any. (Record the results of particular inspection applied separately).	N/A	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2, C3 and FI coded items to be recorded in Section F of the report.

SCHEDULES

CIRCUIT DETAILS													TEST RESULTS															
Circuit number	Circuit designation * To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box	Type of wiring (see code below)	Reference Method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices					RCD	Maximum Z_s permitted by BS 7671	Circuit impedances (Ω)					Insulation resistance					RCD operating times		Test button operation	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, $I_{\Delta n}$ (mA)			Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line (M Ω)	Line/Neutral (M Ω)	Line/Earth (M Ω)	Neutral/Earth (M Ω)	Polarity (\checkmark)	Maximum measured earth fault loop impedance, Z_s (Ω)	at $I_{\Delta n}$ (ms)		at $5I_{\Delta n}$ (ms) (if applicable)
															r_1 (Line)	r_n (Neutral)	r_2 (cpc)	$R_1 + R_2$	R_2									
																		r_1 (Line)	r_n (Neutral)	r_2 (cpc)	$R_1 + R_2$	R_2						
1	Cooker	A	C	1	6.0	2.5	0.4	60898 MCB	B	32	6	N/A	1.37	N/A	N/A	N/A	0.15	N/A	N/A	> 200	> 200	> 200	\checkmark	0.42	N/A	N/A		
2	Lights flat	A	C	9	1.0	1.0	0.4	60898 MCB	B	6	6	N/A	7.28	N/A	N/A	N/A	1.20	N/A	N/A	> 200	> 200	> 200	\checkmark	1.47	N/A	N/A		
3	Spare																											
4	Spare																											
5	Sockets house	A	C	29	2.5	1.5	0.4	61009 RCD/R	B	32	6	30	1.37	0.48	0.49	0.73	0.25	N/A	N/A	> 200	> 200	> 200	\checkmark	0.52	20.3	15.7	\checkmark	

Location of consumer unit **By front door.** Designation of consumer unit **Main DB** Prospective fault current at consumer unit **0.90** kA

TEST INSTRUMENTS		Test instruments (serial numbers) used									
Multi-functional	1589042	Insulation resistance	N/A	Continuity	N/A	Earth electrode resistance	N/A	Earth fault loop impedance	N/A	RCD	N/A

CODES FOR TYPE OF WIRING
 A Thermoplastic insulated cables in sheath
 B Thermoplastic cables in non-metallic conduit
 C Thermoplastic cables in non-metallic conduit
 D Thermoplastic cables in non-metallic trunking
 E Thermoplastic cables in non-metallic trunking
 F Thermoplastic SWA cables
 G Thermosetting SWA cables
 H Mineral-insulated cables
 J (Other - please state)

Original (To the person ordering the work)

This report is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT

Client: Grwp Gwalia Cyf

Address: Ty Gwalia
 7-13 The Kingsway
 Swansea
 West Glamorgan

Postcode: SA1 5JN

B. PURPOSE OF THE REPORT

Purpose for which this report is required: Periodic inspection & Test only.

Date(s) on which inspection and testing were carried out: 17th December 2018

C. DETAILS OF THE INSTALLATION

Occupier: Tenant

Address: Block C Flat 2
 Ty Beck House,
 Sketty Road,
 Uplands,
 Swansea, Postcode: SA2 0NH

Estimated age of the electrical installation: 25 years Evidence of alterations or additions If yes, estimated age 5 years

Date of previous inspection: N/A Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: N/A

Records of installation available: No Records held by: N/A

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
 Main DB and associated circuits only.

Agreed limitations (including the reasons), if any, on the inspection and testing:
 Audio circuits,
 Heating control circuits,
 Telecommunication circuits,
 Attic voids

Agreed with: Client

Operational limitations including the reasons (see page No. N/A)
 None.

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
 All in working order.

Summary of the condition of the installation continued on additional pages? No Yes Specify page

Overall assessment of the installation: **SATISFACTORY** ~~UNSATISFACTORY~~ * An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

5 Years

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or F1 (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading Title: **A & R Electrical Wales Ltd**

Address: **15 Alder Road
Cimla
Neath
Glam**

Postcode: **SA11 3NY**

Telephone number: **01639 775810**

Email Address: **office@aandreelectrical.co.uk**

Enrolment number: **040640**

(Essential information)

Branch number: **001**
(if applicable)



K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System Type(s)		Number and Type of Live Conductors		Nature of Supply Parameters		Characteristics of Primary Supply Overcurrent Protective Device(s)	
TN-S	<input type="checkbox"/>	a.c.	<input checked="" type="checkbox"/>	Nominal Voltage(s), U ⁽¹⁾	N/A V	U ₀ ⁽¹⁾	230 V
TN-C-S	<input checked="" type="checkbox"/>	1-phase (2 wire)	<input type="checkbox"/>	Nominal frequency, f ⁽¹⁾	50 Hz	Number of sources	1
TT	<input type="checkbox"/>	2-phase (3 wire)	<input type="checkbox"/>	Prospective fault current, I _{pr} ⁽²⁾⁽³⁾	0.85 kA	External earth fault loop impedance, Z _e ⁽³⁾⁽⁴⁾	0.28 Ω
		3-phase (3 wire)	<input type="checkbox"/>	Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one source, record the higher or highest value (4) by measurement			
		3-phase (4 wire)	<input type="checkbox"/>	BS(EN)	BS 1361 Fuse HBC Domestic Type		
		Other (please state)		Type	2		
				Rated current	100 A		
				Short-circuit capacity	16.5 kA		
				Confirmation of supply polarity	<input checked="" type="checkbox"/> <input type="checkbox"/>		

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of Earthing		Details of Installation Earth Electrode (where applicable)		Earthing and protective bonding conductors		Bonding of extraneous-conductive-parts (✓)	
Distributor's facility:	<input checked="" type="checkbox"/>	Type: (eg rod(s), tape etc)	N/A	Location:	N/A		
Installation earth electrode:	<input type="checkbox"/>	Electrode resistance, R _A :	N/A (Ω)	Method of measurement:	N/A		
Main Switch/Switch-Fuse/Circuit-Breaker/RCD				Earthing conductor		Main protective bonding conductors	
Type: BS(EN)	BS EN 60947-	Voltage rating	230 V	Conductor material	Copper		
No of Poles	2	Rated current, I _n	100 A	Conductor csa	10.0 mm ²		
Primary supply conductors (material)	Copper	RCD operating current, I _{Δn} *	N/A mA	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)		
Primary supply conductors (csa)	16.0 mm ²	Rated time delay*	N/A ms				
		RCD operating time (at I _{Δn})*	N/A ms				
					Water service <input checked="" type="checkbox"/>		
					Gas Service <input checked="" type="checkbox"/>		
					Oil service <input type="checkbox"/>		
					Structural steel <input type="checkbox"/>		
					Lightning protection <input type="checkbox"/>		
					Other (Specify)		

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment†		
1.1	Service cable	✓	
1.2	Service head	✓	
1.3	Distributor's earthing arrangement	✓	
1.4	Meter tails - Distributor/Consumer	✓	
1.5	Metering equipment	✓	
1.6	Means of main isolation (where present)	✓	
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
3.0	Earthing and bonding arrangements		
3.1	Presence and condition of distributor's earthing arrangement	✓	
3.2	Presence and condition of earth electrode connection	N/A	
3.3	Confirmation of adequate earthing conductor size	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	
3.6	Accessibility and condition of main protective bonding conductor connections	✓	
3.7	Accessibility and condition of other protective bonding connections	✓	
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	

Item	Description	Outcome*	Location reference
4.0	Consumer unit(s)		
4.1	Adequacy of working space or access to consumer unit	✓	
4.2	Security of fixing	✓	
4.3	Condition of enclosure(s) in terms of IP rating	✓	
4.4	Condition of enclosure(s) in terms of fire rating	C3	
4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	
4.6	Presence of linked main switch	✓	
4.7	Operation of main switch (functional check)	✓	
4.8	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	
4.9	Correct identification of circuits and protective devices	✓	
4.10	Presence of RCD test notice at or near consumer unit	✓	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓	
4.12	Presence of alternative or additional supply warning notice at or near consumer unit	N/A	
4.13	Presence of replacement next inspection recommendation label	✓	
4.14	Presence of other required labelling (please specify)	N/A	
4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
4.16	Single-pole switching or protective devices in the line conductors only	✓	
4.17	Protection against mechanical damage where cables enter consumer unit	✓	
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	N/A	
4.19	RCDs provided for fault protection - includes RCBOs	✓	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 ✗ indicates a limitation
 N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state FI (to determine whether danger or potential danger exists)
 † Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.

Outcome
 Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
4.20	RCDs provided for additional protection - includes RCBOs	✓	
4.21	Confirmation of indication that SPD is functional	N/A	
4.22	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓	
5.0 Distribution/final circuits			
5.1	Identification of conductors	✓	
5.2	Cables correctly supported throughout their length	LIM	
5.3	Condition of insulation of live parts	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	N/A	
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓	
5.6	Adequacy of protective devices; type and rated current for fault protection	✓	
5.7	Presence and adequacy of circuit protective conductors	✓	
5.8	Co-ordination between conductors and overload protective devices	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓	
5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage		
	installed in prescribed zones (see Section D. Extent and limitations)	N/A	
	incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the	N/A	

Item	Description	Outcome*	Location reference
5.11	Provision of additional protection by RCD not exceeding 30 mA		
	⚡ for all socket-outlets of rating 20 A or less	✓	
	⚡ for mobile equipment not exceeding a rating of 32A for use outdoors	✓	
	⚡ for cables installed in walls or partitions at a depth of less than 50 mm	C3	
	⚡ for cables installed in walls / partitions containing metal parts regardless of depth	C3	
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	LIM	
5.13	Band II cables segregated/separated from Band I cables	LIM	
5.14	Cables segregated/separated from communications cabling	LIM	
5.15	Cables segregated/separated from non-electrical services	LIM	
5.16	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
	• Connections soundly made and under no undue strain	✓	
	• No basic insulation of a conductor visible outside enclosures	✓	
	• Connections of live conductors adequately enclosed	✓	
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓	
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	
5.18	Suitability of accessories for external influences	✓	
5.19	Adequacy of working space / accessibility to equipment	✓	
5.20	Single-pole devices for switching or protection in line conductors only	✓	

6.0 Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)
Notes: Switchgear designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI+ (to determine whether danger or potential danger exists)

Original (To the person ordering the work)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
6.1	In general		
	presence and condition of appropriate devices	✓	
	correct operation verified	✓	
6.2	For isolation and switching for mechanical maintenance only		
	capable of being secured in the OFF position where appropriate	N/A	
	acceptable location - state if local or remote from equipment being controlled where appropriate	N/A	
	clearly identified by position and/or durable marking(s)	N/A	
6.3	For isolation only		
	warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.0	Current-using equipment (Permanently connected)		
7.1	Condition of equipment in terms of IP rating	✓	
7.2	Equipment does not constitute a fire hazard	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety	✓	
7.4	Suitability for the environment and external influences	✓	
7.5	Security of fixing	✓	
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire List number and location of luminaires inspected. (Separate page)	LIM	
7.7	Recessed luminaires (downlighters)		
	correct type of lamps fitted	N/A	
	installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	N/A	
	no signs of overheating to surrounding building fabric	✓	

Item	Description	Outcome*	Location reference
	no signs of overheating to conductors/terminations	✓	
8.0	Location(s) containing a bath or shower		
8.1	Additional protection by RCD not exceeding 30 mA		
	for low voltage circuits serving the location	C3	
	for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	C3	
8.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	N/A	
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓	
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	
8.7	Suitability of equipment for installation in a particular zone	✓	
9.0	Other special installations or locations - Part 7s		
9.1	List all other special installations or locations present, if any. (Record the results of particular inspection applied separately).	N/A	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2, C3 and FI coded items to be recorded in Section F of the report.

SCHEDULES

Original (To the person ordering the work)

CIRCUIT DETAILS													TEST RESULTS															
Circuit number	Circuit designation * To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box	Type of wiring (see code below)	Reference Method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices					RCD	Maximum Z _s permitted by BS 7671	Circuit impedances (Ω)					Insulation resistance					RCD operating times		Test button operation	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)			Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)	Polarity (✓)	Maximum measured earth fault loop impedance, Z _s (Ω)	at I _{Δn} (ms)		at 5I _{Δn} (if applicable) (ms)
															r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	R ₁ + R ₂	R ₂									
1	Cooker	A	C	1	6.0	2.5	0.4	60898 MCB	B	32	6	N/A	1.37	N/A	N/A	N/A	0.18	N/A	N/A	> 200	> 200	> 200	✓	0.46	N/A	N/A		
2	Lights flat	A	C	9	1.0	1.0	0.4	60898 MCB	B	6	6	N/A	7.28	N/A	N/A	N/A	1.22	N/A	N/A	> 200	> 200	> 200	✓	1.50	N/A	N/A		
3	Spare																											
4	Spare																											
5	Sockets house	A	C	29	2.5	1.5	0.4	61009 RCD/R	B	32	6	30	1.37	0.44	0.44	0.65	0.38	N/A	N/A	> 200	> 200	> 200	✓	0.66	8.7	5.3	✓	

Location of consumer unit **By front door.** Designation of consumer unit **Main DB** Prospective fault current at consumer unit **0.85** kA

TEST INSTRUMENTS		Test instruments (serial numbers) used									
Multi-functional	1589042	Insulation resistance	N/A	Continuity	N/A	Earth electrode resistance	N/A	Earth fault loop impedance	N/A	RCD	N/A

CODES FOR TYPE OF WIRING										
A	B	C	D	E	F	G	H	I	J	K
Thermoplastic insulated cables in sheath	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in non-metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic cables in non-metallic trunking

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT

Client: Grwp Gwalia Cyf

Address: Ty Gwalia
7-13 The Kingsway
Swansea
West Glamorgan

Postcode: SA1 5JN

B. PURPOSE OF THE REPORT

Purpose for which this report is required: Periodic inspection & Test only.

Date(s) on which inspection and testing were carried out: 17th December 2018

C. DETAILS OF THE INSTALLATION

Occupier: Tenant

Address: Block C Flat 3
Ty Beck House,
Sketty Road,
Uplands,
Swansea, Postcode: SA2 0NH

Estimated age of the electrical installation: 25 years Evidence of alterations or additions If yes, estimated age 5 years

Date of previous inspection: N/A Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: N/A

Records of installation available: No Records held by: N/A

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
Main DB and associated circuits only.

Agreed limitations (including the reasons), if any, on the inspection and testing:
Audio circuits,
Heating control circuits,
Telecommunication circuits,
Attic voids

Agreed with: Client

Operational limitations including the reasons (see page No. N/A)
None.

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
All in working order.

Summary of the condition of the installation continued on additional pages? No Yes Specify page

Overall assessment of the installation: **SATISFACTORY** ~~UNSATISFACTORY~~ * An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

5 Years

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or F1 (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading Title: **A & R Electrical Wales Ltd**

Address: **15 Alder Road
Cimla
Neath
Glam**

Postcode: **SA11 3NY**

Telephone number: **01639 775810**

Email Address: **office@aandreelectrical.co.uk**

Enrolment number: **040640**

(Essential information)

Branch number: **001**



K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System Type(s)		Number and Type of Live Conductors		Nature of Supply Parameters		Characteristics of Primary Supply Overcurrent Protective Device(s)	
TN-S	<input type="checkbox"/>	a.c.	<input checked="" type="checkbox"/>	Nominal Voltage(s), $U^{(1)}$	N/A V	$U_0^{(1)}$	230 V
TN-C-S	<input checked="" type="checkbox"/>	1-phase (2 wire)	<input type="checkbox"/>	Nominal frequency, $f^{(1)}$	50 Hz	Number of sources	1
TT	<input type="checkbox"/>	2-phase (3 wire)	<input type="checkbox"/>	Prospective fault current, $I_{pf}^{(2)(3)}$	0.83 kA	Rated current	100 A
		3-phase (3 wire)	<input type="checkbox"/>	External earth fault loop impedance, $Z_e^{(3)(4)}$	0.29 Ω	Short-circuit capacity	16.5 kA
		3-phase (4 wire)	<input type="checkbox"/>	Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one source, record the higher or highest value (4) by measurement		Confirmation of supply polarity	<input checked="" type="checkbox"/> <input type="checkbox"/>
Other (please state)							
						BS(EN) BS 1361 Fuse HBC Domestic Type	
						Type 2	

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of Earthing		Details of Installation Earth Electrode (where applicable)		Earthing and protective bonding conductors		Bonding of extraneous-conductive-parts (✓)	
Distributor's facility:	<input checked="" type="checkbox"/>	Type: (eg rod(s), tape etc)	N/A	Location:	N/A	Water service	<input checked="" type="checkbox"/>
Installation earth electrode:	<input type="checkbox"/>	Electrode resistance, R_A :	N/A (Ω)	Method of measurement:	N/A	Oil service	<input type="checkbox"/>
						Gas Service	<input checked="" type="checkbox"/>
						Structural steel	<input type="checkbox"/>
						Lightning protection	<input type="checkbox"/>
						Other (Specify)	<input type="checkbox"/>
Main Switch/Switch-Fuse/Circuit-Breaker/RCD				Earthing conductor		Main protective bonding conductors	
Type: BS(EN)	BS EN 60947-	Voltage rating	230 V	Conductor material	Copper	Conductor material	Copper
No of Poles	2	Rated current, I_n	100 A	Conductor csa	10.0 mm ²	Conductor csa	10.0 mm ²
Primary supply conductors (material)	Copper	RCD operating current, $I_{\Delta n}^*$	N/A mA	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)
Primary supply conductors (csa)	16.0 mm ²	Rated time delay*	N/A ms				
		RCD operating time (at $I_{\Delta n}$)*	N/A ms				

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment†		
1.1	Service cable	✓	
1.2	Service head	✓	
1.3	Distributor's earthing arrangement	✓	
1.4	Meter tails - Distributor/Consumer	✓	
1.5	Metering equipment	✓	
1.6	Means of main isolation (where present)	✓	
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
3.0	Earthing and bonding arrangements		
3.1	Presence and condition of distributor's earthing arrangement	✓	
3.2	Presence and condition of earth electrode connection	N/A	
3.3	Confirmation of adequate earthing conductor size	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	
3.6	Accessibility and condition of main protective bonding conductor connections	✓	
3.7	Accessibility and condition of other protective bonding connections	✓	
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	

Item	Description	Outcome*	Location reference
4.0	Consumer unit(s)		
4.1	Adequacy of working space or access to consumer unit	✓	
4.2	Security of fixing	✓	
4.3	Condition of enclosure(s) in terms of IP rating	✓	
4.4	Condition of enclosure(s) in terms of fire rating	C3	
4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	
4.6	Presence of linked main switch	✓	
4.7	Operation of main switch (functional check)	✓	
4.8	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	
4.9	Correct identification of circuits and protective devices	✓	
4.10	Presence of RCD test notice at or near consumer unit	✓	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓	
4.12	Presence of alternative or additional supply warning notice at or near consumer unit	N/A	
4.13	Presence of replacement next inspection recommendation label	✓	
4.14	Presence of other required labelling (please specify)	N/A	
4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
4.16	Single-pole switching or protective devices in the line conductors only	✓	
4.17	Protection against mechanical damage where cables enter consumer unit	✓	
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	N/A	
4.19	RCDs provided for fault protection - includes RCBOs	✓	

* All Outcome boxes must be completed
 indicates Acceptable condition
 indicates a limitation
 indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state FI (to determine whether danger or potential danger exists)
 Outcome Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
4.20	RCDs provided for additional protection - includes RCBOs	✓	
4.21	Confirmation of indication that SPD is functional	N/A	
4.22	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓	
5.0 Distribution/final circuits			
5.1	Identification of conductors	✓	
5.2	Cables correctly supported throughout their length	LIM	
5.3	Condition of insulation of live parts	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	N/A	
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓	
5.6	Adequacy of protective devices; type and rated current for fault protection	✓	
5.7	Presence and adequacy of circuit protective conductors	✓	
5.8	Co-ordination between conductors and overload protective devices	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓	
5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage		
	installed in prescribed zones (see Section D. Extent and limitations)	N/A	
	incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the	N/A	

Item	Description	Outcome*	Location reference
5.11	Provision of additional protection by RCD not exceeding 30 mA		
	⚡ for all socket-outlets of rating 20 A or less	✓	
	⚡ for mobile equipment not exceeding a rating of 32A for use outdoors	✓	
	⚡ for cables installed in walls or partitions at a depth of less than 50 mm	C3	
	⚡ for cables installed in walls / partitions containing metal parts regardless of depth	C3	
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	LIM	
5.13	Band II cables segregated/separated from Band I cables	LIM	
5.14	Cables segregated/separated from communications cabling	LIM	
5.15	Cables segregated/separated from non-electrical services	LIM	
5.16	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
	• Connections soundly made and under no undue strain	✓	
	• No basic insulation of a conductor visible outside enclosures	✓	
	• Connections of live conductors adequately enclosed	✓	
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓	
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	
5.18	Suitability of accessories for external influences	✓	
5.19	Adequacy of working space / accessibility to equipment	✓	
5.20	Single-pole devices for switching or protection in line conductors only	✓	

6.0 Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)

Notes: Switching devices designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI+ (to determine whether danger or potential danger exists)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
6.1	In general		
	presence and condition of appropriate devices	✓	
	correct operation verified	✓	
6.2	For isolation and switching for mechanical maintenance only		
	capable of being secured in the OFF position where appropriate	N/A	
	acceptable location - state if local or remote from equipment being controlled where appropriate	N/A	
	clearly identified by position and/or durable marking(s)	N/A	
6.3	For isolation only		
	warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.0	Current-using equipment (Permanently connected)		
7.1	Condition of equipment in terms of IP rating	✓	
7.2	Equipment does not constitute a fire hazard	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety	✓	
7.4	Suitability for the environment and external influences	✓	
7.5	Security of fixing	✓	
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire List number and location of luminaires inspected. (Separate page)	LIM	
7.7	Recessed luminaires (downlighters)		
	correct type of lamps fitted	N/A	
	installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	N/A	
	no signs of overheating to surrounding building fabric	✓	

Item	Description	Outcome*	Location reference
	no signs of overheating to conductors/terminations	✓	
8.0	Location(s) containing a bath or shower		
8.1	Additional protection by RCD not exceeding 30 mA		
	for low voltage circuits serving the location	C3	
	for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	C3	
8.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	N/A	
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓	
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	
8.7	Suitability of equipment for installation in a particular zone	✓	
9.0	Other special installations or locations - Part 7s		
9.1	List all other special installations or locations present, if any. (Record the results of particular inspection applied separately).	N/A	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2, C3 and FI coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT

Client: Grwp Gwalia Cyf

Address: Ty Gwalia
 7-13 The Kingsway
 Swansea
 West Glamorgan

Postcode: SA1 5JN

B. PURPOSE OF THE REPORT

Purpose for which this report is required: Periodic inspection & Test only.

Date(s) on which inspection and testing were carried out: 17th December 2018

C. DETAILS OF THE INSTALLATION

Occupier: Tenant

Address: Block C Flat 4
 Ty Beck House,
 Sketty Road,
 Uplands,
 Swansea, Postcode: SA2 0NH

Estimated age of the electrical installation: 25 years Evidence of alterations or additions If yes, estimated age 5 years

Date of previous inspection: N/A Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: N/A

Records of installation available: No Records held by: N/A

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
 Main DB and associated circuits only.

Agreed limitations (including the reasons), if any, on the inspection and testing:
 Audio circuits,
 Heating control circuits,
 Telecommunication circuits,
 Attic voids

Agreed with: Client

Operational limitations including the reasons (see page No. N/A)
 None.

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
 All in working order.

Summary of the condition of the installation continued on additional pages? No Yes Specify page

Overall assessment of the installation: **SATISFACTORY** ~~UNSATISFACTORY~~ * An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

5 Years

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or F1 (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading Title: A & R Electrical Wales Ltd

Address: 15 Alder Road
Cimla
Neath
Glam

Telephone number: 01639 775810

Email Address: office@aandreelectrical.co.uk



Postcode: SA11 3NY

Enrolment number: 040640

(Essential information)

Branch number: 001

K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System Type(s)		Number and Type of Live Conductors		Nature of Supply Parameters		Characteristics of Primary Supply Overcurrent Protective Device(s)	
TN-S	<input type="checkbox"/>	a.c.	<input checked="" type="checkbox"/>	Nominal Voltage(s), U ⁽¹⁾	N/A V	U ₀ ⁽¹⁾	230 V
TN-C-S	<input checked="" type="checkbox"/>	1-phase (2 wire)	<input type="checkbox"/>	Nominal frequency, f ⁽¹⁾	50 Hz	Number of sources	1
TT	<input type="checkbox"/>	2-phase (3 wire)	<input type="checkbox"/>	Prospective fault current, I _{pr} ⁽²⁾⁽³⁾	0.92 kA	BS(EN)	BS 1361 Fuse HBC Domestic Type
		3-phase (3 wire)	<input type="checkbox"/>	External earth fault loop impedance, Z _e ⁽³⁾⁽⁴⁾	0.26 Ω	Type	2
		3-phase (4 wire)	<input type="checkbox"/>			Rated current	100 A
		Other (please state)				Short-circuit capacity	16.5 kA
						Confirmation of supply polarity	<input checked="" type="checkbox"/> <input type="checkbox"/>

*Notes:
(1) by enquiry
(2) by enquiry or by measurement
(3) where more than one source, record the higher or highest value
(4) by measurement*

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of Earthing		Details of Installation Earth Electrode (where applicable)		Earthing and protective bonding conductors		Bonding of extraneous-conductive-parts (✓)	
Distributor's facility:	<input checked="" type="checkbox"/>	Type: (eg rod(s), tape etc)	N/A	Location:	N/A	Water service	<input checked="" type="checkbox"/>
Installation earth electrode:	<input type="checkbox"/>	Electrode resistance, R _A :	N/A (Ω)	Method of measurement:	N/A	Oil service	<input type="checkbox"/>
						Lightning protection	<input type="checkbox"/>
						Other (Specify)	<input type="checkbox"/>
Main Switch/Switch-Fuse/Circuit-Breaker/RCD				Earthing conductor		Main protective bonding conductors	
Type: BS(EN)	BS EN 60947-	Voltage rating	230 V	Conductor material	Copper	Conductor material	Copper
No of Poles	2	Rated current, I _n	100 A	Conductor csa	10.0 mm ²	Conductor csa	10.0 mm ²
Primary supply conductors (material)	Copper	RCD operating current, I _{Δn} *	N/A mA	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)
Primary supply conductors (csa)	16.0 mm ²	Rated time delay*	N/A ms				
		RCD operating time (at I _{Δn})*	N/A ms				

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment†		
1.1	Service cable	✓	
1.2	Service head	✓	
1.3	Distributor's earthing arrangement	✓	
1.4	Meter tails - Distributor/Consumer	✓	
1.5	Metering equipment	✓	
1.6	Means of main isolation (where present)	✓	
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
3.0	Earthing and bonding arrangements		
3.1	Presence and condition of distributor's earthing arrangement	✓	
3.2	Presence and condition of earth electrode connection	N/A	
3.3	Confirmation of adequate earthing conductor size	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	
3.6	Accessibility and condition of main protective bonding conductor connections	✓	
3.7	Accessibility and condition of other protective bonding connections	✓	
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	

Item	Description	Outcome*	Location reference
4.0	Consumer unit(s)		
4.1	Adequacy of working space or access to consumer unit	✓	
4.2	Security of fixing	✓	
4.3	Condition of enclosure(s) in terms of IP rating	✓	
4.4	Condition of enclosure(s) in terms of fire rating	C3	
4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	
4.6	Presence of linked main switch	✓	
4.7	Operation of main switch (functional check)	✓	
4.8	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	
4.9	Correct identification of circuits and protective devices	✓	
4.10	Presence of RCD test notice at or near consumer unit	✓	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓	
4.12	Presence of alternative or additional supply warning notice at or near consumer unit	N/A	
4.13	Presence of replacement next inspection recommendation label	✓	
4.14	Presence of other required labelling (please specify)	N/A	
4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
4.16	Single-pole switching or protective devices in the line conductors only	✓	
4.17	Protection against mechanical damage where cables enter consumer unit	✓	
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	N/A	
4.19	RCDs provided for fault protection - includes RCBOs	✓	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 ✗ indicates a limitation
 N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state FI (to determine whether danger or potential danger exists)
 Outcome Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.
 † Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.
 This report is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

Original (To the person ordering the work)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
4.20	RCDs provided for additional protection - includes RCBOs	✓	
4.21	Confirmation of indication that SPD is functional	N/A	
4.22	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓	
5.0 Distribution/final circuits			
5.1	Identification of conductors	✓	
5.2	Cables correctly supported throughout their length	LIM	
5.3	Condition of insulation of live parts	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	N/A	
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓	
5.6	Adequacy of protective devices; type and rated current for fault protection	✓	
5.7	Presence and adequacy of circuit protective conductors	✓	
5.8	Co-ordination between conductors and overload protective devices	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓	
5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage		
	installed in prescribed zones (see Section D. Extent and limitations)	N/A	
	incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the	N/A	

Item	Description	Outcome*	Location reference
5.11	Provision of additional protection by RCD not exceeding 30 mA		
	⚡ for all socket-outlets of rating 20 A or less	✓	
	⚡ for mobile equipment not exceeding a rating of 32A for use outdoors	✓	
	⚡ for cables installed in walls or partitions at a depth of less than 50 mm	C3	
	⚡ for cables installed in walls / partitions containing metal parts regardless of depth	C3	
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	LIM	
5.13	Band II cables segregated/separated from Band I cables	LIM	
5.14	Cables segregated/separated from communications cabling	LIM	
5.15	Cables segregated/separated from non-electrical services	LIM	
5.16	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
	• Connections soundly made and under no undue strain	✓	
	• No basic insulation of a conductor visible outside enclosures	✓	
	• Connections of live conductors adequately enclosed	✓	
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓	
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	
5.18	Suitability of accessories for external influences	✓	
5.19	Adequacy of working space / accessibility to equipment	✓	
5.20	Single-pole devices for switching or protection in line conductors only	✓	

6.0 Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)
Notes: Switchgear designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI+ (to determine whether danger or potential danger exists)

Original (To the person ordering the work)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
6.1	In general		
	presence and condition of appropriate devices	✓	
	correct operation verified	✓	
6.2	For isolation and switching for mechanical maintenance only		
	capable of being secured in the OFF position where appropriate	N/A	
	acceptable location - state if local or remote from equipment being controlled where appropriate	N/A	
	clearly identified by position and/or durable marking(s)	N/A	
6.3	For isolation only		
	warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.0	Current-using equipment (Permanently connected)		
7.1	Condition of equipment in terms of IP rating	✓	
7.2	Equipment does not constitute a fire hazard	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety	✓	
7.4	Suitability for the environment and external influences	✓	
7.5	Security of fixing	✓	
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire List number and location of luminaires inspected. (Separate page)	LIM	
7.7	Recessed luminaires (downlighters)		
	correct type of lamps fitted	N/A	
	installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	N/A	
	no signs of overheating to surrounding building fabric	✓	

Item	Description	Outcome*	Location reference
	no signs of overheating to conductors/terminations	✓	
8.0	Location(s) containing a bath or shower		
8.1	Additional protection by RCD not exceeding 30 mA		
	for low voltage circuits serving the location	C3	
	for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	C3	
8.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	N/A	
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓	
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	
8.7	Suitability of equipment for installation in a particular zone	✓	
9.0	Other special installations or locations - Part 7s		
9.1	List all other special installations or locations present, if any. (Record the results of particular inspection applied separately).	N/A	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2, C3 and FI coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT

Client: Grwp Gwalia Cyf

Address: Ty Gwalia
7-13 The Kingsway
Swansea
West Glamorgan

Postcode: SA1 5JN

B. PURPOSE OF THE REPORT

Purpose for which this report is required: Periodic inspection & Test only.

Date(s) on which inspection and testing were carried out: 17th December 2018

C. DETAILS OF THE INSTALLATION

Occupier: Tenant

Address: Block C Flat 5
Ty Beck House,
Sketty Road,
Uplands,
Swansea, Postcode: SA2 0NH

Estimated age of the electrical installation: 25 years Evidence of alterations or additions If yes, estimated age 5 years

Date of previous inspection: N/A Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: N/A

Records of installation available: No Records held by: N/A

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
Main DB and associated circuits only.

Agreed limitations (including the reasons), if any, on the inspection and testing:
Audio circuits,
Heating control circuits,
Telecommunication circuits,
Attic voids

Agreed with: Client

Operational limitations including the reasons (see page No. N/A)
None.

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
All in working order.

Summary of the condition of the installation continued on additional pages? No Yes Specify page

Overall assessment of the installation: **SATISFACTORY** ~~UNSATISFACTORY~~ * An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

5 Years

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or F1 (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading Title: A & R Electrical Wales Ltd

Address: 15 Alder Road
Cimla
Neath
Glam

Telephone number: 01639 775810

Email Address: office@aandreelectrical.co.uk



Enrolment number: 040640

(Essential information)

Branch number: 001

Postcode: SA11 3NY

K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System Type(s)		Number and Type of Live Conductors		Nature of Supply Parameters		Characteristics of Primary Supply Overcurrent Protective Device(s)	
TN-S	<input type="checkbox"/>	a.c.	<input checked="" type="checkbox"/>	Nominal Voltage(s), $U^{(1)}$	N/A V	$U_0^{(1)}$	230 V
TN-C-S	<input checked="" type="checkbox"/>	1-phase (2 wire)	<input type="checkbox"/>	Nominal frequency, $f^{(1)}$	50 Hz	Number of sources	1
TT	<input type="checkbox"/>	2-phase (3 wire)	<input type="checkbox"/>	Prospective fault current, $I_{pf}^{(2)(3)}$	0.89 kA	Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one source, record the higher or highest value (4) by measurement	
		3-phase (3 wire)	<input type="checkbox"/>	External earth fault loop impedance, $Z_e^{(3)(4)}$	0.27 Ω	BS(EN)	BS 1361 Fuse HBC Domestic Type
		3-phase (4 wire)	<input type="checkbox"/>			Type	2
		Other (please state)				Rated current	100 A
						Short-circuit capacity	16.5 kA
						Confirmation of supply polarity	<input checked="" type="checkbox"/> <input type="checkbox"/>

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of Earthing		Details of Installation Earth Electrode (where applicable)		Earthing and protective bonding conductors		Bonding of extraneous-conductive-parts (✓)	
Distributor's facility:	<input checked="" type="checkbox"/>	Type: (eg rod(s), tape etc)	N/A	Location:	N/A	Water service	<input checked="" type="checkbox"/>
Installation earth electrode:	<input type="checkbox"/>	Electrode resistance, R_A :	N/A (Ω)	Method of measurement:	N/A	Oil service	<input type="checkbox"/>
Main Switch/Switch-Fuse/Circuit-Breaker/RCD				Main protective bonding conductors		Gas Service	
Type: BS(EN)	BS EN 60947-	Voltage rating	230 V	Conductor material	Copper	Structural steel	<input checked="" type="checkbox"/>
No of Poles	2	Rated current, I_n	100 A	Conductor csa	10.0 mm ²	Lightning protection	<input type="checkbox"/>
Primary supply conductors (material)	Copper	RCD operating current, $I_{\Delta n}^*$	N/A mA	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)	Other (Specify)	<input type="checkbox"/>
Primary supply conductors (csa)	16.0 mm ²	Rated time delay*	N/A ms				
		RCD operating time (at $I_{\Delta n}$)*	N/A ms				

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment†		
1.1	Service cable	✓	
1.2	Service head	✓	
1.3	Distributor's earthing arrangement	✓	
1.4	Meter tails - Distributor/Consumer	✓	
1.5	Metering equipment	✓	
1.6	Means of main isolation (where present)	✓	
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
3.0	Earthing and bonding arrangements		
3.1	Presence and condition of distributor's earthing arrangement	✓	
3.2	Presence and condition of earth electrode connection	N/A	
3.3	Confirmation of adequate earthing conductor size	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	
3.6	Accessibility and condition of main protective bonding conductor connections	✓	
3.7	Accessibility and condition of other protective bonding connections	✓	
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	

Item	Description	Outcome*	Location reference
4.0	Consumer unit(s)		
4.1	Adequacy of working space or access to consumer unit	✓	
4.2	Security of fixing	✓	
4.3	Condition of enclosure(s) in terms of IP rating	✓	
4.4	Condition of enclosure(s) in terms of fire rating	C3	
4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	
4.6	Presence of linked main switch	✓	
4.7	Operation of main switch (functional check)	✓	
4.8	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	
4.9	Correct identification of circuits and protective devices	✓	
4.10	Presence of RCD test notice at or near consumer unit	✓	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓	
4.12	Presence of alternative or additional supply warning notice at or near consumer unit	N/A	
4.13	Presence of replacement next inspection recommendation label	✓	
4.14	Presence of other required labelling (please specify)	N/A	
4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
4.16	Single-pole switching or protective devices in the line conductors only	✓	
4.17	Protection against mechanical damage where cables enter consumer unit	✓	
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	N/A	
4.19	RCDs provided for fault protection - includes RCBOs	✓	

* All Outcome boxes must be completed
 indicates Acceptable condition
 indicates a limitation
 indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state FI (to determine whether danger or potential danger exists)
 † Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.

Outcome
 Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
4.20	RCDs provided for additional protection - includes RCBOs	✓	
4.21	Confirmation of indication that SPD is functional	N/A	
4.22	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓	
5.0 Distribution/final circuits			
5.1	Identification of conductors	✓	
5.2	Cables correctly supported throughout their length	LIM	
5.3	Condition of insulation of live parts	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	N/A	
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓	
5.6	Adequacy of protective devices; type and rated current for fault protection	✓	
5.7	Presence and adequacy of circuit protective conductors	✓	
5.8	Co-ordination between conductors and overload protective devices	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓	
5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage		
	installed in prescribed zones (see Section D. Extent and limitations)	N/A	
	incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the	N/A	

Item	Description	Outcome*	Location reference
5.11	Provision of additional protection by RCD not exceeding 30 mA		
	⚡ for all socket-outlets of rating 20 A or less	✓	
	⚡ for mobile equipment not exceeding a rating of 32A for use outdoors	✓	
	⚡ for cables installed in walls or partitions at a depth of less than 50 mm	C3	
	⚡ for cables installed in walls / partitions containing metal parts regardless of depth	C3	
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	LIM	
5.13	Band II cables segregated/separated from Band I cables	LIM	
5.14	Cables segregated/separated from communications cabling	LIM	
5.15	Cables segregated/separated from non-electrical services	LIM	
5.16	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
	• Connections soundly made and under no undue strain	✓	
	• No basic insulation of a conductor visible outside enclosures	✓	
	• Connections of live conductors adequately enclosed	✓	
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓	
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	
5.18	Suitability of accessories for external influences	✓	
5.19	Adequacy of working space / accessibility to equipment	✓	
5.20	Single-pole devices for switching or protection in line conductors only	✓	

6.0 Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)
Notes: Switching devices designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI+ (to determine whether danger or potential danger exists)

Notes: Switching devices designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

Original (To the person ordering the work)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
6.1	In general		
	presence and condition of appropriate devices	✓	
	correct operation verified	✓	
6.2	For isolation and switching for mechanical maintenance only		
	capable of being secured in the OFF position where appropriate	N/A	
	acceptable location - state if local or remote from equipment being controlled where appropriate	N/A	
	clearly identified by position and/or durable marking(s)	N/A	
6.3	For isolation only		
	warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.0	Current-using equipment (Permanently connected)		
7.1	Condition of equipment in terms of IP rating	✓	
7.2	Equipment does not constitute a fire hazard	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety	✓	
7.4	Suitability for the environment and external influences	✓	
7.5	Security of fixing	✓	
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire List number and location of luminaires inspected. (Separate page)	LIM	
7.7	Recessed luminaires (downlighters)		
	correct type of lamps fitted	N/A	
	installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	N/A	
	no signs of overheating to surrounding building fabric	✓	

Item	Description	Outcome*	Location reference
	no signs of overheating to conductors/terminations	✓	
8.0	Location(s) containing a bath or shower		
8.1	Additional protection by RCD not exceeding 30 mA		
	for low voltage circuits serving the location	C3	
	for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	C3	
8.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	N/A	
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓	
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	
8.7	Suitability of equipment for installation in a particular zone	✓	
9.0	Other special installations or locations - Part 7s		
9.1	List all other special installations or locations present, if any. (Record the results of particular inspection applied separately).	N/A	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2, C3 and FI coded items to be recorded in Section F of the report.

CIRCUIT DETAILS													TEST RESULTS															
Circuit number	Circuit designation * To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box	Type of wiring (see code below)	Reference Method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices					RCD	Maximum Z_s permitted by BS 7671	Circuit impedances (Ω)					Insulation resistance					RCD operating times		Test button operation	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, $I_{\Delta n}$ (mA)			Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line (M Ω)	Line/Neutral (M Ω)	Line/Earth (M Ω)	Neutral/Earth (M Ω)	Polarity	Maximum measured earth fault loop impedance, Z_s (Ω)	at $I_{\Delta n}$ (ms)		at $5I_{\Delta n}$ (if applicable) (ms)
															r_1 (Line)	r_n (Neutral)	r_2 (cpc)	$R_1 + R_2$	R_2									
															\checkmark	\checkmark	\checkmark	\checkmark	\checkmark									
1	Cooker	A	C	1	6.0	2.5	0.4	60898 MCB	B	32	6	N/A	1.37	N/A	N/A	N/A	0.19	N/A	N/A	> 200	> 200	> 200	\checkmark	0.46	N/A	N/A		
2	Lights flat	A	C	8	1.0	1.0	0.4	60898 MCB	B	6	6	N/A	7.28	N/A	N/A	N/A	0.93	N/A	N/A	> 200	> 200	> 200	\checkmark	1.20	N/A	N/A		
3	Spare																											
4	Spare																											
5	Sockets house	A	C	0.30	2.5	1.5	0.4	61009 RCD/R	B	32	6	30	1.37	0.60	0.57	0.87	0.30	N/A	N/A	> 200	> 200	> 200	\checkmark	0.57	48.5	5.7	\checkmark	

Location of consumer unit **By front door.**

Designation of consumer unit **Main DB**

Prospective fault current at consumer unit **0.89** kA

TEST INSTRUMENTS

Test instruments (serial numbers) used

Multi-functional **1589042**

Insulation resistance **N/A**

Continuity **N/A**

Earth electrode resistance **N/A**

Earth fault loop impedance **N/A**

RCD **N/A**

CODES FOR TYPE OF WIRING											
A	Thermoplastic insulated cables in sheath	B	Thermoplastic cables in non-metallic conduit	C	Thermoplastic cables in non-metallic conduit	D	Thermoplastic cables in non-metallic trunking	E	Thermoplastic cables in non-metallic trunking	F	Thermoplastic SWA cables
G	Thermosetting SWA cables	H	Mineral-insulated cables	I	Other - please state						

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT

Client: Grwp Gwalia Cyf

Address: Ty Gwalia
 7-13 The Kingsway
 Swansea
 West Glamorgan

Postcode: SA1 5JN

B. PURPOSE OF THE REPORT

Purpose for which this report is required: Periodic inspection & Test only.

Date(s) on which inspection and testing were carried out: 17th December 2018

C. DETAILS OF THE INSTALLATION

Occupier: Tenant

Address: Block C Flat 6
 Ty Beck House,
 Sketty Road,
 Uplands,
 Swansea, Postcode: SA2 0NH

Estimated age of the electrical installation: 25 years Evidence of alterations or additions If yes, estimated age 5 years

Date of previous inspection: N/A Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: N/A

Records of installation available: No Records held by: N/A

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
 Main DB and associated circuits only.

Agreed limitations (including the reasons), if any, on the inspection and testing:
 Audio circuits,
 Heating control circuits,
 Telecommunication circuits,
 Attic voids

Agreed with: Client

Operational limitations including the reasons (see page No. N/A)
 None.

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
 All in working order.

Summary of the condition of the installation continued on additional pages? No Yes Specify page

Overall assessment of the installation: **SATISFACTORY** ~~UNSATISFACTORY~~ * An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

5 Years

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or F1 (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading Title: A & R Electrical Wales Ltd

Address: 15 Alder Road
Cimla
Neath
Glam

Telephone number: 01639 775810

Email Address: office@aandreelectrical.co.uk



Enrolment number: 040640

(Essential information)

Branch number: 001

Postcode: SA11 3NY

K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System Type(s)		Number and Type of Live Conductors		Nature of Supply Parameters		Characteristics of Primary Supply Overcurrent Protective Device(s)	
TN-S	<input type="checkbox"/>	a.c.	<input checked="" type="checkbox"/>	Nominal Voltage(s), $U^{(1)}$	N/A V	$U_0^{(1)}$	230 V
TN-C-S	<input checked="" type="checkbox"/>	1-phase (2 wire)	<input type="checkbox"/>	Nominal frequency, $f^{(1)}$	50 Hz	Number of sources	1
TT	<input type="checkbox"/>	2-phase (3 wire)	<input type="checkbox"/>	Prospective fault current, $I_{pf}^{(2)(3)}$	0.95 kA	Notes:	(1) by enquiry (2) by enquiry or by measurement (3) where more than one source, record the higher or highest value (4) by measurement
		3-phase (3 wire)	<input type="checkbox"/>	External earth fault loop impedance, $Z_e^{(3)(4)}$	0.28 Ω	BS(EN)	BS 1361 Fuse HBC Domestic Type
		3-phase (4 wire)	<input type="checkbox"/>			Type	2
						Rated current	100 A
						Short-circuit capacity	16.5 kA
						Confirmation of supply polarity	<input checked="" type="checkbox"/> <input type="checkbox"/>

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of Earthing		Details of Installation Earth Electrode (where applicable)		Earthing and protective bonding conductors		Bonding of extraneous-conductive-parts (✓)	
Distributor's facility:	<input checked="" type="checkbox"/>	Type: (eg rod(s), tape etc)	N/A	Location:	N/A	Water service	<input checked="" type="checkbox"/>
Installation earth electrode:	<input type="checkbox"/>	Electrode resistance, R_A :	N/A (Ω)	Method of measurement:	N/A	Oil service	<input type="checkbox"/>
						Gas Service	<input checked="" type="checkbox"/>
						Structural steel	<input type="checkbox"/>
						Lightning protection	<input type="checkbox"/>
						Other (Specify)	<input type="checkbox"/>

Main Switch/Switch-Fuse/Circuit-Breaker/RCD				Earthing conductor		Main protective bonding conductors	
Type: BS(EN)	BS EN 60947-	Voltage rating	230 V	Conductor material	Copper	Conductor material	Copper
No of Poles	2	Rated current, I_n	100 A	Conductor csa	10.0 mm ²	Conductor csa	10.0 mm ²
Primary supply conductors (material)	Copper	RCD operating current, $I_{\Delta n}^*$	N/A mA	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)
Primary supply conductors (csa)	16.0 mm ²	Rated time delay*	N/A ms				
		RCD operating time (at $I_{\Delta n}$)*	N/A ms				

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment†		
1.1	Service cable	✓	
1.2	Service head	✓	
1.3	Distributor's earthing arrangement	✓	
1.4	Meter tails - Distributor/Consumer	✓	
1.5	Metering equipment	✓	
1.6	Means of main isolation (where present)	✓	
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
3.0	Earthing and bonding arrangements		
3.1	Presence and condition of distributor's earthing arrangement	✓	
3.2	Presence and condition of earth electrode connection	N/A	
3.3	Confirmation of adequate earthing conductor size	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	
3.6	Accessibility and condition of main protective bonding conductor connections	✓	
3.7	Accessibility and condition of other protective bonding connections	✓	
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	

Item	Description	Outcome*	Location reference
4.0	Consumer unit(s)		
4.1	Adequacy of working space or access to consumer unit	✓	
4.2	Security of fixing	✓	
4.3	Condition of enclosure(s) in terms of IP rating	✓	
4.4	Condition of enclosure(s) in terms of fire rating	C3	
4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	
4.6	Presence of linked main switch	✓	
4.7	Operation of main switch (functional check)	✓	
4.8	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	
4.9	Correct identification of circuits and protective devices	✓	
4.10	Presence of RCD test notice at or near consumer unit	✓	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓	
4.12	Presence of alternative or additional supply warning notice at or near consumer unit	N/A	
4.13	Presence of replacement next inspection recommendation label	✓	
4.14	Presence of other required labelling (please specify)	N/A	
4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
4.16	Single-pole switching or protective devices in the line conductors only	✓	
4.17	Protection against mechanical damage where cables enter consumer unit	✓	
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	N/A	
4.19	RCDs provided for fault protection - includes RCBOs	✓	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 N/A indicates Not applicable
 ✗ indicates a limitation
 LIM: Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.
 This report is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

Further investigation required without delay state FI (to determine whether danger or potential danger exists)
 Outcome Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

Original (To the person ordering the work)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
4.20	RCDs provided for additional protection - includes RCBOs	✓	
4.21	Confirmation of indication that SPD is functional	N/A	
4.22	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓	
5.0 Distribution/final circuits			
5.1	Identification of conductors	✓	
5.2	Cables correctly supported throughout their length	LIM	
5.3	Condition of insulation of live parts	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	N/A	
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓	
5.6	Adequacy of protective devices; type and rated current for fault protection	✓	
5.7	Presence and adequacy of circuit protective conductors	✓	
5.8	Co-ordination between conductors and overload protective devices	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓	
5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage		
	installed in prescribed zones (see Section D. Extent and limitations)	N/A	
	incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the	N/A	

Item	Description	Outcome*	Location reference
5.11	Provision of additional protection by RCD not exceeding 30 mA		
	⚡ for all socket-outlets of rating 20 A or less	✓	
	⚡ for mobile equipment not exceeding a rating of 32A for use outdoors	✓	
	⚡ for cables installed in walls or partitions at a depth of less than 50 mm	C3	
	⚡ for cables installed in walls / partitions containing metal parts regardless of depth	C3	
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	LIM	
5.13	Band II cables segregated/separated from Band I cables	LIM	
5.14	Cables segregated/separated from communications cabling	LIM	
5.15	Cables segregated/separated from non-electrical services	LIM	
5.16	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
	• Connections soundly made and under no undue strain	✓	
	• No basic insulation of a conductor visible outside enclosures	✓	
	• Connections of live conductors adequately enclosed	✓	
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓	
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	
5.18	Suitability of accessories for external influences	✓	
5.19	Adequacy of working space / accessibility to equipment	✓	
5.20	Single-pole devices for switching or protection in line conductors only	✓	

6.0 Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)

Notes: Switchgear designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI (to determine whether danger or potential danger exists)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
6.1	In general		
	presence and condition of appropriate devices	✓	
	correct operation verified	✓	
6.2	For isolation and switching for mechanical maintenance only		
	capable of being secured in the OFF position where appropriate	N/A	
	acceptable location - state if local or remote from equipment being controlled where appropriate	N/A	
	clearly identified by position and/or durable marking(s)	N/A	
6.3	For isolation only		
	warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.0	Current-using equipment (Permanently connected)		
7.1	Condition of equipment in terms of IP rating	✓	
7.2	Equipment does not constitute a fire hazard	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety	✓	
7.4	Suitability for the environment and external influences	✓	
7.5	Security of fixing	✓	
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire List number and location of luminaires inspected. (Separate page)	LIM	
7.7	Recessed luminaires (downlighters)		
	correct type of lamps fitted	N/A	
	installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	N/A	
	no signs of overheating to surrounding building fabric	✓	

Item	Description	Outcome*	Location reference
	no signs of overheating to conductors/terminations	✓	
8.0	Location(s) containing a bath or shower		
8.1	Additional protection by RCD not exceeding 30 mA		
	for low voltage circuits serving the location	C3	
	for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	C3	
8.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	N/A	
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓	
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	
8.7	Suitability of equipment for installation in a particular zone	✓	
9.0	Other special installations or locations - Part 7s		
9.1	List all other special installations or locations present, if any. (Record the results of particular inspection applied separately).	N/A	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2, C3 and FI coded items to be recorded in Section F of the report.

SCHEDULES

Original (To the person ordering the work)

CIRCUIT DETAILS													TEST RESULTS																	
Circuit number	Circuit designation * To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box	Type of wiring (see code below)	Reference Method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices					RCD	Maximum Z_s permitted by BS 7671	Circuit impedances (Ω)					Insulation resistance					Maximum measured earth fault loop impedance, Z_s	RCD operating times		Test button operation		
					Live (mm ²)	cpc (mm ²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, $I_{\Delta n}$ (mA)			Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line (M Ω)	Line/Neutral (M Ω)	Line/Earth (M Ω)	Neutral/Earth (M Ω)	Polarity					at $I_{\Delta n}$ (ms)	at $5I_{\Delta n}$ (ms) (if applicable)
															r_1 (Line)	r_n (Neutral)	r_2 (cpc)	$R_1 + R_2$	R_2											
1	Cooker	A	C	1	6.0	2.5	0.4	60898 MCB	B	32	6	N/A	1.37	N/A	N/A	N/A	0.20	N/A	N/A	> 200	> 200	> 200	✓	0.48	N/A	N/A				
2	Lights flat	A	C	9	1.0	1.0	0.4	60898 MCB	B	6	6	N/A	7.28	N/A	N/A	N/A	1.13	N/A	N/A	> 200	> 200	> 200	✓	1.41	N/A	N/A				
3	Shower	A	B	1	6.0	2.5	0.4	60898 MCB	B	32	6	N/A	1.37	N/A	N/A	N/A	0.12	N/A	N/A	> 200	> 200	> 200	✓	0.40	N/A	N/A				
4	Spare																													
5	Sockets house	A	C	29	2.5	1.5	0.4	61009 RCD/R	B	32	6	30	1.37	0.50	0.49	0.74	0.37	N/A	N/A	> 200	> 200	> 200	✓	0.65	17.8	15.3	✓			

Location of consumer unit **By front door.**

Designation of consumer unit **Main DB**

Prospective fault current at consumer unit **0.95** kA

TEST INSTRUMENTS

Test instruments (serial numbers) used

Multi-functional **1589042**

Insulation resistance **N/A**

Continuity **N/A**

Earth electrode resistance **N/A**

Earth fault loop impedance **N/A**

RCD **N/A**

CODES FOR TYPE OF WIRING			
A	Thermoplastic insulated cables in sheathed cable/metallic conduit		
B	Thermoplastic cables in non-metallic conduit		
C	Thermoplastic cables in non-metallic conduit		
D	Thermoplastic cables in non-metallic conduit		
E	Thermoplastic cables in non-metallic conduit		
F	Thermoplastic cables in non-metallic conduit		
G	Thermoplastic cables in non-metallic conduit		
H	Mineral-insulated cables		
I	Other (please state)		

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT

Client: Grwp Gwalia Cyf

Address: Ty Gwalia
7-13 The Kingsway
Swansea
West Glamorgan

Postcode: SA1 5JN

B. PURPOSE OF THE REPORT

Purpose for which this report is required: Periodic inspection & Test only.

Date(s) on which inspection and testing were carried out: 17th December 2018

C. DETAILS OF THE INSTALLATION

Occupier: Tenant

Address: Block C Flat 7
Ty Beck House,
Sketty Road,
Uplands,
Swansea, Postcode: SA2 0NH

Estimated age of the electrical installation: 25 years Evidence of alterations or additions If yes, estimated age 5 years

Date of previous inspection: N/A Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: N/A

Records of installation available: No Records held by: N/A

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
Main DB and associated circuits only.

Agreed limitations (including the reasons), if any, on the inspection and testing:
Audio circuits,
Heating control circuits,
Telecommunication circuits,
Attic voids

Agreed with: Client

Operational limitations including the reasons (see page No. N/A)
None.

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
All in working order.

Summary of the condition of the installation continued on additional pages? No Yes Specify page

Overall assessment of the installation: **SATISFACTORY** ~~UNSATISFACTORY~~ * An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

5 Years

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or F1 (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading Title: **A & R Electrical Wales Ltd**

Address: **15 Alder Road
Cimla
Neath
Glam**

Telephone number: **01639 775810**

Email Address: **office@aandreelectrical.co.uk**

Enrolment number: **040640**

(Essential information)

Branch number: **001**

(if applicable)



Postcode: **SA11 3NY**

K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System Type(s)		Number and Type of Live Conductors		Nature of Supply Parameters		Characteristics of Primary Supply Overcurrent Protective Device(s)		
TN-S	<input type="checkbox"/>	a.c.	<input checked="" type="checkbox"/>	Nominal Voltage(s), $U^{(1)}$	N/A V	$U_0^{(1)}$	230 V	
TN-C-S	<input checked="" type="checkbox"/>	1-phase (2 wire)	<input type="checkbox"/>	Nominal frequency, $f^{(1)}$	50 Hz	Number of sources	1	
TT	<input type="checkbox"/>	2-phase (3 wire)	<input type="checkbox"/>	Prospective fault current, $I_{pf}^{(2)(3)}$	0.82 kA	External earth fault loop impedance, $Z_e^{(3)(4)}$	0.29 Ω	
		3-phase (3 wire)	<input type="checkbox"/>	Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one source, record the higher or highest value (4) by measurement				
		3-phase (4 wire)	<input type="checkbox"/>	Confirmation of supply polarity				<input checked="" type="checkbox"/> <input type="checkbox"/>

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of Earthing		Details of Installation Earth Electrode (where applicable)		Earthing and protective bonding conductors		Bonding of extraneous-conductive-parts (✓)	
Distributor's facility:	<input checked="" type="checkbox"/>	Type: (eg rod(s), tape etc)	N/A	Location:	N/A	Water service	<input checked="" type="checkbox"/>
Installation earth electrode:	<input type="checkbox"/>	Electrode resistance, R_A :	N/A (Ω)	Method of measurement:	N/A	Oil service	<input type="checkbox"/>
Main Switch/Switch-Fuse/Circuit-Breaker/RCD				Main protective bonding conductors		Gas Service	
Type: BS(EN)	BS EN 60947-	Voltage rating	230 V	Conductor material	Copper	Structural steel	<input checked="" type="checkbox"/>
No of Poles	2	Rated current, I_n	100 A	Conductor csa	10.0 mm ²	Lightning protection	<input type="checkbox"/>
Primary supply conductors (material)	Copper	RCD operating current, $I_{\Delta n}^*$	N/A mA	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)	Other (Specify)	<input type="checkbox"/>
Primary supply conductors (csa)	16.0 mm ²	Rated time delay*	N/A ms				
		RCD operating time (at $I_{\Delta n}$)*	N/A ms				

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment†		
1.1	Service cable	✓	
1.2	Service head	✓	
1.3	Distributor's earthing arrangement	✓	
1.4	Meter tails - Distributor/Consumer	✓	
1.5	Metering equipment	✓	
1.6	Means of main isolation (where present)	✓	
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
3.0	Earthing and bonding arrangements		
3.1	Presence and condition of distributor's earthing arrangement	✓	
3.2	Presence and condition of earth electrode connection	N/A	
3.3	Confirmation of adequate earthing conductor size	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	
3.6	Accessibility and condition of main protective bonding conductor connections	✓	
3.7	Accessibility and condition of other protective bonding connections	✓	
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	

Item	Description	Outcome*	Location reference
4.0	Consumer unit(s)		
4.1	Adequacy of working space or access to consumer unit	✓	
4.2	Security of fixing	✓	
4.3	Condition of enclosure(s) in terms of IP rating	✓	
4.4	Condition of enclosure(s) in terms of fire rating	C3	
4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	
4.6	Presence of linked main switch	✓	
4.7	Operation of main switch (functional check)	✓	
4.8	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	
4.9	Correct identification of circuits and protective devices	✓	
4.10	Presence of RCD test notice at or near consumer unit	✓	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓	
4.12	Presence of alternative or additional supply warning notice at or near consumer unit	N/A	
4.13	Presence of replacement next inspection recommendation label	✓	
4.14	Presence of other required labelling (please specify)	N/A	
4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
4.16	Single-pole switching or protective devices in the line conductors only	✓	
4.17	Protection against mechanical damage where cables enter consumer unit	✓	
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	N/A	
4.19	RCDs provided for fault protection - includes RCBOs	✓	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 ✗ indicates a limitation
 N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state FI (to determine whether danger or potential danger exists)
 † Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.
 This report is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

Outcome
 Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
4.20	RCDs provided for additional protection - includes RCBOs	✓	
4.21	Confirmation of indication that SPD is functional	N/A	
4.22	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓	
5.0 Distribution/final circuits			
5.1	Identification of conductors	✓	
5.2	Cables correctly supported throughout their length	LIM	
5.3	Condition of insulation of live parts	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	N/A	
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓	
5.6	Adequacy of protective devices; type and rated current for fault protection	✓	
5.7	Presence and adequacy of circuit protective conductors	✓	
5.8	Co-ordination between conductors and overload protective devices	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓	
5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage		
	installed in prescribed zones (see Section D. Extent and limitations)	N/A	
	incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the	N/A	

Item	Description	Outcome*	Location reference
5.11	Provision of additional protection by RCD not exceeding 30 mA		
	⚡ for all socket-outlets of rating 20 A or less	✓	
	⚡ for mobile equipment not exceeding a rating of 32A for use outdoors	✓	
	⚡ for cables installed in walls or partitions at a depth of less than 50 mm	C3	
	⚡ for cables installed in walls / partitions containing metal parts regardless of depth	C3	
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	LIM	
5.13	Band II cables segregated/separated from Band I cables	LIM	
5.14	Cables segregated/separated from communications cabling	LIM	
5.15	Cables segregated/separated from non-electrical services	LIM	
5.16	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
	• Connections soundly made and under no undue strain	✓	
	• No basic insulation of a conductor visible outside enclosures	✓	
	• Connections of live conductors adequately enclosed	✓	
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓	
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	
5.18	Suitability of accessories for external influences	✓	
5.19	Adequacy of working space / accessibility to equipment	✓	
5.20	Single-pole devices for switching or protection in line conductors only	✓	

6.0 Isolation and switching (isolation, switching off for mechanical maintenance and functional

Notes: Switchgear designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI (to determine whether danger or potential danger exists)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
6.1	In general		
	presence and condition of appropriate devices	✓	
	correct operation verified	✓	
6.2	For isolation and switching for mechanical maintenance only		
	capable of being secured in the OFF position where appropriate	N/A	
	acceptable location - state if local or remote from equipment being controlled where appropriate	N/A	
	clearly identified by position and/or durable marking(s)	N/A	
6.3	For isolation only		
	warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.0	Current-using equipment (Permanently connected)		
7.1	Condition of equipment in terms of IP rating	✓	
7.2	Equipment does not constitute a fire hazard	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety	✓	
7.4	Suitability for the environment and external influences	✓	
7.5	Security of fixing	✓	
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire List number and location of luminaires inspected. (Separate page)	LIM	
7.7	Recessed luminaires (downlighters)		
	correct type of lamps fitted	N/A	
	installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	N/A	
	no signs of overheating to surrounding building fabric	✓	

Item	Description	Outcome*	Location reference
	no signs of overheating to conductors/terminations	✓	
8.0	Location(s) containing a bath or shower		
8.1	Additional protection by RCD not exceeding 30 mA		
	for low voltage circuits serving the location	C3	
	for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	C3	
8.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	N/A	
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓	
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	
8.7	Suitability of equipment for installation in a particular zone	✓	
9.0	Other special installations or locations - Part 7s		
9.1	List all other special installations or locations present, if any. (Record the results of particular inspection applied separately).	N/A	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2, C3 and FI coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT

Client: Grwp Gwalia Cyf

Address: Ty Gwalia
7-13 The Kingsway
Swansea
West Glamorgan

Postcode: SA1 5JN

B. PURPOSE OF THE REPORT

Purpose for which this report is required: Periodic inspection & Test only.

Date(s) on which inspection and testing were carried out: 17th December 2018

C. DETAILS OF THE INSTALLATION

Occupier: Tenant

Address: Block C Flat 8
Ty Beck House,
Sketty Road,
Uplands,
Swansea, Postcode: SA2 0NH

Estimated age of the electrical installation: 25 years Evidence of alterations or additions If yes, estimated age 5 years

Date of previous inspection: N/A Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: N/A

Records of installation available: No Records held by: N/A

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
Main DB and associated circuits only.

Agreed limitations (including the reasons), if any, on the inspection and testing:
Audio circuits,
Heating control circuits,
Telecommunication circuits,
Attic voids

Agreed with: Client

Operational limitations including the reasons (see page No. N/A)
None.

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
All in working order.

Summary of the condition of the installation continued on additional pages? No Yes Specify page

Overall assessment of the installation: **SATISFACTORY** ~~UNSATISFACTORY~~

* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

5 Years

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or F1 (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading Title: A & R Electrical Wales Ltd		Telephone number: 01639 775810
Address: 15 Alder Road Cimla Neath Glam		Email Address: office@aandrelectrical.co.uk
Postcode: SA11 3NY		Enrolment number: 040640 <small>(Essential information)</small>
		Branch number: 001 <small>(if applicable)</small>

K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System Type(s)	Number and Type of Live Conductors	Nature of Supply Parameters	Characteristics of Primary Supply Overcurrent Protective Device(s)
TN-S <input type="checkbox"/>	a.c. <input checked="" type="checkbox"/> Other (please state) <div style="border: 1px solid black; height: 40px; width: 100%;"></div>	Nominal Voltage(s), U ⁽¹⁾ N/A V U ₀ ⁽¹⁾ 230 V	BS(EN) BS 1361 Fuse HBC Domestic Type
TN-C-S <input checked="" type="checkbox"/>	1-phase (2 wire) <input type="checkbox"/> 1-phase (3 wire) <input checked="" type="checkbox"/>	Nominal frequency, f ⁽¹⁾ 50 Hz Number of sources 1	Type 2
TT <input type="checkbox"/>	2-phase (3 wire) <input type="checkbox"/> 3-phase (4 wire) <input type="checkbox"/>	Prospective fault current, I _{pr} ⁽²⁾⁽³⁾ 0.89 kA	Rated current 100 A
		External earth fault loop impedance, Z _e ⁽³⁾⁽⁴⁾ 0.27 Ω	Short-circuit capacity 16.5 kA
		<small>Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one source, record the higher or highest value (4) by measurement</small>	Confirmation of supply polarity <input checked="" type="checkbox"/> <input type="checkbox"/>

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of Earthing Distributor's facility: <input checked="" type="checkbox"/> Installation earth electrode: <input type="checkbox"/>		Details of Installation Earth Electrode (where applicable) Type: N/A Location: N/A (eg rod(s), tape etc) Electrode resistance, R _A : N/A (Ω) Method of measurement: N/A	
Main Switch/Switch-Fuse/Circuit-Breaker/RCD Type: BS EN 60947- Voltage rating 230 V BS(EN) No of Poles 2 Rated current, I _n 100 A Primary supply conductors (material) Copper RCD operating current, I _{Δn} * N/A mA Primary supply conductors (csa) 16.0 mm² Rated time delay* N/A ms RCD operating time (at I _{Δn})* N/A ms		Earthing and protective bonding conductors Earthing conductor Conductor material Copper Conductor csa 10.0 mm ² Connection/continuity verified <input checked="" type="checkbox"/> <input type="checkbox"/>	
		Main protective bonding conductors Conductor material Copper Conductor csa 10.0 mm ² Connection/continuity verified <input checked="" type="checkbox"/> <input type="checkbox"/>	
		Bonding of extraneous-conductive-parts (✓) Water service <input checked="" type="checkbox"/> Gas Service <input checked="" type="checkbox"/> Oil service <input type="checkbox"/> Structural steel <input type="checkbox"/> Lightning protection <input type="checkbox"/> Other (Specify) <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

This report is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands © Copyright Certsure LLP / January 2015

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment†		
1.1	Service cable	✓	
1.2	Service head	✓	
1.3	Distributor's earthing arrangement	✓	
1.4	Meter tails - Distributor/Consumer	✓	
1.5	Metering equipment	✓	
1.6	Means of main isolation (where present)	✓	
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
3.0	Earthing and bonding arrangements		
3.1	Presence and condition of distributor's earthing arrangement	✓	
3.2	Presence and condition of earth electrode connection	N/A	
3.3	Confirmation of adequate earthing conductor size	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	
3.6	Accessibility and condition of main protective bonding conductor connections	✓	
3.7	Accessibility and condition of other protective bonding connections	✓	
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	

Item	Description	Outcome*	Location reference
4.0	Consumer unit(s)		
4.1	Adequacy of working space or access to consumer unit	✓	
4.2	Security of fixing	✓	
4.3	Condition of enclosure(s) in terms of IP rating	✓	
4.4	Condition of enclosure(s) in terms of fire rating	C3	
4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	
4.6	Presence of linked main switch	✓	
4.7	Operation of main switch (functional check)	✓	
4.8	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	
4.9	Correct identification of circuits and protective devices	✓	
4.10	Presence of RCD test notice at or near consumer unit	✓	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓	
4.12	Presence of alternative or additional supply warning notice at or near consumer unit	N/A	
4.13	Presence of replacement next inspection recommendation label	✓	
4.14	Presence of other required labelling (please specify)	N/A	
4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
4.16	Single-pole switching or protective devices in the line conductors only	✓	
4.17	Protection against mechanical damage where cables enter consumer unit	✓	
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	N/A	
4.19	RCDs provided for fault protection - includes RCBOs	✓	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 ✗ indicates a limitation
 N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state FI (to determine whether danger or potential danger exists)
 Outcome Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
4.20	RCDs provided for additional protection - includes RCBOs	✓	
4.21	Confirmation of indication that SPD is functional	N/A	
4.22	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓	
5.0 Distribution/final circuits			
5.1	Identification of conductors	✓	
5.2	Cables correctly supported throughout their length	LIM	
5.3	Condition of insulation of live parts	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	N/A	
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓	
5.6	Adequacy of protective devices; type and rated current for fault protection	✓	
5.7	Presence and adequacy of circuit protective conductors	✓	
5.8	Co-ordination between conductors and overload protective devices	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓	
5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage		
	installed in prescribed zones (see Section D. Extent and limitations)	N/A	
	incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the	N/A	

Item	Description	Outcome*	Location reference
5.11	Provision of additional protection by RCD not exceeding 30 mA		
	⚡ for all socket-outlets of rating 20 A or less	✓	
	⚡ for mobile equipment not exceeding a rating of 32A for use outdoors	✓	
	⚡ for cables installed in walls or partitions at a depth of less than 50 mm	C3	
	⚡ for cables installed in walls / partitions containing metal parts regardless of depth	C3	
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	LIM	
5.13	Band II cables segregated/separated from Band I cables	LIM	
5.14	Cables segregated/separated from communications cabling	LIM	
5.15	Cables segregated/separated from non-electrical services	LIM	
5.16	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
	• Connections soundly made and under no undue strain	✓	
	• No basic insulation of a conductor visible outside enclosures	✓	
	• Connections of live conductors adequately enclosed	✓	
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓	
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	
5.18	Suitability of accessories for external influences	✓	
5.19	Adequacy of working space / accessibility to equipment	✓	
5.20	Single-pole devices for switching or protection in line conductors only	✓	

6.0 Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)
Notes: Switching devices designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI+ (to determine whether danger or potential danger exists)

Original (To the person ordering the work)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
6.1	In general		
	presence and condition of appropriate devices	✓	
	correct operation verified	✓	
6.2	For isolation and switching for mechanical maintenance only		
	capable of being secured in the OFF position where appropriate	N/A	
	acceptable location - state if local or remote from equipment being controlled where appropriate	N/A	
	clearly identified by position and/or durable marking(s)	N/A	
6.3	For isolation only		
	warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.0	Current-using equipment (Permanently connected)		
7.1	Condition of equipment in terms of IP rating	✓	
7.2	Equipment does not constitute a fire hazard	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety	✓	
7.4	Suitability for the environment and external influences	✓	
7.5	Security of fixing	✓	
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire List number and location of luminaires inspected. (Separate page)	LIM	
7.7	Recessed luminaires (downlighters)		
	correct type of lamps fitted	N/A	
	installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	N/A	
	no signs of overheating to surrounding building fabric	✓	

Item	Description	Outcome*	Location reference
	no signs of overheating to conductors/terminations	✓	
8.0	Location(s) containing a bath or shower		
8.1	Additional protection by RCD not exceeding 30 mA		
	for low voltage circuits serving the location	C3	
	for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	C3	
8.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	N/A	
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓	
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	
8.7	Suitability of equipment for installation in a particular zone	✓	
9.0	Other special installations or locations - Part 7s		
9.1	List all other special installations or locations present, if any. (Record the results of particular inspection applied separately).	N/A	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2, C3 and FI coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT	
Client:	Grwp Gwalia Cyf
Address:	Ty Gwalia 7-13 The Kingsway Swansea West Glamorgan
	Postcode: SA1 5JN

B. PURPOSE OF THE REPORT	
Purpose for which this report is required:	Periodic inspection & Test only.
Date(s) on which inspection and testing were carried out:	17th December 2018

C. DETAILS OF THE INSTALLATION	
Occupier	Tenant
Address	Block C Flat 9 Ty Beck House, Sketty Road, Uplands, Swansea,
	Postcode: SA2 0NH
Estimated age of the electrical installation:	25 years
Evidence of alterations or additions	<input checked="" type="checkbox"/>
If yes, estimated age	5 years
Date of previous inspection:	N/A
Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No:	N/A
Records of installation available:	No
Records held by:	N/A

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING	
Extent of the electrical installation covered by this report:	
Main DB and associated circuits only.	
Agreed limitations (including the reasons), if any, on the inspection and testing:	
Audio circuits, Heating control circuits, Telecommunication circuits, Attic voids	
Agreed with: Client	
Operational limitations including the reasons (see page No. N/A)	
None.	
The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.	

E. SUMMARY OF THE CONDITION OF THE INSTALLATION	
General condition of the installation (in terms of electrical safety):	
All in working order.	
Summary of the condition of the installation continued on additional pages? No <input checked="" type="checkbox"/> Yes <input type="checkbox"/> Specify page <input type="text"/>	
Overall assessment of the installation:	SATISFACTORY UNSATISFACTORY
* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required	

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

5 Years

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or F1 (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading Title: **A & R Electrical Wales Ltd**

Address: **15 Alder Road
Cimla
Neath
Glam**

Postcode: **SA11 3NY**

Telephone number: **01639 775810**

Email Address: **office@aandreelectrical.co.uk**

Enrolment number: **040640**

(Essential information)

Branch number: **001**



K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System Type(s)	Number and Type of Live Conductors	Nature of Supply Parameters	Characteristics of Primary Supply Overcurrent Protective Device(s)
TN-S <input type="checkbox"/>	a.c. <input checked="" type="checkbox"/> Other (please state)	Nominal Voltage(s), $U^{(1)}$ N/A V $U_0^{(1)}$ 230 V	BS(EN) BS 1361 Fuse HBC Domestic Type
TN-C-S <input checked="" type="checkbox"/>	1-phase (2 wire) <input type="checkbox"/> 1-phase (3 wire) <input checked="" type="checkbox"/>	Nominal frequency, $f^{(1)}$ 50 Hz Number of sources 1	Type 2
TT <input type="checkbox"/>	2-phase (3 wire) <input type="checkbox"/> 3-phase (4 wire) <input type="checkbox"/>	Prospective fault current, $I_{pf}^{(2)(3)}$ 0.86 kA	Rated current 100 A
		External earth fault loop impedance, $Z_e^{(3)(4)}$ 0.28 Ω	Short-circuit capacity 16.5 kA
		<small>Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one source, record the higher or highest value (4) by measurement</small>	Confirmation of supply polarity <input checked="" type="checkbox"/> <input type="checkbox"/>

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of Earthing	Details of Installation Earth Electrode (where applicable)
Distributor's facility: <input checked="" type="checkbox"/>	Type: N/A Location: N/A
Installation earth electrode: <input type="checkbox"/>	Electrode resistance, R_A : N/A (Ω) Method of measurement: N/A

Main Switch/Switch-Fuse/Circuit-Breaker/RCD	Earthing and protective bonding conductors	Bonding of extraneous-conductive-parts (✓)
Type: BS(EN) BS EN 60947- Voltage rating 230 V	Earthing conductor Conductor material Copper	Water service <input checked="" type="checkbox"/> Gas Service <input checked="" type="checkbox"/>
No of Poles 2 Rated current, I_n 100 A	Conductor csa 10.0 mm ²	Oil service <input type="checkbox"/> Structural steel <input type="checkbox"/>
Primary supply conductors (material) Copper RCD operating current, $I_{\Delta n}$ N/A mA	Connection/continuity verified <input checked="" type="checkbox"/> (✓)	Lightning protection <input type="checkbox"/>
Primary supply conductors (csa) 16.0 mm ² Rated time delay* N/A ms		Other (Specify) <input type="text"/>
RCD operating time (at $I_{\Delta n}$)* N/A ms		

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment†		
1.1	Service cable	✓	
1.2	Service head	✓	
1.3	Distributor's earthing arrangement	✓	
1.4	Meter tails - Distributor/Consumer	✓	
1.5	Metering equipment	✓	
1.6	Means of main isolation (where present)	✓	
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
3.0	Earthing and bonding arrangements		
3.1	Presence and condition of distributor's earthing arrangement	✓	
3.2	Presence and condition of earth electrode connection	N/A	
3.3	Confirmation of adequate earthing conductor size	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	
3.6	Accessibility and condition of main protective bonding conductor connections	✓	
3.7	Accessibility and condition of other protective bonding connections	✓	
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	

Item	Description	Outcome*	Location reference
4.0	Consumer unit(s)		
4.1	Adequacy of working space or access to consumer unit	✓	
4.2	Security of fixing	✓	
4.3	Condition of enclosure(s) in terms of IP rating	✓	
4.4	Condition of enclosure(s) in terms of fire rating	C3	
4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	
4.6	Presence of linked main switch	✓	
4.7	Operation of main switch (functional check)	✓	
4.8	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	
4.9	Correct identification of circuits and protective devices	✓	
4.10	Presence of RCD test notice at or near consumer unit	✓	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓	
4.12	Presence of alternative or additional supply warning notice at or near consumer unit	N/A	
4.13	Presence of replacement next inspection recommendation label	✓	
4.14	Presence of other required labelling (please specify)	N/A	
4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
4.16	Single-pole switching or protective devices in the line conductors only	✓	
4.17	Protection against mechanical damage where cables enter consumer unit	✓	
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	N/A	
4.19	RCDs provided for fault protection - includes RCBOs	✓	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 ✗ indicates a limitation
 N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state FI (to determine whether danger or potential danger exists)
 Outcome Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.
 † Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.
 This report is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

Original (To the person ordering the work)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
4.20	RCDs provided for additional protection - includes RCBOs	✓	
4.21	Confirmation of indication that SPD is functional	N/A	
4.22	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓	
5.0 Distribution/final circuits			
5.1	Identification of conductors	✓	
5.2	Cables correctly supported throughout their length	LIM	
5.3	Condition of insulation of live parts	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	N/A	
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓	
5.6	Adequacy of protective devices; type and rated current for fault protection	✓	
5.7	Presence and adequacy of circuit protective conductors	✓	
5.8	Co-ordination between conductors and overload protective devices	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓	
5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage		
	installed in prescribed zones (see Section D. Extent and limitations)	N/A	
	incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the	N/A	

Item	Description	Outcome*	Location reference
5.11	Provision of additional protection by RCD not exceeding 30 mA		
	⚡ for all socket-outlets of rating 20 A or less	✓	
	⚡ for mobile equipment not exceeding a rating of 32A for use outdoors	✓	
	⚡ for cables installed in walls or partitions at a depth of less than 50 mm	C3	
	⚡ for cables installed in walls / partitions containing metal parts regardless of depth	C3	
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	LIM	
5.13	Band II cables segregated/separated from Band I cables	LIM	
5.14	Cables segregated/separated from communications cabling	LIM	
5.15	Cables segregated/separated from non-electrical services	LIM	
5.16	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
	• Connections soundly made and under no undue strain	✓	
	• No basic insulation of a conductor visible outside enclosures	✓	
	• Connections of live conductors adequately enclosed	✓	
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓	
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	
5.18	Suitability of accessories for external influences	✓	
5.19	Adequacy of working space / accessibility to equipment	✓	
5.20	Single-pole devices for switching or protection in line conductors only	✓	

6.0 Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)

Notes: Switchgear designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI+ (to determine whether danger or potential danger exists)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
6.1	In general		
	presence and condition of appropriate devices	✓	
	correct operation verified	✓	
6.2	For isolation and switching for mechanical maintenance only		
	capable of being secured in the OFF position where appropriate	N/A	
	acceptable location - state if local or remote from equipment being controlled where appropriate	N/A	
	clearly identified by position and/or durable marking(s)	N/A	
6.3	For isolation only		
	warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.0	Current-using equipment (Permanently connected)		
7.1	Condition of equipment in terms of IP rating	✓	
7.2	Equipment does not constitute a fire hazard	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety	✓	
7.4	Suitability for the environment and external influences	✓	
7.5	Security of fixing	✓	
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire List number and location of luminaires inspected. (Separate page)	LIM	
7.7	Recessed luminaires (downlighters)		
	correct type of lamps fitted	N/A	
	installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	N/A	
	no signs of overheating to surrounding building fabric	✓	

Item	Description	Outcome*	Location reference
	no signs of overheating to conductors/terminations	✓	
8.0	Location(s) containing a bath or shower		
8.1	Additional protection by RCD not exceeding 30 mA		
	for low voltage circuits serving the location	C3	
	for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	C3	
8.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	N/A	
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓	
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	
8.7	Suitability of equipment for installation in a particular zone	✓	
9.0	Other special installations or locations - Part 7s		
9.1	List all other special installations or locations present, if any. (Record the results of particular inspection applied separately).	N/A	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2, C3 and FI coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT

Client: Grwp Gwalia Cyf

Address: Ty Gwalia
 7-13 The Kingsway
 Swansea
 West Glamorgan

Postcode: SA1 5JN

B. PURPOSE OF THE REPORT

Purpose for which this report is required: Periodic inspection & Test only.

Date(s) on which inspection and testing were carried out: 17th December 2018

C. DETAILS OF THE INSTALLATION

Occupier: Tenant

Address: Block C Flat 10
 Ty Beck House,
 Sketty Road,
 Uplands,
 Swansea, Postcode: SA2 0NH

Estimated age of the electrical installation: 25 years Evidence of alterations or additions If yes, estimated age 5 years

Date of previous inspection: N/A Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: N/A

Records of installation available: No Records held by: N/A

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
 Main DB and associated circuits only.

Agreed limitations (including the reasons), if any, on the inspection and testing:
 Audio circuits,
 Heating control circuits,
 Telecommunication circuits,
 Attic voids

Agreed with: Client

Operational limitations including the reasons (see page No. N/A)
 None.

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
 All in working order.

Summary of the condition of the installation continued on additional pages? No Yes Specify page

Overall assessment of the installation: **SATISFACTORY** ~~UNSATISFACTORY~~ * An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

5 Years

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or F1 (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading Title: A & R Electrical Wales Ltd

Address: 15 Alder Road
Cimla
Neath
Glam

Telephone number: 01639 775810

Email Address: office@aandreelectrical.co.uk



Enrolment number: 040640

(Essential information)

Branch number: 001

Postcode: SA11 3NY

K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System Type(s)		Number and Type of Live Conductors		Nature of Supply Parameters		Characteristics of Primary Supply Overcurrent Protective Device(s)	
TN-S	<input type="checkbox"/>	a.c.	<input checked="" type="checkbox"/>	Nominal Voltage(s), $U^{(1)}$	N/A V	$U_0^{(1)}$	230 V
TN-C-S	<input checked="" type="checkbox"/>	1-phase (2 wire)	<input type="checkbox"/>	Nominal frequency, $f^{(1)}$	50 Hz	Number of sources	1
TT	<input type="checkbox"/>	2-phase (3 wire)	<input type="checkbox"/>	Prospective fault current, $I_{pf}^{(2)(3)}$	0.88 kA	Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one source, record the higher or highest value (4) by measurement	
		3-phase (3 wire)	<input type="checkbox"/>	External earth fault loop impedance, $Z_e^{(3)(4)}$	0.28 Ω	BS(EN)	BS 1361 Fuse HBC Domestic Type
		3-phase (4 wire)	<input type="checkbox"/>			Type	2
						Rated current	100 A
						Short-circuit capacity	16.5 kA
						Confirmation of supply polarity	<input checked="" type="checkbox"/> <input type="checkbox"/>

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of Earthing		Details of Installation Earth Electrode (where applicable)		Earthing and protective bonding conductors		Bonding of extraneous-conductive-parts (✓)	
Distributor's facility:	<input checked="" type="checkbox"/>	Type: (eg rod(s), tape etc)	N/A	Location:	N/A	Water service	<input checked="" type="checkbox"/>
Installation earth electrode:	<input type="checkbox"/>	Electrode resistance, R_A :	N/A (Ω)	Method of measurement:	N/A	Oil service	<input type="checkbox"/>
Main Switch/Switch-Fuse/Circuit-Breaker/RCD				Main protective bonding conductors		Lightning protection	<input type="checkbox"/>
Type: BS(EN)	BS EN 60947-	Voltage rating	230 V	Earthing conductor	Conductor material	Gas Service	<input checked="" type="checkbox"/>
No of Poles	2	Rated current, I_n	100 A	Conductor material	Copper	Structural steel	<input type="checkbox"/>
Primary supply conductors (material)	Copper	RCD operating current, $I_{\Delta n}^*$	N/A mA	Conductor csa	10.0 mm ²	Other (Specify)	
Primary supply conductors (csa)	16.0 mm ²	Rated time delay*	N/A ms	Connection/continuity verified	<input checked="" type="checkbox"/> (✓)		
		RCD operating time (at $I_{\Delta n}$)*	N/A ms				

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment†		
1.1	Service cable	✓	
1.2	Service head	✓	
1.3	Distributor's earthing arrangement	✓	
1.4	Meter tails - Distributor/Consumer	✓	
1.5	Metering equipment	✓	
1.6	Means of main isolation (where present)	✓	
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
3.0	Earthing and bonding arrangements		
3.1	Presence and condition of distributor's earthing arrangement	✓	
3.2	Presence and condition of earth electrode connection	N/A	
3.3	Confirmation of adequate earthing conductor size	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	
3.6	Accessibility and condition of main protective bonding conductor connections	✓	
3.7	Accessibility and condition of other protective bonding connections	✓	
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	

Item	Description	Outcome*	Location reference
4.0	Consumer unit(s)		
4.1	Adequacy of working space or access to consumer unit	✓	
4.2	Security of fixing	✓	
4.3	Condition of enclosure(s) in terms of IP rating	✓	
4.4	Condition of enclosure(s) in terms of fire rating	C3	
4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	
4.6	Presence of linked main switch	✓	
4.7	Operation of main switch (functional check)	✓	
4.8	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	
4.9	Correct identification of circuits and protective devices	✓	
4.10	Presence of RCD test notice at or near consumer unit	✓	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓	
4.12	Presence of alternative or additional supply warning notice at or near consumer unit	N/A	
4.13	Presence of replacement next inspection recommendation label	✓	
4.14	Presence of other required labelling (please specify)	N/A	
4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
4.16	Single-pole switching or protective devices in the line conductors only	✓	
4.17	Protection against mechanical damage where cables enter consumer unit	✓	
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	N/A	
4.19	RCDs provided for fault protection - includes RCBOs	✓	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 ✗ indicates a limitation
 N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state FI (to determine whether danger or potential danger exists)
 Outcome Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
4.20	RCDs provided for additional protection - includes RCBOs	✓	
4.21	Confirmation of indication that SPD is functional	N/A	
4.22	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓	
5.0 Distribution/final circuits			
5.1	Identification of conductors	✓	
5.2	Cables correctly supported throughout their length	LIM	
5.3	Condition of insulation of live parts	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	N/A	
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓	
5.6	Adequacy of protective devices; type and rated current for fault protection	✓	
5.7	Presence and adequacy of circuit protective conductors	✓	
5.8	Co-ordination between conductors and overload protective devices	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓	
5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage		
	installed in prescribed zones (see Section D. Extent and limitations)	N/A	
	incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the	N/A	

Item	Description	Outcome*	Location reference
5.11	Provision of additional protection by RCD not exceeding 30 mA		
	⚡ for all socket-outlets of rating 20 A or less	✓	
	⚡ for mobile equipment not exceeding a rating of 32A for use outdoors	✓	
	⚡ for cables installed in walls or partitions at a depth of less than 50 mm	C3	
	⚡ for cables installed in walls / partitions containing metal parts regardless of depth	C3	
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	LIM	
5.13	Band II cables segregated/separated from Band I cables	LIM	
5.14	Cables segregated/separated from communications cabling	LIM	
5.15	Cables segregated/separated from non-electrical services	LIM	
5.16	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
	• Connections soundly made and under no undue strain	✓	
	• No basic insulation of a conductor visible outside enclosures	✓	
	• Connections of live conductors adequately enclosed	✓	
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓	
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	
5.18	Suitability of accessories for external influences	✓	
5.19	Adequacy of working space / accessibility to equipment	✓	
5.20	Single-pole devices for switching or protection in line conductors only	✓	

6.0 Isolation and switching (isolation, switching off for mechanical maintenance and functional

switching off) *Notes: Switching devices designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.*

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI (to determine whether danger or potential danger exists)

Original (To the person ordering the work)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference
6.1	In general		
	presence and condition of appropriate devices	✓	
	correct operation verified	✓	
6.2	For isolation and switching for mechanical maintenance only		
	capable of being secured in the OFF position where appropriate	N/A	
	acceptable location - state if local or remote from equipment being controlled where appropriate	N/A	
	clearly identified by position and/or durable marking(s)	N/A	
6.3	For isolation only		
	warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.0	Current-using equipment (Permanently connected)		
7.1	Condition of equipment in terms of IP rating	✓	
7.2	Equipment does not constitute a fire hazard	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety	✓	
7.4	Suitability for the environment and external influences	✓	
7.5	Security of fixing	✓	
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire List number and location of luminaires inspected. (Separate page)	LIM	
7.7	Recessed luminaires (downlighters)		
	correct type of lamps fitted	N/A	
	installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	N/A	
	no signs of overheating to surrounding building fabric	✓	

Item	Description	Outcome*	Location reference
	no signs of overheating to conductors/terminations	✓	
8.0	Location(s) containing a bath or shower		
8.1	Additional protection by RCD not exceeding 30 mA		
	for low voltage circuits serving the location	C3	
	for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	C3	
8.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	N/A	
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓	
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	
8.7	Suitability of equipment for installation in a particular zone	✓	
9.0	Other special installations or locations - Part 7s		
9.1	List all other special installations or locations present, if any. (Record the results of particular inspection applied separately).	N/A	

* All Outcome boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation

N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3

Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2, C3 and FI coded items to be recorded in Section F of the report.

