

Electrical Installation Condition Report

Requirements for Electrical Installations - BS 7671:2018
(IET Wiring Regulations 18th Edition)



Information for recipients:

The purpose of this report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).

The person ordering the report should have received the Original©Report and the inspector should have retained a duplicate.

The Original©Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.

Where the installation incorporates residual current devices (RCDs) there should be a notice at or near the devices stating that they should be tested every 6 months. **For safety reasons it is important that these instructions are followed.**

Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The Inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licencing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.

For items classified in Section K as C1 (“Danger Present”), **the safety of those using the installation is at risk**, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.

For items classified in Section K as C2 (“Potentially Dangerous”), **the safety of those using the installation may be at risk** and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where it has been stated in Section K that an observation requires further investigation code FI the inspection has revealed an apparent deficiency which may result on a code C1 or C2 could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons competent in such work. The recommended date by which the next inspection is due is stated in Section F of the report under ‘Recommendations’ and on label at or near to the consumer unit/distribution board.

ELECTRICAL INSTALLATION CONDITION REPORT

FT/
EICR 110148205

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



A. Details of the Installation

Client	UPP Residential Services Ltd	Installation	Swansea University Bay Campus - Deganwy 13
Address	First Floor 12 Arthur Street London	Address	Reception - Ground Floor Tower Information Centre Fabian Way Crymlyn Burrows Swansea
Postcode	EC4R 9AB	Postcode	SA1 8EN

B. Reason for Producing this Report *This form is to be used only for reporting on the condition of an existing installation.*

Essential information requested by the client in accordance with the electricity at work regulations 1989.

Date(s) on which the inspection and testing were carried out to

C. Details of Installation which is the Subject of this Report

Description of premises Domestic Commercial Industrial Other (please specify)

Estimated age of the wiring system years

Evidence of alterations or addition Yes No Not apparent if 'Yes', estimated years

Records of installation available Yes No Records held by

Date of last inspection Electrical Installation Certificate No. or previous Inspection Report No.

D. Extent of Electrical Installation Covered by this Report:

Testing of all sub mains, lighting and power circuits, within the constraints of the agreed limitations.

Agreed Limitations and Operational Limitations (Regulations 653.2)

Unable to completely isolate the installation. Unable to access the sealed supply device characteristics. Ze and Ipf have been taken with all earthing and bonding in place. Insulation resistance testing has been carried out to regulation 612.3.3 on circuits where it was impracticable to disconnect load. DB LL2/P and DB LL2/L have not had breakers in there designated as there is almost no way into the distribution board, i cannot verify if breakers installed in the DB have outgoing circuits, the door opens onto a duct pipe which prevents access into the DB leaving a number of breakers with unverified cable sizes and unverified designations also cannot perform ZE, Ipf, R1+R2, IR and ring tests on --Please see Continuation Page--

Agreed with:

The inspection and testing detailed within this report and accompanying schedule has been carried out in accordance with BS 7671: 2018 (IET Wiring Regulations) amended to

It should be noted that cables concealed within trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

E. Summary of the Condition of the Installation

General conditions of the installation (in terms of electrical safety)

Incoming system is a three phase TN-C-S (Terra Neutral Combined Separate) earthing system. Mains are located in the mains room located on the ground floor of the installation, on the left hand side of the building. Cables used through out installation are BS6242Y twin and earth PVC/PVC double --Please see Continuation Page--

Overall assessment of the installation in terms of its suitability for continued use **SATISFACTORY** ***UNSATISFACTORY**

*An UNSATISFACTORY assessment indicates that dangerous (code C1), or potentially dangerous (code C2), Further investigation (code FI) conditions have been identified

F. Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potential dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further Investigation required' (code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by (date)

ELECTRICAL INSTALLATION CONDITION REPORT

FT/ 110148205
EICR

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



G. Declaration

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company	PHS Compliance	Inspected and tested by	Authorised for issue by
Address	Kid Glove Road, Golborne, Warrington,	Name:	Liam Kimble
		Signature:	
Postcode	WA3 3GR		
Branch No.		Position:	Electrical Test Engineer
Scheme No.		Date:	04/07/2022
			Technical Auditor
			18/08/2022

EICRs are produced by a UKAS accredited inspection body, No. 0433

H. Schedule(s)

1 schedule(s) of inspection and 129 schedule(s) of test results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

I. Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S TN-C-S TT Other Please specify _____

Number & Type of live conductors AC DC No. of phases 3 No. of wires 4

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ 400/230 v Nominal frequency, f⁽¹⁾ 50 Hz Confirmation of supply polarity

Prospective fault current, I_{pr} ⁽²⁾ 4.8 kA External loop impedance, Z_e ⁽²⁾ 0.10 Ω

Supply Protective Device BS (EN) LIM Type LIM Rated Current LIM A

No. of Additional Supplies N/A

J. Particulars of Installation Referred to in this Report

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) _____ Distributors facility Installation Earth Electrode

Location _____ Electrode resistance to earth _____ Ω Maximum Demand (load) LIM Amps KVA

Main Protective Conductors	Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper	120	Continuity Verified <input checked="" type="checkbox"/>	Ω Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor (to extraneous-conductive-parts)	Copper	50	Continuity Verified <input checked="" type="checkbox"/>	Ω Connection Verified <input checked="" type="checkbox"/>

Main Supply Conductor Copper 120 (connection / continuity) (✓) or Value (✓) or Value

Main Switch Location Main Electrical Room Water installation Ω To structural steel Ω

Fuse/device rating or setting 400 A Voltage rating 400 V Gas installation pipes Ω To lightning protection NA Ω

If RCD main switch: Rated residual operating current I Δn N/A mA Oil installation pipes NA Ω Other IT Cabinet Ω

BS(EN) 60947-3 No. of Poles 4 Current Rating 400 A Rated time delay N/A ms Measured operating trip time N/A ms

K. Observations

Referring to the attached schedule of inspection and test results, and subject to the limitations at Section D.

- No remedial work required
- The following observations are made

Explanation of codes

C1	Danger present. Risk of Injury. Immediate remedial action required.
C2	Potentially dangerous. Urgent remedial action required.
C3	Improvement recommended.
F1	Further Investigation required without delay

Item No.	Observations	Code
1	Observation: Live conductors are incorrectly identified. Location: DB Main CCT 1/TP Regulation: 514.3.1	C3
2	Observation: No IP2X protection (>12mm hole) on the bottom surface of Socket. Location: DB CL1 14/L1 Regulation: 416.2.1	C3
3	Observation: Ring circuit with conductors of the same size shall have resistance values within 0.05 ohm of each other. Where Twin and earth is used the resistance value differential between live conductors and earth shall be approximately 1.67 times the value of the live readings. Location: DB CL8 CCT 8/L3 Reg 643.2.1	F1
4	Observation: Damaged socket back box. Location: DB CL1 CCT 14/L1 Regulation: 416.2	C2

ELECTRICAL INSTALLATION CONDITION REPORT

FT/
EICR 110148205

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



5	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL7 CCT 8/L3 Regulation: 537.2.4	FI
6	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL13 CCT 5/L3, 6/L3 Regulation: 537.2.4	FI
7	Observation: Limited access to DB Location: DB LL2/L Regulation: 132.12	FI
8	Observation: Limited access to DB Location: DB LL2/P Regulation: 132.12	FI

One of the following codes, as appropriate, has been allocated to each of the observations made above and/or any attached observation sheets to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1 Danger present. Risk of Injury. Immediate remedial action required.	0
C2 Potentially dangerous. Urgent remedial action required.	1
C3 Improvement recommended.	2
FI Further Investigation required without delay	5

The above values are a total count of Observation per outcome

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



Outcomes

Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further Investigation:	Not Verified:	Limitation:	Not Applicable:
	or					

Item No.	Description	Outcome
1.0 External Condition Of Intake Equipment (Visual Inspection Only) Where inadequacies are encountered, it is recommended that the person ordering the report informs the appropriate authority		
1.1	Service cable	
1.2	Service head	
1.3	Earthing arrangement	
1.4	Meter tails	
1.5	Metering equipment	
1.6	Isolator (where present)	
2.0 Parallel Or Switched Alternative Sources Of Supply		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	
3.0 Automatic Disconnection Of Supply		
3.1	Main earthing/bonding arrangements (411.3; Chap 54)	
3.1.1	Presence of distributors earthing arrangement (542.1.2.1; 542.1.2.2)	
3.1.2	Presence of installation earth electrode arrangement (542.1.2.3)	
3.1.3	Adequacy of earthing conductor size (542.3; 543.1.1)	
3.1.4	Adequacy of earthing conductor connections (542.3.2)	
3.1.5	Accessibility of earthing conductor connections (543.3.2)	
3.1.6	Adequacy of main protective bonding conductor sizes (544.1)	
3.1.7	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	
3.1.8	Accessibility of all protective bonding connections (543.3.2)	
3.1.9	Provision of earthing/bonding labels at all appropriate locations (514.13)	
3.2	FELV - requirements satisfied (411.7; 411.7.1)	
4.0 Other Methods Of Protection (Where any of the methods listed below are employed details should be provided on separate sheets)		
4.1	Non-conducting location (418.1)	
4.2	Earth-free local equipotential bonding (418.2)	
4.3	Electrical separation (Section 413; 418.3)	
4.4	Double insulation (Section 412)	
4.5	Reinforced insulation (Section 412)	
5.0 Distribution Equipment		
5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	
5.2	Security of fixing (134.1.1)	
5.3	Condition of insulation of live parts (416.1)	
5.4	Adequacy/security of barriers (416.2)	
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	
5.6	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)	
5.8	Presence and effectiveness of obstacles (417.2)	
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	
5.10	Operation of main switch(es) (functional check) (643.10)	
5.11	Manual operation of circuit-breakers and RCD(s) to prove disconnection (643.10)	
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)	
5.13	RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2)	
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBO(s) (411.3.3; 415.1)	
5.15	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	
5.17	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	
5.18	Presence of alternative supply warning notice at or near equipment, where required (514.15)	
5.19	Presence of next inspection recommendation label (514.12.1)	
5.2	Presence of other required labelling (please specify) (Section 514)	
5.21	Compatibility of protective device, base and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.4.5; 411.4.6; Sections 432; 433)	
5.22	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	
5.23	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	
5.24	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	
6.0 Distribution Circuits		

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



6.1	Identification of conductors (514.3.1)	✓
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
6.3	Condition of insulation of live parts (416.1)	✓
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. Integrity of containment (521.10.1)	✓
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	✓
6.6	Cables correctly terminated in enclosures (Section 526)	✓
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	✓
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	✓
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	✓
6.15	Cables concealed under floors, above ceilings, in walls/partitions less than 50 mm from a surface, and in partitions containing metal parts	
6.15.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202) or	✓
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.204)	✓
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
6.17	Band II cables segregated/separated from Band I cables (528.1)	✓
6.18	Cables segregated/separated from non-electrical services (528.3)	✓
6.19	Condition of circuit accessories (651.2)	✓
6.20	Suitability of circuit accessories for external influences (512.2)	✓
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
6.22	Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/record numbers and locations of items inspected (Section 526)	✓
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; 537)	✓
6.24	General condition of wiring systems (651.2)	✓
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)	✓
7.0 CONSUMER UNIT/DISTRIBUTION BOARD(S)		
7.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1)	✓
7.2	Security of fixing (134.1.1)	✓
7.3	Condition of enclosure(s) in terms of IP rating (Barriers etc) (416.2)	✓
7.4	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	✓
7.5	Enclosure/obstacles not damaged/deteriorated so as to impair safety (651.2)	✓
7.5.1	Presence and effectiveness of obstacles (417.2)	✓
7.6	Presence of main linked switch (as required by 462.1.201)	✓
7.7	Operation of main switch (functional check) (643.10)	✓
7.8	Manual operation of circuit-breakers and RCD(s) (test button) to prove disconnection (643.10)	✓
7.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	✓
7.10	Presence of RCD six-monthly test notice at or near consumer unit/distribution board (514.12.2)	✓
7.11	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	✓
7.12	Presence of alternative supply warning notice at or consumer unit/distribution board (514.15)	✓
7.13	Presence of other required labelling (Please specify) (Section 514)	✓
7.14	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	✓
7.15	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3)	✓
7.16	Protection against mechanical damage where cables enter consumer unit/distribution board (132.14.1; 522.8.1; 522.8.5; 522.8.11)	✓
7.17	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	✓
7.18	RCD(s) provided for fault protection - includes RCBO(s)(411.4.204; 411.5.2; 531.2)	✓
7.19	RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1)	✓
7.20	Confirmation of indication that SPD is functional (651.4)	✓
7.21	Confirmation that ALL conductor connections, including connections to the busbars are correctly located in terminals and are tight and secure (526.1)	✓
7.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	✓
7.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	✓
8.0 FINAL CIRCUITS		
8.1	Identification of conductors (514.3.1)	✓
8.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
8.3	Condition of insulation of live parts (416.1)	✓

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

8.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	✓
8.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)	✓
8.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
8.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
8.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
8.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	✓
8.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓
8.10	Connected cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	✓
8.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (522.6.204)	✓
8.12	Provision of additional requirements for protection by RCD not exceeding 30 mA:	
8.12.1	For all socket-outlets of rating 32 A or less unless exempt (4.11.3.3)	✓
8.12.2	For the supply of Mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	✓
8.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	✓
8.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	✓
8.12.5	For circuits supplying luminaires within domestic (household) premises (411.3.4)	✓
8.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
8.14	Band II cables segregated/separated from Band I cables (528.1)	✓
8.15	Cables segregated/separated from communications cabling (528.2)	✓
8.16	Cables segregated/separated from non-electrical services (528.3)	✓
8.17	Termination of cables at enclosures - indicate extent of sampling in section d of the report (section 526)	
8.17.1	Connections soundly made and under no undue strain (526.6)	✓
8.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	✓
8.17.3	Connections of live conductors adequately enclosed (526.5)	✓
8.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓
8.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v))	✓
8.19	Suitability of accessories for external influences (512.2)	✓
8.20	Adequacy or working space/accessibility to equipment (132.12; 513.1)	✓
8.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
9.0 ISOLATION AND SWITCHING		
9.1	Isolators (Section 460; 537)	
9.1.1	Presence and condition of appropriate devices (462; 537.2.7)	✓
9.1.2	Acceptable location - state if local or remote from equipment in question (462; 537.2.7)	✓
9.1.3	Capable of being secured in the OFF position (462.3)	✓
9.1.4	Correct operation verified (643.10)	✓
9.1.5	Clearly identified by position and/or durable marking (537.2.6)	✓
9.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	✓
9.2	Switching off for mechanical maintenance (Section 464; 537.3.2)	
9.2.1	Presence and condition of appropriate devices (464.1; 527.3.2)	✓
9.2.2	Acceptable location - state if local or remote from equipment in question (537.3.2.4)	✓
9.2.3	Capable of being secured in the OFF position (462.3)	✓
9.2.4	Correct operation verified (643.10)	✓
9.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	✓
9.3	Emergency switching/stopping (465; 537.3.3)	
9.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	✓
9.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	✓
9.3.3	Correct operation verified (643.10)	✓
9.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	✓
9.4	Functional switching (section 463; 537.3.1)	
9.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	✓
9.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	✓
10.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)		
10.1	Condition of equipment in terms of IP rating etc (416.2)	✓
10.2	Equipment does not constitute a fire hazard (Section 421)	✓
10.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	✓
10.4	Suitability for the environment and external influences (512.2)	✓
10.5	Security of fixing (134.1.1)	✓
10.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	✓
10.7	Recessed luminaires (downlighters)	
10.7.1	Correct type of lamps fitted (559.3.1)	✓
10.7.2	Installed to minimize build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	✓
10.7.3	No signs of overheating to surrounding building fabric (559.4.1)	✓

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



10.7.4	No signs of overheating to conductors/terminations (526.1)	✓
--------	--	---

11.0 PART 7 SPECIAL INSTALLATIONS OR LOCATIONS

11.01	If any special installations or locations are present, list the particular inspections applied.	✓
-------	---	---

12.0 Schedule of Tests

Results to be recorded on Schedule of Test Results

12.1	External earth loop impedance, Z ^e	Yes
12.2	Installation earth electrode	Yes
12.3	Prospective fault current, I _p ^f	Yes
12.4	Continuity of Earth Conductors	Yes
12.5	Continuity of Circuit Protective Conductors	Yes
12.6	Continuity of ring final circuit	Yes
12.7	Continuity of Protective Bonding Conductors	Yes
12.8	Volt drop verified	Yes

12.9	Insulation Resistance between Live Conductors	Yes
12.10	Insulation Resistance between Live Conductors & Earth	Yes
12.11	Polarity (prior to energisation)	Yes
12.12	Polarity (after energisation) including phase sequence	Yes
12.13	Earth Fault Loop Impedance	Yes
12.14	RCDs/RCBOs including selectivity	Yes
12.15	Functional testing of RCD devices	Yes
12.16	Functional testing of AFDD(s) devices	N/A

Inspector's Name: Liam Kimble

Date: 04/07/2022

Signature:

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Mains Electrical Room [Schneider] Designation: DB Main Num. of ways: 10 Num. of phases: 3 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input checked="" type="checkbox"/>	Supply to distribution board is from: Overcurrent protective device for the distribution circuit: Type: BS(EN) Rating: A Voltage: 400/230 V	Associated RCD(if any): BS (EN) Operating at 1 IΔn ms 30mA or below Operating at 5 IΔn ms Time delay (if applicable) ms	Loop impedance: 080408/5657 Insulation resistance: 080408/5657 Continuity: 080408/5657 RCD: 080408/5657

CIRCUIT DETAILS													TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDO (✓)				
														r1	r	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
1/TP	SPD	D	B	1	16	16	0.4	60947 MCCB	N/A	60	50	N/A	N/A	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	N/A	0.09	N/A	N/A	N/A	N/A	N/A
2/TP	Sub Mains(BB 1)	F	E	1	50	25	5	60947 MCCB	N/A	160	50	N/A	N/A	N/A	N/A	N/A	N/A	0.03	N/A	250	LIM	>299	N/A	0.10	N/A	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	Sub Mains(BB 2)	F	E	1	50	25	5	60947 MCCB	N/A	160	50	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.10	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	Sub Mains(DB CL1)	A	B	1	16	16	5	60947 MCCB	N/A	63	25	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.20	N/A	N/A	N/A	N/A
8/L2	Refuge Disabled Alarm	A	B	1	2.5	2.5	0.4	60947 MCCB	N/A	16	25	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0.22	N/A	LIM	LIM	LIM	✓	0.30	N/A	N/A	N/A	N/A
8/L3	FA Panel	O	B	1	2.5	2.5	0.4	60947 MCCB	N/A	16	25	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0.17	N/A	LIM	LIM	LIM	✓	0.28	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance Company Address: Kid Glove Road Postcode: WA3 3GR Branch No.: Scheme No.:
 Client: UPP Residential Services Ltd Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: G Floor Riser Designation: BB 1 Num. of ways: 20 Num. of phases: 3
 Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(DB Main, 2/TP)
 Overcurrent protective device for the distribution circuit: Type: BS(EN) 60947 MCCB Rating: 160 A Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn: N/A ms
 Zs: 0.12 Ω No. of poles: N/A 30mA or below Ipr: 4.4 kA IΔn: N/A Operating at 5 IΔn: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	APDD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Sub Mains(DB CL2)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.22	N/A	N/A	N/A	N/A
1/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL3)	A	B	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.18	N/A	N/A	N/A	N/A
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L3	Sub Mains(DB CL7)	A	B	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.20	N/A	N/A	N/A	N/A
11/L1	Sub Mains(DB CL6)	A	B	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.24	N/A	N/A	N/A	N/A
11/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE Position: Electrical Test Engineer Date: 05/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises




Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																											
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	Operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation													
	BB 1				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Δn ms	30mA or below 5 Δn ms	RCD (✓)	AFDD (✓)												
															r1	m	r2												R1 + R2	R2										
															(✓)	R1 + R2	R2												(✓)	(✓)										
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
13/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
14/L2	Sub Mains(DB CL9)	A	B	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.26	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L3	Sub Mains(DB CL13)	A	B	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.20	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L1	Sub Mains(DB CL12)	A	B	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.22	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
19/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
19/L2	Sub Mains(DB LL2/P, DB LL2/L)	A	B	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	LIM	LIM	LIM	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
19/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
20/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature 

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: G Floor Riser	Supply to distribution board is from: Sub Mains(DB Main, 6/TP)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: BB 2	Overcurrent protective device for the distribution circuit: BS(EN) 60947 MCCB	Operating at 1 IΔn: N/A	Insulation resistance: 080408/5756
Num. of ways: 24	Type: Rating 160 A Voltage 400/230	30mA or below: N/A	Continuity: 080408/5756
Supply polarity confirmed: <input checked="" type="checkbox"/>		Operating at 5 IΔn: N/A	RCD: 080408/5756
Phase sequence confirmed: <input checked="" type="checkbox"/>		Time delay (if applicable): N/A	

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	r2	Fig 8 check (✓)										All circuits to be completed using R1R2 or R2, not both		
														R1 + R2		R2												
1/L1	Sub Mains(DB CL4)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.22	N/A	N/A	N/A	N/A
1/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	Sub Mains(DB CL5)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.26	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L3	Sub Mains(DB CL8)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.22	N/A	N/A	N/A	N/A
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR

110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																									
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation											
	BB 2				Circuit designation	L / N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)										
															r1	m	r2												R1 + R2	R2								
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
13/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
14/L1	Sub Mains(DB CL10)	A	B	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
15/L2	Sub Mains(DB CL11)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
16/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/TP	Sub Mains(DB PL)	F	C	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
19/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
19/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
19/L3	Sub Mains(DB CL14)	A	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.22	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
20/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
21/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
22/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
23/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: G Floor Kitchen [Schneider]
 Designation: DB CL1
 Num. of ways: 18 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(DB Main, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: BS(EN) 60947 MCCB | Rating: 63 A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Above 30mA (if applicable): N/A ms
 Operating at 1 I_{Δn}: N/A | 30mA or below: N/A ms
 Z_s: 0.20 Ω | No. of poles: N/A
 I_{pf}: 1.04 kA | I_{Δn}: N/A | Operating at 5 I_{Δn}: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Z _s Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I _{Δn} ms			30mA or below 5 I _{Δn} ms	RCD (✓)	APDD (✓)	
														r1	rn	r2												R1 + R2
					Circuit designation																							
1/L1	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.52	36.3	16.4	✓	N/A
2/L1	Lighting Rooms 1,3	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.47	N/A	250	LIM	>299	✓	0.77	38.2	18.8	✓	N/A
3/L1	Lighting Rooms 2,4,6	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.55	N/A	250	LIM	>299	✓	0.83	40.4	20.4	✓	N/A
4/L1	Lighting Rooms 5,7	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.41	N/A	250	LIM	>299	✓	0.73	22.6	18.4	✓	N/A
5/L1	Lighting Rooms 8,9	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.82	N/A	250	LIM	>299	✓	1.04	51.2	29.1	✓	N/A
6/L1	Lighting Rooms 10,11	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.57	22.4	19.3	✓	N/A
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	Sub Mains(DB CL1/8, DB CL1/8-1)	A	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.51	0.51	0.62	N/A	0.28	N/A	250	LIM	>299	✓	0.37	30.4	20.4	✓	N/A
9/L1	Sub Mains(DB CL1/9, DB CL1/9-1)	A	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.47	0.50	0.58	N/A	0.26	N/A	250	LIM	>299	✓	0.44	28.2	16.4	✓	N/A
10/L1	Sub Mains(DB CL1/10-2, DB CL1/10, DB CL1/10-1)	A	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.48	0.48	0.55	N/A	0.26	N/A	250	LIM	>299	✓	0.40	32.2	18.8	✓	N/A
11/L1	Sub Mains(DB CL1/11-1, DB CL1/11)	A	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.47	0.47	0.53	N/A	0.25	N/A	250	LIM	>299	✓	0.44	29.2	18.9	✓	N/A
12/L1	Sub Mains(DB CL1/12-1, DB CL1/12)	A	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.56	0.56	0.63	N/A	0.30	N/A	250	LIM	>299	✓	0.41	28.4	20.0	✓	N/A
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L1	Common Room Ring 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.30	0.30	0.39	N/A	0.17	N/A	250	LIM	>299	✓	0.44	29.2	16.4	✓	N/A
15/L1	Common Room Ring 2	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.38	0.38	0.44	N/A	0.21	N/A	250	LIM	>299	✓	0.44	34.0	18.8	✓	N/A
16/L1	HOB 1	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.28	32.6	18.8	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing | Date(s) dead testing: 04/07/2022 To 04/07/2022 | Date(s) live testing: 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR

110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation		Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
	DB CL1	Circuit designation				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
						r1	m		r2	R1 + R2	R2				V	M(Ω)	M(Ω)												(✓)	(✓)	
						(Ω)	(Ω)		(Ω)	(Ω)	(Ω)				(Ω)	(Ω)	(Ω)												(Ω)	(Ω)	
17/L1	HOB 2		A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	✓	0.38	29.4	19.3	✓	N/A		
18/L1	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR **110148205**



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance
 Company Address Kid Glove Road
 Postcode WA3 3GR
 Branch No.
 Scheme No.
 Client UPP Residential Services Ltd
 Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea
 Postcode SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 7 [Schneider]
 Designation: DB CL1/8
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL1, 8/L1)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn 30.4 ms
 Z_s 0.37 Ω No. of poles 30mA or below
 I_{pf} kA IΔn 30 Operating at 5 IΔn 20.4 ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)		
														r1	r _n	r2												R1 + R2	R2
1/L1	Sockets Room 7	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20		250	LIM	>299	✓	0.78	N/A	N/A	N/A	N/A	
2/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	N/A	N/A
3/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	N/A	N/A
4/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing
 Date(s) dead testing 04/07/2022 To 04/07/2022
 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE
 Position Electrical Test Engineer
 Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Riser Room 3 [Schneider] Designation: DB CL1/9 Num. of ways: 5 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>	Supply to distribution board is from: Sub Mains (DB CL1, 9/L1) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V	Associated RCD(if any): BS (EN) Operating at 1 IΔn: 28.2 ms Zs: 0.44 Ω No. of poles: 30mA or below Ipf: kA IΔn: 30 Operating at 5 IΔn: 16.4 ms Time delay (if applicable):	Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
2/L1	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20		250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A		
3/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	N/A	N/A	
4/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A	N/A	N/A
5/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A	N/A	N/A
6/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 04/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider]
 Designation: DB CL1/10
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL1, 10/L1)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn 32.2 ms
 Z_s 0.40 Ω No. of poles 30mA or below
 I_{pr} kA IΔn 30 Operating at 5 IΔn 18.8 ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L1	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 10 [Schneider]
 Designation: DB CL1/12
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL1, 12/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) | Above 30mA (if applicable): Operating at 1 IΔn: 28.4 ms
 Z_s: 0.41 Ω | No. of poles: | 30mA or below: I_{pn}: kA | IΔn: 30 | Operating at 5 IΔn: 20.0 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														r1	rn	r2		R1 + R2	R2									
					80%	80%		80%	80%	80%				80%	80%													
1/L1	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider] | Designation: DB CL1/10-2 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL1, 10/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) | Operating at 1 IΔn: 32.2 ms (Above 30mA) | 18.8 ms (30mA or below)
 Z_s: 0.40 Ω | No. of poles: | I_{pr}: kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	80%		80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%	80%	
1/L1	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Kitchen RHS [Schneider]
 Designation: DB CL2
 Num. of ways: 18 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 1, 1/L1)
 Overcurrent protective device for the distribution circuit: Type: gG | Rating: 63 A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Above 30mA (if applicable): N/A ms
 Operating at 1 I_{Δn}: N/A | 30mA or below: N/A ms
 Z_s: 0.22 Ω | No. of poles: N/A
 I_{pr}: 1.02 kA | I_{Δn}: N/A | Operating at 5 I_{Δn}: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA I _{Δn}	30mA or below 5 I _{Δn}			RCD (✓)	APDD (✓)				
														r1	rn	r2										Fig 8 (✓)	All circuits to be completed using R1R2 or R2, not both		
								R1+R2	R2	V				M(Ω)	M(Ω)	ms	ms	(✓)	(✓)										
1/L1	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.51	N/A	250	LIM	>299	✓	0.73	28.3	20.2	✓	N/A	
2/L1	Lighting Rooms 8,9	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.59	N/A	250	LIM	>299	✓	0.82	18.4	18.0	✓	N/A	
3/L1	Lighting Rooms 6,7	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.68	N/A	250	LIM	>299	✓	0.91	24.6	20.2	✓	N/A	
4/L1	Lighting Rooms 2,4	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.50	N/A	250	LIM	>299	✓	0.75	25.2	18.2	✓	N/A	
5/L1	Lighting Rooms 1,3,5	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.41	N/A	250	LIM	>299	✓	0.68	30.2	15.4	✓	N/A	
6/L1	Lighting Rooms 10,11	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.53	N/A	250	LIM	>299	✓	0.77	26.4	18.3	✓	N/A	
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	Sub Mains(DB CL1/8-2, DB CL2/8, DB CL2/8-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.55	0.55	0.63	N/A	0.30	N/A	250	LIM	>299	✓	0.44	32.4	18.8	✓	N/A	
9/L1	Sub Mains(DB CL2/9-1, DB CL2/9)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.51	0.51	0.59	N/A	0.28	N/A	250	LIM	>299	✓	0.42	28.3	18.4	✓	N/A	
10/L1	Sub Mains(DB CL2/10-1, DB CL2/10)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.38	0.42	0.51	N/A	0.23	N/A	250	LIM	>299	✓	0.50	30.6	16.4	✓	N/A	
11/L1	Sub Mains(DB CL2/11-1, DB CL2/11)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.40	0.40	0.52	N/A	0.23	N/A	250	LIM	>299	✓	0.47	34.6	18.2	✓	N/A	
12/L1	Sub Mains(DB CL2/12-1, DB CL2/12)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.38	0.38	0.47	N/A	0.21	N/A	250	LIM	>299	✓	0.43	30.2	14.2	✓	N/A	
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L1	Common Room Ring 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.29	0.29	0.53	N/A	0.22	N/A	250	LIM	>299	✓	0.40	29.4	19.3	✓	N/A	
15/L1	Common Room Ring 2	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.30	0.32	0.51	N/A	0.20	N/A	250	LIM	>299	✓	0.42	32.5	16.4	✓	N/A	
16/L1	HOB 1	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.33	19.4	15.3	✓	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing | Date(s) dead testing: 04/07/2022 To 04/07/2022 | Date(s) live testing: 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																			
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation							
	DB CL2				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)					
	80%														r1	m	r2												R1 + R2	R2			
17/L1	HOB 2	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.29	22.6	19.4	✓	N/A					
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser (Schneider)
 Designation: DB CL2/10
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 10/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 30.6 ms (Above 30mA) | 30mA or below: 16.4 ms (if applicable)
 Zs: 0.50 Ω | No. of poles: 2 | Ipr: 0.48 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)				
														r1	rn	r2												R1 + R2	R2		
					80%	80%		80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%	80%		
1/L1	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.88	N/A	N/A	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider]
 Designation: DB CL2/11
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 11/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) | Above 30mA (if applicable): N/A | Operating at 1 IΔn: 34.6 ms
 Z_s: 0.47 Ω | No. of poles: N/A | 30mA or below: | Operating at 5 IΔn: 18.2 ms
 I_{pr}: 0.50 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	r _n	r2												R1 + R2	R2
1/L1	Room 8 Sockets	A	B	1	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.09		250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A	
2/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	N/A	N/A
3/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	N/A	N/A
4/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name Company Address Postcode Branch No. Scheme No.
 Client Installation Address Postcode

Distribution board details - Complete in every case
 Location
 Designation
 Num. of ways Num. of phases
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from
 Overcurrent protective device for the distribution circuit: Type Rating A Voltage
 BS(EN)

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn ms
 Z_s Ω No. of poles 30mA or below
 I_{pn} kA IΔn Operating at 5 IΔn ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance
 Insulation resistance
 Continuity
 RCD

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	r _n	r2												R1 + R2
1/L1	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.60	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schnieder] | Designation: DB CL2/8-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 32.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.44 Ω | No. of poles: 2 | Ipf: 0.55 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)		
														r1	rn	r2												R1 + R2	R2
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)									
1/L1	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.70	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 5 Riser [Schnieder] | Designation: DB CL1/8-2 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 32.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.44 Ω | No. of poles: 2 | Ipf: 0.55 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L1	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 7 Riser [Schnieder]
 Designation: DB CL2/9-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 9/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 32.4 ms (Above 30mA) | Operating at 5 IΔn: 18.8 ms (30mA or below)
 Zs: 0.44 Ω | No. of poles: 2
 Ipf: 0.55 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L1	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.73	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location <input type="text" value="Room 1 Riser [Schnieder]"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB CL2, 10/L1)"/>		Associated RCD(if any): BS (EN) <input type="text" value="61009"/> Above 30mA (if applicable) <input type="text" value="32.4"/> ms
Designation <input type="text" value="DB CL2/10-1"/>				Z_s <input type="text" value="0.44"/> Ω No. of poles <input type="text" value="2"/> 30mA or below <input type="text" value="18.8"/> ms
Num. of ways <input type="text" value="4"/> Num. of phases <input type="text" value="1"/>		Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="V"/>		I_{pr} <input type="text" value="0.55"/> kA $I_{\Delta n}$ <input type="text" value="30"/>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) <input type="text" value="N/A"/>
Test instrument serial number(s)				
Loop impedance <input type="text" value="080408/5756"/>				
Insulation resistance <input type="text" value="080408/5756"/>				
Continuity <input type="text" value="080408/5756"/>				
RCD <input type="text" value="080408/5756"/>				

CIRCUIT DETAILS														TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z_s Other (80%)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z_s (Ω)	RCD testing		Manual test button operation				
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA $I_{\Delta n}$ ms			30mA or below 5 $I_{\Delta n}$ ms	RCD (\checkmark)	AFDD (\checkmark)				
														r1	r2	r2												R1 + R2	R2		
																	(\checkmark)														
1/L1	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	\checkmark	0.62	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 9 Riser [Schnieder]
 Designation: DB CL2/11-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 11/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 32.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.46 Ω | No. of poles: 2
 Ipf: 0.48 kA | IΔn: 30 | Operating at 5 IΔn: 18.8 ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L1	Room 9 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 04/07/2022 To 04/07/2022 | Date(s) live testing: 04/07/2022 To 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location Room 1 Riser [Schnieder]	Supply to distribution board is from Sub Mains(DB CL2, 12/L1)	Associated RCD(if any): BS (EN) 61009	Loop impedance 080408/5756
Designation DB CL2/12-1	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V	Operating at 1 IΔn 32.4 ms	Insulation resistance 080408/5756
Num. of ways 4	BS(EN) 61009 RCD/RCBO	30mA or below Ipf 0.55 kA IΔn 30	Continuity 080408/5756
Supply polarity confirmed <input checked="" type="checkbox"/>		Operating at 5 IΔn 18.8 ms	RCD 080408/5756
Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r2	r2												R1 + R2	R2	
					80%	(Ω)		(Ω)	(Ω)	(Ω)				(Ω)																
1/L1	Room 11 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 4 Kitchen [Schneider]	Supply to distribution board is from: Sub Mains(BB 2, 1/L1)	Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn N/A ms	Loop impedance: 080408/5756
Designation: DB CL4	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V	Z _s 0.22 Ω No. of poles 30mA or below I _{pn} 1.03 kA IΔn N/A Operating at 5 IΔn N/A ms	Insulation resistance: 080408/5756
Num. of ways: 18 Num. of phases: 1		Time delay (if applicable):	Continuity: 080408/5756
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>			RCD: 080408/5756

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			APDD (✓)				
														r1	rn	r2										Fig 8 (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2														
1/L1	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.52	32.5	23.5	✓	N/A	
2/L1	Lighting Rooms 2,3	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.41	N/A	250	LIM	>299	✓	0.63	28.4	18.4	✓	N/A	
3/L1	Lighting Rooms 4,5	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.52	36.4	24.4	✓	N/A	
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	Sub Mains(DB CL4/5)	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.19	0.22	0.30	N/A	0.12	N/A	250	LIM	>299	✓	0.43	28.3	18.4	✓	N/A	
6/L1	Sub Mains(DB CL4/6-1, DB CL4/6)	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.21	0.21	0.28	N/A	0.12	N/A	250	LIM	>299	✓	0.35	25.4	18.8	✓	N/A	
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	Common Room Ring 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.22	0.25	0.33	N/A	0.14	N/A	250	LIM	>299	✓	0.44	28.4	18.4	✓	N/A	
9/L1	Common Room 2	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.28	0.28	0.38	N/A	0.17	N/A	250	LIM	>299	✓	0.38	26.2	18.4	✓	N/A	
10/L1	Hob	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.40	28.0	16.4	✓	N/A	
11/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance Company Address: Kid Glove Road Postcode: WA3 3GR Branch No.: Scheme No.:
 Client: UPP Residential Services Ltd Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Flat 3 Kitchen [Schneider] Designation: DB CL3 Num. of ways: 18 Num. of phases: 1
 Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 1, 6/L2)
 Overcurrent protective device for the distribution circuit: Type: gG Rating: 63 A Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) N/A Operating at 1 IΔn: N/A ms Above 30mA (if applicable)
 Zs: 0.18 Ω No. of poles: N/A 30mA or below
 Ipr: 1.22 kA IΔn: N/A Operating at 5 IΔn: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	APDD (✓)		
														r1	rn	r2												R1 + R2	R2
1/L2	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	✓	0.63	24.2	20.0	✓	N/A	
2/L2	Lighting Rooms 8,9,10	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.77	30.2	16.6	✓	N/A	
3/L2	Lighting Rooms 3,5,7	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.68	41.2	18.4	✓	N/A	
4/L2	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.37	N/A	250	LIM	>299	✓	0.59	35.4	19.4	✓	N/A	
5/L2	Lighting Rooms 4,6	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.59	N/A	250	LIM	>299	✓	0.72	42.2	18.4	✓	N/A	
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	Sub Mains(DB CL3/7-1, DB CL3/7)	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.33	0.33	0.42	N/A	0.19	N/A	250	LIM	>299	✓	0.42	32.2	18.4	✓	N/A	
8/L2	Sub Mains(DB CL3/8)	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.40	0.37	0.44	N/A	0.21	N/A	250	LIM	>299	✓	0.44	29.8	19.0	✓	N/A	
9/L2	Sub Mains(DB CL3/9)	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.38	0.34	0.42	N/A	0.20	N/A	250	LIM	>299	✓	0.38	35.2	16.2	✓	N/A	
10/L2	Sub Mains(DB CL3/10-1, DB CL3/10)	A	B	1	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.33	0.35	0.37	N/A	0.18	N/A	250	LIM	>299	✓	0.35	39.5	18.8	✓	N/A	
11/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L2	Common Room Ring 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.25	0.25	0.33	N/A	0.15	N/A	250	LIM	>299	✓	0.35	24.4	18.8	✓	N/A	
13/L2	Common Room Ring 2	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.26	0.25	0.38	N/A	0.16	N/A	250	LIM	>299	✓	0.38	19.4	14.2	✓	N/A	
14/L2	Hob 1	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.25	32.6	18.6	✓	N/A	
15/L2	Hob 2	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.28	30.6	12.4	✓	N/A	
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 04/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 8 [Schneider]
 Designation: DB CL3/7
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(DB CL3, 7/L2)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 32.2 ms
 Zs 0.42 Ω No. of poles 2 30mA or below
 Ipr 0.55 kA IΔn 30 Operating at 5 IΔn 18.4 ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L2	Sub Mains(DB CL3/7-2)	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider] | Designation: DB CL3/10 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL3, 10/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 39.5 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.35 Ω | No. of poles: 2 | Ipf: 0.66 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Riser Room 10 [Schneider]	Supply to distribution board is from: Sub Mains(DB CL3/7, 1/L2)	Associated RCD(if any): BS (EN) 61008		Test instrument serial number(s) Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756
Designation: DB CL3/7-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Operating at 1 IΔn: 32.2 ms (if applicable)		
Num. of ways: 4	Type: C	Operating at 5 IΔn: 18.4 ms		
Num. of phases: 1	Rating: 32 A	Time delay (if applicable):		
Supply polarity confirmed: <input checked="" type="checkbox"/>	Phase sequence confirmed: <input type="checkbox"/>	Voltage: V		

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	80%		80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%	80%	80%
1/L2	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To 04/07/2022 Date(s) live testing: 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 5 [Schneider]
 Designation: DB CL3/8-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL3/8, 1/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 32.2 ms (Above 30mA)
 Zs: 0.42 Ω | No. of poles: 2 | 30mA or below: Ipf: 0.55 kA | IΔn: 30 | Operating at 5 IΔn: 18.4 ms (if applicable)
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	80%		80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%	80%	80%
1/L2	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 7 [Schneider]
 Designation: DB CL3/8-2
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL3/8, 1/L2)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 32.2 ms
 Z_s 0.42 Ω No. of poles 2 30mA or below
 I_{pr} 0.55 kA IΔn 30 Operating at 5 IΔn 18.4 ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r _n	r2												R1 + R2
1/L2	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 8 [Schneider]
 Designation: DB CL3/9-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL3/9, 1/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 32.2 ms (Above 30mA)
 Z_s: 0.42 Ω | No. of poles: 2 | 30mA or below: I_{pf} 0.55 kA | IΔn: 30 | Operating at 5 IΔn: 18.4 ms (if applicable)
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 8 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 6 [Schneider]
 Designation: DB CL3/10-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL3, 10/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 32.2 ms (Above 30mA)
 Zs: 0.42 Ω | No. of poles: 2 | 30mA or below: Ipr: 0.55 kA | IΔn: 30 | Operating at 5 IΔn: 18.4 ms (if applicable)
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L2	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.70	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 2 Riser [Schneider]	Supply to distribution board is from: Sub Mains(DB CL4, 5/L1)	Associated RCD(if any): BS (EN) 61008	Above 30mA (if applicable): Operating at 1 IΔn 28.3 ms	Test instrument serial number(s)
Designation: DB CL4/5	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V	Zs 0.43 Ω No. of poles 2	30mA or below: Operating at 5 IΔn 18.4 ms	
Num. of ways 4 Num. of phases 1		Ipf 0.51 kA IΔn 30	Time delay (if applicable)	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				
				Loop impedance 080408/5756
				Insulation resistance 080408/5756
				Continuity 080408/5756
				RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
					80%	(Ω)		(Ω)	(Ω)	(Ω)				(Ω)	(Ω)													
1/L1	Sub Mains(DB CL4/5-1)	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.18		250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A
2/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
3/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
4/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR

110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN	
Distribution board details - Complete in every case				Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 4 Riser [Schneider]		Supply to distribution board is from: Sub Mains(DB CL4, 6/L1)		Associated RCD(if any): BS (EN) 61008		Test instrument serial number(s) Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756
Designation: DB CL4/6		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V		Operating at 1 IΔn: 25.4 ms (Above 30mA)		
Num. of ways: 4 Num. of phases: 1				30mA or below: 18.8 ms (Operating at 5 IΔn)		
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>				Time delay (if applicable):		

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r2												R1 + R2
					80%	(Ω)	(Ω)	(Ω)	(Ω)	(Ω)				(Ω)	(Ω)	(Ω)												
1/L1	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schneider] | Designation: DB CL4/5-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL4/5, 1/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 25.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.38 Ω | No. of poles: 2 | Ipf: 0.68 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L1	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 5 Riser [Schneider] | Designation: DB CL4/6-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL4, 6/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 25.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.35 Ω | No. of poles: 2 | Ipf: 0.68 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L1	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.67	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)		
Location	Flat 5 Kitchen [Schneider]	Supply to distribution board is from	Sub Mains(BB 2, 4/L2)	Associated RCD(if any): BS (EN)	61008	Above 30mA (if applicable)	Loop impedance	080408/5756
Designation	DB CL5	Overcurrent protective device for the distribution circuit: Type	BS(EN) 88-2 HRC	Operating at 1 IΔn	N/A	ms	Insulation resistance	080408/5756
Num. of ways	18	Rating	63	30mA or below	N/A	ms	Continuity	080408/5756
Supply polarity confirmed	<input checked="" type="checkbox"/>	Voltage		Operating at 5 IΔn	N/A	ms	RCD	080408/5756
Phase sequence confirmed	<input type="checkbox"/>			Time delay (if applicable)				

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn	30mA or below 5 IΔn	RCD (✓)			APDD (✓)			
														r1	rn	r2										Fig 8 (✓)	All circuits to be completed using R1R2 or R2, not both	
					r1	rn	r2	(✓)	R1 + R2	R2				V	M(Ω)	M(Ω)	ms	ms	(✓)	(✓)								
1/L2	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.35	N/A	250	LIM	>299	✓	0.57	28.4	20.0	✓	N/A
2/L2	Lighting Rooms 1,3,5	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.63	32.5	18.8	✓	N/A
3/L2	Lighting Rooms 2,4,6	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.59	28.9	18.8	✓	N/A
4/L2	Lighting Rooms 7,8	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.37	N/A	250	LIM	>299	✓	0.61	32.2	19.4	✓	N/A
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL5/6-2, DB CL5/6, DB CL5/6-1)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.30	0.29	0.35	N/A	0.16	N/A	250	LIM	>299	N/A	0.37	29.8	18.8	✓	N/A
7/L2	Sub Mains(DB CL5/7-1, DB CL5/7, DB CL5/7-2)	A	B	9	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.25	0.28	0.40	N/A	0.16	N/A	250	LIM	>299	N/A	0.35	32.2	18.0	✓	N/A
8/L2	Sub Mains(DB CL5/8-1, DB CL5/8)	A	B	6	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.20	0.25	0.33	N/A	0.13	N/A	250	LIM	>299	N/A	0.44	30.8	20.2	✓	N/A
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	Common Room Sockets 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.24	0.24	0.36	N/A	0.15	N/A	250	LIM	>299	✓	0.38	28.4	15.2	✓	N/A
11/L2	Common Room Sockets 2	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.28	0.28	0.51	N/A	0.20	N/A	250	LIM	>299	✓	0.33	32.2	18.8	✓	N/A
12/L2	Hob 1	A	B	1	2.5	1.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.49	25.6	20.4	✓	N/A
13/L2	Hob 2	A	B	1	2.5	1.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.47	32.8	19.4	✓	N/A
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																							
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation									
	DB CL5				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Δn ms			30mA or below 5 Δn ms	RCD (✓)	AFDD (✓)									
	Circuit designation													r1	m	r2																				
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) Position Date Signature

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case Location: Room 1 Riser [Schneider] Designation: DB CL5/6 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains (DB CL5, 6/L2) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V		Characteristics at this distribution board Associated RCD (if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 29.8 ms Zs 0.37 Ω No. of poles 2 30mA or below Ipr 0.66 kA IΔn 30 Operating at 5 IΔn 18.8 ms Time delay (if applicable)		Test instrument serial number(s) Loop impedance 080408/5756 Insulation resistance 080408/5756 Continuity 080408/5756 RCD 080408/5756	
---	--	--	--	---	--	---	--

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L2	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider]
 Designation: DB CL5/7
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 32.2 ms (Above 30mA) | 18.0 ms (30mA or below)
 Z_s: 0.35 Ω | No. of poles: 2
 I_{pn}: 0.63 kA | IΔn: 30 | Operating at 5 IΔn: 18.0 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 7 Riser [Schneider]
 Designation: DB CL5/8
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 8/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 30.8 ms (Above 30mA) | 30mA or below: 20.2 ms (if applicable)
 Z_s: 0.44 Ω | No. of poles: 2 | I_{pn}: 0.51 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schneider] | Designation: DB CL5/6-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 6/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 29.8 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.37 Ω | No. of poles: 2 | Ipf: 0.66 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L2	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 5 Riser [Schneider] | Designation: DB CL5/6-2 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 6/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 29.8 ms | Above 30mA (if applicable)
 Z_s: 0.37 Ω | No. of poles: 2 | 30mA or below
 I_{pr}: 0.66 kA | IΔn: 30 | Operating at 5 IΔn: 18.8 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.49	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case Location: Room 4 Riser [Schneider] Designation: DB CL5/7-1 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains(DB CL5, 7/L2) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V	Characteristics at this distribution board Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 29.8 ms Zs 0.37 Ω No. of poles 2 30mA or below Ipf 0.66 kA IΔn 30 Operating at 5 IΔn 18.8 ms Time delay (if applicable)	Test instrument serial number(s) Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756
---	--	--	---

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (80%) (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L2	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider] | Designation: DB CL5/7-2 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 29.8 ms (Above 30mA) | 18.8 ms (30mA or below)
 Z_s: 0.37 Ω | No. of poles: 2 | I_{pn}: 0.66 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.50	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To 04/07/2022 Date(s) live testing: 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider]
 Designation: DB CL5/8-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 8/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 29.8 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.37 Ω | No. of poles: 2
 Ipf: 0.66 kA | IΔn: 30 | Operating at 5 IΔn: 18.8 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	80%		80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%	80%	
1/L2	Room 8 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.65	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Flat 8 Kitchen [Schneider]
 Designation: DB CL8
 Num. of ways: 18 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 2, 10/L3)
 Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Above 30mA (if applicable) N/A Operating at 1 IΔn N/A ms
 Z_s 0.22 Ω No. of poles N/A 30mA or below
 I_{pr} 1.08 kA IΔn N/A Operating at 5 IΔn N/A ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L3	Common room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44		250	LIM	>299	✓	0.69	29.5	32.2	✓	N/A
2/L3	Lighting Rooms 1,3,5	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38		250	LIM	>299	✓	0.71	32.2	20.0	✓	N/A
3/L3	Lighting Rooms 2,4,6	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.57		250	LIM	>299	✓	0.82	44.6	32.6	✓	N/A
4/L3	Lighting Room 7,8	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44		250	LIM	>299	✓	0.72	28.2	16.4	✓	N/A
5/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
6/L3	Sub Mains(DB CL8/6-2, DB CL8/6, DB CL8/6-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.29	0.24	0.32	N/A	0.15		250	LIM	>299	✓	0.37	22.4	16.3	✓	N/A
7/L3	Sub Mains(DB CL8/7-2, DB CL8/7, DB CL8/7-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.19	0.19	0.33	N/A	0.13		250	LIM	>299	✓	0.35	30.4	18.8	✓	N/A
8/L3	Sub Mains(DB CL8/8-1, DB CL8/8)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.27	0.20	0.34	N/A	0.15		250	LIM	>299	✓	0.39	29.8	20.0	✓	N/A
9/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
10/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
11/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
12/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
13/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
14/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
15/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
16/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
17/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

CIRCUIT DETAILS											TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
	DB CL8				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFFD (✓)
	Circuit designation				80%	r1		m	r2	R1 + R2				R2													
18/L3	SPARE												N/A	N/A	N/A	N/A									N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider]
 Designation: DB CL8/6
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL8, 6/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 22.4 ms (Above 30mA) | 30mA or below: 16.3 ms (if applicable)
 Zs: 0.37 Ω | No. of poles: 2 | Ipr: 0.63 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L3	Sockets Room 1	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case Location: Room 2 Riser [Schneider] Designation: DB CL8/7 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains(DB CL8, 7/L3) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V	Characteristics at this distribution board Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn 30.4 ms Above 30mA (if applicable) Zs 0.35 Ω No. of poles 2 30mA or below Ipr 0.70 kA IΔn 30 Operating at 5 IΔn 18.8 ms Time delay (if applicable) N/A	Test instrument serial number(s) Loop impedance 080408/5756 Insulation resistance 080408/5756 Continuity 080408/5756 RCD 080408/5756
---	---	---	---

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L3	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.60	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 7 Riser [Schneider] | Designation: DB CL8/8 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL8, 8/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 29.8 ms (Above 30mA) | 30mA or below: 20.0 ms (if applicable)
 Zs: 0.39 Ω | No. of poles: 2 | Ipf: 0.59 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L3	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.51	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 3 [Schneider]
 Designation: DB CL8/6-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL8, 6/L3)
 Overcurrent protective device for the distribution circuit: Type: | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 22.4 ms (Above 30mA) | 30mA or below: 16.3 ms (if applicable)
 Z_s: 0.37 Ω | No. of poles: 2 | I_{pn}: 0.62 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L3	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name Company Address Postcode Branch No. Scheme No.
 Client Installation Address Postcode

Distribution board details - Complete in every case
 Location
 Designation
 Num. of ways Num. of phases
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from
 Overcurrent protective device for the distribution circuit: Type Rating A Voltage V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn ms
 Z_s Ω No. of poles 30mA or below
 I_{pn} kA IΔn Operating at 5 IΔn ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance
 Insulation resistance
 Continuity
 RCD

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	(Ω)		(V)	(M(Ω))	(M(Ω))				(ms)	(ms)	(✓)	(✓)													
1/L3	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.46	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board	
Location: Room 4 Riser [Schneider]		Supply to distribution board is from: Sub Mains (DB CL8, 7/L3)		Associated RCD (if any): BS (EN) 61009	
Designation: DB CL8/7-1		Overcurrent protective device for the distribution circuit: Type: BS(EN) Rating: A Voltage: V		Operating at 1 IΔn: 30.4 ms (Above 30mA)	
Num. of ways: 4 Num. of phases: 1				Operating at 5 IΔn: 18.8 ms (30mA or below)	
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>				Time delay (if applicable): N/A	
				Test instrument serial number(s)	
				Loop impedance: 080408/5756	
				Insulation resistance: 080408/5756	
				Continuity: 080408/5756	
				RCD: 080408/5756	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r2	r3												R1 + R2	R2	
					80%	r1		r2	r3	R1 + R2				R2	V	M(Ω)	M(Ω)	(✓)	(✓)	(✓)										
1/L3	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 05/07/2022

Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 6 Riser [Schneider]
 Designation: DB CL8/7-2
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL8, 7/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 30.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.35 Ω | No. of poles: 2 | Ipr: 0.60 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation					
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)				
														r1	rn	r2		R1 + R2	R2													
					80%	80%		80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%	80%	80%	80%	80%
1/L3	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider]
 Designation: DB CL8/8-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL8, 8/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 29.8 ms (Above 30mA) | 30mA or below: 20.0 ms (if applicable)
 Z_s: 0.39 Ω | No. of poles: 2 | I_{pn}: 0.56 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L3	Room 8 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.23	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance Company Address: Kid Glove Road Postcode: WA3 3GR Branch No. Scheme No.
 Client: UPP Residential Services Ltd Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Flat 7 Kitchen [Schneider] Designation: DB CL7 Num. of ways: 18 Num. of phases: 1
 Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 1, 10/L3)
 Overcurrent protective device for the distribution circuit: Type: gG Rating: 63 A Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Above 30mA (if applicable) N/A Operating at 1 IΔn N/A ms
 Zs: 0.20 Ω No. of poles: N/A 30mA or below
 Ipr: 1.14 kA IΔn: N/A Operating at 5 IΔn N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)				
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
1/L3	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.37	N/A	250	LIM	>299	✓	0.72	23.5	20.0	✓	N/A	
2/L3	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.70	30.4	18.8	✓	N/A	
3/L3	Lighting Rooms 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.54	29.2	19.3	✓	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/L3	Sub Mains(DB CL7/5-2, DB CL7/5, DB CL7/5-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.40	0.37	0.44	N/A	0.12	N/A	250	LIM	>299	✓	0.36	19.4	18.8	✓	N/A	
6/L3	Sub Mains(DB CL7/6, DB CL7/6-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.40	0.40	0.60	N/A	0.25	N/A	250	LIM	>299	✓	0.42	24.4	16.4	✓	N/A	
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8/L3	Isolated	A	B	LIM	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.30	0.30	0.42	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	LIM	N/A
9/L3	Common Room Ring	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.22	0.22	0.32	N/A	0.13	N/A	250	LIM	>299	✓	0.40	26.2	12.4	✓	N/A	
10/L3	Hob	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.32	30.8	18.8	✓	N/A	
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
12/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
13/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE Position: Electrical Test Engineer Date: 05/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR

110148205

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



Circuit No. and Line No.	CIRCUIT DETAILS										TEST RESULTS																							
	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation								
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)							
														r1	m	r2												R1 + R2	R2					
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature 

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schneider] | Designation: DB CL7/5 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL7, 5/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 19.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Z_s: 0.36 Ω | No. of poles: 2 | I_{pn}: 0.65 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L3	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider]
 Designation: DB CL7/6
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL7, 6/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 24.4 ms (Above 30mA) | 16.4 ms (30mA or below)
 Z_s: 0.42 Ω | No. of poles: 2
 I_{pr}: 0.55 kA | IΔn: 30 | Operating at 5 IΔn: 16.4 ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L3	Room 1 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider] | Designation: DB CL7/5-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL7, 5/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61009 | Operating at 1 IΔn: 19.4 ms (Above 30mA) | 30mA or below: 18.8 ms (if applicable)
 Zs: 0.36 Ω | No. of poles: 2 | Ipf: 0.60 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L3	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.72	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Room 5 Riser	Designation: DB CL7/5-2	Supply to distribution board is from: Sub Mains(DB CL7, 5/L3)	Associated RCD(if any): BS (EN) 61009	Test instrument serial number(s) Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756
Num. of ways: 4	Num. of phases: 1	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Operating at 1 IΔn: 19.4 ms (Above 30mA)	
Supply polarity confirmed: <input checked="" type="checkbox"/>	Phase sequence confirmed: <input type="checkbox"/>		Operating at 5 IΔn: 18.8 ms (30mA or below)	
			Time delay (if applicable): N/A	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2											Fig 8 check (✓)	R1 + R2	R2
					80%	(Ω)		(Ω)	(Ω)	(Ω)				(Ω)	(Ω)														
1/L3	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14		250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A	
2/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	N/A	N/A
3/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	N/A	N/A
4/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider] | Designation: DB CL7/6-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL7, 6/L3)
 Overcurrent protective device for the distribution circuit: Type C | Rating 32 | A | Voltage 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 22.4 ms | Above 30mA (if applicable)
 Z_s: 0.42 Ω | No. of poles: 2 | 30mA or below
 I_{pn}: 0.55 kA | IΔn: 30 | Operating at 5 IΔn: 16.4 ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS														TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	r _n	r2												R1 + R2	R2
1/L3	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 6 Kitchen [Schneider]	Supply to distribution board is from: Sub Mains(BB 1, 11/L1)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5657
Designation: DB CL6	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 080408/5657
Num. of ways: 18 Num. of phases: 1		No. of poles: N/A	Continuity: 080408/5657
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 080408/5657
		Time delay (if applicable): N/A	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)				
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2	
																		V	M(Ω)	M(Ω)									
1/L1	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.65	32.2	16.2	✓	N/A	
2/L1	Lighting Room 8,9,10	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.35	N/A	250	LIM	>299	✓	0.59	39.2	20.2	✓	N/A	
3/L1	Lighting Room 3,5,7	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.72	28.4	18.8	✓	N/A	
4/L1	Lighting Room 1,2	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.55	33.4	20.4	✓	N/A	
5/L1	Lighting Room 4,6	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.63	29.3	16.4	✓	N/A	
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	Sub Mains(DB CL6/7-2, DB CL6/7, DB CL6/7-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.33	0.33	0.52	N/A	0.21	N/A	250	LIM	>299	✓	0.45	28.4	20.4	✓	N/A	
8/L1	Sub Mains(DB CL6/8-2, DB CL6/8, DB CL6/8-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.29	0.29	0.35	N/A	0.16	N/A	250	LIM	>299	✓	0.38	24.0	16.4	✓	N/A	
9/L1	Sub Mains(DB CL6/9, DB CL6/9-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.28	0.25	0.32	N/A	0.15	N/A	250	LIM	>299	✓	0.37	32.0	18.4	✓	N/A	
10/L1	Sub Mains(DB CL6/10-1, DB CL6/10)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.31	0.31	0.42	N/A	0.18	N/A	250	LIM	>299	✓	0.35	20.2	14.2	✓	N/A	
11/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L1	Common ring 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.31	0.31	0.40	N/A	0.18	N/A	250	LIM	>299	✓	0.42	32.4	22.6	✓	N/A	
13/L1	Common Ring 2	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.22	0.22	0.29	N/A	0.13	N/A	250	LIM	>299	✓	0.37	34.6	25.4	✓	N/A	
14/L1	Hob 1	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.31	29.6	22.5	✓	N/A	
15/L1	Hob 2	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.35	25.4	19.8	✓	N/A	
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110148205

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS														TEST RESULTS																				
Circuit No. and Line No.	Distribution board Designation		Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
	DB CL6	Circuit designation				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)						
															r1	m	r2												R1 + R2	R2				
17/L1	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider] | Designation: DB CL6/7 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL6, 7/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.4 ms (Above 30mA) | 30mA or below: 20.4 ms (if applicable)
 Zs: 0.45 Ω | No. of poles: 2 | Ipf: 0.52 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L1	Room 8 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.65	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schneider]
 Designation: DB CL6/8
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL6, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 24.0 ms (Above 30mA) | 30mA or below: 16.4 ms (if applicable)
 Zs: 0.38 Ω | No. of poles: 2 | Ipf: 0.61 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)				
														r1	rn	r2												R1 + R2	R2		
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)											
1/L1	Sockets Room 3	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.50	N/A	N/A	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location: Room 1 Riser [Schneider]	Designation: DB CL6/9	Supply to distribution board is from: Sub Mains(DB CL6, 9/L1)	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V	Associated RCD(if any): BS (EN) 61009	Operating at 1 IΔn: 32.0 ms	Loop impedance: 080408/5756	Insulation resistance: 080408/5756
Num. of ways: 4	Num. of phases: 1	Sub Mains(DB CL6, 9/L1)	BS(EN) 61009 RCD/RCBO	Zs: 0.37 Ω	Operating at 5 IΔn: 18.4 ms	Continuity: 080408/5756	RCD: 080408/5756
Supply polarity confirmed: <input checked="" type="checkbox"/>	Phase sequence confirmed: <input type="checkbox"/>			Ipf: 0.62 kA			
				Time delay (if applicable): N/A			

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L1	Room 9 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 10 Riser [Schneider]
 Designation: DB CL6/7-2
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL6, 7/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.4 ms (Above 30mA)
 Zs: 0.45 Ω | No. of poles: 2 | 30mA or below
 Ipr: 0.52 kA | IΔn: 30 | Operating at 5 IΔn: 20.4 ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)				
														r1	rn	r2												R1 + R2	R2		
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)											
1/L1	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.54	N/A	N/A	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Flat 11 Kitchen [Schneider]
 Designation: DB CL11
 Num. of ways: 18 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 2, 15/L2)
 Overcurrent protective device for the distribution circuit: Type: gG | Rating: 63 A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Above 30mA (if applicable): N/A ms
 Operating at 1 IΔn: N/A | 30mA or below: N/A ms
 Zs: 0.28 Ω | No. of poles: N/A
 Ipr: 0.87 kA | IΔn: N/A | Operating at 5 IΔn: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		All circuits to be completed using R1R2 or R2, not both										
1/L2	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.27		250	LIM	>299	✓	0.56	28.8	20.0	✓	N/A
2/L2	Lighting Rooms 1,3,5	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.47		250	LIM	>299	✓	0.73	32.4	18.8	✓	N/A
3/L2	Lighting Rooms 2,4,6	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52		250	LIM	>299	✓	0.80	42.4	22.4	✓	N/A
4/L2	Lighting Rooms 7,8	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33		250	LIM	>299	✓	0.56	38.8	19.4	✓	N/A
5/L2	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
6/L2	Sub Mains(DB CL11/6-2, DB CL11/6, DB CL11/6-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.38	0.36	0.42	N/A	0.20		250	LIM	>299	✓	0.42	34.5	18.4	✓	N/A
7/L2	Sub Mains(DB CL11/7, DB CL11/7-1, DB CL11/7-2)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.35	0.35	0.46	N/A	0.20		250	LIM	>299	✓	0.42	28.8	20.6	✓	N/A
8/L2	Sub Mains(DB CL11/8, DB CL11/8-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.26	0.26	0.33	N/A	0.15		250	LIM	>299	✓	0.38	24.2	16.8	✓	N/A
9/L2	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
10/L2	Common Room Ring 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.41	0.41	0.55	N/A	0.24		250	LIM	>299	✓	0.45	29.2	18.8	✓	N/A
11/L2	Common Room Ring 2	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.35	0.35	0.42	N/A	0.19		250	LIM	>299	✓	0.39	31.8	18.6	✓	N/A
12/L2	Hob 1	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.10		250	LIM	>299	✓	0.35	42.4	20.4	✓	N/A
13/L2	Hob 2	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.12		250	LIM	>299	✓	0.39	38.6	18.2	✓	N/A
14/L2	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
15/L2	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
16/L2	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
17/L2	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider]
 Designation: DB CL11/6
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 6/L2)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 34.5 ms
 Zs 0.42 Ω No. of poles 2 30mA or below
 Ipf 0.55 kA IΔn 30 Operating at 5 IΔn 18.4 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L2	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider]
 Designation: DB CL11/7
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 7/L2)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms
 Z_s 0.42 Ω No. of poles 2 30mA or below
 I_{pf} 0.57 kA IΔn 30 Operating at 5 IΔn 20.6 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	r _n	r2		R1 + R2	R2											
1/L2	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Room 7 Riser [Schneider] Designation: DB CL11/8 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Supply to distribution board is from: Sub Mains (DB CL11, 8/L2) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V	Associated RCD (if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 24.2 ms Zs 0.38 Ω No. of poles 2 30mA or below Ipr 0.61 kA IΔn 30 Operating at 5 IΔn 16.8 ms Time delay (if applicable) N/A	Loop impedance 080408/5756 Insulation resistance 080408/5756 Continuity 080408/5756 RCD 080408/5756

CIRCUIT DETAILS	TEST RESULTS
-----------------	--------------

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)		
														r1	rn	r2												R1 + R2	R2
1/L2	Room 7 Riser	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name Company Address Postcode Branch No. Scheme No.
 Client Installation Address Postcode

Distribution board details - Complete in every case
 Location
 Designation
 Num. of ways Num. of phases
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from
 Overcurrent protective device for the distribution circuit: Type Rating A Voltage V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn ms
 Z_s Ω No. of poles 30mA or below
 I_{pr} kA IΔn Operating at 5 IΔn ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance
 Insulation resistance
 Continuity
 RCD

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	80%		80%	80%	80%				80%	80%															
1/L2	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case Location: Room 5 Riser [Schneider] Designation: DB CL11/6-2 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains (DB CL11, 6/L2) Overcurrent protective device for the distribution circuit: Type: BS(EN) Rating: A Voltage: V		Characteristics at this distribution board Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn: 34.5 ms Above 30mA (if applicable) Z _s : 0.42 Ω No. of poles: 2 30mA or below I _{pf} : 0.55 kA IΔn: 30 Operating at 5 IΔn: 18.4 ms Time delay (if applicable): N/A		Test instrument serial number(s) Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756	
--	--	--	--	--	--	---	--

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L2	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.50	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022
 Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider]
 Designation: DB CL11/7-1
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: BS(EN) Rating: A Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61009 Operating at 1 IΔn: 28.8 ms Above 30mA (if applicable)
 Z_s: 0.42 Ω No. of poles: 2 30mA or below
 I_{pr}: 0.57 kA IΔn: 30 Operating at 5 IΔn: 20.6 ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	rn	r2		R1 + R2	R2											
					80%	80%		80%	80%	80%				80%	80%															
1/L2	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.50	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 6 Riser [Schneider] | Designation: DB CL11/7-2 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.8 ms (Above 30mA) | 30mA or below: 20.6 ms (if applicable)
 Z_s: 0.42 Ω | No. of poles: 2 | I_{pn}: 0.57 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L2	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider]
 Designation: DB CL11/8-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 8/L2)
 Overcurrent protective device for the distribution circuit: Type: | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 24.2 ms (Above 30mA) | 30mA or below: 16.8 ms (if applicable)
 Z_s: 0.38 Ω | No. of poles: 2 | I_{pr}: 0.61 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5657
 Insulation resistance: 080408/5657
 Continuity: 080408/5657
 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 8 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Flat 10 Kitchen [Schneider]
 Designation: DB CL10
 Num. of ways: 18 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 2, 14/L1)
 Overcurrent protective device for the distribution circuit: Type: gG | Rating: 63 A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Above 30mA (if applicable): N/A ms
 Operating at 1 IΔn: N/A | 30mA or below: N/A ms
 Operating at 5 IΔn: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 dteak (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	APDD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.56	20.4	19.8	✓	N/A
2/L1	Lighting Room 1,2	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.52	34.6	25.4	✓	N/A
3/L1	Lighting Room 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.61	28.5	18.8	✓	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	Sub Mains(DB CL10/5-1, DB CL10/5)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.29	0.27	0.31	N/A	0.15	N/A	250	LIM	>299	✓	0.34	22.4	19.8	✓	N/A
6/L1	Sub Mains(DB CL10/6-2, DB CL10/6, DB CL10/6-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.34	0.34	0.40	N/A	0.19	N/A	250	LIM	>299	✓	0.45	25.4	18.2	✓	N/A
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	Common Room Ring 1	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.41	0.37	0.48	N/A	0.23	N/A	250	LIM	>299	✓	0.46	29.4	24.2	✓	N/A
9/L1	Common Room Ring 2	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.38	0.35	0.42	N/A	0.20	N/A	250	LIM	>299	✓	0.40	18.4	14.0	✓	N/A
10/L1	Hob	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.39	32.6	18.6	✓	N/A
11/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider]
 Designation: DB CL10/5
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL10, 5/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 22.4 ms (Above 30mA)
 Zs: 0.34 Ω | No. of poles: 2 | 30mA or below
 Ipr: 0.68 kA | IΔn: 30 | Operating at 5 IΔn: 19.8 ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.45	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/
EICR 110148205

for Industrial/Commercial Premises



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case Location <input type="text" value="Room 3 Riser [Schneider]"/> Designation <input type="text" value="DB CL10/6"/> Num. of ways <input type="text" value="4"/> Num. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from <input type="text" value="Sub Mains(DB CL10, 6/L1)"/> Overcurrent protective device for the distribution circuit: Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="V"/>	Characteristics at this distribution board Associated RCD(if any): BS (EN) <input type="text" value="61009"/> Above 30mA (if applicable) Operating at 1 IΔn <input type="text" value="25.4"/> ms Zs <input type="text" value="0.45"/> Ω No. of poles <input type="text" value="2"/> 30mA or below Ipr <input type="text" value="0.51"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="18.2"/> ms Time delay (if applicable) <input type="text" value="N/A"/>	Test instrument serial number(s) Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>
--	--	--	---

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)						
														r1	rn	r2												R1 + R2	R2				
1/L1	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.37	N/A	N/A	N/A	N/A	N/A	N/A			
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

Signature

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider] | Designation: DB CL10/5-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL10, 5/L1)
 Overcurrent protective device for the distribution circuit: Type: | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 22.4 ms (Above 30mA) | 30mA or below: 19.8 ms (if applicable)
 Z_s: 0.34 Ω | No. of poles: 2 | I_{pn}: 0.68 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L1	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider]
 Designation: DB CL10/6-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL10, 6/L1)
 Overcurrent protective device for the distribution circuit: Type: | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 25.4 ms (Above 30mA) | 30mA or below: 18.2 ms (if applicable)
 Z_s: 0.45 Ω | No. of poles: 2 | I_{pn}: 0.51 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L1	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location: Room 5 Riser [Schneider]	Designation: DB CL10/6-2	Supply to distribution board is from: Sub Mains(DB CL10, 6/L1)	Overcurrent protective device for the distribution circuit: Type: BS(EN) Rating: A Voltage: V	Associated RCD(if any): BS (EN) 61009	Operating at 1 IΔn: 25.4 ms	Loop impedance: 080408/5756	Insulation resistance: 080408/5756
Num. of ways: 4	Num. of phases: 1	Overcurrent protective device for the distribution circuit: Type: BS(EN) Rating: A Voltage: V		Z _s : 0.45 Ω	No. of poles: 2	Continuity: 080408/5756	RCD: 080408/5756
Supply polarity confirmed: <input type="checkbox"/>	Phase sequence confirmed: <input type="checkbox"/>			I _{pf} : 0.51 kA	IΔn: 30		
					Operating at 5 IΔn: 18.2 ms		
					Time delay (if applicable):		

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location	Flat 9 Kitchen [Schneider]	Supply to distribution board is from	Associated RCD(if any): BS (EN)		Above 30mA (if applicable)		Loop impedance
Designation	DB CL9	Sub Mains(BB 1, 14/L2)	N/A		Operating at 1 IΔn		Insulation resistance
Num. of ways	18	Overcurrent protective device for the distribution circuit: Type	BS(EN) 88-2 HRC		30mA or below		Continuity
Supply polarity confirmed	<input checked="" type="checkbox"/>	Rating	gG 63 A		Operating at 5 IΔn		RCD
Phase sequence confirmed	<input type="checkbox"/>	Voltage			Time delay (if applicable)		080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	rn	r2										Fig 8 (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2	V	M(Ω)	M(Ω)										
1/L2	Common room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.43		250	LIM	>299	✓	0.70	42.4	24.0	✓	N/A
2/L2	Lighting Rooms 8,9,10	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38		250	LIM	>299	✓	0.65	36.4	22.4	✓	N/A
3/L2	Lighting Rooms 3,5,7	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52		250	LIM	>299	✓	0.75	30.8	18.0	✓	N/A
4/L2	Lighting Rooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.46		250	LIM	>299	✓	0.70	36.2	20.4	✓	N/A
5/L2	Lighting 4,6	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38		250	LIM	>299	✓	0.64	28.4	16.4	✓	N/A
6/L2	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
7/L2	Sub Mains(DB CL9/7-2, DB CL9/7, DB CL9/7-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.42	0.42	0.55	N/A	0.24		250	LIM	>299	✓	0.49	22.5	19.8	✓	N/A
8/L2	Sub Mains(DB CL9/8-2, DB CL9/8, DB CL9/8-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.39	0.39	0.53	N/A	0.23		250	LIM	>299	✓	0.46	30.4	22.1	✓	N/A
9/L2	Sub Mains(DB CL9/9-1, DB CL9/9)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.28	0.28	0.34	N/A	0.16		250	LIM	>299	✓	0.37	28.4	14.4	✓	N/A
10/L2	Sub Mains(DB CL9/10-1, DB CL9/10)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.24	0.24	0.35	N/A	0.15		250	LIM	>299	✓	0.35	32.4	18.6	✓	N/A
11/L2	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
12/L2	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
13/L2	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
14/L2	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
15/L2	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
16/L2	SPARE													N/A	N/A	N/A	N/A										N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS															TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA 1Δn ms	30mA or below 5 1Δn ms	RCD (✓)	AFDD (✓)		
	r1													m	r2	R1 + R2												R2	
17/L2	SPARE												N/A	N/A	N/A	N/A											N/A	N/A	
18/L2	SPARE												N/A	N/A	N/A	N/A												N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
Location: Room 8 Riser [Schneider]
Designation: DB CL9/7
Num. of ways: 4 Num. of phases: 1
Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
Supply to distribution board is from: Sub Mains (DB CL9, 7/L2)
Overcurrent protective device for the distribution circuit: Type: C Rating: 32 A Voltage: V

Characteristics at this distribution board
Associated RCD (if any): BS (EN) 61009 Operating at 1 IΔn: 22.5 ms (if applicable) Above 30mA
Zs: 0.49 Ω No. of poles: 2 30mA or below
Ipf: 0.47 kA IΔn: 30 Operating at 5 IΔn: 19.8 ms
Time delay (if applicable):

Test instrument serial number(s)
Loop impedance: 080408/5756
Insulation resistance: 080408/5756
Continuity: 080408/5756
RCD: 080408/5756

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL9/7 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)		
														r1	r2	r2												R1 + R2	R2
1/L2	Room 8 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.51	N/A	N/A	N/A	N/A	
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 05/07/2022 To 05/07/2022 Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location Room 9 Riser [Schneider]	Designation DB CL9/7-1	Supply to distribution board is from Sub Mains(DB CL9, 7/L2)	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V	Associated RCD(if any): BS (EN) 61009	Operating at 1 IΔn 22.5 ms	Loop impedance 080408/5756	Insulation resistance 080408/5756
Num. of ways 4	Num. of phases 1	BS(EN) 61009 RCD/RCBO		Zs 0.49 Ω	No. of poles 2	Continuity 080408/5756	RCD 080408/5756
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>			Ipf 0.47 kA	IΔn 30		
					Operating at 5 IΔn 19.8 ms		
					Time delay (if applicable)		

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r2	r2												R1 + R2	R2	
					80%	r1	r2	r2	R1 + R2	R2				V	M(Ω)	M(Ω)	(✓)	(✓)	(✓)											
1/L2	Room 9 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 10 Riser [Schneider]
 Designation: DB CL9/7-2
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL9, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61009 | Operating at 1 IΔn: 22.5 ms (Above 30mA)
 Zs: 0.49 Ω | No. of poles: 2 | 30mA or below
 Ipr: 0.47 kA | IΔn: 30 | Operating at 5 IΔn: 19.8 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)				
														r1	rn	r2												R1 + R2	R2		
1/L2	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A	N/A	N/A	
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schneider]
 Designation: DB CL9/8
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL9, 8/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 30.4 ms (Above 30mA)
 Z_s: 0.46 Ω | No. of poles: 2 | 30mA or below
 I_{pr}: 0.50 kA | IΔn: 30 | Operating at 5 IΔn: 22.1 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)		
														r1	r _n	r2		R1 + R2	R2											
					80%	(Ω)		(V)	(M(Ω))	(M(Ω))				(ms)	(ms)	(ms)	(ms)													
1/L2	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To 05/07/2022 Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 5 Riser [Schneider]
 Designation: DB CL9/8-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL9, 8/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 30.4 ms (Above 30mA) | 22.1 ms (30mA or below)
 Z_s: 0.46 Ω | No. of poles: 2 | I_{pn}: 0.50 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case			Complete only if the distribution board is not connected directly to the origin of the installation			Characteristics at this distribution board			Test instrument serial number(s)			
Location	Room 7 Riser [Schneider]		Supply to distribution board is from	Sub Mains(DB CL9, 8/L2)		Associated RCD(if any): BS (EN)	61009		Above 30mA (if applicable)	Loop impedance		
Designation	DB CL9/8-2		Overcurrent protective device for the distribution circuit: Type	C		Operating at 1 IΔn	30.4		ms	Insulation resistance		
Num. of ways	4		Rating	32		No. of poles	2		30mA or below	Continuity		
Num. of phases	1		Voltage			I _{pr}	0.50		Operating at 5 IΔn	RCD		
Supply polarity confirmed	<input checked="" type="checkbox"/>					Time delay (if applicable)						

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
					80%	80%	80%	80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%
1/L2	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider]
 Designation: DB CL9/9
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL9, 9/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.4 ms (Above 30mA) | 14.4 ms (30mA or below)
 Zs: 0.37 Ω | No. of poles: 2 | Ipf: 0.62 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.49	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider]
 Designation: DB CL9/9-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL9, 9/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61009 | Operating at 1 IΔn: 28.4 ms (Above 30mA)
 Zs: 0.37 Ω | No. of poles: 2 | 30mA or below
 Ipr: 0.62 kA | IΔn: 30 | Operating at 5 IΔn: 14.4 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
1/L2	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider] | Designation: DB CL9/10 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL9, 10/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 32.4 ms (Above 30mA) | 18.6 ms (30mA or below)
 Z_s: 0.35 Ω | No. of poles: 2 | I_{pn}: 0.66 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L2	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 6 Riser [Schneider] | Designation: DB CL9/10-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL9, 10/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 32.4 ms (Above 30mA) | 18.6 ms (30mA or below)
 Zs: 0.35 Ω | No. of poles: 2 | Ipf: 0.66 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L2	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Flat 14 Kitchen [Schneider]
 Designation: DB CL14
 Num. of ways: 18 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 2, 19/L3)
 Overcurrent protective device for the distribution circuit: Type: gG | Rating: 63 A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Above 30mA (if applicable): N/A ms
 Operating at 1 IΔn: N/A | 30mA or below: N/A ms
 Zs: 0.22 Ω | No. of poles: N/A
 Ipr: 1.1 kA | IΔn: N/A | Operating at 5 IΔn: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)		
														r1	rn	r2										Fig 8 check (✓)	R1 + R2
					All circuits to be completed using R1R2 or R2, not both																						
1/L3	Common Room Ring	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.30	250	LIM	>299	✓	0.55	21.4	16.2	✓	N/A
2/L3	Lighting Room 1,3,5	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.36	250	LIM	>299	✓	0.58	22.5	18.4	✓	N/A
3/L3	Lighting Room 2,4,6	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.41	250	LIM	>299	✓	0.46	28.4	14.4	✓	N/A
4/L3	Lighting Room 7,8	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.39	250	LIM	>299	✓	0.71	24.4	12.5	✓	N/A
5/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A
6/L3	Sub Mains(DB CL14/6-2, DB CL14/6, DB CL14/6-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.32	0.32	0.40	N/A	0.18	250	LIM	>299	✓	0.38	29.2	20.0	✓	N/A
7/L3	Sub Mains(DB CL14/7-2, DB CL14/7, DB CL14/7-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.35	0.35	0.44	N/A	0.20	250	LIM	>299	✓	0.44	32.4	18.2	✓	N/A
8/L3	Sub Mains(DB CL14/8-1, DB CL14/8)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.25	0.25	0.32	N/A	0.14	250	LIM	>299	✓	0.37	29.4	14.4	✓	N/A
9/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A
10/L3	Common Room Rong	A	B	4	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.44	0.42	0.51	N/A	0.24	250	LIM	>299	✓	0.44	23.4	12.2	✓	N/A
11/L3	Common Room Ring 2	A	B	4	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.39	0.42	0.48	N/A	0.22	250	LIM	>299	✓	0.50	32.2	16.4	✓	N/A
12/L3	Hob 1	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.11	250	LIM	>299	✓	0.37	30.8	20.8	✓	N/A
13/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A
14/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A
15/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A
16/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A
17/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR

110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS												TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
	DB CL14				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
	Circuit designation													r1	m	r2											
18/L3	SPARE												N/A	N/A	N/A	N/A						N/A	N/A				

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider] | Designation: DB CL14/6 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL14, 6/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 29.2 ms | Above 30mA (if applicable)
 Z_s: 0.38 Ω | No. of poles: 2 | 30mA or below
 I_{pr}: 0.61 kA | IΔn: 30 | Operating at 5 IΔn: 20.0 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)				
														r1	r _n	r2												R1 + R2	R2		
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)											
1/L3	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schneider] | Designation: DB CL14/6-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL14, 6/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 29.2 ms (Above 30mA) | 30mA or below: 20.0 ms (if applicable)
 Zs: 0.38 Ω | No. of poles: 2 | Ipf: 0.61 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L3	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.51	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name <input type="text" value="PHS Compliance"/>	Company Address <input type="text" value="Kid Glove Road"/>	Postcode <input type="text" value="WA3 3GR"/>	Branch No. <input type="text"/>	Scheme No. <input type="text"/>
Client <input type="text" value="UPP Residential Services Ltd"/>	Installation Address <input type="text" value="Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea"/>	Postcode <input type="text" value="SA1 8EN"/>		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location <input type="text" value="Room 5 Riser [Schneider]"/> Designation <input type="text" value="DB CL14/6-2"/> Num. of ways <input type="text" value="4"/> Num. of phases <input type="text" value="1"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Supply to distribution board is from <input type="text" value="Sub Mains(DB CL14, 6/L3)"/> Overcurrent protective device for the distribution circuit: BS(EN) <input type="text" value="61009 RCD/RCBO"/> Type <input type="text" value="C"/> Rating <input type="text" value="32"/> A Voltage <input type="text" value="V"/>	Associated RCD(if any): BS (EN) <input type="text" value="61009"/> Operating at 1 IΔn <input type="text" value="29.2"/> ms Above 30mA (if applicable) Zs <input type="text" value="0.38"/> Ω No. of poles <input type="text" value="2"/> 30mA or below Ipf <input type="text" value="0.61"/> kA IΔn <input type="text" value="30"/> Operating at 5 IΔn <input type="text" value="20.0"/> ms Time delay (if applicable) <input type="text"/>	Loop impedance <input type="text" value="080408/5756"/> Insulation resistance <input type="text" value="080408/5756"/> Continuity <input type="text" value="080408/5756"/> RCD <input type="text" value="080408/5756"/>

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)			
														r1	rn	r2		R1 + R2	R2												
1/L3	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location: Room 2 Riser [Schneider]	Designation: DB CL14/7	Supply to distribution board is from: Sub Mains(DB CL14, 7/L3)	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V	Associated RCD(if any): BS (EN) 61009	Operating at 1 IΔn: 29.2 ms	Loop impedance: 080408/5756	Insulation resistance: 080408/5756
Num. of ways: 4	Num. of phases: 1	BS(EN) 61009 RCD/RCBO		Zs: 0.44 Ω	No. of poles: 2	Continuity: 080408/5756	RCD: 080408/5756
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>			Ipf: 0.52 kA	IΔn: 30		
				Time delay (if applicable)			

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL14/7	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L3	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 05/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider]
 Designation: DB CL14/7-1
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(DB CL14, 7/L3)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61009 Above 30mA (if applicable) Operating at 1 IΔn 29.2 ms
 Z_s 0.44 Ω No. of poles 2 30mA or below
 I_{pr} 0.52 kA IΔn 30 Operating at 5 IΔn 20.0 ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														r1	r _n	r2		R1 + R2	R2									
1/L3	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 6 Riser [Schneider] | Designation: DB CL14/7-2 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL14, 7/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 29.2 ms (Above 30mA) | 30mA or below: 20.0 ms (if applicable)
 Z_s: 0.44 Ω | No. of poles: 2 | I_{pn}: 0.52 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
					80%	(Ω)		(V)	(M(Ω))	(M(Ω))				(ms)	(ms)	(✓)	(✓)													
1/L3	Room 6 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name Company Address Postcode Branch No. Scheme No.
 Client Installation Address Postcode

Distribution board details - Complete in every case
 Location
 Designation
 Num. of ways Num. of phases
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from
 Overcurrent protective device for the distribution circuit: Type Rating A Voltage V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn ms
 Z_s Ω No. of poles 30mA or below
 I_{pn} kA IΔn Operating at 5 IΔn ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance
 Insulation resistance
 Continuity
 RCD

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)		
														r1	r _n	r2												R1 + R2	R2
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)									
1/L3	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider]
 Designation: DB CL14/8-1
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL14, 8/L3)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 Operating at 1 IΔn Above 30mA (if applicable) 29.2 ms
 Zs 0.37 Ω No. of poles 2 30mA or below
 Ipr 0.62 kA IΔn 30 Operating at 5 IΔn 20.0 ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)
														r1	rn	r2		R1 + R2	R2									
					80%	80%		80%	80%	80%				80%	80%													
1/L3	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 13 Kitchen [Schneider]	Supply to distribution board is from: Sub Mains(BB 1, 15/L3)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: DB CL13	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V	Operating at 1 IΔn: N/A ms	Insulation resistance: 080408/5756
Num. of ways: 18 Num. of phases: 1		No. of poles: N/A	Continuity: 080408/5756
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 080408/5756
		Time delay (if applicable): N/A	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			APDD (✓)				
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2	
					All circuits to be completed using R1R2 or R2, not both																								
1/L3	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.53	N/A	250	LIM	>299	✓	0.75	28.2	20.2	✓	N/A	
2/L3	Lighting Room 1,2	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.70	30.0	18.2	✓	N/A	
3/L3	Lighting Rooms 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.56	N/A	250	LIM	>299	✓	0.76	24.4	16.6	✓	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/L3	Isolated	A	B	LIM	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	LIM	N/A
6/L3	Isolated	A	B	LIM	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	LIM	N/A
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L3	Common Room Ring	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.28	0.28	0.33	N/A	0.15	N/A	250	LIM	>299	✓	0.36	19.8	14.4	✓	N/A	
9/L3	Common Room Ring 2	A	B	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.32	0.32	0.45	N/A	0.19	N/A	250	LIM	>299	✓	0.40	22.4	20.0	✓	N/A	
10/L3	Hob	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.35	28.4	25.4	✓	N/A	
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:	
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN			

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 12 Kitchen [Schneider]	Supply to distribution board is from: Sub Mains(BB 1, 18/L1)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: DB CL12	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V	Operating at 1 IΔn: N/A ms	Insulation resistance: 080408/5756
Num. of ways: 18	BS(EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 080408/5756
Supply polarity confirmed: <input checked="" type="checkbox"/>		Time delay (if applicable): N/A	RCD: 080408/5756

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn	30mA or below 5 IΔn	RCD (✓)			APDD (✓)				
														r1	rn	r2										Fig 8 (✓)	R1 + R2	R2	
																		V	M(Ω)	M(Ω)	ms	ms							
1/L1	Common Room Lights	A	B	9	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.56	32.2	22.4	✓	N/A	
2/L1	Lighting Room 8,9,10	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.60	30.4	20.2	✓	N/A	
3/L1	Lighting Room 3,5,7	A	B	12	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.36	N/A	250	LIM	>299	✓	0.59	29.2	18.4	✓	N/A	
4/L1	Lighting Room 1,2	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.59	31.4	22.4	✓	N/A	
5/L1	Lighting Room 4,6	A	B	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.60	33.6	20.4	✓	N/A	
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	Sub Mains(DB CL12/7-2, DB CL12/7, DB CL12/7-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.30	0.30	0.38	N/A	0.17	N/A	250	LIM	>299	✓	0.40	29.4	18.4	✓	N/A	
8/L1	Sub Mains(DB CL12/8-2, DB CL12/8, DB CL12/8-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.35	0.35	0.44	N/A	0.20	N/A	250	LIM	>299	✓	0.41	26.4	20.2	✓	N/A	
9/L1	Sub Mains(DB CL12/9-1, DB CL12/9)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.29	0.29	0.39	N/A	0.17	N/A	250	LIM	>299	✓	0.39	32.2	18.8	✓	N/A	
10/L1	Sub Mains(DB CL12/10, DB CL12/10-1)	A	B	1	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.26	0.26	0.37	N/A	0.16	N/A	250	LIM	>299	✓	0.42	30.4	16.6	✓	N/A	
11/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L1	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.28	0.28	0.44	N/A	0.18	N/A	250	LIM	>299	✓	0.49	32.5	20.4	✓	N/A	
13/L1	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.34	0.34	0.47	N/A	0.20	N/A	250	LIM	>299	✓	0.43	40.2	18.4	✓	N/A	
14/L1	Hob 2	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.45	36.4	22.4	✓	N/A	
15/L1	Hob1	A	B	1	10	6	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.49	32.5	20.2	✓	N/A	
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR

110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS													TEST RESULTS																			
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
	DB CL12				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)							
	Circuit designation							r1	m	r2				Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both																	
								R1 + R2		R2																						
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location: Room 9 Riser [Schneider]	Designation: DB CL12/7-1	Supply to distribution board is from: Sub Mains(DB CL12, 7/L1)	Overcurrent protective device for the distribution circuit: Type: BS(EN) Rating: A Voltage: V	Associated RCD(if any): BS (EN) 61009	Operating at 1 IΔn: 29.4 ms	Loop impedance: 080408/5756	Insulation resistance: 080408/5756
Num. of ways: 4	Num. of phases: 1			Z _s : 0.40 Ω	No. of poles: 2	Continuity: 080408/5756	RCD: 080408/5756
Supply polarity confirmed: <input checked="" type="checkbox"/>	Phase sequence confirmed: <input type="checkbox"/>			I _{pf} : 0.57 kA	IΔn: 30		
					Operating at 5 IΔn: 18.4 ms		
					Time delay (if applicable):		

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
					80%																							
1/L1	Room 9 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case Location: Room 10 Riser [Schneider] Designation: DB CL12/7-2 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains(DB CL12, 7/L1) Overcurrent protective device for the distribution circuit: Type: BS(EN) Rating: A Voltage: V	Characteristics at this distribution board Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn ms Z _s Ω No. of poles 30mA or below I _{pf} kA IΔn Operating at 5 IΔn ms Time delay (if applicable) ms	Test instrument serial number(s) Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756
--	--	--	---

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL12/7-2 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation						
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)						
														r1	r _n	r2												R1 + R2	R2				
1/L1	Room 10 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 05/07/2022 To 05/07/2022 Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 05/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider] | Designation: DB CL12/8 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL12, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: BS(EN) | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) | Operating at 1 IΔn: | ms | Above 30mA (if applicable)
 Z_s: 0.41 Ω | No. of poles: | 30mA or below
 I_{pf}: 0.56 kA | IΔn: | Operating at 5 IΔn: | ms
 Time delay (if applicable): |

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation			
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	rn	r2												R1 + R2	R2	
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)										
1/L1	Room 3 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.54	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR **110148205**



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location: Room 5 Riser [Schneider]	Designation: DB CL12/8-1	Supply to distribution board is from: Sub Mains(DB CL12, 8/L1)	Overcurrent protective device for the distribution circuit: Type: BS(EN) Rating: A Voltage: V	Associated RCD(if any): BS (EN) Operating at 1 IΔn ms	Z _s 0.41 Ω No. of poles	Loop impedance: 080408/5756	Insulation resistance: 080408/5756
Num. of ways: 4	Num. of phases: 1			I _{pn} 0.56 kA IΔn ms	Time delay (if applicable)	Continuity: 080408/5756	RCD: 080408/5756
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>						

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Room 5 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 7 Riser [Schneider] | Designation: DB CL12/8-2 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL12, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: BS(EN) | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Operating at 1 IΔn: | ms | Above 30mA (if applicable)
 Z_s: 0.41 Ω | No. of poles: | 30mA or below
 I_{pn}: 0.56 kA | IΔn: | Operating at 5 IΔn: | ms
 Time delay (if applicable): |

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
					80%	r1		rn	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)								
1/L1	Room 7 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider] | Designation: DB CL12/9 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL12, 9/L1)
 Overcurrent protective device for the distribution circuit: Type: BS(EN) | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Operating at 1 IΔn: | ms | Above 30mA (if applicable)
 Zs: 0.39 Ω | No. of poles: | 30mA or below
 Ipf: 0.59 kA | IΔn: | Operating at 5 IΔn: | ms
 Time delay (if applicable): |

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Room 1 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.	
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea				Postcode	SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Room 2 Riser [Schneider] Designation: DB CL12/9-1 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>	Supply to distribution board is from: Sub Mains (DB CL12, 9/L1) Overcurrent protective device for the distribution circuit: Type: BS(EN) [] Rating: [] A Voltage: [] V	Associated RCD(if any): BS (EN) [] Operating at 1 IΔn [] ms Above 30mA (if applicable) 30mA or below I _{pf} 0.59 kA IΔn [] Operating at 5 IΔn [] ms Time delay (if applicable) []	Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756

CIRCUIT DETAILS														TEST RESULTS																			
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)						
														r1	r2	r2												R1 + R2	R2				
					Circuit designation																												
1/L1	Room 2 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider] | Designation: DB CL12/10 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL12, 10/L1)
 Overcurrent protective device for the distribution circuit: Type: BS(EN) | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Operating at 1 IΔn: | ms | Above 30mA (if applicable)
 Z_s: 0.42 Ω | No. of poles: | 30mA or below
 I_{pf}: 0.54 kA | IΔn: | Operating at 5 IΔn: | ms
 Time delay (if applicable): |

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	r _n	r2												R1 + R2
					80%	r1		r _n	r2	(✓)				R1 + R2	R2	V	M(Ω)	M(Ω)	(✓)	(✓)								
1/L1	Room 4 Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location Plant Room [Schneider]	Designation DB PL	Supply to distribution board is from Sub Mains(BB 2, 18/TP)	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V	Associated RCD(if any): BS (EN)	Operating at 1 IΔn Above 30mA (if applicable) ms	Loop impedance 080408/5657	Insulation resistance 080408/5657
Num. of ways 24	Num. of phases 3	BS(EN) 88-2 HRC		Z _s 0.18 Ω No. of poles	Operating at 5 IΔn 30mA or below (if applicable) ms	Continuity 080408/5657	RCD 080408/5657
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>			I _{pr} kA IΔn N/A	Time delay (if applicable)		

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			APDD (✓)				
					r1	rn		r2	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both				R1+R2	R2														
1/L1	Ext Fan 1	D	B	1	2.5	2.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	32.5	18.4	✓	N/A	
1/L2	Ext Fan 2	D	B	1	2.5	2.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	34.6	22.6	✓	N/A	
1/L3	Ext Fan 3	D	B	1	2.5	2.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	26.4	18.4	✓	N/A	
2/L1	Ext Fan 4	D	B	1	2.5	2.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	28.4	20.4	✓	N/A	
2/L2	Isolated	D	B	LIM	2.5	2.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A	
2/L3	Ext Fan 6	D	B	1	2.5	2.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	32.2	20.2	✓	N/A	
3/L1	Ext Fan 7	D	B	1	2.5	2.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	30.6	22.6	✓	N/A	
3/L2	Ext Fan 8	D	B	1	2.5	2.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	38.4	18.4	✓	N/A	
3/L3	Ext Fan 9	D	B	1	2.5	2.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	32.6	20.4	✓	N/A	
4/L1	Ext Fan 10	D	B	1	2.5	2.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	36.8	18.4	✓	N/A	
4/L2	Ext Fan 11	D	B	1	2.5	2.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	25.6	19.8	✓	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	Plant ring	D	B	4	2x2.5	2x2.5	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	✓	LIM	29.8	20.4	✓	N/A	
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	FA Interface	O	B	1	2.5	2.5	0.4	60898 MCB	B	6	10	N/A	5.82	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.44	N/A	N/A	N/A	N/A	
6/L2	Plant Room Lights	D	B	4	1.5	1.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.32	N/A	250	LIM	>299	✓	0.62	32.2	18.8	✓	N/A	
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																									
Circuit No. and Line No.	Distribution board Designation		Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation											
	DB PL	Circuit designation				L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)										
						r1	m		r2	R1 + R2	R2																												
7/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				
8/TP	Sub Mains(DB Mech)		A	B	1	10	6	0.4	60898 MCB	C	32	10	N/A	0.54	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A					
9/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				
10/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
11/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
12/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
13/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
14/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
15/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
16/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
19/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
20/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
21/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
22/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
23/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24/TP	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:		
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN				
Distribution board details - Complete in every case Location: Plant Room Roof [Schneider] Designation: DB Mech Num. of ways: 6 Num. of phases: 3 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains (DB PL, 8/TP) Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V			Characteristics at this distribution board Associated RCD (if any): BS (EN) Above 30mA (if applicable) N/A ms Operating at 1 IΔn 30mA or below Z _s 0.24 Ω No. of poles N/A I _{pr} 2.02 kA IΔn N/A ms Operating at 5 IΔn ms Time delay (if applicable) N/A	Test instrument serial number(s) Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Z _s Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)		
														r1	rn	r2												R1 + R2	R2
																									Polarity (✓)	Max. Measured Z _s (Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)
1/L1	Press Unit	O	B	1	1.5	1.5	0.4	60898 MCB	D	4	10	N/A	2.18	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.35	N/A	N/A	N/A	N/A	
1/L2	Boiler 1	O	B	1	1.5	1.5	0.4	60898 MCB	C	4	10	N/A	4.37	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A	
1/L3	Boiler 2	O	B	1	1.5	1.5	0.4	60898 MCB	C	4	10	N/A	4.37	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A	
2/L1	VT Pump 1	O	B	1	1.5	1.5	0.4	60898 MCB	D	4	10	N/A	2.18	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A	
2/L2	Water Heat 1	O	B	1	1.5	1.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A	
2/L3	Water Heat 2	O	B	1	1.5	1.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A	
3/L1	VT Pumo 2	O	B	1	1.5	1.5	0.4	60898 MCB	D	4	10	N/A	2.18	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.31	N/A	N/A	N/A	N/A	
3/L2	Sec Pump	O	B	1	1.5	1.5	0.4	60898 MCB	D	2	10	N/A	4.37	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.26	N/A	N/A	N/A	N/A	
3/L3	Control Pump	O	B	1	10	10	0.4	60898 MCB	C	50	10	N/A	0.35	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.30	N/A	N/A	N/A	N/A	
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 14/07/2022 To 14/07/2022 Date(s) live testing: 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 14/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 12 Riser [Schneider]	Supply to distribution board is from: Sub Mains(BB 1, 19/L2)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 080408/5756
Designation: DB LL2/L	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400/230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 080408/5756
Num. of ways: 12 Num. of phases: 1		30mA or below: N/A ms	Continuity: 080408/5756
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 080408/5756
		Time delay (if applicable): N/A	

CIRCUIT DETAILS													TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDO (✓)				
														r1	r	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
1/L2	Flat 11 corridor	A	B	9	LIM	LIM	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.35	28.4	20.6	✓	N/A	
2/L2	Flat 9 Corridor	A	B	9	LIM	LIM	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.40	18.5	19.4	✓	N/A	
3/L2	Flat 14 Corridor	A	B	9	LIM	LIM	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.37	27.4	27.0	✓	N/A	
4/L2	Flat 12,13 Corridor	A	B	18	LIM	LIM	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.34	28.4	21.4	✓	N/A	
5/L2	Lobby + Stair Lights	A	B	12	LIM	LIM	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.33	22.1	22.5	✓	N/A	
6/L2	Lobby + Stair Lights 2	A	B	12	LIM	LIM	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.38	32.1	20.4	✓	N/A	
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 14/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Flat 12 Riser [Schneider]
 Designation: DB LL2/P
 Num. of ways: 24 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 1, 19/L2)
 Overcurrent protective device for the distribution circuit: Type: gG | Rating: 63 A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) N/A | Operating at 1 IΔn: N/A ms (Above 30mA)
 Zs: LIM Ω | No. of poles: N/A | 30mA or below
 Ipr: LIM kA | IΔn: N/A | Operating at 5 IΔn: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	APCD (✓)	
														r1	rn	r2												R1 + R2
					Circuit designation																							
1/L2	Sockets Corridor 4th Floor	A	B	4	LIM	LIM	0.4	61009 RCD/	C	32	10	30	0.54	LIM	LIM	LIM	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.34	29.2	18.6	✓	N/A
2/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
3/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
4/L2	Corridor 4th Floor East	A	B	4	LIM	LIM	0.4	61009 RCD/	C	32	10	30	0.54	LIM	LIM	LIM	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.39	26.4	22.0	✓	N/A
5/L2	Corridor 4th Floor West	A	B	4	LIM	LIM	0.4	61009 RCD/	C	32	10	30	0.54	LIM	LIM	LIM	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.43	28.8	29.4	✓	N/A
6/L2	Maglock 3rd Floor	A	B	1	LIM	LIM	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	LIM		LIM	LIM	LIM	✓	0.29	28.3	19.2	✓	N/A
7/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
8/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
9/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
10/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
11/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
12/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
13/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
14/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
15/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
16/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
17/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
18/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 14/07/2022 To: 14/07/2022 Date(s) live testing: 14/07/2022 To: 14/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 14/07/2022 | Signature:

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
	DB LL2/P				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Δn ms	30mA or below 5 Δn ms	RCD (✓)	AFDD (✓)		
	Circuit designation													r1	m	r2												R1 + R2	R2
19/L2	SPARE												N/A	N/A	N/A	N/A							N/A	N/A					
20/L2	SPARE												N/A	N/A	N/A	N/A							N/A	N/A					
21/L2	SPARE												N/A	N/A	N/A	N/A							N/A	N/A					
22/L2	SPARE												N/A	N/A	N/A	N/A							N/A	N/A					
23/L2	SPARE												N/A	N/A	N/A	N/A							N/A	N/A					
24/L2	SPARE												N/A	N/A	N/A	N/A							N/A	N/A					

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

Generic Continuation

Agreed limitations and operational limitations:
circuits.

General Conditions of the Electrical Installation:

insulated solid copper cables, BS5467 XLPE steel wire armoured cables, BSEN6491X Single core copper strand single insulated cables.

DB LL2/P & DB LL2/L are tucked behind a pipe in riser cupboard, this is a problem as you cannot gain access into the distribution board to test the Ze, IPF of the DB or even get the cable sizes of the circuits.

Main Earthing bond for water service is located in the mains room and the main earth bonding cable is tight to the service pipe and wired with a 50mm BS6491X green and yellow PVC copper strand cable labelled with a BS951 label appropriately sited and readable.

Nothing over 3 metres in height has been tested due to health and safety precautions, the circuit will be tested to the nearest available point, the items will only be visually inspected.

Please note that the supplementary conductor's box at the top of the test results page is not applicable in most cases as the area fed from the circuits contained within the associated DB do not require supplementary bonding. This version of the Software does not allow N/A to be selected which is the reason for the boxes being ticked. Our software provider has assured us that this box will be omitted in future versions of the software.

Where stop buttons and isolators have been installed the correct operation of these has not been verified.

To comply with Regulation 643.8 of BS 7671 and to verify that RCD devices within this installation will disconnect within 40ms we have maintained the practice of testing at both 1x and 5x the rated residual operating current to provide an indication of the life cycle of the RCD. The reading recorded in the test results box will be 1x the residual operating current as required by the model form of the EICR in BS 7671.

This installation has been designed and installed prior to July 2018. There is no evidence of over voltage protection within the electrical installation, we recommend Type 2 Surge Protective Devices be installed at the origin to reduce the risk of damage to the installation by external transient over voltage's or switching, Reg 534.4.1.1

Remarks:

DB Main Remarks:

8/L3 - FA Panel: O=FP200

DB PL Remarks:

6/L1 - FA Interface: O=FP200

DB Mech Remarks:

1/L1 - Press Unit: O=YY

1/L2 - Boiler 1: O=YY

1/L3 - Boiler 2: O=YY

2/L1 - VT Pump 1: O=YY

2/L2 - Water Heat 1: O=YY

2/L3 - Water Heat 2: O=YY

3/L1 - VT Pumo 2: O=YY

3/L2 - Sec Pump: O=YY

3/L3 - Control Pump: O=Tails from thermosetting SWA