

# **Electrical Installation Condition Report**

## **Requirements for Electrical Installations - BS 7671:2018 (IET Wiring Regulations 18th Edition)**

### Information for recipients:

The purpose of this report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).

The person ordering the report should have received the Original©Report and the inspector should have retained a duplicate.

The Original©Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.

Where the installation incorporates residual current devices (RCDs) there should be a notice at or near the devices stating that they should be tested every 6 months. **For safety reasons it is important that these instructions are followed.**

Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The Inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licencing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.

For items classified in Section K as C1 (“Danger Present”), **the safety of those using the installation is at risk**, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.

For items classified in Section K as C2 (“Potentially Dangerous”), **the safety of those using the installation may be at risk** and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where it has been stated in Section K that an observation requires further investigation code FI the inspection has revealed an apparent deficiency which may result on a code C1 or C2 could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons competent in such work. The recommended date by which the next inspection is due is stated in Section F of the report under ‘Recommendations’ and on label at or near to the consumer unit/distribution board.

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR 110151231

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)

## A. Details of the Installation

Client	UPP Residential Services Ltd	Installation	Swansea University Bay Campus - Dryslwyn 1B & Nest 2
Address	First Floor 12 Arthur Street London	Address	Reception - Ground Floor Tower Information Centre Fabian Way Crymlyn Burrows Swansea West Glamorgan
Postcode	EC4R 9A	Postcode	SA1 8EN

## B. Reason for Producing this Report

*This form is to be used only for reporting on the condition of an existing installation.*

Essential information requested by the client in accordance with the electricity at work regulations 1989

Date(s) on which the inspection and testing were carried out  to

## C. Details of Installation which is the Subject of this Report

Description of premises Domestic  Commercial  Industrial  Other (please specify)

Estimated age of the wiring system  years

Evidence of alterations or addition Yes  No  Not apparent  if 'Yes', estimated  years

Records of installation available Yes  No  Records held by

Date of last inspection  Electrical Installation Certificate No. or previous Inspection Report No.

## D. Extent of Electrical Installation Covered by this Report:

Testing of all sub mains, lighting and power circuits, within the constraints of the agreed limitations.

### Agreed Limitations and Operational Limitations (Regulations 653.2)

Unable to completely isolate the installation. Unable to access the sealed supply device characteristics. Ze and Ip<sub>f</sub> have been taken with all earthing and bonding in place. Insulation resistance testing has been carried out to regulation 643.3.3 on circuits where it was impracticable to disconnect load.

Agreed with: The inspection and testing detailed within this report and accompanying schedule has been carried out in accordance with BS 7671: 2018 (IET Wiring Regulations) amended to 

It should be noted that cables concealed within trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

## E. Summary of the Condition of the Installation

General conditions of the installation (in terms of electrical safety)

Installation Details

Overall assessment of the installation in terms of its suitability for continued use **SATISFACTORY**  **\*UNSATISFACTORY**

\*An UNSATISFACTORY assessment indicates that dangerous (code C1), or potentially dangerous (code C2), Further investigation (code F1) conditions have been identified

## F. Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potential dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further Investigation required' (code F1). Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by  (date)

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR 110151231

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)



## G. Declaration

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company	PHS Compliance	Inspected and tested by	Authorised for issue by
Address	Kid Glove Road, Golborne, Warrington,	Name:	Liam Kimble
		Signature:	
Postcode	WA3 3GR		
Branch No.		Position:	Electrical Test Engineer
Scheme No.		Date:	19/08/2022
			Technical Auditor
			06/10/2022

EICRs are produced by a UKAS accredited inspection body, No. 0433

## H. Schedule(s)

1 schedule(s) of inspection and 224 schedule(s) of test results are attached.  
The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

## I. Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S  TN-C-S  TT  Other  Please specify \_\_\_\_\_

Number & Type of live conductors AC  DC  No. of phases 3 No. of wires 4

**Nature of Supply Parameters (Note: <sup>(1)</sup> by enquiry, <sup>(2)</sup> by enquiry or by measurement)**

Nominal voltage,  $U/U_0^{(1)}$  400/230 v Nominal frequency,  $f^{(1)}$  50 Hz Confirmation of supply polarity

Prospective fault current,  $I_{pf}^{(2)}$  9.4 kA External loop impedance,  $Z_e^{(2)}$  0.05  $\Omega$

Supply Protective Device BS (EN) LIM Type LIM Rated Current LIM A

No. of Additional Supplies N/A

## J. Particulars of Installation Referred to in this Report

**Details of installation Earth Electrode** (where applicable) Type (e.g. rod(s), tape etc) \_\_\_\_\_

Location \_\_\_\_\_ Electrode resistance to earth \_\_\_\_\_  $\Omega$

**Means of Earthing** Distributors facility  Installation Earth Electrode

Maximum Demand (load) LIM Amps \_\_\_\_\_ KVA \_\_\_\_\_

Main Protective Conductors	Material	csa	( <input checked="" type="checkbox"/> ) or Value	( <input checked="" type="checkbox"/> ) or Value
Earthing Conductor	Copper	95	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor	Copper	50	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>

**Main Supply Conductor** Material Copper csa 150 mm<sup>2</sup>

**Main Switch** Location Mains Room Dryslwyn mm<sup>2</sup>

**Fuse/device rating or setting** 315 A Voltage rating 400 V

**If RCD main switch:** Rated residual operating current  $I_{\Delta n}$  N/A mA

BS(EN) 60947-2 MCCB No. of Poles 3 Current Rating 400 A Rated time delay N/A ms Measured operating trip time N/A ms

**(connection / continuity) () or Value**

Water installation   $\Omega$  To structural steel   $\Omega$

Gas installation pipes   $\Omega$  To lightning protection   $\Omega$

Oil installation pipes NA  $\Omega$  Other NA  $\Omega$

## K. Observations

Referring to the attached schedule of inspection and test results, and subject to the limitations at Section D.

- No remedial work required
- The following observations are made

### Explanation of codes

<b>C1</b>	Danger present. Risk of Injury. Immediate remedial action required.
<b>C2</b>	Potentially dangerous. Urgent remedial action required.
<b>C3</b>	Improvement recommended.
<b>FI</b>	Further Investigation required without delay

Item No.	Observations	Code
1	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL23 CCT 9/L3 Regulation: 537.2.4	FI
2	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL23 CCT 8/L3 Regulation: 537.2.4	FI
3	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL22 CCT 8/L3 Regulation: 537.2.4	FI
4	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL22 CCT 9/L3 Regulation: 537.2.4	FI

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)

5	Observation: Ring circuit with conductors of the same size shall have resistance values within 0.05 ohm of each other. Where Twin and earth is used the resistance value differential between live conductors and earth shall be approximately 1.67 times the value of the live readings. Location: DB CL22 CCT 11/L2 Reg 643.2.1	FI
6	Observation: Screws missing from DB cover, cover still secure. Location: DB CL1 Regulation: 416.2.3	C3
7	Observation: A detailed legible diagram, chart or table or equivalent form of information has not been provided in the vicinity of the distribution board indicating type and composition of circuits as well as other relevant information. Location: DB CL5 Regulation: 514.9.1	C3
8	Observation: Trunking lid is missing. Location: DB CL20 Regulation: 521.10.1	C3
9	Observation: No mechanical protection for single insulated cables. Location: DB CL20 Regulation: 521.10.1	C2
10	Observation: Minor Damage to cooker hood light switch Location: CL20 Kitchen Regulation: 416.2.3	C3
11	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL2 CCT 9/L2 Regulation: 537.2.4	FI
12	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL2 CCT 8/L2 Regulation: 537.2.4	FI
13	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL3 CCT 8/L2 Regulation: 537.2.4	FI
14	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL3 CCT 9/L2 Regulation: 537.2.4	FI
15	Observation: Damaged switch Location: Flat 3 Nest Kitchen Regulation: 416.2	C2
16	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL7 CCT 8/L2 Regulation: 537.2.4	FI
17	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL7 CCT 9/L2 Regulation: 537.2.4	FI
18	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL19 CCT 9/L2 Regulation: 537.2.4	FI
19	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL19 CCT 8/L2 Regulation: 537.2.4	FI
20	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL11 CCT 9/L2 Regulation: 537.2.4	FI
21	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL11 CCT 8/L2 Regulation: 537.2.4	FI
22	Observation: No mechanical protection for single insulated cables. 100mm Location: DB LL1 Regulation: 521.10.1	C2
23	Observation: Trunking lid is missing. 100mm T bend Steel Galv (cable coming out of the trunking coiled up) Location: DB LL1 Regulation: 521.10.1	C3
24	Observation: Over rated over current protective device in relation to the current carrying capacity of the connected cables. Location: MDB CCT 9/TP Regulation 433.1.1	C2
25	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL21 CCT 8/L2 Regulation: 537.2.4	FI

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)

26	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL21 CCT 9/L2 Regulation: 537.2.4	FI
27	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL6 CCT 8/L2 Regulation: 537.2.4	FI
28	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL6 CCT 7/L2 Regulation: 537.2.4	FI
29	Observation: All untraced circuits must have their circuit designations verified. Location: DB LL4/P CCT 7/L1 Regulation: 514.8.1	FI
30	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL15 CCT 8/L2 Regulation: 537.2.4	FI
31	Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL15 CCT 9/L2 Regulation: 537.2.4	FI
32	Observations: There is no RCD protection in place as an additional requirement for circuits supplying socket outlets not exceeding 32A . It is recommended that 30mA RCD,s are installed to provide additional protection. Location: DB LL4/P cct's 4L2 and 5L2 Regulation: 411.3.3	C3
33	Observations: There is no RCD protection in place as an additional requirement for circuits supplying socket outlets not exceeding 32A . It is recommended that 30mA RCD,s are installed to provide additional protection. Location: DB LL2/P cct's 1L2, 2L2, 3L2, 5L3 and 8L3 Regulation: 411.3.3	C3
34	Observation: This installation has been designed and installed prior to July 2018. There is no evidence of over voltage protection within the electrical installation, we recommend (Type 1/Type 2) Surge Protective Devices be installed in order to reduce the risk of damage to the installation by external transient over voltage's or switching Location: Origin/Distribution boards Reg 534.4.1.1	C3

One of the following codes, as appropriate, has been allocated to each of the observations made above and/or any attached observation sheets to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

<b>C1</b> Danger present. Risk of Injury. Immediate remedial action required.	0
<b>C2</b> Potentially dangerous. Urgent remedial action required.	4
<b>C3</b> Improvement recommended.	8
<b>FI</b> Further Investigation required without delay	22

The above values are a total count of Observation per outcome

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671:2018+A2:2022 (IET Wiring Regulations 18<sup>th</sup> Edition)

**Outcomes**

Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further Investigation:	Not Verified:	Limitation:	Not Applicable:
	or					

Item No.	Description	Outcome
<b>1.0 External Condition Of Intake Equipment (Visual Inspection Only) Where inadequacies are encountered, it is recommended that the person ordering the report informs the appropriate authority</b>		
1.1	Service cable	
1.2	Service head	
1.3	Earthing arrangement	
1.4	Meter tails	
1.5	Metering equipment	
1.6	Isolator (where present)	
<b>2.0 Parallel Or Switched Alternative Sources Of Supply</b>		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	
<b>3.0 Automatic Disconnection Of Supply</b>		
3.1	Main earthing/bonding arrangements (411.3; Chap 54)	
3.1.1	Presence of distributors earthing arrangement (542.1.2.1; 542.1.2.2)	
3.1.2	Presence of installation earth electrode arrangement (542.1.2.3)	
3.1.3	Adequacy of earthing conductor size (542.3; 543.1.1)	
3.1.4	Adequacy of earthing conductor connections (542.3.2)	
3.1.5	Accessibility of earthing conductor connections (543.3.2)	
3.1.6	Adequacy of main protective bonding conductor sizes (544.1)	
3.1.7	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	
3.1.8	Accessibility of all protective bonding connections (543.3.2)	
3.1.9	Provision of earthing/bonding labels at all appropriate locations (514.13)	
3.2	FELV - requirements satisfied (411.7; 411.7.1)	
<b>4.0 Other Methods Of Protection (Where any of the methods listed below are employed details should be provided on separate sheets)</b>		
4.1	Non-conducting location (418.1)	
4.2	Earth-free local equipotential bonding (418.2)	
4.3	Electrical separation (Section 413; 418.3)	
4.4	Double insulation (Section 412)	
4.5	Reinforced insulation (Section 412)	
<b>5.0 Distribution Equipment</b>		
5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	
5.2	Security of fixing (134.1.1)	
5.3	Condition of insulation of live parts (416.1)	
5.4	Adequacy/security of barriers (416.2)	
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	
5.6	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)	
5.8	Presence and effectiveness of obstacles (417.2)	
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	
5.10	Operation of main switch(es) (functional check) (643.10)	
5.11	Manual operation of circuit-breakers and RCD(s) to prove disconnection (643.10)	
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)	
5.13	RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2)	
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBO(s) (411.3.3; 415.1)	
5.15	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	
5.17	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	
5.18	Presence of alternative supply warning notice at or near equipment, where required (514.15)	
5.19	Presence of next inspection recommendation label (514.12.1)	
5.2	Presence of other required labelling (please specify) (Section 514)	
5.21	Compatibility of protective device, base and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.4.5; 411.4.6; Sections 432; 433)	
5.22	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	
5.23	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	
5.24	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	
<b>6.0 Distribution Circuits</b>		

for Industrial/Commercial Premises



**Requirements for Electrical Installations  
BS7671:2018+A2:2022 (IET Wiring Regulations 18<sup>th</sup> Edition)**

6.1	Identification of conductors (514.3.1)	FI
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
6.3	Condition of insulation of live parts (416.1)	✓
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. Integrity of containment (521.10.1)	✓
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	✓
6.6	Cables correctly terminated in enclosures (Section 526)	✓
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	✓
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	C2
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	✓
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	✓
<b>6.15</b>	<b>Cables concealed under floors, above ceilings, in walls/partitions less than 50 mm from a surface, and in partitions containing metal parts</b>	
6.15.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202) or	✓
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.204)	✓
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
6.17	Band II cables segregated/separated from Band I cables (528.1)	✓
6.18	Cables segregated/separated from non-electrical services (528.3)	✓
6.19	Condition of circuit accessories (651.2)	✓
6.20	Suitability of circuit accessories for external influences (512.2)	✓
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
6.22	Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/record numbers and locations of items inspected (Section 526)	✓
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; 537)	✓
6.24	General condition of wiring systems (651.2)	✓
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)	✓
<b>7.0 CONSUMER UNIT/DISTRIBUTION BOARD(S)</b>		
7.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1)	✓
7.2	Security of fixing (134.1.1)	C3
7.3	Condition of enclosure(s) in terms of IP rating (Barriers etc) (416.2)	✓
7.4	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	✓
7.5	Enclosure/obstacles not damaged/deteriorated so as to impair safety (651.2)	✓
7.5.1	Presence and effectiveness of obstacles (417.2)	NA
7.6	Presence of main linked switch (as required by 462.1.201)	✓
7.7	Operation of main switch (functional check) (643.10)	✓
7.8	Manual operation of circuit-breakers and RCD(s) (test button) to prove disconnection (643.10)	✓
7.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	FI
7.10	Presence of RCD six-monthly test notice at or near consumer unit/distribution board (514.12.2)	✓
7.11	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	✓
7.12	Presence of alternative supply warning notice at or consumer unit/distribution board (514.15)	✓
7.13	Presence of other required labelling (Please specify) (Section 514)	✓
7.14	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	✓
7.15	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3)	✓
7.16	Protection against mechanical damage where cables enter consumer unit/distribution board (132.14.1; 522.8.1; 522.8.5; 522.8.11)	C3
7.17	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	✓
7.18	RCD(s) provided for fault protection - includes RCBO(s)(411.4.204; 411.5.2; 531.2)	✓
7.19	RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1)	C3
7.20	Confirmation of indication that SPD is functional (651.4)	NA
7.21	Confirmation that ALL conductor connections, including connections to the busbars are correctly located in terminals and are tight and secure (526.1)	✓
7.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	NA
7.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	NA
<b>8.0 FINAL CIRCUITS</b>		
8.1	Identification of conductors (514.3.1)	✓
8.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
8.3	Condition of insulation of live parts (416.1)	✓

8.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	✓
8.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)	C3
8.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
8.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
8.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
8.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	✓
8.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓
8.10	Connected cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	✓
8.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (522.6.204)	✓
<b>8.12</b>	<b>Provision of additional requirements for protection by RCD not exceeding 30 mA:</b>	
8.12.1	For all socket-outlets of rating 32 A or less unless exempt (4.11.3.3)	C3
8.12.2	For the supply of Mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	✓
8.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	✓
8.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	✓
8.12.5	For circuits supplying luminaires within domestic (household) premises (411.3.4)	✓
8.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
8.14	Band II cables segregated/separated from Band I cables (528.1)	✓
8.15	Cables segregated/separated from communications cabling (528.2)	✓
8.16	Cables segregated/separated from non-electrical services (528.3)	✓
<b>8.17</b>	<b>Termination of cables at enclosures - indicate extent of sampling in section d of the report (section 526)</b>	
8.17.1	Connections soundly made and under no undue strain (526.6)	✓
8.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	✓
8.17.3	Connections of live conductors adequately enclosed (526.5)	✓
8.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓
8.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v))	C3
8.19	Suitability of accessories for external influences (512.2)	✓
8.20	Adequacy or working space/accessibility to equipment (132.12; 513.1)	✓
8.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
<b>9.0 ISOLATION AND SWITCHING</b>		
<b>9.1</b>	<b>Isolators (Section 460; 537)</b>	
9.1.1	Presence and condition of appropriate devices (462; 537.2.7)	FI
9.1.2	Acceptable location - state if local or remote from equipment in question (462; 537.2.7)	✓
9.1.3	Capable of being secured in the OFF position (462.3)	✓
9.1.4	Correct operation verified (643.10)	✓
9.1.5	Clearly identified by position and/or durable marking (537.2.6)	✓
9.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	✓
<b>9.2</b>	<b>Switching off for mechanical maintenance (Section 464; 537.3.2)</b>	
9.2.1	Presence and condition of appropriate devices (464.1; 527.3.2)	FI
9.2.2	Acceptable location - state if local or remote from equipment in question (537.3.2.4)	✓
9.2.3	Capable of being secured in the OFF position (462.3)	✓
9.2.4	Correct operation verified (643.10)	✓
9.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	✓
<b>9.3</b>	<b>Emergency switching/stopping (465; 537.3.3)</b>	
9.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	✓
9.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	✓
9.3.3	Correct operation verified (643.10)	✓
9.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	✓
<b>9.4</b>	<b>Functional switching (section 463; 537.3.1)</b>	
9.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	✓
9.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	✓
<b>10.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)</b>		
10.1	Condition of equipment in terms of IP rating etc (416.2)	✓
10.2	Equipment does not constitute a fire hazard (Section 421)	✓
10.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	✓
10.4	Suitability for the environment and external influences (512.2)	✓
10.5	Security of fixing (134.1.1)	✓
10.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	✓
<b>10.7</b>	<b>Recessed luminaires (downlighters)</b>	
10.7.1	Correct type of lamps fitted (559.3.1)	✓
10.7.2	Installed to minimize build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	✓
10.7.3	No signs of overheating to surrounding building fabric (559.4.1)	✓



for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS7671:2018+A2:2022 (IET Wiring Regulations 18<sup>th</sup> Edition)

10.7.4	No signs of overheating to conductors/terminations (526.1)	✓
<b>11.0 PART 7 SPECIAL INSTALLATIONS OR LOCATIONS</b>		
11.01	If any special installations or locations are present, list the particular inspections applied.	✓
11.54	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)	✓
11.55	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	✓
11.56	Shaver supply units comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	✓
11.58	Low voltage (e.g. 230 V) socket-outlets sited at least 2.5 m from zone 1 (701.512.3)	✓
11.59	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	✓
11.60	Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	✓
11.61	Suitability of current-using equipment for particular position within the location (701.55)	✓


**12.0 Schedule of Tests** Results to be recorded on Schedule of Test Results

12.1	External earth loop impedance, Z <sup>e</sup>	Yes
12.2	Installation earth electrode	N/A
12.3	Prospective fault current, I <sub>p</sub> <sup>f</sup>	Yes
12.4	Continuity of Earth Conductors	Yes
12.5	Continuity of Circuit Protective Conductors	Yes
12.6	Continuity of ring final circuit	Yes
12.7	Continuity of Protective Bonding Conductors	Yes
12.8	Volt drop verified	Yes

12.9	Insulation Resistance between Live Conductors	Yes
12.10	Insulation Resistance between Live Conductors & Earth	Yes
12.11	Polarity (prior to energisation)	Yes
12.12	Polarity (after energisation) including phase sequence	Yes
12.13	Earth Fault Loop Impedance	Yes
12.14	RCDs/RCBOs including selectivity	Yes
12.15	Functional testing of RCD devices	Yes
12.16	Functional testing of AFDD(s) devices	N/A

Inspector's Name:

Date:

Signature: 

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: Mains Room [Schneider]	Supply to distribution board is from		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation: MDB	Overcurrent protective device for the distribution circuit: Type N/A Rating N/A A Voltage 400/230 V		Operating at 1 IΔn ms	
Num. of ways: 12 Num. of phases: 3			30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>			Time delay (if applicable)	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)				
														r1	r <sub>n</sub>	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2														
1/L1	Disabled Alarm	O	B	1	4	4	0.4	60947 MCCB	N/A	20	36	N/A	0.70	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.34	N/A	N/A	N/A	N/A	
1/L2	Fire Alarm	O	B	1	4	4	0.4	60947 MCCB	N/A	20	36	N/A	0.70	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.39	N/A	N/A	N/A	N/A	
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPD	D	B	1	16	16	0.4	60947 MCCB	N/A	60	36	N/A	0.40	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	✓	0.18	N/A	N/A	N/A	N/A	N/A
8/TP	Sub Mains(BB Nest)	D	B	1	2X50	SWA	5	60947 MCCB	N/A	200	36	N/A	0.40	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A	N/A
9/TP	Sub Mains(BB Dryslwyn)	D	B	1	50	SWA	5	60947 MCCB	N/A	200	36	N/A	0.40	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.12	N/A	N/A	N/A	N/A	N/A
10/L1	Sub Mains(DB CL3)	D	B	1	25	SWA	5	60947 MCCB	N/A	63	36	N/A	0.37	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A	N/A
10/L2	Sub Mains(DB CL2)	D	B	1	25	SWA	5	60947 MCCB	N/A	63	36	N/A	0.37	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.11	N/A	N/A	N/A	N/A	N/A
10/L3	Sub Mains(DB CL1)	D	B	1	25	SWA	5	60947 MCCB	N/A	80	36	N/A	0.39	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A	N/A
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 28/07/2022 To 28/07/2022 Date(s) live testing 28/07/2022 To 28/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 28/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Nest Floor 6 Kitchen [Schneider]	Supply to distribution board is from		Associated RCD (if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL23	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V		Operating at 1 IΔn N/A ms	
Num. of ways 18 Num. of phases 1			Zs 0.14 Ω No. of poles N/A	
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		Ipr 1.66 kA IΔn N/A Operating at 5 IΔn N/A ms	
				Time delay (if applicable) N/A
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Bedroom Lighting 3+5	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.32	N/A	250	LIM	>299	✓	0.63	29.4	28.0	✓	N/A
2/L3	Bedroom Lighting 2+4	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.41	N/A	250	LIM	>299	✓	0.72	32.4	27.2	✓	N/A
3/L3	Bedroom Lighting 6+8	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.64	36.8	25.5	✓	N/A
4/L3	Bedroom Lighting 7+9	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.74	28.6	25.4	✓	N/A
5/L3	Common Room Lights	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.32	N/A	250	LIM	>299	✓	0.66	28.8	27.2	✓	N/A
6/L3	Common Room Ring 1	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.44	0.44	0.52	N/A	0.24	N/A	250	LIM	>299	✓	0.40	28.8	26.4	✓	N/A
7/L3	Common Room Ring 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.38	0.38	0.45	N/A	0.21	N/A	250	LIM	>299	✓	0.34	28.4	27.4	✓	N/A
8/L3	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	C	32	10	30	0.54	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
9/L3	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	C	32	10	30	0.54	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
10/L3	Sub Mains(DB CL23/10, DB CL23/10-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.24	0.24	0.33	N/A	0.14	N/A	250	LIM	>299	✓	0.40	28.8	27.2	✓	N/A
11/L3	Sub Mains(DB CL23/11, DB CL23/11-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.30	0.30	0.45	N/A	0.19	N/A	250	LIM	>299	✓	0.36	27.4	27.0	✓	N/A
12/L3	Sub Mains(DB CL23/12, DB CL23/12-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.42	0.42	0.57	N/A	0.25	N/A	250	LIM	>299	✓	0.42	28.8	27.2	✓	N/A
13/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS														TEST RESULTS																			
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation							
	DB CL23				Circuit designation	L/N		OPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)					
															r1	m	r2												R1 + R2	R2			
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L3	Sub Mains(DB CL23/18, DB CL23/18-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	C	32	10	30	0.54	0.32	0.32	0.47	N/A	0.20	N/A	250	LIM	>299	✓	0.38	28.8	24.2	✓	N/A					

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: Room 2 Riser [Schneider]	Supply to distribution board is from: Sub Mains (DB CL23, 10/L3)		Associated RCD (if any): BS (EN) 61008 Above 30mA (if applicable)	
Designation: DB CL23/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type C Rating 32 A Voltage 230 V		Operating at 1 IΔn 28.8 ms	
Num. of ways: 4 Num. of phases: 1			Zs 0.40 Ω No. of poles 2 30mA or below	
Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr 0.54 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
																	R1 + R2		R2									
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

Company Name  Company Address  Postcode  Branch No.  Scheme No.   
 Client  Installation Address  Postcode

**Distribution board details - Complete in every case**  
 Location   
 Designation   
 Num. of ways  Num. of phases   
 Supply polarity confirmed  Phase sequence confirmed

**Complete only if the distribution board is not connected directly to the origin of the installation**  
 Supply to distribution board is from   
 Overcurrent protective device for the distribution circuit: BS(EN)  Type  Rating  A Voltage  V

**Characteristics at this distribution board**  
 Associated RCD(if any): BS (EN)  Above 30mA (if applicable) Operating at 1 IΔn  ms  
 Zs  Ω No. of poles  30mA or below  
 Ipr  kA IΔn  Operating at 5 IΔn  ms  
 Time delay (if applicable)

**Test instrument serial number(s)**  
 Loop impedance   
 Insulation resistance   
 Continuity   
 RCD

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.46	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing  To  Date(s) live testing  To

Tested by: Name (capital letters)  Position  Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance, Company Address Kid Glove Road, Postcode WA3 3GR, Branch No., Scheme No., Client UPP Residential Services Ltd, Installation Address Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan, Postcode SA1 8EN

CIRCUIT DETAILS TEST RESULTS

Table with 27 columns: Circuit No. and Line No., Distribution board Designation, Type of wiring, Ref. method, No. of points, Circuit conductors csa (mm²), Overcurrent protective devices, BS EN Number, Type No., Rating (A), Breaking capacity (KA), RCD operating (mA), BS 7671 Max. permitted Zs, Circuit impedance Ω, Insulation resistance, Polarity, Measured Max. Zs (Ω), RCD testing, Manual test button operation.

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.			
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan				Postcode	SA1 8EN			
<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			<b>Characteristics at this distribution board</b>			<b>Test instrument serial number(s)</b>		
Location	Room 5 Riser [Schneider]		Supply to distribution board is from			Associated RCD(if any): BS (EN) 61008			Loop impedance	100701/4664	
Designation	DB CL23/11-1		Sub Mains(DB CL23, 11/L3)			Operating at 1 IΔn			Insulation resistance	100701/4664	
Num. of ways	4	Num. of phases	1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO			Above 30mA (if applicable)			Continuity	100701/4664
Supply polarity confirmed <input type="checkbox"/>		Phase sequence confirmed <input type="checkbox"/>		Type: C Rating: 32 A Voltage: 230 V			Operating at 5 IΔn			RCD	100701/4664
						Time delay (if applicable)			N/A		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2		R2												
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>		<b>Test instrument serial number(s)</b>	
Location: Room 6 Riser [Schneider]	Designation: DB CL23/12	Supply to distribution board is from: Sub Mains(DB CL23, 12/L3)	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: C Rating: 32 A Voltage: 230 V	Associated RCD(if any): BS (EN) 61008	Above 30mA (if applicable): Operating at 1 IΔn 28.8 ms	Loop impedance: 100701/4664	Insulation resistance: 100701/4664
Num. of ways: 4	Num. of phases: 1			Zs: 0.42 Ω	No. of poles: 2	30mA or below: 100701/4664	Continuity: 100701/4664
Supply polarity confirmed: <input type="checkbox"/>	Phase sequence confirmed: <input type="checkbox"/>			Ipf: 0.54 kA	IΔn: 30	Operating at 5 IΔn: 27.2 ms	RCD: 100701/4664
				Time delay (if applicable): N/A			

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL23, 12/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms	
Designation DB CL23/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type C Rating 32 A Voltage 230 V		$Z_s$ 0.42 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			$I_{pn}$ 0.54 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 27.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted $Z_s$ Other 80% ( $\Omega$ )	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )			
														r1	m	r2										Fig 8 check ( $\checkmark$ )	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	$\checkmark$	0.54	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL23, 18/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL23/18	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type C Rating 32 A Voltage 230 V	Zs 0.38 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Insulation resistance	
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room X Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL23, 18/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL23/18-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type C Rating 32 A Voltage 230 V		Zs 0.38 Ω No. of poles 2 30mA or below	
Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipf 0.60 kA IΔn 30 Operating at 5 IΔn 24.2 ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
		Loop impedance 100701/4664		
		Insulation resistance 100701/4664		
		Continuity 100701/4664		
		RCD 100701/4664		

### CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Plant Room [Schneider]	Supply to distribution board is from		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB PL/P	Overcurrent protective device for the distribution circuit: Type BS(EN) Rating A Voltage V		Operating at 1 IΔn N/A ms	
Num. of ways 24 Num. of phases 3			Zs 0.12 Ω No. of poles N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>			Ipr 3.3 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		
Continuity 100701/4664		RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFCD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Plant Room Ring	A	E	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.22	0.22	0.30	N/A	0.12	N/A	250	LIM	>299	✓	0.39	29.8	28.0	✓	N/A
1/L2	Head Of Smoke Shaft AOV	O	E	1	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.32	N/A	N/A	N/A	N/A
1/L3	Tube Heater	A	E	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A
2/TP	Roof Extract Fan 2	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.26	N/A	N/A	N/A	N/A
3/TP	Roof Extract Fan 1	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.33	N/A	N/A	N/A	N/A
4/TP	Roof Extract Fan 3	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.26	N/A	N/A	N/A	N/A
5/TP	Roof Extract Fan 4	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.29	N/A	N/A	N/A	N/A
6/TP	Roof Extract Fan 5	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.31	N/A	N/A	N/A	N/A
7/TP	Roof Extract Fan 6	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.29	N/A	N/A	N/A	N/A
8/TP	Roof Extract Fan 7	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.34	N/A	N/A	N/A	N/A
9/TP	Roof Extract Fan 8	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.22	N/A	N/A	N/A	N/A
10/TP	Roof Extract Fan 10	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.25	N/A	N/A	N/A	N/A
11/TP	Roof Extract Fan 9	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.31	N/A	N/A	N/A	N/A
12/TP	Roof Extract Fan 12	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.28	N/A	N/A	N/A	N/A
13/TP	Roof Extract Fan 11	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.34	N/A	N/A	N/A	N/A
14/TP	Roof Extract Fan 14	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.22	N/A	N/A	N/A	N/A
15/TP	Roof Extract Fan 13	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.25	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
	DB PL/P				L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)		
	Circuit designation													r1	m	r2												R1 + R2	R2
16/TP	Roof Extract Fan 15	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.36	N/A	N/A	N/A	N/A	
17/TP	Roof Extract Fan 17	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A	
18/TP	Roof Extract Fan 16	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.30	N/A	N/A	N/A	N/A	
19/TP	Roof Extract Fan 18	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.28	N/A	N/A	N/A	N/A	
20/TP	Roof Extract Fan 21	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.36	N/A	N/A	N/A	N/A	
21/TP	Roof Extract Fan 20	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.33	N/A	N/A	N/A	N/A	
22/TP	Roof Extract Fan 22	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.29	N/A	N/A	N/A	N/A	
23/TP	Roof Extract Fan 19	G	C	1	2.5	SWA	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.33	N/A	N/A	N/A	N/A	
24/L1	Contact Power Supply	D	B	1	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	1.75	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.20	N/A	N/A	N/A	N/A	
24/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.			
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			Postcode	SA1 8EN				
<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			<b>Characteristics at this distribution board</b>			<b>Test instrument serial number(s)</b>		
Location	Plant Room Nest [Schneider]	Supply to distribution board is from				Associated RCD(if any):	BS (EN) Above 30mA (if applicable)		Loop impedance	100701/4664	
Designation	DB PL/L	Overcurrent protective device for the distribution circuit:	Type	Rating	A	Voltage	V	Time delay (if applicable)	N/A	Insulation resistance	100701/4664
Num. of ways	4	Num. of phases	3							Continuity	100701/4664
Supply polarity confirmed <input checked="" type="checkbox"/>		Phase sequence confirmed <input checked="" type="checkbox"/>								RCD	100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	Plantroom Lights	A	E	3	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.55	26.4	22.0	✓	N/A
1/L2	Stairwell Lights	A	E	2	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.62	29.0	27.4	✓	N/A
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/TP	SPD	D	B	1	16	16	5	60898 MCB	C	50	10	N/A	0.35	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	✓	0.20	N/A	N/A	N/A	N/A
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 22 Nest Kitchen [Schneider]	Supply to distribution board is from		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL22	Overcurrent protective device for the distribution circuit: Type BS(EN) Rating A Voltage V		Operating at 1 IΔn N/A ms	
Num. of ways 18 Num. of phases 1			Zs 0.10 Ω No. of poles N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr 2.2 kA IΔn N/A Operating at 5 IΔn N/A ms	
				Time delay (if applicable) N/A
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	r1	m	r2			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														RCD testing		Manual test button operation														
					Circuit designation		Circuit designation		Circuit designation					Circuit designation		Circuit designation		Circuit designation		Circuit designation		Circuit designation			Circuit designation		Circuit designation		Circuit designation	
1/L2	Bedroom Lighting 1+2	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.40	26.8	18.6	✓	N/A		
2/L2	Bedroom Lighting 3+4	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.53	28.6	26.4	✓	N/A		
3/L2	Bedroom Lighting 7+8	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.52	28.8	28.0	✓	N/A		
4/L2	Bedroom Lighting 5+6	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.36	N/A	250	LIM	>299	✓	0.48	24.0	24.0	✓	N/A		
5/L2	Common Room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.51	29.7	27.2	✓	N/A		
6/L2	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.25	0.25	0.36	N/A	0.15	N/A	250	LIM	>299	✓	0.30	26.4	22.6	✓	N/A		
7/L2	Common Room Ring 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.49	N/A	0.20	N/A	250	LIM	>299	✓	0.38	28.4	28.0	✓	N/A		
8/L2	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	LIM	N/A		
9/L2	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	LIM	N/A		
10/L2	Sub Mains(DB CL22/10, DB CL22/10-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.23	0.23	0.36	N/A	0.15	N/A	250	LIM	>299	✓	0.34	28.8	24.3	✓	N/A		
11/L2	Sub Mains(DB CL22/11, DB CL22/11-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.34	0.40	0.46	N/A	0.20	N/A	250	LIM	>299	✓	0.41	28.8	27.2	✓	N/A		
12/L2	Sub Mains(DB CL22/12, DB CL22/12-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.57	N/A	0.24	N/A	250	LIM	>299	✓	0.38	28.8	27.2	✓	N/A		
13/L2	Sub Mains(DB CL22/13, DB CL22/13-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.51	N/A	0.23	N/A	250	LIM	>299	✓	0.40	28.4	27.2	✓	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



**ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests**

for Industrial/Commercial Premises



**Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)**

CIRCUIT DETAILS													TEST RESULTS																				
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
	DB CL22				Circuit designation	L/N		OPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)					
															r1	m	r2												N/A	N/A	N/A	N/A	N/A
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL22, 10/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL22/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.34 Ω No. of poles 2 30mA or below Ipr 0.65 kA IΔn 30 Operating at 5 IΔn 24.3 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	<b>Postcode</b> SA1 8EN		

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location: Room 8 Riser [Schneider] Designation: DB CL22/10-1 Num. of ways: 4, Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> , Phase sequence confirmed <input type="checkbox"/>	Supply to distribution board is from: Sub Mains(DB CL22, 10/L2) Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO, Type: B, Rating: 32, A, Voltage: 230 V	Associated RCD(if any): BS (EN) 61008, Operating at 1 $\Delta n$ : 28.8 ms, Above 30mA (if applicable) $Z_s$ : 0.34 $\Omega$ , No. of poles: 2, 30mA or below $I_{pr}$ : 0.65 kA, $\Delta n$ : 30, Operating at 5 $\Delta n$ : 24.3 ms Time delay (if applicable): N/A	Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664

### CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms	RCD (✓)			AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898	MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.32	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL22, 11/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL22/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Z <sub>s</sub> 0.41 Ω	No. of poles 2
Num. of ways 4 Num. of phases 1			I <sub>pn</sub> 0.59 kA	IΔn 30
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Operating at 5 IΔn 27.2 ms	
			Time delay (if applicable) N/A	<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z <sub>s</sub> Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	<b>Postcode</b> SA1 8EN			
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL22, 11/L2)	Associated RCD(if any): BS (EN) 61008	Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	Loop impedance 100701/4664	
Designation DB CL22/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Zs 0.41 Ω	30mA or below	Insulation resistance 100701/4664	
Num. of ways 4	Type B Rating 32 A Voltage 230 V	Ipf 0.59 kA IΔn 30	Operating at 5 IΔn 27.2 ms	Continuity 100701/4664	
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A	
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL22, 12/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL22/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.38 Ω No. of poles 2 30mA or below		Test instrument serial number(s)
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Loop impedance 100701/4664	
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.60	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 6 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL22, 12/L2)	Associated RCD(if any): BS (EN) 61008		Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms
Designation DB CL22/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V	Zs 0.38 Ω	No. of poles 2	30mA or below Operating at 5 IΔn 27.2 ms
Num. of ways 4 Num. of phases 1		Ipf 0.60 kA	IΔn 30	Time delay (if applicable) N/A
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	<b>Postcode</b> SA1 8EN			
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL22, 13/L2)	Associated RCD(if any): BS (EN) 61008	Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.4 ms	Loop impedance 100701/4664	
Designation DB CL22/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	$Z_s$ 0.40 $\Omega$	30mA or below No. of poles 2	Insulation resistance 100701/4664	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	$I_{pn}$ 0.58 kA $\Delta n$ 30	Operating at 5 $\Delta n$ 27.2 ms	Continuity 100701/4664	
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted $Z_s$ Other 80% ( $\Omega$ )	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms	RCD ( $\checkmark$ )			AFDD ( $\checkmark$ )				
														r1	m	r2										Fig 8 check ( $\checkmark$ )	All circuits to be completed using R1R2 or R2, not both		
															R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	$\checkmark$	0.45	N/A	N/A	N/A	N/A	
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room X Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL22, 13/L2)	Associated RCD(if any): BS (EN) 61008		Test instrument serial number(s) Loop impedance 100701/4664 Insulation resistance 100701/4664 Continuity 100701/4664 RCD 100701/4664
Designation DB CL22/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms		
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.40 Ω No. of poles 2 30mA or below		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Ipf 0.58 kA IΔn 30 Operating at 5 IΔn 27.2 ms		
		Time delay (if applicable) N/A		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 11 Nest [Schneider]	Supply to distribution board is from		Associated RCD (if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL21	Overcurrent protective device for the distribution circuit: Type BS(EN) Rating A Voltage V		Operating at 1 IΔn N/A ms	
Num. of ways 18 Num. of phases 1			Zs 0.11 Ω No. of poles N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr 3.8 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Bedroom Lighting 7,8	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.22		250	LIM	>299	✓	0.42	28.4	18.4	✓	N/A
2/L1	Bedroom Lighting 9,10	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.19		250	LIM	>299	✓	0.49	28.2	27.0	✓	N/A
3/L1	Bedroom Lighting 4,5,6	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.25		250	LIM	>299	✓	0.40	28.8	32.6	✓	N/A
4/L1	Bedroom Lighting 1,2,3	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.22		250	LIM	>299	✓	0.50	26.4	22.4	✓	N/A
5/L1	Common Room Lighting	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34		250	LIM	>299	✓	0.64	28.2	28.0	✓	N/A
6/L1	Common Room Ring 1	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.21	0.21	0.36	N/A	0.14		250	LIM	>299	✓	0.31	28.8	27.2	✓	N/A
7/L1	Common Room Ring 2	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.39	0.39	0.52	N/A	0.23		250	LIM	>299	✓	0.37	26.4	17.4	✓	N/A
8/L1	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM		250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
9/L1	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM		250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
10/L1	Sub Mains(DB CL21/10, DB CL21/10-1, DB CL21/10-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.46	0.46	0.55	N/A	0.24		250	LIM	>299	✓	0.53	26.2	27.2	✓	N/A
11/L1	Sub Mains(DB CL21/11, DB CL21/11-1, DB CL21/11-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.58	N/A	0.25		250	LIM	>299	✓	0.42	28.8	22.8	✓	N/A
12/L1	Sub Mains(DB CL21/12, DB CL21/12-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.37	N/A	0.17		250	LIM	>299	✓	0.38	28.2	26.2	✓	N/A
13/L1	Sub Mains(DB CL21/13-1, DB CL21/13)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.62	N/A	0.26		250	LIM	>299	✓	0.40	28.8	18.4	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 4 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL21, 10/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 26.2 ms	
Designation DB CL21/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.53 Ω No. of poles 2 30mA or below Ipf 0.42 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
Num. of ways 4 Num. of phases 1			Time delay (if applicable) N/A	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			<b>Test instrument serial number(s)</b>	
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.47	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL21, 10/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 26.2 ms	
Designation DB CL21/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.53 Ω No. of poles 2 Operating at 5 IΔn 27.2 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 6 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL21, 10/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 26.2 ms	
Designation DB CL21/10-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.53 Ω No. of poles 2 30mA or below Ipr 0.42 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL21, 11/L1)	Associated RCD(if any): BS (EN) 61008		Test instrument serial number(s) Loop impedance 100701/4664 Insulation resistance 100701/4664 Continuity 100701/4664 RCD 100701/4664
Designation DB CL21/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms		
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.42 Ω No. of poles 2 30mA or below		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Ipr 0.51 kA IΔn 30 Operating at 5 IΔn 22.8 ms		
		Time delay (if applicable) N/A		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL21, 11/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL21/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.42 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.51 kA IΔn 30 Operating at 5 IΔn 22.8 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL21, 11/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL21/11-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.42 Ω No. of poles 2 30mA or below Ipr 0.51 kA IΔn 30 Operating at 5 IΔn 22.8 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL21, 12/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable)	
Designation DB CL21/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 28.2 ms	
Num. of ways 4 Num. of phases 1			Zs 0.38 Ω No. of poles 2 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipf 0.61 kA IΔn 30 Operating at 5 IΔn 26.2 ms	
				Time delay (if applicable) N/A
<b>Test instrument serial number(s)</b>				
		Loop impedance 100701/4664		
		Insulation resistance 100701/4664		
		Continuity 100701/4664		
		RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2												
														Fig 8 check (✓)		All circuits to be completed using R1R2 or R2, not both												
		R1 + R2	R2																									
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL21, 12/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms	
Designation DB CL21/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.38 Ω No. of poles 2 Operating at 5 IΔn 26.2 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2		R2												
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 9 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL21, 13/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms	
Designation DB CL21/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Z <sub>s</sub> 0.40 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			I <sub>pr</sub> 0.56 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 18.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z <sub>s</sub> Other 80% ( $\Omega$ )	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured Z <sub>s</sub> ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )			
														r1	m	r2										Fig 8 check ( $\checkmark$ )	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	$\checkmark$	0.66	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 10 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL21, 13/L1)	Associated RCD(if any): BS (EN) 61008		Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms
Designation DB CL21/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	$Z_s$ 0.40 $\Omega$	No. of poles 2	30mA or below
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	$I_{pn}$ 0.56 kA	$\Delta n$ 30	Operating at 5 $\Delta n$ 18.4 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A		<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted $Z_s$ Other 80%	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Dryslwyn Riser [Schneider]	Supply to distribution board is from Sub Mains(MDB, 9/TP)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) ms	
Designation BB Dryslwyn	Overcurrent protective device for the distribution circuit: Type N/A Rating 200 A Voltage 400 V		Operating at 1 IΔn N/A ms	
Num. of ways 20 Num. of phases 3			Zs 0.12 Ω No. of poles N/A	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>			Ipr 3.8 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation								
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFCD (✓)										
														r1	m	r2																			
					Fig 8 check (✓)			All circuits to be completed using R1R2 or R2, not both																											
1/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
2/L2	Sub Mains(DB CL4)	F	C	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
2/L3	Sub Mains(DB CL5 )	F	C	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/TP	Sub Mains(DB LL 1/P, DB LL 1/L)	F	C	1	25	25	5	88-2 HRC	gG	100	80	N/A	0.33	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L1	Sub Mains(DB CL8)	F	C	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/L2	Sub Mains(DB CL9)	F	C	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	Sub Mains(DB CL12)	F	C	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	Sub Mains(DB CL13)	F	C	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	✓	0.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 17/08/2022 To 17/08/2022 Date(s) live testing 17/08/2022 To 17/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 17/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

0.02

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS																											
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation														
	BB Dryslwyn				L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)													
	Circuit designation				r1	m		r2	R1 + R2	R2																															
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
9/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
9/L3	Sub Mains(DB CL16)	F	C	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
10/L1	Sub Mains(DB CL17)	F	C	1	25	SWA	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
10/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
11/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
11/L2	Sub Mains(DB CL20)	A	B	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
11/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
12/TP	Sub Mains(DB LL3/L, DB LL3/P)	F	C	1	25	25	5	88-2 HRC	gG	100	80	N/A	0.33	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
13/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
14/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
19/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
20/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 17/08/2022 To 17/08/2022 Date(s) live testing 17/08/2022 To 17/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 17/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A) 0.02

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>		<b>Test instrument serial number(s)</b>	
Location	G Floor Riser NEst [Schneider]	Supply to distribution board is from	Sub Mains(MDB, 8/TP)	Associated RCD(if any): BS (EN)	Above 30mA (if applicable)	Loop impedance	100701/4664
Designation	BB Nest	Overcurrent protective device for the distribution circuit: Type	BS(EN) 60947 MCCB	Zs	0.16 Ω	Insulation resistance	100701/4664
Num. of ways	12	Rating	200 A	No. of poles	N/A	Continuity	100701/4664
Supply polarity confirmed	<input checked="" type="checkbox"/>	Voltage	400/230 V	Operating at 1 IΔn	N/A ms	RCD	100701/4664
Phase sequence confirmed	<input checked="" type="checkbox"/>			Operating at 5 IΔn	N/A ms		
				Time delay (if applicable)	N/A		

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			A/FDD (✓)			
														r1	r <sub>n</sub>	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/TP	Sub Mains(DB LL2/L, DB LL2/P)	F	C	1	25	25	5	88-2 HRC	gG	100	80	N/A	0.33	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.11	N/A	N/A	N/A	N/A
2/TP	Sub Mains(DB CL6)	A	E	1	25	25	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.11	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	Sub Mains(DB CL7)	A	E	1	25	25	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	Sub Mains(DB CL10)	A	E	1	25	25	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.12	N/A	N/A	N/A	N/A
5/L1	Sub Mains(DB CL11)	A	E	1	25	25	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Sub Mains(DB CL14)	A	E	1	25	25	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.15	N/A	N/A	N/A	N/A
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	Sub Mains(DB CL15)	A	E	1	25	25	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 15/08/2022 To 15/08/2022 Date(s) live testing 15/08/2022 To 15/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 15/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/EICR 110151231



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
	BB Nest				Circuit designation	L/N		OPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)
															r1	m	r2											
8/TP	Sub Mains(DB LL4/L, DB LL4/P)	A	E	1	25	25	5	88-2 HRC	gG	100	80	N/A	0.33	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.12	N/A	N/A	N/A	N/A
9/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/L2	Sub Mains(DB CL18)	A	E	1	25	25	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A
9/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L3	Sub Mains(DB CL19)	A	E	1	25	25	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 15/08/2022 To 15/08/2022 Date(s) live testing 15/08/2022 To 15/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 15/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: FLat 2 Nest [Schneider]	Supply to distribution board is from: Sub Mains(MDB, 10/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation: DB CL3	Overcurrent protective device for the distribution circuit: Type N/A Rating 63 A Voltage 230 V		Operating at 1 IΔn N/A ms	
Num. of ways: 18 Num. of phases: 1			Zs 0.14 Ω No. of poles N/A	
Supply polarity confirmed <input checked="" type="checkbox"/>			Ipr 1.77 kA IΔn N/A Operating at 5 IΔn N/A ms	
Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance		100701/4664		
Insulation resistance		100701/4664		
Continuity		100701/4664		
RCD		100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFCD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2		R2												
1/L1	Bedroom Lighting 5,6,7	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.57	N/A	250	LIM	>299	✓	0.83	28.4	27.4	✓	N/A
2/L1	Bedroom Lighting 1,2,3	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.43	N/A	250	LIM	>299	✓	0.65	28.8	27.2	✓	N/A
3/L1	Common Room Lights	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.39	28.4	27.9	✓	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	Common Room Ring	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.34	0.34	0.48	✓	0.21	N/A	250	LIM	>299	✓	0.40	32.0	27.4	✓	N/A
6/L1	Common Room Ring 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.44	✓	0.19	N/A	250	LIM	>299	✓	0.35	28.8	28.0	✓	N/A
7/L1	Isolated	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
8/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/L1	Sub Mains(DB CL3/9, DB CL3/9-1, DB CL3/9-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.55	✓	0.24	N/A	250	LIM	>299	✓	0.36	27.4	27.2	✓	N/A
10/L1	Sub Mains(DB CL3/10, DB CL3/10-1, DB CL3/10-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.37	0.37	0.48	✓	0.21	N/A	250	LIM	>299	✓	0.34	28.4	26.5	✓	N/A
11/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 01/08/2022 To 01/08/2022 Date(s) live testing 01/08/2022 To 01/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 01/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5A), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	Postcode SA1 8EN		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		
Location Flat 1 Nest [Schneider]		Supply to distribution board is from Sub Mains(MDB, 10/L2)		
Designation DB CL2		Overcurrent protective device for the distribution circuit: Type N/A Rating 63 A Voltage 230 V		
Num. of ways 18 Num. of phases 1		Characteristics at this distribution board		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) ms Operating at 1 IΔn N/A ms Zs 0.11 Ω No. of poles N/A 30mA or below Ipr 2.2 kA IΔn N/A Operating at 5 IΔn N/A ms Time delay (if applicable) N/A		
		Test instrument serial number(s)		
		Loop impedance 100701/4664		
		Insulation resistance 100701/4664		
		Continuity 100701/4664		
		RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Bedroom Lighting 4,5,6	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.36	N/A	250	LIM	>299	✓	0.48	28.5	26.0	✓	N/A
2/L2	Bedroom Lighting 1,2,3	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.52	28.8	27.2	✓	N/A
3/L2	Bedroom Lighting 7,8,9	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.55	27.2	22.4	✓	N/A
4/L2	Common Room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.37	28.5	20.4	✓	N/A
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.32	0.32	0.48	✓	0.20	N/A	250	LIM	>299	✓	0.35	32.6	27.0	✓	N/A
7/L2	Common Room Ring 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.35	0.35	0.55	✓	0.22	N/A	250	LIM	>299	✓	0.42	28.4	19.5	✓	N/A
8/L2	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
9/L2	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
10/L2	Sub Mains(DB CL2/10, DB CL2/10-1, DB CL2/10-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.47	0.47	0.64	✓	0.28	N/A	250	LIM	>299	✓	0.40	28.8	27.6	✓	N/A
11/L2	Sub Mains(DB CL2/11, DB CL2/11-1, DB CL2/11-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.52	0.52	0.66	✓	0.30	N/A	250	LIM	>299	✓	0.46	28.8	27.2	✓	N/A
12/L2	Sub Mains(DB CL2/12, DB CL2/12-1, DB CL2/12-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.39	0.42	0.50	✓	0.22	N/A	250	LIM	>299	✓	0.36	28.4	18.5	✓	N/A
13/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 01/08/2022 To 01/08/2022 Date(s) live testing 01/08/2022 To 01/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 01/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																						
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation								
	DB CL2				Circuit designation	L/N		OPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)							
															r1	m	r2												R1 + R2	R2					
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 01/08/2022 To 01/08/2022 Date(s) live testing 01/08/2022 To 01/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 01/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 1 Kitchen Dryslwyn [Schneider]	Supply to distribution board is from Sub Mains(MDB, 10/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) ms	
Designation DB CL1	Overcurrent protective device for the distribution circuit: Type N/A Rating 80 A Voltage 230 V		Operating at 1 IΔn N/A ms	
Num. of ways 21	Num. of phases 1	BS(EN) 60947 MCCB		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Type N/A Rating 80 A Voltage 230 V		Operating at 5 IΔn N/A ms
		Time delay (if applicable) N/A		<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Bedroom Lighting 1	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.52	28.8	26.2	✓	N/A
2/L3	Bedroom Lighting 2	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.31	32.0	27.9	✓	N/A
3/L3	Bedroom Lighting 3	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.44	28.4	30.2	✓	N/A
4/L3	Bedroom Lighting 4	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.56	28.2	27.2	✓	N/A
5/L3	Bedroom Lighting 5	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.55	28.8	27.0	✓	N/A
6/L3	Common room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.62	32.4	19.8	✓	N/A
7/L3	Common Room Ring 1	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.19	0.19	0.32	✓	0.14	N/A	250	LIM	>299	✓	0.36	28.4	24.0	✓	N/A
8/L3	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.25	0.25	0.35	✓	0.15	N/A	250	LIM	>299	✓	0.32	28.8	26.4	✓	N/A
9/L3	Hob 1	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.29	25.2	27.2	✓	N/A
10/L3	Hob 2	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.29	28.4	19.3	✓	N/A
11/L3	Sub Mains(DB CL1/11, DB CL1/11-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.28	0.28	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.30	28.4	26.4	✓	N/A
12/L3	Sub Mains(DB CL1/12, DB CL1/12-1, DB CL1/12-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.32	0.32	0.52	✓	0.21	N/A	250	LIM	>299	✓	0.34	28.4	26.2	✓	N/A
13/L3	Sub Mains(DB CL1/13, DB CL1/13-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.32	28.8	27.2	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 28/07/2022 To 28/07/2022 Date(s) live testing 28/07/2022 To 28/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 28/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS														TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	DB CL1				Circuit designation	L/N		OPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)	
	r1														m	r2	R1 + R2												R2
14/L3	Sub Mains(DB CL1/14, DB CL1/14-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.24	0.24	0.44	✓	0.17	N/A	250	LIM	>299	✓	0.30	28.8	24.2	✓	N/A	
15/L3	Executive Room Ring	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.47	0.47	0.63	✓	0.28	N/A	250	LIM	>299	✓	0.40	29.4	23.9	✓	N/A	
16/L3	Executiv Kitchen Ring	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.35	0.36	0.55	✓	0.20	N/A	250	LIM	>299	✓	0.31	28.8	21.4	✓	N/A	
17/L3	Executive Room Cooker	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.32	26.4	22.6	✓	N/A	
18/L3	Bus Stop Supply	G	C	1	4	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	✓	LIM	28.2	19.4	✓	N/A	
19/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
20/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
21/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 28/07/2022 To 28/07/2022 Date(s) live testing 28/07/2022 To 28/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 28/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 9 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL1, 11/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL1/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.4 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.30 Ω No. of poles 2 30mA or below		<b>Test instrument serial number(s)</b>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Ipf 0.78 kA IΔn 30 Operating at 5 IΔn 26.4 ms		Time delay (if applicable) N/A	
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)





# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 6 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL1, 12/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL1/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.4 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.34 Ω No. of poles 2 30mA or below		<b>Test instrument serial number(s)</b>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Loop impedance 100701/4664	
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2		R2												
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: Room 7 Riser [Schneider]	Supply to distribution board is from: Sub Mains (DB CL1, 12/L3)		Associated RCD (if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Designation: DB CL1/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.34 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.70 kA IΔn 30 Operating at 5 IΔn 26.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
																	R1 + R2		R2									
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.65	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL1, 12/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL1/12-2	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 28.4 ms	
Num. of ways 4 Num. of phases 1	BS(EN) 61009 RCD/RCBO		Zs 0.34 Ω No. of poles 2 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipf 0.70 kA IΔn 30 Operating at 5 IΔn 26.2 ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL1, 13/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL1/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.32 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.71 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
			<b>Test instrument serial number(s)</b>	
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.60	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL1, 13/L3)	Associated RCD(if any): BS (EN) 61008		Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms
Designation DB CL1/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V	$Z_s$ 0.32 $\Omega$	No. of poles 2	30mA or below Operating at 5 $\Delta n$ 27.2 ms
Num. of ways 4 Num. of phases 1		$I_{pn}$ 0.71 kA	$\Delta n$ 30	Time delay (if applicable) N/A
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% ( $\Omega$ )	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured Zs ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )			
														r1	m	r2										Fig 8 check ( $\checkmark$ )	All circuits to be completed using R1R2 or R2, not both	
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	$\checkmark$	0.55	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL1, 14/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL1/14	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1			Zs 0.30 Ω No. of poles 2 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipf 0.74 kA IΔn 30 Operating at 5 IΔn 24.2 ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 4 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL1, 14/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL1/14-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.30 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipf 0.74 kA IΔn 30 Operating at 5 IΔn 24.2 ms	
		Time delay (if applicable) N/A		<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.71	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 6 [Kitchen]	Supply to distribution board is from Sub Mains(BB Dryslwyn, 2/L2)		Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) ms	
Designation DB CL4	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V		Operating at 1 IΔn N/A ms	
Num. of ways 18	Num. of phases 1	BS(EN) 88-2 HRC	Zs 0.14 Ω No. of poles N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Type gG Rating 63 A Voltage 230 V	Ipr 1.7 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFCD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
										R1 + R2				R2														
1/L2	Lighting Bedrooms 1,2	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.45	28.4	26.9	✓	N/A
2/L2	Lighting Bedrooms 3,4	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.35	N/A	250	LIM	>299	✓	0.53	28.2	27.0	✓	N/A
3/L2	Common Room Lights	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.41	N/A	250	LIM	>299	✓	0.52	28.8	19.4	✓	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L2	Common Room Ring 1	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.28	0.25	0.33	✓	0.15	N/A	250	LIM	>299	✓	0.32	28.4	26.2	✓	N/A
6/L2	Common Room Ring 2	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.24	0.24	0.30	✓	0.14	N/A	250	LIM	>299	✓	0.26	28.2	22.4	✓	N/A
7/L2	Hob	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.24	28.8	16.4	✓	N/A
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	Sub Mains(DB CL4/10, DB CL4/10-1)	A	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.46	✓	0.19	N/A	250	LIM	>299	✓	0.29	28.4	27.0	✓	N/A
11/L2	Sub Mains(DB CL4/11, DB CL4/11-1)	A	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.24	0.24	0.48	✓	0.18	N/A	250	LIM	>299	✓	0.33	28.8	24.3	✓	N/A
12/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 28/07/2022 To 28/07/2022 Date(s) live testing 28/07/2022 To 28/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 28/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																					
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation							
	DB CL4				Circuit designation	L/N		OPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)						
															r1	m	r2												R1 + R2	R2				
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing  To  Date(s) live testing  To

Tested by: Name (capital letters)  Position  Date

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	Postcode SA1 8EN		

<b>Distribution board details - Complete in every case</b> Location: Room 1 Riser [Schneider] Designation: DB CL4/10 Num. of ways: 4    Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Supply to distribution board is from: Sub Mains (DB CL4, 10/L2) Overcurrent protective device for the distribution circuit: Type B    Rating 32    A    Voltage 230    V	<b>Characteristics at this distribution board</b> Associated RCD (if any): BS (EN) 61008    Above 30mA (if applicable) Operating at 1 IΔn 28.4    ms Zs 0.29    Ω    No. of poles 2    30mA or below Ipr 0.8    kA    IΔn 30    Operating at 5 IΔn 27.0    ms Time delay (if applicable) N/A	<b>Test instrument serial number(s)</b> Loop impedance 100701/4664 Insulation resistance 100701/4664 Continuity 100701/4664 RCD 100701/4664
---	--	---	---

### CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)					
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both			
								R1 + R2		R2																				
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A		
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL4, 11/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL4/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.33 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.66 kA IΔn 30 Operating at 5 IΔn 24.3 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.56	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 4 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL4, 11/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL4/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.33 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.66 kA IΔn 30 Operating at 5 IΔn 24.3 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 7 Drwslwyn [Schneider]	Supply to distribution board is from Sub Mains(BB Dryslwyn, 2/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) ms	
Designation DB CL5	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400/230		Operating at 1 IΔn N/A ms	
Num. of ways 18 Num. of phases 1			Zs 0.10 Ω No. of poles N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr 2.4 kA IΔn N/A Operating at 5 IΔn N/A ms	
				Time delay (if applicable) N/A
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r3												R1 + R2
1/L3	Bedroom Lighting 1	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.63	28.4	26.2	✓	N/A
2/L3	Bedroom Lighting 2	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	✓	0.41	24.0	20.4	✓	N/A
3/L3	Bedroom Lighting 3	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.55	27.2	27.0	✓	N/A
4/L3	Common Room Lights	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.41	N/A	250	LIM	>299	✓	0.61	29.0	24.6	✓	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	Common Room Sockets	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.22	0.22	0.35	✓	0.14	N/A	250	LIM	>299	✓	0.35	28.6	25.4	✓	N/A
7/L3	Common Room Socket 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.21	0.21	0.42	✓	0.16	N/A	250	LIM	>299	✓	0.42	24.8	21.8	✓	N/A
8/L3	Hob 1	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.22	28.8	27.4	✓	N/A
9/L3	Hob 2	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.30	32.6	19.4	✓	N/A
10/L3	Sub Mains(DB CL5/10, DB CL5/10-1)	A	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.34	0.34	0.45	✓	0.20	N/A	250	LIM	>299	✓	0.38	26.4	25.2	✓	N/A
11/L3	Sub Mains(DB CL5/11, DB CL5/11-1, DB CL5/11-2)	A	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.52	✓	0.23	N/A	250	LIM	>299	✓	0.40	28.8	24.0	✓	N/A
12/L3	Sub Mains(DB CL5/12, DB CL5/12-1, DB CL5/12-2)	A	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.35	0.38	0.44	✓	0.20	N/A	250	LIM	>299	✓	0.36	28.4	24.4	✓	N/A
13/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 28/07/2022 To 28/07/2022 Date(s) live testing 28/07/2022 To 28/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 28/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																								
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation											
	DB CL5				L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)										
	Circuit designation													r1	m	r2												R1 + R2	R2								
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 28/07/2022 To 28/07/2022 Date(s) live testing 28/07/2022 To 28/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 28/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL5 , 10/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 26.4 ms	
Designation DB CL5/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.38 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.7 kA IΔn 30 Operating at 5 IΔn 25.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 6 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL5 , 10/L3)	Associated RCD(if any): BS (EN) 61008		Test instrument serial number(s) Loop impedance 100701/4664 Insulation resistance 100701/4664 Continuity 100701/4664 RCD 100701/4664
Designation DB CL5/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Above 30mA (if applicable) Operating at 1 IΔn 26.4 ms		
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.38 Ω No. of poles 2 30mA or below		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Ipr 0.7 kA IΔn 30 Operating at 5 IΔn 25.2 ms		
		Time delay (if applicable) N/A		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL5 , 11/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL5/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.40 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.66 kA IΔn 30 Operating at 5 IΔn 24.0 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
		Loop impedance 100701/4664		
		Insulation resistance 100701/4664		
		Continuity 100701/4664		
		RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.75	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL5 , 11/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL5/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.40 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipf 0.66 kA IΔn 30 Operating at 5 IΔn 24.0 ms	
		Time delay (if applicable) N/A		<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 9 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL5, 11/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL5/11-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.40 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.66 kA IΔn 30 Operating at 5 IΔn 24.0 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN		
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL5 , 12/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)		
Designation DB CL5/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.4 ms		
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.36 Ω No. of poles 2 30mA or below		Test instrument serial number(s)	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Loop impedance 100701/4664		
			Insulation resistance 100701/4664		
			Continuity 100701/4664		
			RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL5 , 12/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Designation DB CL5/12-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.36 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.62 kA IΔn 30 Operating at 5 IΔn 24.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: Level 2 Kitchen [Schneider]	Supply to distribution board is from: Sub Mains(BB Dryslwyn, 4/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) N/A ms	
Designation: DB CL8	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC Type: gG Rating: 63 A Voltage: 230 V		Operating at 1 IΔn N/A ms	
Num. of ways: 18 Num. of phases: 1			Zs: 0.10 Ω No. of poles: N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr: 2.4 kA IΔn: N/A Operating at 5 IΔn N/A ms	
				Time delay (if applicable): N/A
				<b>Test instrument serial number(s)</b>
				Loop impedance: 100710/4664
				Insulation resistance: 100710/4664
				Continuity: 100710/4664
				RCD: 100710/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	m	r2												R1 + R2
1/L1	Bedroom Lighting 7,8	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.50	25.4	20.4	✓	N/A
2/L1	Bedroom Lighting 5,6	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.72	28.4	27.9	✓	N/A
3/L1	Bedroom Lighting 1,2	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.44	26.2	24.2	✓	N/A
4/L1	Bedroom Lighting 3,4	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.66	21.4	27.2	✓	N/A
5/L1	Common Room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.55	20.5	16.4	✓	N/A
6/L1	Common Room Ring	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.25	0.25	0.48	✓	0.18	N/A	250	LIM	>299	✓	0.40	28.4	21.4	✓	N/A
7/L1	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.21	0.21	0.53	✓	0.19	N/A	250	LIM	>299	✓	0.44	24.0	18.4	✓	N/A
8/L1	Hob 1	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.36	28.6	25.4	✓	N/A
9/L1	Hob 2	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.40	26.4	24.4	✓	N/A
10/L1	Sub Mains(DB CL8/10, DB CL8/10-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.24	0.24	0.34	✓	0.15	N/A	250	LIM	>299	✓	0.30	28.4	27.6	✓	N/A
11/L1	Sub Mains(DB CL8/11, DB CL8/11-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.26	0.26	0.38	✓	0.16	N/A	250	LIM	>299	✓	0.34	28.4	23.5	✓	N/A
12/L1	Sub Mains(DB CL8/12, DB CL8/12-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.31	0.31	0.38	✓	0.17	N/A	250	LIM	>299	✓	0.31	28.8	22.6	✓	N/A
13/L1	Sub Mains(DB CL8/13, DB CL8/13-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.36	0.36	0.44	✓	0.20	N/A	250	LIM	>299	✓	0.25	28.2	19.4	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 28/07/2022 To 28/07/2022 Date(s) live testing 28/07/2022 To 28/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 28/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL8, 10/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Designation DB CL8/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.30 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.75 kA IΔn 30 Operating at 5 IΔn 27.6 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.54	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)





# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL8, 11/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL8/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.4 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.34 Ω No. of poles 2 30mA or below		<b>Test instrument serial number(s)</b>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Ipf 0.68 kA IΔn 30 Operating at 5 IΔn 23.5 ms		Time delay (if applicable) N/A	
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL8, 12/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms	
Designation DB CL8/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		$Z_s$ 0.31 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			$I_{pn}$ 0.72 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 22.6 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted $Z_s$ Other 80%	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)





# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN		
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL8, 13/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)		
Designation DB CL8/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.2 ms		
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.25 Ω No. of poles 2 30mA or below		Test instrument serial number(s)	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Loop impedance 100701/4664		
			Insulation resistance 100701/4664		
			Continuity 100701/4664		
			RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN		
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	
Location Room 4 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL8, 13/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)		
Designation DB CL8/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.2 ms		
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.25 Ω No. of poles 2 30mA or below		Test instrument serial number(s)	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Loop impedance 100701/4664		
			Insulation resistance 100701/4664		
			Continuity 100701/4664		
			RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 11 [Schneider]	Supply to distribution board is from Sub Mains(BB Dryslwyn, 5/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL9	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V		Operating at 1 IΔn N/A ms	
Num. of ways 18 Num. of phases 1			30mA or below	
Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Operating at 5 IΔn N/A ms	
				Time delay (if applicable)
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)	
														r1	m	r2												R1 + R2
1/L2	Bedroom Lights	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.47	N/A	250	LIM	>299	✓	0.64	25.2	32.8	✓	N/A
2/L2	Bedroom Lights 2	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.36	N/A	250	LIM	>299	✓	0.52	29.4	27.4	✓	N/A
3/L2	Bedroom Lights 3	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.51	N/A	250	LIM	>299	✓	0.74	26.2	28.0	✓	N/A
4/L2	Common Room Lights	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.44	28.4	27.9	✓	N/A
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	Common Room Ring 1	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.34	29.2	27.4	✓	N/A
7/L2	Common Room Ring 2	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.24	0.24	0.31	✓	0.14	N/A	250	LIM	>299	✓	0.28	24.8	22.1	✓	N/A
8/L2	Hob 1	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.40	28.6	26.0	✓	N/A
9/L2	Hob 2	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.37	22.6	19.8	✓	N/A
10/L2	Sub Mains(DB CL9/10, DB CL9/10-1)	A	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.28	0.28	0.32	✓	0.15	N/A	250	LIM	>299	✓	0.31	28.8	25.4	✓	N/A
11/L2	Sub Mains(DB CL9/11, DB CL9/11-1, DB CL9/11-2)	A	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.24	0.26	0.38	✓	0.17	N/A	250	LIM	>299	✓	0.32	28.4	27.2	✓	N/A
12/L2	Sub Mains(DB CL9/12, DB CL9/12-1, DB CL9/12-2)	A	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.34	0.34	0.42	✓	0.19	N/A	250	LIM	>299	✓	0.44	28.8	26.2	✓	N/A
13/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 28/07/2022 To 28/07/2022 Date(s) live testing 28/07/2022 To 28/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 28/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL9, 10/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL9/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.31 Ω No. of poles 2 30mA or below		<b>Test instrument serial number(s)</b>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Ipr 0.75 kA IΔn 30 Operating at 5 IΔn 25.4 ms		Time delay (if applicable) N/A	
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A	
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 6 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL9, 10/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL9/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.31 Ω No. of poles 2 30mA or below		<b>Test instrument serial number(s)</b>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Ipf 0.75 kA IΔn 30 Operating at 5 IΔn 25.4 ms		Time delay (if applicable) N/A	
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.41	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL9, 11/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Designation DB CL9/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.32 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.73 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.45	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)





# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN		
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	
Location Room 9 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL9, 11/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)		
Designation DB CL9/11-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.4 ms		
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.32 Ω No. of poles 2 30mA or below		Test instrument serial number(s)	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Loop impedance 100701/4664		
			Insulation resistance 100701/4664		
			Continuity 100701/4664		
			RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.45	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL9, 12/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL9/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.44 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.55 kA IΔn 30 Operating at 5 IΔn 26.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.41	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location 5th Floor Dryslwyn [Schneider]	Supply to distribution board is from Sub Mains(BB Dryslwyn, 11/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) N/A ms	
Designation DB CL20	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V		Operating at 1 IΔn N/A ms	
Num. of ways 21 Num. of phases 1	BS(EN) 88-2 HRC		30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Type gG Rating 63 A Voltage 230 V		Ipr 1.83 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2	R2																			
1/L2	Bedroom Lighting 7,8,9	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.66	28.4	26.7	✓	N/A
2/L2	Bedroom Lighting 5,6	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.37	N/A	250	LIM	>299	✓	0.51	27.4	27.2	✓	N/A
3/L2	Bedroom Lighting 1,2,3	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.51	N/A	250	LIM	>299	✓	0.66	28.8	27.9	✓	N/A
4/L2	Bedroom Lighting 4	A	B	4	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.76	28.6	20.4	✓	N/A
5/L2	Common Room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.50	28.8	19.4	✓	N/A
6/L2	Common Room Ring 1	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.17	0.17	0.26	✓	0.11	N/A	250	LIM	>299	✓	0.25	28.4	26.4	✓	N/A
7/L2	Common Room Ring 2	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.23	0.23	0.31	✓	0.14	N/A	250	LIM	>299	✓	0.29	25.6	25.4	✓	N/A
8/L2	Hob 1	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.25	28.5	28.5	✓	N/A
9/L2	Hob 2	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.34	28.8	27.2	✓	N/A
10/L2	Sub Mains(DB CL20/10, DB CL20/10-1, DB CL20/10-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.33	0.33	0.52	✓	0.21	N/A	250	LIM	>299	✓	0.35	28.8	25.4	✓	N/A
11/L2	Sub Mains(DB CL20/11, DB CL20/11-1, DB CL20/11-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.37	0.37	0.52	✓	0.22	N/A	250	LIM	>299	✓	0.38	28.4	27.2	✓	N/A
12/L2	Sub Mains(DB CL20/12, DB CL20/12-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.44	0.44	0.63	✓	0.27	N/A	250	LIM	>299	✓	0.44	27.6	27.4	✓	N/A
13/L2	Executive Room Ring	A	B	12	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.71	0.72	1.28	✓	0.50	N/A	250	LIM	>299	✓	0.84	28.4	27.2	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 29/07/2022 To 29/07/2022 Date(s) live testing 29/07/2022 To 29/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 29/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/EICR 110151231



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS														TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	DB CL20				Circuit designation	L/N		OPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)
															r1	m	r2		R1 + R2	R2									
14/L2	Executive Room Kitchen Ring	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.70	0.70	0.88	✓	0.40	N/A	250	LIM	>299	✓	0.51	26.2	22.4	✓	N/A	
15/L2	Executive Room Cooker	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.59	30.4	28.4	✓	N/A	
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
19/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
20/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
21/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 29/07/2022 To 29/07/2022 Date(s) live testing 29/07/2022 To 29/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 29/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL20, 10/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL20/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.35 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr 0.61 kA IΔn 30 Operating at 5 IΔn 25.4 ms	
		Time delay (if applicable) N/A		<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)









# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL20, 11/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Designation DB CL20/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.38 Ω	No. of poles 2
Num. of ways 4	Num. of phases 1		Ipf 0.61 kA	IΔn 30
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		Operating at 5 IΔn 27.2 ms	
			Time delay (if applicable) N/A	<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.77	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)





# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room X Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL20, 12/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 27.6 ms	
Designation DB CL20/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.44 Ω No. of poles 2 30mA or below Ipr 0.58 kA IΔn 30 Operating at 5 IΔn 27.4 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.77	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location 4th Floor Kitchen Dryslwyn [Schneider]	Supply to distribution board is from Sub Mains(BB Dryslwyn, 9/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) N/A ms	
Designation DB CL16	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V		Operating at 1 IΔn N/A ms	
Num. of ways 18 Num. of phases 1			Zs 0.10 Ω No. of poles N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr 2.05 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	m	r2												R1 + R2
1/L3	Bedroom Lighting 8,9,10	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.36	N/A	250	LIM	>299	✓	0.62	28.4	24.8	✓	N/A
2/L3	Bedroom Lighting 6,7	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.47	N/A	250	LIM	>299	✓	0.54	28.8	26.8	✓	N/A
3/L3	Bedroom Lighting 4,5	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.55	N/A	250	LIM	>299	✓	0.80	27.4	27.2	✓	N/A
4/L3	Bedroom Lighting 1,2,3	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.72	28.8	26.9	✓	N/A
5/L3	Common Room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.27	N/A	250	LIM	>299	✓	0.54	29.0	27.2	✓	N/A
6/L3	Common Room Ring	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.25	0.25	0.42	✓	0.17	N/A	250	LIM	>299	✓	0.27	28.4	28.0	✓	N/A
7/L3	Common Room Ring 2	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.27	0.27	0.48	✓	0.19	N/A	250	LIM	>299	✓	0.32	28.8	25.4	✓	N/A
8/L3	Hob 1	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.40	26.4	27.2	✓	N/A
9/L3	Hob 2	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.38	28.4	18.4	✓	N/A
10/L3	Sub Mains(DB CL16/10, DB CL16/10-1, DB CL16/10-2)	A	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.37	0.37	0.47	✓	0.21	N/A	250	LIM	>299	✓	0.33	28.4	22.1	✓	N/A
11/L3	Sub Mains(DB CL16/11, DB CL16/11-1, DB CL16/11-2)	A	B	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.36	0.36	0.45	✓	0.20	N/A	250	LIM	>299	✓	0.36	28.8	27.9	✓	N/A
12/L3	Sub Mains(DB CL16/12, DB CL16/12-1)	A	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.57	✓	0.25	N/A	250	LIM	>299	✓	0.32	28.6	29.0	✓	N/A
13/L3	Sub Mains(DB CL16/13, DB CL16/13-1)	A	B	2	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.42	0.61	✓	0.25	N/A	250	LIM	>299	✓	0.36	28.6	27.7	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 29/07/2022 To 29/07/2022 Date(s) live testing 29/07/2022 To 29/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 29/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																									
Circuit No. and Line No.	Distribution board Designation DB CL16 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation												
					L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)											
														r1	m	r2												R1 + R2	R2									
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	80%	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 29/07/2022 To 29/07/2022 Date(s) live testing 29/07/2022 To 29/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 29/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)







# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 10 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL16, 10/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Designation DB CL16/10-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.33 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.70 kA IΔn 30 Operating at 5 IΔn 22.1 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL16, 11/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL16/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.36 Ω No. of poles 2 30mA or below Ipf 0.68 kA IΔn 30 Operating at 5 IΔn 27.9 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL16, 11/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms	
Designation DB CL16/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.36 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			I <sub>pn</sub> 0.68 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 27.9 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
		Loop impedance 100701/4664		
		Insulation resistance 100701/4664		
		Continuity 100701/4664		
		RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% ( $\Omega$ )	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured Zs ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )			
														r1	m	r2										Fig 8 check ( $\checkmark$ )	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	$\checkmark$	0.65	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL16, 11/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL16/11-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.36 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.68 kA IΔn 30 Operating at 5 IΔn 27.9 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 6 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL16, 12/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.6 ms	
Designation DB CL16/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.32 Ω No. of poles 2 Operating at 5 IΔn 29.0 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL16, 12/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.6 ms	
Designation DB CL16/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.32 Ω No. of poles 2 Operating at 5 IΔn 29.0 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 4 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL16, 13/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.6 ms	
Designation DB CL16/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.36 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.70 kA IΔn 30 Operating at 5 IΔn 27.7 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.72	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL16, 13/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.6 ms	
Designation DB CL16/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.36 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.70 kA IΔn 30 Operating at 5 IΔn 27.7 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFCD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.26	N/A	250	LIM	>299	✓	0.67	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location 4th Floor RHS Kitchen Dryslwyn [Schneider]	Supply to distribution board is from Sub Mains(BB Dryslwyn, 10/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) N/A Operating at 1 IΔn N/A ms	
Designation DB CL17	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V		Zs 0.12 Ω No. of poles N/A 30mA or below	
Num. of ways 18 Num. of phases 1	BS(EN) 88-2 HRC		Ipr 1.77 kA IΔn N/A Operating at 5 IΔn N/A ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFCD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Bedroom Lighting 5,6,7	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.36	N/A	250	LIM	>299	✓	0.58	26.2	22.1	✓	N/A
2/L1	Bedroom Lighting 8,9	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.62	28.0	27.9	✓	N/A
3/L1	Bedroom Lighting 1,2,3	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.67	25.2	20.5	✓	N/A
4/L1	Common Room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.42	27.8	27.2	✓	N/A
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Common Room Ring 1	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.29	0.29	0.44	✓	0.18	N/A	250	LIM	>299	✓	0.35	28.8	27.2	✓	N/A
7/L1	Common Room Ring 2	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.27	0.27	0.38	✓	0.16	N/A	250	LIM	>299	✓	0.30	27.0	27.0	✓	N/A
8/L1	Hob 1	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	LIM	0.14	N/A	250	LIM	>299	✓	0.29	28.8	27.9	✓	N/A
9/L1	Hob 2	A	B	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.32	28.6	27.2	✓	N/A
10/L1	Sub Mains(DB CL17/10, DB CL17/10-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.32	0.32	0.40	✓	0.18	N/A	250	LIM	>299	✓	0.34	27.2	22.6	✓	N/A
11/L1	Sub Mains(DB CL17/11, DB CL17/11-1, DB CL17/11-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.37	0.40	0.48	✓	0.21	N/A	250	LIM	>299	✓	0.38	26.2	28.4	✓	N/A
12/L1	Sub Mains(DB CL17/12, DB CL17/12-1, DB CL17/12-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.50	0.50	0.67	✓	0.29	N/A	250	LIM	>299	✓	0.46	28.8	20.2	✓	N/A
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 29/07/2022 To 29/07/2022 Date(s) live testing 29/07/2022 To 29/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 29/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																									
Circuit No. and Line No.	Distribution board Designation DB CL17 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation											
					L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Idn ms			30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)											
														r1	m	r2												R1 + R2	R2									
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 29/07/2022 To 29/07/2022 Date(s) live testing 29/07/2022 To 29/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 29/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)





# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL17, 11/L1)	Associated RCD(if any): BS (EN) 61008		Above 30mA (if applicable) Operating at 1 $\Delta n$ 26.2 ms
Designation DB CL17/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	$Z_s$ 0.38 $\Omega$	No. of poles 2	30mA or below
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	$I_{pn}$ 0.58 kA	$\Delta n$ 30	Operating at 5 $\Delta n$ 28.4 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A		<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted $Z_s$ Other 80% ( $\Omega$ )	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )			
														r1	m	r2										Fig 8 check ( $\checkmark$ )	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	$\checkmark$	0.70	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL17, 11/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 26.2 ms	
Designation DB CL17/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Z <sub>s</sub> 0.38 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			I <sub>pn</sub> 0.58 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 28.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z <sub>s</sub> Other 80% ( $\Omega$ )	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured Z <sub>s</sub> ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )			
														r1	m	r2												
					Fig 8 check ( $\checkmark$ )			All circuits to be completed using R1R2 or R2, not both		R1 + R2				R2														
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	$\checkmark$	0.66	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 9 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL17, 11/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL17/11-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 26.2 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.38 Ω No. of poles 2 30mA or below		<b>Test instrument serial number(s)</b>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Ipf 0.58 kA IΔn 30 Operating at 5 IΔn 28.4 ms		Time delay (if applicable) N/A	
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL17, 12/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL17/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.46 Ω No. of poles 2 Operating at 5 IΔn 20.2 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL17, 12/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms	
Designation DB CL17/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.46 $\Omega$ No. of poles 2 Operating at 5 $\Delta n$ 20.2 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs ( $\Omega$ )	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL17, 12/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms	
Designation DB CL17/12-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		$Z_s$ 0.46 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			$I_{pn}$ 0.50 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 20.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted $Z_s$ Other 80% ( $\Omega$ )	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )			
														r1	m	r2										Fig 8 check ( $\checkmark$ )	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	$\checkmark$	0.68	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 14 Kitchen (Schneider)	Supply to distribution board is from Sub Mains(BB Dryslwyn, 6/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) <input type="checkbox"/> Operating at 1 IΔn <input type="checkbox"/> ms	
Designation DB CL12	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V		Zs 0.09 Ω No. of poles N/A 30mA or below	
Num. of ways 18 Num. of phases 1			Ipr 2.50 kA IΔn N/A Operating at 5 IΔn <input type="checkbox"/> ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) NA	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	m	r2												R1 + R2
1/L3	Bedroom Lights 7,8	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.40	N/A	250	LIM	>299	✓	0.50	28.7	29.7	✓	N/A
2/L3	Bedroom Lights 5,6	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.49	28.7	28.6	✓	N/A
3/L3	Bedroom Lights 1,2	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.26	N/A	250	LIM	>299	✓	0.37	29.7	28.6	✓	N/A
4/L3	Bedroom Lights 3,4	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	✓	0.40	28.7	29.6	✓	N/A
5/L3	Common Room Lights	A	E	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.25	28.7	28.7	✓	N/A
6/L3	Common Room Ring 1	A	E	3	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.28	0.25	0.42	✓	0.17	N/A	250	LIM	>299	✓	0.24	28.7	29.6	✓	N/A
7/L3	Common Room Ring 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.33	0.35	0.60	✓	0.23	N/A	250	LIM	>299	✓	0.26	29.7	28.7	✓	N/A
8/L3	Common Room Cooker 1	A	E	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.17	28.7	29.7	✓	N/A
9/L3	Common Room Cooker 2	A	E	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.16	29.7	37.6	✓	N/A
10/L3	Sub Mains(DB CL12/10, DB CL12/10-1)	A	E	8	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.31	0.31	0.53	✓	0.21	N/A	250	LIM	>299	✓	0.33	29.7	28.7	✓	N/A
11/L3	Sub Mains(DB CL12/11, DB CL12/11-1)	A	E	9	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.41	0.63	✓	0.25	N/A	250	LIM	>299	✓	0.35	28.7	29.7	✓	N/A
12/L3	Sub Mains(DB CL12/12, DB CL12/12-1)	A	E	8	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.66	✓	0.26	N/A	250	LIM	>299	✓	0.36	28.7	29.7	✓	N/A
13/L3	Sub Mains(DB CL12/13, DB CL12/13-1)	A	E	8	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.48	0.49	0.72	✓	0.30	N/A	250	LIM	>299	✓	0.42	28.7	28.7	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 29/07/2022 To 29/07/2022 Date(s) live testing 29/07/2022 To 29/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 29/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z <sub>s</sub> Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation				
	DB CL12				L / N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
	Circuit designation													r1	m	r2												R1 + R2	R2	
14/L3	SPARE												N/A	N/A	N/A	N/A												N/A	N/A	
15/L3	SPARE												N/A	N/A	N/A	N/A													N/A	N/A
16/L3	SPARE												N/A	N/A	N/A	N/A													N/A	N/A
17/L3	SPARE												N/A	N/A	N/A	N/A													N/A	N/A
18/L3	SPARE												N/A	N/A	N/A	N/A													N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing  To  Date(s) live testing  To

Tested by: Name (capital letters)  Position  Date

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL12, 10/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 29.7 ms	
Designation DB CL12/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.33 Ω No. of poles 2 Operating at 5 IΔn 28.7 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.73	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL12, 10/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 29.7 ms	
Designation DB CL12/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.33 Ω No. of poles 2 Operating at 5 IΔn 28.7 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL12, 11/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL12/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.7 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.35 Ω No. of poles 2 30mA or below		Test instrument serial number(s)
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Ipr 0.65 kA IΔn 30 Operating at 5 IΔn 29.7 ms		Time delay (if applicable) N/A	
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location: Room 2 Riser [Schneider] Designation: DB CL12/11-1 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Supply to distribution board is from: Sub Mains (DB CL12, 11/L3) Overcurrent protective device for the distribution circuit: Type: B BS(EN) 61009 RCD/RCBO Rating: 32 A Voltage: 230 V	Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 Δn 28.7 ms Zs: 0.35 Ω No. of poles: 2 30mA or below Ipf: 0.65 kA Δn: 30 Operating at 5 Δn 29.7 ms Time delay (if applicable): N/A	Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Δn ms	30mA or below 5 Δn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 26/07/2022 To: 26/07/2022 Date(s) live testing: 26/07/2022 To: 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 26/07/2022

Signature:

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance		<b>Company Address</b> Kid Glove Road		<b>Postcode</b> WA3 3GR	<b>Branch No.</b>		<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd		<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN			

<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			<b>Characteristics at this distribution board</b>			<b>Test instrument serial number(s)</b>					
Location	Room 5 Riser [Schneider]		Supply to distribution board is from	Sub Mains(DB CL12, 12/L3)		Associated RCD(if any): BS (EN)	Above 30mA (if applicable)		Loop impedance	100701/4664				
Designation	DB CL12/12		Overcurrent protective device for the distribution circuit:	Type	B	Rating	32	A	Operating at 1 IΔn	28.7 ms				
Num. of ways	4	Num. of phases	BS(EN) 61009 RCD/RCBO		Type		B	Rating	32	A	Operating at 5 IΔn	Insulation resistance	100701/4664	
Supply polarity confirmed <input checked="" type="checkbox"/>		Phase sequence confirmed <input type="checkbox"/>		Voltage		230		V	I <sub>pr</sub>	0.62 kA		Continuity	100701/4664	
						Time delay (if applicable)			N/A			RCD	100701/4664	

### CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	CIRCUIT DETAILS													TEST RESULTS																							
	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation											
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)												
	r1	m	r2	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both																																
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A	N/A	N/A							
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A						
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A						
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A					

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance		<b>Company Address</b> Kid Glove Road		<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd		<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>				<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: Room 6 Riser [Schneider]		Supply to distribution board is from: Sub Mains(DB CL12, 12/L3)		Associated RCD(if any): BS (EN) 61008		Test instrument serial number(s)
Designation: DB CL12/12-1		Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.7 ms		
Num. of ways: 4    Num. of phases: 1		Type: B    Rating: 32 A    Voltage: 230 V		Zs: 0.36 Ω    No. of poles: 2		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 29.7 ms		Loop impedance: 100701/4664
				Time delay (if applicable): N/A		Insulation resistance: 100701/4664
						Continuity: 100701/4664
						RCD: 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL12/12-1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing      Date(s) dead testing: 26/07/2022 To 26/07/2022      Date(s) live testing: 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE      Position: Electrical Test Engineer      Date: 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL12, 13/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.7 ms	
Designation DB CL12/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.42 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.53 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 28.7 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
			<b>Test instrument serial number(s)</b>	
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% ( $\Omega$ )	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured Zs ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )			
														r1	m	r2												
					Fig 8 check ( $\checkmark$ )			All circuits to be completed using R1R2 or R2, not both		R1 + R2				R2														
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	$\checkmark$	0.74	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 4 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL12, 13/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL12/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.7 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.42 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr 0.53 kA IΔn 30 Operating at 5 IΔn 28.7 ms	
		Time delay (if applicable) N/A		<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	Postcode SA1 8EN		
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Room 4 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL2, 10/L2)	Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 Δn 28.8 ms		Test instrument serial number(s)
Designation DB CL2/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V	Z <sub>s</sub> 0.40 Ω No. of poles 2	Loop impedance 100701/4664	
Num. of ways 4 Num. of phases 1		I <sub>pn</sub> 0.52 kA Δn 30 Operating at 5 Δn 27.6 ms	Insulation resistance 100701/4664	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z <sub>s</sub> Other 80%	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Δn ms			30mA or below 5 Δn ms	RCD (✓)	AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A	
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL2, 10/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL2/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.40 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipf 0.52 kA IΔn 30 Operating at 5 IΔn 27.6 ms	
		Time delay (if applicable) N/A		<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN

<b>Distribution board details - Complete in every case</b> Location: Room 6 Riser [Schneider] Designation: DB CL2/10-2 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Supply to distribution board is from: Sub Mains (DB CL2, 10/L2) Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: B Rating: 32 A Voltage: 230 V	<b>Characteristics at this distribution board</b> Associated RCD(if any): BS (EN) 61008 Operating at 1 IΔn: 28.8 ms Above 30mA (if applicable) Zs: 0.40 Ω No. of poles: 2 30mA or below Ipr: 0.52 kA IΔn: 30 Operating at 5 IΔn: 27.6 ms Time delay (if applicable): N/A	<b>Test instrument serial number(s)</b> Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664
--	---	---	---

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFCD (✓)					
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both			
																R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.77	N/A	N/A	N/A	N/A		
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL2, 11/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL2/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.46 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.50 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL2, 11/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL2/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.46 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.50 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.79	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL2, 11/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL2/11-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.46 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.50 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
		Loop impedance 100701/4664		
		Insulation resistance 100701/4664		
		Continuity 100701/4664		
		RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL2, 12/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL2/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.4 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.36 Ω No. of poles 2 30mA or below		<b>Test instrument serial number(s)</b>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Ipf 0.62 kA IΔn 30 Operating at 5 IΔn 18.5 ms		Time delay (if applicable) N/A	
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.84	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL2, 12/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Designation DB CL2/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.36 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.62 kA IΔn 30 Operating at 5 IΔn 18.5 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location Room X Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL2, 12/L2)		<b>Characteristics at this distribution board</b>	
Designation DB CL2/12-2	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Num. of ways 4 Num. of phases 1			Zs 0.36 Ω No. of poles 2 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipf 0.62 kA IΔn 30 Operating at 5 IΔn 18.5 ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.82	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL3, 9/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 27.4 ms	
Designation DB CL3/9	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.36 Ω No. of poles 2 Operating at 5 IΔn 27.2 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.95	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 6 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL3, 9/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL3/9-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 27.4 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.36 Ω No. of poles 2 30mA or below		Test instrument serial number(s)
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Ipf 0.64 kA IΔn 30 Operating at 5 IΔn 27.2 ms		Time delay (if applicable) N/A	
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL3, 9/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 27.4 ms	
Designation DB CL3/9-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.36 Ω No. of poles 2 Operating at 5 IΔn 27.2 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
																											R1 + R2	R2
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL3, 10/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL3/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.4 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.34 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Ipr 0.68 kA IΔn 30 Operating at 5 IΔn 26.5 ms	
			<b>Test instrument serial number(s)</b>	
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL3, 10/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Designation DB CL3/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.34 Ω No. of poles 2 Operating at 5 IΔn 26.5 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.77	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location: Room 3 Riser [Schneider] Designation: DB CL3/10-2 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Supply to distribution board is from: Sub Mains (DB CL3, 10/L1) Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: B Rating: 32 A Voltage: 230 V	Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ : 28.4 ms $Z_s$ : 0.34 $\Omega$ No. of poles: 2 30mA or below $I_{pn}$ : 0.68 kA $\Delta n$ : 30 Operating at 5 $\Delta n$ : 26.5 ms Time delay (if applicable): N/A	Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664

### CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs ( $\Omega$ )	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms	RCD (✓)			AFDD (✓)					
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both			
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.67	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 3 [Schneider]	Supply to distribution board is from		Associated RCD (if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL6	Sub Mains(BB Nest, 2/TP)		N/A Operating at 1 IΔn N/A ms	
Num. of ways 18	Num. of phases 1	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC	Zs 0.11 Ω No. of poles N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Type gG Rating 63 A Voltage 400 V	Ipr 2.02 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	r1	m			r2	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1+R2 R2	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														Fig 8 check (✓)		R1+R2														
					Circuit designation																									
1/L1	Bedroom Lighting 6,7	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.56	29.5	28.5	✓	N/A		
2/L1	Bedroom Lighting 8,9	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.64	28.4	20.4	✓	N/A		
3/L1	Bedroom Lighting 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.58	28.8	27.9	✓	N/A		
4/L1	Bedroom Lighting 1,2	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.72	27.4	24.2	✓	N/A		
5/L1	Common Room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.55	29.0	27.2	✓	N/A		
6/L1	Common Room Ring	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.36	0.36	0.52	✓	0.22	N/A	250	LIM	>299	✓	0.36	28.4	25.2	✓	N/A		
7/L1	Common Room Ring 2	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.36	0.36	0.55	✓	0.23	N/A	250	LIM	>299	✓	0.40	29.2	27.5	✓	N/A		
8/L1	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A		
9/L1	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A		
10/L1	Sub Mains(DB CL6/10, DB CL6/10-1, DB CL6/10-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.53	0.50	0.62	✓	0.29	N/A	250	LIM	>299	✓	0.44	28.7	29.4	✓	N/A		
11/L1	Sub Mains(DB CL6/11, DB CL6/11-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.46	0.46	0.77	✓	0.31	N/A	250	LIM	>299	✓	0.48	28.5	25.1	✓	N/A		
12/L1	Sub Mains(DB CL6/12, DB CL6/12-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.65	✓	0.26	N/A	250	LIM	>299	✓	0.42	28.8	22.6	✓	N/A		
13/L1	Sub Mains(DB CL6/13, DB CL6/13-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.55	✓	0.24	N/A	250	LIM	>299	✓	0.36	28.8	26.4	✓	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 01/08/2022 To 01/08/2022 Date(s) live testing 01/08/2022 To 01/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 01/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																					
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation							
	DB CL6				Circuit designation	L/N		OPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA Δn ms	30mA or below 5 Δn ms	RCD (✓)	AFDD (✓)					
															r1	m	r2		R1 + R2	R2														
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 01/08/2022 To 01/08/2022 Date(s) live testing 01/08/2022 To 01/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 01/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL6, 10/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.7 ms	
Designation DB CL6/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		$Z_s$ 0.44 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			$I_{pn}$ 0.50 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 29.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted $Z_s$ Other 80%	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 4 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL6, 10/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.7 ms	
Designation DB CL6/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.44 Ω No. of poles 2 30mA or below Ipr 0.50 kA IΔn 30 Operating at 5 IΔn 29.4 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.63	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location: Room 5 Riser [Schneider]	Supply to distribution board is from: Sub Mains(DB CL6, 10/L1)	Associated RCD(if any): BS (EN) 61008	Loop impedance: 100701/4664
Designation: DB CL6/10-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V	Operating at 1 IΔn 28.7 ms	Insulation resistance: 100701/4664
Num. of ways: 4 Num. of phases: 1		Zs 0.44 Ω No. of poles 2	Continuity: 100701/4664
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Ipf 0.50 kA IΔn 30 Operating at 5 IΔn 29.4 ms	RCD: 100701/4664
		Time delay (if applicable) N/A	

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 6 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL6, 11/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.5 ms	
Designation DB CL6/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.48 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.48 kA IΔn 30 Operating at 5 IΔn 25.1 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	<b>Postcode</b> SA1 8EN			
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL6, 11/L1)	Associated RCD(if any): BS (EN) 61008	Above 30mA (if applicable) Operating at 1 Δn 28.5 ms	Loop impedance 100701/4664	
Designation DB CL6/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Zs 0.48 Ω	No. of poles 2	Insulation resistance 100701/4664	
Num. of ways 4	Type B Rating 32 A Voltage 230 V	Ipf 0.48 kA Δn 30	Operating at 5 Δn 25.1 ms	Continuity 100701/4664	
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL6/11-1	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Δn ms	30mA or below 5 Δn ms			RCD (✓)	AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2														
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.65	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL6, 12/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms	
Designation DB CL6/12	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Zs 0.42 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.60 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 22.6 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% ( $\Omega$ )	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured Zs ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms	RCD ( $\checkmark$ )			AFDD ( $\checkmark$ )				
														r1	m	r2										Fig 8 check ( $\checkmark$ )	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2														
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	$\checkmark$	0.65	N/A	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL6, 12/L1)	Associated RCD(if any): BS (EN) 61008		Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms
Designation DB CL6/12-1	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Zs 0.42 Ω	No. of poles 2	30mA or below Operating at 5 IΔn 22.6 ms
Num. of ways 4 Num. of phases 1		Ipf 0.60 kA	IΔn 30	Time delay (if applicable) N/A
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.75	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL6, 13/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL6/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.36 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.64 kA IΔn 30 Operating at 5 IΔn 26.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	<b>Postcode</b> SA1 8EN			
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location Room X Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL6, 13/L1)	Associated RCD(if any): BS (EN) 61008	Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms	Loop impedance 100701/4664	
Designation DB CL6/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	$Z_s$ 0.36 $\Omega$	No. of poles 2	30mA or below	Insulation resistance 100701/4664
Num. of ways 4	Type B Rating 32 A Voltage 230 V	$I_{pn}$ 0.64 kA	$\Delta n$ 30	Operating at 5 $\Delta n$ 26.4 ms	Continuity 100701/4664
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted $Z_s$ Other 80% ( $\Omega$ )	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms	RCD ( $\checkmark$ )			AFDD ( $\checkmark$ )				
														r1	m	r2										Fig 8 check ( $\checkmark$ )	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2														
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	$\checkmark$	0.76	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 4 Nest [Schneider]	Supply to distribution board is from Sub Mains(BB Nest, 3/L2)		Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) ms	
Designation DB CL7	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC Type gG Rating 63 A Voltage 230 V		Operating at 1 IΔn N/A ms	
Num. of ways 18 Num. of phases 1			Zs 0.14 Ω No. of poles N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr 1.9 kA IΔn N/A Operating at 5 IΔn N/A ms	
				Time delay (if applicable) N/A
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Bedroom Lighting 7,8	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.46	N/A	250	LIM	>299	✓	0.75	28.8	27.4	✓	N/A
2/L2	Bedroom Lighting 5,6	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.82	28.2	27.9	✓	N/A
3/L2	Bedroom Lighting 1,2	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.67	28.9	25.2	✓	N/A
4/L2	Bedroom Lighting 3,4	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.55	N/A	250	LIM	>299	✓	0.70	25.8	27.9	✓	N/A
5/L2	Kitchen Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.32	N/A	250	LIM	>299	✓	0.55	28.5	28.2	✓	N/A
6/L2	Common Room Ring	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.57	✓	0.25	N/A	250	LIM	>299	✓	0.42	28.5	26.0	✓	N/A
7/L2	Common Room Ring 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.37	0.37	0.49	✓	0.22	N/A	250	LIM	>299	✓	0.40	28.8	25.4	✓	N/A
8/L2	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
9/L2	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
10/L2	Sub Mains(DB CL7/10, DB CL7/10-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.34	0.34	0.48	✓	0.21	N/A	250	LIM	>299	✓	0.37	28.4	22.2	✓	N/A
11/L2	Sub Mains(DB CL7/11, DB CL7/11-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.62	✓	0.26	N/A	250	LIM	>299	✓	0.44	28.8	24.0	✓	N/A
12/L2	Sub Mains(DB CL7/12, DB CL7/12-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.36	0.36	0.62	✓	0.25	N/A	250	LIM	>299	✓	0.38	26.5	22.0	✓	N/A
13/L2	Sub Mains(DB CL7/13, DB CL7/13-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.38	0.38	0.52	✓	0.23	N/A	250	LIM	>299	✓	0.40	28.8	27.2	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 02/08/2022 To 02/08/2022 Date(s) live testing 02/08/2022 To 02/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 02/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL7, 10/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Designation DB CL7/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.37 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.61 kA IΔn 30 Operating at 5 IΔn 22.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.									
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan				Postcode	SA1 8EN									
<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>				<b>Characteristics at this distribution board</b>										
Location	Room 8 Riser [Schneider]		Supply to distribution board is from				Associated RCD(if any):	BS (EN)	Above 30mA (if applicable)								
Designation	DB CL7/10-1		Sub Mains(DB CL7, 10/L2)				Zs	61008	Operating at 1 ΔIn	28.4 ms							
Num. of ways	4	Num. of phases	1	Overcurrent protective device for the distribution circuit:				Type	B	Rating	32 A	Voltage	230 V	Operating at 5 ΔIn	22.2 ms	<b>Test instrument serial number(s)</b> Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664	
Supply polarity confirmed		<input checked="" type="checkbox"/>		Phase sequence confirmed		<input type="checkbox"/>		Time delay (if applicable)		N/A							

CIRCUIT DETAILS												TEST RESULTS																						
Circuit No. and Line No.	Distribution board Designation		Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation							
	DB CL7/10-1					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA ΔIn ms	30mA or below 5 ΔIn ms			RCD (✓)	AFDD (✓)								
	r1	m													r2	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both																	
1/L2	Sockets		A	B	6	2.5	1.5	0.4	60898	MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.72	N/A	N/A	N/A	N/A				
2/L2	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				
3/L2	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				
4/L2	SPARE		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL7, 11/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL7/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.44 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.51 kA IΔn 30 Operating at 5 IΔn 24.0 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 6 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL7, 11/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL7/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.44 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipf 0.51 kA IΔn 30 Operating at 5 IΔn 24.0 ms	
		Time delay (if applicable) N/A		<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.75	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL7, 12/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL7/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 26.5 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.38 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Ipf 0.62 kA IΔn 30 Operating at 5 IΔn 22.0 ms	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL7, 12/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 26.5 ms	
Designation DB CL7/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.38 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.62 kA IΔn 30 Operating at 5 IΔn 22.0 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.69	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	<b>Postcode</b> SA1 8EN			
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL7, 13/L2)	Associated RCD(if any): BS (EN) 61008		Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	Loop impedance 100701/4664
Designation DB CL7/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Zs 0.40 Ω	No. of poles 2	30mA or below Ipf 0.58 kA IΔn 30	Insulation resistance 100701/4664
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Operating at 5 IΔn 27.2 ms		Time delay (if applicable) N/A	Continuity 100701/4664
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
																R1 + R2	R2											
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.80	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room X Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL7, 13/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL7/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.40 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.50 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.77	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 5 Nest [Schneider]	Supply to distribution board is from Sub Mains(BB Nest, 4/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) N/A ms	
Designation DB CL10	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC Type gG Rating 63 A Voltage 230 V		Operating at 1 IΔn N/A ms	
Num. of ways 18 Num. of phases 1			Zs 0.12 Ω No. of poles N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr 2.0 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
			<b>Test instrument serial number(s)</b>	
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Bedroom Lighting 6,7	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.74	32.0	25.2	✓	N/A
2/L3	Bedroom Lighting 8,9	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.55	N/A	250	LIM	>299	✓	0.73	28.8	27.2	✓	N/A
3/L3	Bedroom Lighting 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.36	N/A	250	LIM	>299	✓	0.46	28.4	24.2	✓	N/A
4/L3	Bedroom Lighting 1,2	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.55	N/A	250	LIM	>299	✓	0.72	28.4	25.2	✓	N/A
5/L3	Common Room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.40	27.6	20.4	✓	N/A
6/L3	Common Room Ring	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.44	0.44	0.58	✓	0.26	N/A	250	LIM	>299	✓	0.36	28.8	27.9	✓	N/A
7/L3	Common Room Ring 2	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.37	0.37	0.44	✓	0.21	N/A	250	LIM	>299	✓	0.33	28.4	18.4	✓	N/A
8/L3	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
9/L3	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
10/L3	Sub Mains(DB CL10/10, DB CL10/10-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.25	0.25	0.36	✓	0.15	N/A	250	LIM	>299	✓	0.28	28.5	27.5	✓	N/A
11/L3	Sub Mains(DB CL10/11, DB CL10/11-1, DB CL10/11-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.53	✓	0.23	N/A	250	LIM	>299	✓	0.35	28.8	22.0	✓	N/A
12/L3	Sub Mains(DB CL10/12, DB CL10/12-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.45	✓	0.19	N/A	250	LIM	>299	✓	0.32	28.8	24.4	✓	N/A
13/L3	Sub Mains(DB CL10/13, DB CL10/13-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.36	0.36	0.52	✓	0.22	N/A	250	LIM	>299	✓	0.35	28.2	27.6	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 02/08/2022 To 02/08/2022 Date(s) live testing 02/08/2022 To 02/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 02/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																								
Circuit No. and Line No.	Distribution board Designation DB CL10 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation											
					L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)										
														r1	m	r2												R1 + R2	R2								
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 02/08/2022 To 02/08/2022 Date(s) live testing 02/08/2022 To 02/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 02/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	<b>Postcode</b> SA1 8EN			
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	
Location Room 4 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL10, 10/L3)	Associated RCD(if any): BS (EN) 61008		Above 30mA (if applicable) Operating at 1 Δn 28.5 ms 30mA or below Operating at 5 Δn 27.5 ms	
Designation DB CL10/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V	Zs 0.28 Ω	No. of poles 2		
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Ipr 0.80 kA	Δn 30		
				Time delay (if applicable) N/A	<b>Test instrument serial number(s)</b>
					Loop impedance 100701/4664
					Insulation resistance 100701/4664
					Continuity 100701/4664
					RCD 100701/4664

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Δn ms	30mA or below 5 Δn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL10, 10/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.5 ms	
Designation DB CL10/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.28 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.80 kA IΔn 30 Operating at 5 IΔn 27.5 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.77	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL10, 11/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms	
Designation DB CL10/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.35 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.72 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 22.0 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
		Loop impedance 100701/4664		
		Insulation resistance 100701/4664		
		Continuity 100701/4664		
		RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% ( $\Omega$ )	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs ( $\Omega$ )	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.73	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL10, 11/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL10/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.35 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.72 kA IΔn 30 Operating at 5 IΔn 22.0 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2														
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.78	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)





# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: Room 6 Riser [Schneider]	Supply to distribution board is from: Sub Mains (DB CL10, 12/L3)		Associated RCD (if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms	
Designation: DB CL10/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.32 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.82 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 24.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
		Loop impedance 100701/4664		
		Insulation resistance 100701/4664		
		Continuity 100701/4664		
		RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.65	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL10, 12/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL10/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 $\Delta n$ 28.8 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.32 $\Omega$ No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Ipr 0.82 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 24.4 ms	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs ( $\Omega$ )	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD (✓)	AFCD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL10, 13/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms	
Designation DB CL10/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.35 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.79 kA IΔn 30 Operating at 5 IΔn 27.6 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room X Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL10, 13/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms	
Designation DB CL10/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.35 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.79 kA IΔn 30 Operating at 5 IΔn 27.6 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 7 Nest [Schneider]	Supply to distribution board is from Sub Mains(BB Nest, 6/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) ms	
Designation DB CL14	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V		Operating at 1 IΔn N/A ms	
Num. of ways 18	Num. of phases 1	BS(EN) 88-2 HRC	30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Type gG Rating 63 A Voltage 230 V	Ipr 1.6 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	m	r2												R1 + R2
1/L2	Bedroom Lighting 6,7	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.32	N/A	250	LIM	>299	✓	0.60	28.4	26.4	✓	N/A
2/L2	Bedroom Lighting 8,9	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.69	28.6	27.2	✓	N/A
3/L2	Bedroom Lighting 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.51	N/A	250	LIM	>299	✓	0.72	28.8	27.9	✓	N/A
4/L2	Bedroom Lighting 1,2	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.62	29.4	28.0	✓	N/A
5/L2	Common Room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.54	28.8	22.8	✓	N/A
6/L2	Common Room Ring 1	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.34	0.34	0.46	✓	0.20	N/A	250	LIM	>299	✓	0.34	28.4	26.4	✓	N/A
7/L2	Common Room Ring 2	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.54	✓	0.24	N/A	250	LIM	>299	✓	0.53	28.8	24.4	✓	N/A
8/L2	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
9/L2	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
10/L2	Sub Mains(DB CL14/10, DB CL14/10-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.24	0.24	0.44	✓	0.19	N/A	250	LIM	>299	✓	0.32	28.5	20.0	✓	N/A
11/L2	Sub Mains(DB CL14/11, DB CL14/11-1, DB CL14/11-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.32	0.32	0.48	✓	0.20	N/A	250	LIM	>299	✓	0.36	28.4	26.4	✓	N/A
12/L2	Sub Mains(DB CL14/12, DB CL14/12-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.45	✓	0.19	N/A	250	LIM	>299	✓	0.30	28.8	24.0	✓	N/A
13/L2	Sub Mains(DB CL14/13, DB CL14/13-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.32	0.32	0.48	✓	0.20	N/A	250	LIM	>299	✓	0.34	28.4	27.2	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 02/08/2022 To 02/08/2022 Date(s) live testing 02/08/2022 To 02/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 02/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																									
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation												
	DB CL14				L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)											
	Circuit designation													r1	m	r2												R1 + R2	R2									
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 02/08/2022 To 02/08/2022 Date(s) live testing 02/08/2022 To 02/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 02/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	<b>Postcode</b> SA1 8EN		

<b>Distribution board details - Complete in every case</b> Location: Room 4 Riser [Schneider] Designation: DB CL14/10 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Supply to distribution board is from: Sub Mains(DB CL14, 10/L2) Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: B Rating: 32 A Voltage: 230 V	<b>Characteristics at this distribution board</b> Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ : 28.5 ms Zs: 0.32 $\Omega$ No. of poles: 2 30mA or below I <sub>pn</sub> : 0.72 kA $\Delta n$ : 30 Operating at 5 $\Delta n$ : 20.0 ms Time delay (if applicable): N/A	<b>Test instrument serial number(s)</b> Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664
---	--	---	---

### CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% ( $\Omega$ )	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured Zs ( $\Omega$ )	RCD testing		Manual test button operation					
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD ( $\checkmark$ )	AFDD ( $\checkmark$ )						
														r1	m	r2										Fig 8 check ( $\checkmark$ )	All circuits to be completed using R1R2 or R2, not both				
																R1 + R2	R2														
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	$\checkmark$	0.62	N/A	N/A	N/A	N/A	N/A	N/A	
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL14, 10/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL14/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.5 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.32 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Insulation resistance	
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
																	R1 + R2		R2									
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR **110151231**

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL14, 11/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL14/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.4 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.36 Ω No. of poles 2 30mA or below		<b>Test instrument serial number(s)</b>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Ipf 0.64 kA IΔn 30 Operating at 5 IΔn 26.4 ms		Time delay (if applicable) N/A	
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.78	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL14, 11/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL14/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 $\Delta n$ 28.4 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Z <sub>s</sub> 0.36 $\Omega$ No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Insulation resistance	
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z <sub>s</sub> Other 80%	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.60	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL14, 11/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Designation DB CL14/11-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.36 Ω No. of poles 2 30mA or below Ipf 0.64 kA IΔn 30 Operating at 5 IΔn 26.4 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
								R1 + R2		R2																			
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A	
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL14, 12/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL14/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.30 Ω No. of poles 2 Operating at 5 IΔn 24.0 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	<b>Postcode</b> SA1 8EN			
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL14, 13/L2)	Associated RCD(if any): BS (EN) 61008	Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms		Loop impedance 100701/4664
Designation DB CL14/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Zs 0.34 Ω	No. of poles 2	30mA or below	Insulation resistance 100701/4664
Num. of ways 4	Type B Rating 32 A Voltage 230 V	Ipf 0.72 kA IΔn 30	Operating at 5 IΔn 27.2 ms	Time delay (if applicable) N/A	Continuity 100701/4664
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2														
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A	
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)





# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Flat 9 Nest [Schneider]	Supply to distribution board is from Sub Mains(BB Nest, 9/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) ms	
Designation DB CL18	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V		Operating at 1 IΔn N/A ms	
Num. of ways 18 Num. of phases 1			Zs 0.14 Ω No. of poles N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr 1.8 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Bedroom Lighting 6,7	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.62	28.8	27.2	✓	N/A
2/L2	Bedroom Lighting 8,9	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.51	N/A	250	LIM	>299	✓	0.82	20.4	15.4	✓	N/A
3/L2	Bedroom Lighting 3,4,5	A	B	12	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.71	28.4	27.0	✓	N/A
4/L2	Bedroom Lighting 1,2	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.52	29.0	28.5	✓	N/A
5/L2	Common Room Lighting	A	B	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.48	28.4	27.9	✓	N/A
6/L2	Common Room Ring 1	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.38	0.38	0.62	✓	0.25	N/A	250	LIM	>299	✓	0.38	28.4	27.2	✓	N/A
7/L2	Common Room Ring 2	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.62	✓	0.26	N/A	250	LIM	>299	✓	0.40	28.8	20.4	✓	N/A
8/L2	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
9/L2	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
10/L2	Sub Mains(DB CL18/10, DB CL18/10-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.32	0.32	0.52	✓	0.21	N/A	250	LIM	>299	✓	0.39	28.5	25.2	✓	N/A
11/L2	Sub Mains(DB CL18/11, DB CL18/11-1, DB CL18/11-2)	A	B	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.60	0.60	0.70	✓	0.33	N/A	250	LIM	>299	✓	0.50	28.8	27.9	✓	N/A
12/L2	Sub Mains(DB CL18/12, DB CL18/12-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.52	✓	0.23	N/A	250	LIM	>299	✓	0.38	28.5	25.4	✓	N/A
13/L2	Sub Mains(DB CL18/13, DB CL18/13-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.47	0.47	0.58	✓	0.26	N/A	250	LIM	>299	✓	0.40	28.8	27.2	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 02/08/2022 To 02/08/2022 Date(s) live testing 02/08/2022 To 02/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 02/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																							
Circuit No. and Line No.	Distribution board Designation DB CL18 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω) 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation										
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Δn ms	30mA or below 5 Δn ms	RCD (✓)	AFDD (✓)									
														r1	m	r2																				
14/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
15/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 02/08/2022 To 02/08/2022 Date(s) live testing 02/08/2022 To 02/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 02/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR **110151231**

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: Room 4 Riser [Schneider]	Supply to distribution board is from: Sub Mains(DB CL18, 10/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.5 ms	
Designation: DB CL18/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: B Rating: 32 A Voltage: 230 V		$Z_s$ : 0.39 $\Omega$ No. of poles: 2 30mA or below	
Num. of ways: 4 Num. of phases: 1			$I_{pf}$ : 0.57 kA $\Delta n$ : 30 Operating at 5 $\Delta n$ 25.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable): N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance: 100701/4664				
Insulation resistance: 100701/4664				
Continuity: 100701/4664				
RCD: 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted $Z_s$ Other (80%)	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity ( $\checkmark$ )	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms	RCD ( $\checkmark$ )			AFDD ( $\checkmark$ )			
														r1	m	r2										Fig 8 check ( $\checkmark$ )	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	$\checkmark$	0.62	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL18, 10/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.5 ms	
Designation DB CL18/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.39 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.57 kA IΔn 30 Operating at 5 IΔn 25.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)





# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL18, 11/L2)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL18/11-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.50 Ω No. of poles 2 30mA or below		<b>Test instrument serial number(s)</b>
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Ipf 0.44 kA IΔn 30 Operating at 5 IΔn 27.9 ms		Time delay (if applicable) N/A	
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 6 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL18, 12/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable)	
Designation DB CL18/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 28.5 ms	
Num. of ways 4 Num. of phases 1			Zs 0.38 Ω No. of poles 2 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr 0.62 kA IΔn 30 Operating at 5 IΔn 25.4 ms	
				Time delay (if applicable) N/A
<b>Test instrument serial number(s)</b>				
		Loop impedance 100701/4664		
		Insulation resistance 100701/4664		
		Continuity 100701/4664		
		RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL18, 12/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.5 ms	
Designation DB CL18/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.38 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.62 kA IΔn 30 Operating at 5 IΔn 25.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL18, 13/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL18/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.40 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.55 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 9 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL18, 13/L2)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL18/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.40 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.55 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2		R2												
1/L2	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.67	N/A	N/A	N/A	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location 4th Floor Kitchen [Schneider]	Supply to distribution board is from Sub Mains(BB Nest, 10/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) N/A ms	
Designation DB CL19	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V		Operating at 1 IΔn N/A ms	
Num. of ways 18 Num. of phases 1	BS(EN) 88-2 HRC		30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Type gG Rating 63 A Voltage 230 V		Ipr 1.6 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Lighting Bedrooms 7,8	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.26	N/A	250	LIM	>299	✓	0.38	24.4	21.3	✓	N/A
2/L3	Lighting Bedrooms 5,6	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.44	27.4	27.2	✓	N/A
3/L3	Lighting Bedrooms 1,2	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.52	26.2	22.6	✓	N/A
4/L3	Lighting Bedrooms 3,4	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.46	25.4	21.4	✓	N/A
5/L3	Common Room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.40	18.6	18.0	✓	N/A
6/L3	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.34	0.32	0.42	✓	0.19	N/A	250	LIM	>299	✓	0.32	28.0	25.4	✓	N/A
7/L3	Common Room Ring 2	A	B	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.38	✓	0.17	N/A	250	LIM	>299	✓	0.30	28.8	24.0	✓	N/A
8/L3	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
9/L3	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
10/L3	Sub Mains(DB CL19/10-1, DB CL19/10)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.20	0.20	0.28	✓	0.12	N/A	250	LIM	>299	✓	0.28	28.2	29.0	✓	N/A
11/L3	Sub Mains(DB CL19/11-1, DB CL19/11)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.32	0.32	0.48	✓	0.20	N/A	250	LIM	>299	✓	0.33	28.8	27.7	✓	N/A
12/L3	Sub Mains(DB CL19/12, DB CL19/12-2)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.27	0.27	0.44	✓	0.18	N/A	250	LIM	>299	✓	0.25	26.4	27.2	✓	N/A
13/L3	Sub Mains(DB CL19/13-1, DB CL19/13)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.55	✓	0.24	N/A	250	LIM	>299	✓	0.40	28.8	27.0	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 15/08/2022 To 15/08/2022 Date(s) live testing 15/08/2022 To 15/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 15/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																					
Circuit No. and Line No.	Distribution board Designation DB CL19 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation								
					L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)							
														r1	m	r2												R1 + R2	R2					
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 15/08/2022 To 15/08/2022 Date(s) live testing 15/08/2022 To 15/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 15/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL19, 10/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms	
Designation DB CL19/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.28 Ω No. of poles 2 30mA or below Ipr 0.94 kA IΔn 30 Operating at 5 IΔn 29.0 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL19, 11/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL19/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.33 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.72 kA IΔn 30 Operating at 5 IΔn 27.7 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL19, 11/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL19/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.33 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.72 kA IΔn 30 Operating at 5 IΔn 27.7 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room X Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL19, 12/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 26.4 ms	
Designation DB CL19/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.25 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.84 kA IΔn 30 Operating at 5 IΔn 27.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.46	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL19, 13/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL19/13	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.40 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.55 kA IΔn 30 Operating at 5 IΔn 27.0 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
		Loop impedance 100701/4664		
		Insulation resistance 100701/4664		
		Continuity 100701/4664		
		RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL19/13 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.71	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 4 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL19, 13/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.8 ms	
Designation DB CL19/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		$Z_s$ 0.40 $\Omega$ No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			$I_{pn}$ 0.55 kA $\Delta n$ 30 Operating at 5 $\Delta n$ 27.0 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
		Loop impedance 100701/4664		
		Insulation resistance 100701/4664		
		Continuity 100701/4664		
		RCD 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL19/13-1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted $Z_s$ Other 80%	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms	RCD (✓)			AFCD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>		<b>Test instrument serial number(s)</b>				
Location	4th Floor Riser [Schneider]	Supply to distribution board is from	Associated RCD(if any): BS (EN) N/A		Above 30mA (if applicable)		Loop impedance	100701/4664		
Designation	DB LL4/P	Sub Mains(BB Nest, 8/TP)	Operating at 1 IΔn		N/A ms		Insulation resistance	100701/4664		
Num. of ways	8	Overcurrent protective device for the distribution circuit: Type	BS(EN)	88-2 HRC	30mA or below		Continuity	100701/4664		
		Type	gG	Rating	100	A	Voltage	400	RCD	100701/4664
		Supply polarity confirmed <input checked="" type="checkbox"/>		Phase sequence confirmed <input checked="" type="checkbox"/>		Time delay (if applicable)		N/A		

### CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFCD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2		R2													
1/L1	4th Floor Cleaners Sockets	A	E	14	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.90	0.90	1.30	✓	0.55	N/A	250	LIM	>299	✓	0.68	28.8	24.0	✓	N/A	
1/L2	3rd Floor Cleaners Sockets	A	E	14	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	1.00	1.00	1.48	✓	0.62	N/A	250	LIM	>299	✓	0.82	28.4	20.2	✓	N/A	
1/L3	5th Floor Cleaners Sockets	A	E	14	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.94	0.94	1.28	✓	0.56	N/A	250	LIM	>299	✓	0.82	28.8	26.0	✓	N/A	
2/L1	4th Floor Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	61009 RCD/RCBO	C	16	10	30	1.09	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.38	25.2	22.5	✓	N/A	
2/L2	3rd Floor Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.33	N/A	N/A	N/A	N/A	
2/L3	5th Floor Smoke Shaft	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A	
3/L1	4th Floor End Of Corridor AOV	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.32	N/A	N/A	N/A	N/A	
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	6th Floor Cleaners Sockets	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	1.00	1.04	1.42	✓	0.61	N/A	250	LIM	>299	✓	0.88	28.4	27.2	✓	N/A	
4/L2	5th Floor Comms Room Commando Socket	A	E	1	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.44	N/A	N/A	N/A	N/A	
4/L3	5th Floor Maglocks	A	E	2	2.5	1.5	0.4	61009 RCD/RCBO	B	16	10	30	2.18	N/A	N/A	N/A	N/A	0.77	N/A	250	LIM	>299	✓	0.94	28.8	24.4	✓	N/A	
5/L1	6th Floor Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.71	N/A	N/A	N/A	N/A	
5/L2	5th Floor Comms Room Commando Socket 2	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	✓	0.50	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 15/08/2022 To 15/08/2022 Date(s) live testing 15/08/2022 To 15/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 15/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																						
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation								
	DB LL4/P				L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Idn ms			30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)								
	Circuit designation													r1	m	r2												R1 + R2	R2						
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L1	6th Floor Head of Stair Core AOV	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/L2	3rd Floor Maglocks	A	E	2	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.60	N/A	250	LIM	>299	✓	0.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7/L1	Untraced	O	E	LIM	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8/L1	4th Floor Maglocks	A	E	2	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.70	N/A	250	LIM	>299	✓	1.02	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 15/08/2022 To 15/08/2022 Date(s) live testing 15/08/2022 To 15/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 15/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location 4th Floor Riser Flat 10 [Schneider]	Supply to distribution board is from		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB LL4/L	Sub Mains(BB Nest, 8/TP)		N/A	
Num. of ways 6	Num. of phases 3	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC gG	Operating at 1 IΔn N/A ms	
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input checked="" type="checkbox"/>	Type gG Rating 100 A Voltage 400 V	30mA or below	
			Ipr 3.3 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2														
1/L1	3rd Floor Corridor Lighting	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.66	N/A	250	LIM	>299	✓	0.88	28.8	25.2	✓	N/A	
1/L2	4th Floor Corridor Lighting	A	E	9	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.54	N/A	250	LIM	>299	✓	0.77	28.0	27.2	✓	N/A	
1/L3	5th Floor Corridor Lighting	A	E	9	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.58	N/A	250	LIM	>299	✓	0.75	27.2	21.0	✓	N/A	
2/L1	3rd Floor Corridor Lighting 2	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.62	N/A	250	LIM	>299	✓	0.79	28.8	27.8	✓	N/A	
2/L2	4th Floor Corridor Lighting 2	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.59	N/A	250	LIM	>299	✓	0.82	25.4	27.2	✓	N/A	
2/L3	5th Floor Corridor Lighting 2	A	E	11	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.64	N/A	250	LIM	>299	✓	0.75	28.2	25.4	✓	N/A	
3/L1	3rd Floor Stair Lighting	A	E	9	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.58	N/A	250	LIM	>299	✓	0.82	25.4	20.4	✓	N/A	
3/L2	4th Floor Stair Lighting	A	E	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.62	N/A	250	LIM	>299	✓	0.75	20.2	14.0	✓	N/A	
3/L3	5th Floor Stair Lighting	A	E	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.55	N/A	250	LIM	>299	✓	0.83	27.2	27.2	✓	N/A	
4/L1	6th Floor Corridor Lighting	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.60	N/A	250	LIM	>299	✓	0.82	28.8	24.0	✓	N/A	
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	6th Floor Stair Lighting	A	E	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.58	N/A	250	LIM	>299	✓	0.75	25.4	21.0	✓	N/A	
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 15/08/2022 To 15/08/2022 Date(s) live testing 15/08/2022 To 15/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 15/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																							
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z <sub>s</sub> Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation										
	DB LL4/L				L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)									
	Circuit designation													r1	m	r2												R1 + R2	R2							
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 15/08/2022 To 15/08/2022 Date(s) live testing 15/08/2022 To 15/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 15/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/EICR 110151231



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>		<b>Test instrument serial number(s)</b>	
Location	3rd Floor [Schneider]	Supply to distribution board is from	Associated RCD(if any): BS (EN)		Above 30mA (if applicable)		Loop impedance
Designation	DB CL15	Sub Mains(BB Nest, 7/L3)	$Z_s$	$Z_e$	$I_{pn}$	Operating at 1 $I_{\Delta n}$	100701/4664
Num. of ways	18	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	$I_{pn}$	No. of poles	Operating at 5 $I_{\Delta n}$	30mA or below	Insulation resistance
Supply polarity confirmed	<input checked="" type="checkbox"/>	BS(EN) 88-2 HRC	Time delay (if applicable)	N/A	N/A	N/A	100701/4664
Phase sequence confirmed	<input checked="" type="checkbox"/>						Continuity
							100701/4664
							RCD
							100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	m	r2												R1 + R2
1/L3	Bedroom Lighting 7,8	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.64	N/A	250	LIM	>299	✓	0.93	32.6	28.2	✓	N/A
2/L3	Bedroom Lighting 5,6	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.70	N/A	250	LIM	>299	✓	0.84	28.4	26.4	✓	N/A
3/L3	Bedroom Lighting 3,4	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.63	N/A	250	LIM	>299	✓	0.88	26.4	20.0	✓	N/A
4/L3	Bedroom Lighting 1,2	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.72	N/A	250	LIM	>299	✓	0.79	25.4	23.2	✓	N/A
5/L3	Common Room Lighting	A	B	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.68	N/A	250	LIM	>299	✓	0.86	28.8	25.6	✓	N/A
6/L3	Common Room Ring 1	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.29	0.29	0.44	✓	0.18	N/A	250	LIM	>299	✓	0.44	28.4	26.2	✓	N/A
7/L3	Common Room Ring 2	A	B	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.52	✓	0.23	N/A	250	LIM	>299	✓	0.51	28.4	27.2	✓	N/A
8/L3	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
9/L3	Isolated	A	B	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A
10/L3	Sub Mains(DB CL15/10, DB CL15/10-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.24	0.24	0.44	✓	0.17	N/A	250	LIM	>299	✓	0.39	28.2	27.2	✓	N/A
11/L3	Sub Mains(DB CL15/11, DB CL15/11-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.52	✓	0.23	N/A	250	LIM	>299	✓	0.40	28.8	20.8	✓	N/A
12/L3	Sub Mains(DB CL15/12, DB CL15/12-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.32	0.32	0.40	✓	0.18	N/A	250	LIM	>299	✓	0.27	28.6	27.6	✓	N/A
13/L3	Sub Mains(DB CL15/13, DB CL15/13-1)	A	B	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.49	✓	0.23	N/A	250	LIM	>299	✓	0.44	28.2	22.4	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 15/08/2022 To 15/08/2022 Date(s) live testing 15/08/2022 To 15/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 15/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																									
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation												
	DB CL15				L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)											
	Circuit designation													r1	m	r2												R1 + R2	R2									
14/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				
15/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
17/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 15/08/2022 To 15/08/2022 Date(s) live testing 15/08/2022 To 15/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 15/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL15, 10/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL15/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.2 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.39 Ω No. of poles 2 30mA or below		Test instrument serial number(s)
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Loop impedance 100701/4664	
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL15, 10/L3)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL15/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.2 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.39 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Insulation resistance	
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)





# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location Room 3 Riser [Schneider]			Supply to distribution board is from	
Designation DB CL15/12			Sub Mains(DB CL15, 12/L3)	
Num. of ways 4 Num. of phases 1			Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Type B Rating 32 A Voltage 230 V	
<b>Characteristics at this distribution board</b>			<b>Test instrument serial number(s)</b>	
Associated RCD(if any): BS (EN) 61008			Above 30mA (if applicable)	
Zs 0.27 Ω			Operating at 1 IΔn 28.6 ms	
Ipf 0.82 kA			30mA or below	
IΔn 30			Operating at 5 IΔn 27.6 ms	
Time delay (if applicable) N/A			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	<b>Postcode</b> SA1 8EN			
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location Room 4 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL15, 12/L3)	Associated RCD(if any): BS (EN) 61008	Above 30mA (if applicable) Operating at 1 $\Delta n$ 28.6 ms	Loop impedance 100701/4664	
Designation DB CL15/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	$Z_s$ 0.27 $\Omega$	30mA or below No. of poles 2	Insulation resistance 100701/4664	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	$I_{pn}$ 0.82 kA	$\Delta n$ 30 Operating at 5 $\Delta n$ 27.6 ms	Continuity 100701/4664	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A		RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted $Z_s$ Other 80%	Circuit impedance $\Omega$						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured $Z_s$ ( $\Omega$ )	RCD testing		Manual test button operation		
					Maximum disconnection	L/N	CPC	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms	RCD (✓)			AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
															R1 + R2	R2													
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A	
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room X Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL15, 13/L3)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms	
Designation DB CL15/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.44 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.50 kA IΔn 30 Operating at 5 IΔn 22.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
				RCD 100701/4664

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFCD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L3	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.72	N/A	N/A	N/A	N/A
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: 2nd Floor Nest	Supply to distribution board is from: Sub Mains(BB Nest, 5/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation: DB CL11	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC Type: gG Rating: 63 A Voltage: 230 V		Operating at 1 IΔn N/A ms	
Num. of ways: 18 Num. of phases: 1			Zs: 0.14 Ω No. of poles: N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Ipr: 1.6 kA IΔn: N/A Operating at 5 IΔn N/A ms	
				Time delay (if applicable): N/A
				<b>Test instrument serial number(s)</b>
				Loop impedance: 100701/4664
				Insulation resistance: 100701/4664
				Continuity: 100701/4664
				RCD: 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	r1	m			r2	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1+R2 R2	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														RCD testing		Manual test button operation														
					Circuit designation		Circuit designation		Circuit designation					Circuit designation		Circuit designation		Circuit designation		Circuit designation				Circuit designation		Circuit designation		Circuit designation		Circuit designation
1/L1	Bedroom Lighting 8,7	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.71	N/A	250	LIM	>299	✓	0.84	28.8	27.2	✓	N/A		
2/L1	Bedroom Lighting 6,5	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.77	N/A	250	LIM	>299	✓	0.88	28.4	26.0	✓	N/A		
3/L1	Bedroom Lighting 2,1	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.58	N/A	250	LIM	>299	✓	0.72	25.4	27.4	✓	N/A		
4/L1	Bedroom Lighting 4,2	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.68	28.6	27.2	✓	N/A		
5/L1	Common Room Lights	A	E	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.40	28.8	26.4	✓	N/A		
6/L1	Common Room Ring	A	E	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.44	0.44	0.56	✓	0.25	N/A	250	LIM	>299	✓	0.40	28.4	27.4	✓	N/A		
7/L1	Common Room Ring 2	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.37	0.37	0.49	✓	0.22	N/A	250	LIM	>299	✓	0.35	28.8	17.2	✓	N/A		
8/L1	Isolated	A	E	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A		
9/L1	Isolated	A	E	LIM	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	LIM	LIM	LIM	N/A		
10/L1	Sub Mains(DB CL11/10, DB CL11/10-1)	A	E	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.48	✓	0.20	N/A	250	LIM	>299	✓	0.39	28.2	20.4	✓	N/A		
11/L1	Sub Mains(DB CL11/11, DB CL11/11-1)	A	E	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.33	0.33	0.44	✓	0.19	N/A	250	LIM	>299	✓	0.42	28.8	22.4	✓	N/A		
12/L1	Sub Mains(DB CL11/12, DB CL11/12-1)	A	E	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.26	0.26	0.46	✓	0.18	N/A	250	LIM	>299	✓	0.36	28.6	27.2	✓	N/A		
13/L1	Sub Mains(DB CL11/13, DB CL11/13-1)	A	E	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.66	✓	0.27	N/A	250	LIM	>299	✓	0.40	28.4	26.4	✓	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 15/08/2022 To 15/08/2022 Date(s) live testing 15/08/2022 To 15/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 15/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL11, 10/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms	
Designation DB CL11/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.39 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.60 kA IΔn 30 Operating at 5 IΔn 20.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL11/10 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 7 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL11, 10/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms	
Designation DB CL11/10-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.39 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipr 0.60 kA IΔn 30 Operating at 5 IΔn 20.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 6 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL11, 11/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation DB CL11/11	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO		Operating at 1 IΔn 28.8 ms	
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.42 Ω No. of poles 2		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		Insulation resistance	
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2	R2																			
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL11, 11/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.8 ms	
Designation DB CL11/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.42 Ω No. of poles 2 30mA or below Ipf 0.52 kA IΔn 30 Operating at 5 IΔn 22.4 ms	
Num. of ways 4 Num. of phases 1			Time delay (if applicable) N/A	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			<b>Test instrument serial number(s)</b>	
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2														
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

Company Name	PHS Compliance	Company Address	Kid Glove Road	Postcode	WA3 3GR	Branch No.		Scheme No.	
Client	UPP Residential Services Ltd	Installation Address	Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			Postcode	SA1 8EN		

Distribution board details - Complete in every case				Complete only if the distribution board is not connected directly to the origin of the installation				Characteristics at this distribution board				Test instrument serial number(s)																	
Location	Room 2 Riser [Schneider]	Supply to distribution board is from		Associated RCD(if any): BS (EN)		Above 30mA (if applicable)		Loop impedance		100701/4664																			
Designation	DB CL11/12	Sub Mains(DB CL11, 12/L1)		61008		Operating at 1 IΔn		28.6 ms		Insulation resistance				100701/4664															
Num. of ways	4	Overcurrent protective device for the distribution circuit: Type		BS(EN) 61009 RCD/RCBO		Zs		0.36 Ω		No. of poles		2		30mA or below		Continuity		100701/4664											
Supply polarity confirmed <input checked="" type="checkbox"/>		Phase sequence confirmed <input type="checkbox"/>		Rating		32 A		Voltage		230 V		Ipf		0.61 kA		IΔn		30		Operating at 5 IΔn		27.2 ms		RCD		100701/4664			
								Time delay (if applicable)				N/A																	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation													
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	r1	m	r2			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)										
														R1 + R2	R2	V															M(Ω)	M(Ω)								
																																	✓	✓	✓	✓	✓			
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL11, 12/L1)	Associated RCD(if any): BS (EN) 61008		<b>Test instrument serial number(s)</b> Loop impedance 100701/4664 Insulation resistance 100701/4664 Continuity 100701/4664 RCD 100701/4664
Designation DB CL11/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Above 30mA (if applicable) Operating at 1 IΔn 28.6 ms		
Num. of ways 4 Num. of phases 1	Type B Rating 32 A Voltage 230 V	Zs 0.36 Ω No. of poles 2 30mA or below		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Ipf 0.61 kA IΔn 30 Operating at 5 IΔn 27.2 ms		
		Time delay (if applicable) N/A		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.70	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance		<b>Company Address</b> Kid Glove Road		<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd		<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN		

<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			<b>Characteristics at this distribution board</b>			<b>Test instrument serial number(s)</b>		
Location: Room 4 Riser [Schneider]			Supply to distribution board is from: Sub Mains(DB CL11, 13/L1)			Associated RCD(if any): BS (EN) 61008			Loop impedance: 100701/4664		
Designation: DB CL11/13			Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO			Operating at 1 IΔn: 28.4 ms			Insulation resistance: 100701/4664		
Num. of ways: 4			Type: B Rating: 32 A Voltage: 230 V			Zs: 0.40 Ω No. of poles: 2			Continuity: 100701/4664		
Supply polarity confirmed: <input checked="" type="checkbox"/>						Operating at 5 IΔn: 26.4 ms			RCD: 100701/4664		
Phase sequence confirmed: <input type="checkbox"/>						Time delay (if applicable): N/A					

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2		R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room X Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL11, 13/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.4 ms	
Designation DB CL11/13-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.40 Ω No. of poles 2 Operating at 5 IΔn 26.4 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664		Insulation resistance 100701/4664		Continuity 100701/4664
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2		R2												
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.77	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location 1st Floor Drslwyn [Schneider]	Supply to distribution board is from Sub Mains(BB Dryslwyn, 3/TP)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) N/A ms	
Designation DB LL1/L	Overcurrent protective device for the distribution circuit: Type gG Rating 100 A Voltage 400 V		Operating at 1 IΔn N/A ms	
Num. of ways 6 Num. of phases 3			Zs 0.12 Ω No. of poles N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>			Ipr 4.0 kA IΔn N/A Operating at 5 IΔn N/A ms	
			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFCD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2														
1/L1	G Floor Lighting Corridor	A	E	9	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.50	N/A	250	LIM	>299	✓	0.64	28.4	27.2	✓	N/A	
1/L2	1st Floor Lighting Corridor	A	E	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.55	N/A	250	LIM	>299	✓	0.62	28.8	22.5	✓	N/A	
1/L3	2nd Floor Lighting Corridor	A	E	10	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.54	N/A	250	LIM	>299	✓	0.68	25.4	25.4	✓	N/A	
2/L1	G Floor Stair Lighting	A	E	5	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.62	28.2	26.4	✓	N/A	
2/L2	1st Floor Stair Lighting	A	E	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.35	N/A	250	LIM	>299	✓	0.47	28.4	27.2	✓	N/A	
2/L3	2nd Floor Corridor Lighting	A	E	6	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.70	N/A	250	LIM	>299	✓	0.88	28.6	22.9	✓	N/A	
3/L1	IT Hub Lighting	A	E	2	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.50	N/A	250	LIM	>299	✓	0.64	28.0	32.5	✓	N/A	
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L3	2nd Floor Stair Lighting	A	E	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.40	N/A	250	LIM	>299	✓	0.55	28.8	19.6	✓	N/A	
4/L1	OS Lighting	A	E	1	2.5	1.5	0.4	61009 RCD/RCBO	C	16	10	30	1.09	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.48	17.5	17.0	✓	N/A	
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	Passage Lighting	A	E	4	2.5	1.5	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	LIM	N/A	250	LIM	>299	LIM	LIM	26.4	20.4	✓	N/A	
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 17/08/2022 To 17/08/2022 Date(s) live testing 17/08/2022 To 17/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 17/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR **110151231**

for Industrial/Commercial Premises



**Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)**

CIRCUIT DETAILS													TEST RESULTS																					
Circuit No. and Line No.	Distribution board Designation DB LL1/L	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z <sub>s</sub> Other (Ω) 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation								
					L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)							
	r1													m	r2	R1 + R2												R2						
	Circuit designation				Circuit designation																													
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			

Details of circuits and/or installed equipment vulnerable to damage when testing      Date(s) dead testing 17/08/2022 To 17/08/2022      Date(s) live testing 17/08/2022 To 17/08/2022

Tested by: Name (capital letters) LIAM KIMBLE      Position Electrical Test Engineer      Date 17/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/EICR 110151231



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: 1st Floor Riser Dryslwyn Riser [Schneider]	Supply to distribution board is from: Sub Mains(BB Dryslwyn, 3/TP)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn N/A ms	
Designation: DB LL1/P	Overcurrent protective device for the distribution circuit: Type gG Rating 100 A Voltage 400/230 V		Zs 0.12 Ω No. of poles N/A 30mA or below	
Num. of ways: 8 Num. of phases: 3	BS(EN) 88-2 HRC gG		Ipr 4.0 kA IΔn N/A Operating at 5 IΔn N/A ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>			Time delay (if applicable) N/A	
				<b>Test instrument serial number(s)</b>
				Loop impedance 100701/4664
				Insulation resistance 100701/4664
				Continuity 100701/4664
				RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	r	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	G Floor Cleaners Sockets	A	E	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.64	0.64	0.77	✓	0.35	N/A	250	LIM	>299	✓	0.47	28.4	22.0	✓	N/A
1/L2	G Floor Electrical Switch Room Sockets	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.52	0.52	0.64	✓	0.29	N/A	250	LIM	>299	✓	0.44	28.5	24.8	✓	N/A
1/L3	Fisrt Floor Cleaners Sockets	A	E	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.70	0.70	0.82	✓	0.38	N/A	250	LIM	>299	✓	0.52	28.8	26.4	✓	N/A
2/L1	G Floor Door Access	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.36	N/A	N/A	N/A	N/A
2/L2	G Floor Tube HEater	A	E	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A
2/L3	1st Floor Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.26	N/A	250	LIM	>299	✓	0.39	N/A	N/A	N/A	N/A
3/L1	G Floor Power Assissted Doors	A	E	2	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A
3/L2	2nd Floor Cleaners Sockets	A	E	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.92	0.92	1.06	✓	0.50	N/A	250	LIM	>299	✓	0.66	28.8	27.2	✓	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	G Floor Door Hold	A	E	2	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A
4/L2	2md Floor Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 17/08/2022 To 17/08/2022 Date(s) live testing 17/08/2022 To 17/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 17/08/2022 Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS														TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
	DB LL1/P				L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Idn ms			30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)			
	Circuit designation													r1	m	r2												Test voltage	L/L, L/N	L/E, N/E
6/L1	G Floor Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.26	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A	N/A	N/A
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 17/08/2022 To 17/08/2022 Date(s) live testing 17/08/2022 To 17/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 17/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: 4th Floor Riser Dryslwyn [Schneider]	Supply to distribution board is from: Sub Mains(BB Dryslwyn, 12/TP)		Associated RCD(if any): BS (EN) Above 30mA (if applicable)	
Designation: DB LL3/P	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC gG Type: gG Rating: 100 A Voltage: 400 V		Operating at 1 IΔn N/A ms	
Num. of ways: 8 Num. of phases: 3			Zs: 0.10 Ω No. of poles: N/A 30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>			Ipr: 4.4 kA IΔn: N/A Operating at 5 IΔn N/A ms	
				Time delay (if applicable): N/A
<b>Test instrument serial number(s)</b>				
		Loop impedance: 100701/4664		
		Insulation resistance: 100701/4664		
		Continuity: 100701/4664		
		RCD: 100701/4664		

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	All circuits to be completed using R1R2 or R2, not both	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)				
														r1	m	r2											Fig 8 check (✓)	R1 + R2	R2	
1/L1	4th Floor Cleaners Sockets	A	E	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.65	0.65	0.80	✓	0.36	N/A	250	LIM	>299	✓	0.49	28.4	27.2	✓	N/A		
1/L2	3rd Floor Cleaners Sockets	A	E	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.80	0.80	0.94	✓	0.44	N/A	250	LIM	>299	✓	0.58	28.8	24.4	✓	N/A		
1/L3	5th Floor Cleaners Sockets	A	E	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.70	0.70	0.88	✓	0.40	N/A	250	LIM	>299	✓	0.52	28.5	29.6	✓	N/A		
2/L1	4th Floor Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.33	N/A	N/A	N/A	N/A		
2/L2	3rd Floor Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.32	N/A	N/A	N/A	N/A		
2/L3	5th Floor Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.34	N/A	N/A	N/A	N/A		
3/L1	4th Floor Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.28	N/A	N/A	N/A	N/A		
3/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L3	5th Floor Stair Core AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.32	N/A	N/A	N/A	N/A	N/A	
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	Roof Top AOV	O	E	1	2.5	2.5	0.4	61009 RCD/RCBO	C	16	10	30	1.09	N/A	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.34	30.2	27.2	✓	N/A	
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L3	5th Floor Door Hold	A	E	2	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 17/08/2022 To 17/08/2022 Date(s) live testing 17/08/2022 To 17/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 17/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																								
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation										
	DB LL3/P				L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Idn ms			30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)										
	Circuit designation													r1	m	r2												N/A	N/A	N/A							
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A					
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A					
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
8/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 17/08/2022 To 17/08/2022 Date(s) live testing 17/08/2022 To 17/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 17/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>		<b>Test instrument serial number(s)</b>	
Location	4th Floor Dryslwyn Riser [Schneider]	Supply to distribution board is from	Sub Mains(BB Dryslwyn, 12/TP)	Associated RCD(if any): BS (EN)	Above 30mA (if applicable)	Loop impedance	100701/4664
Designation	DB LL3/L	Overcurrent protective device for the distribution circuit: Type	BS(EN) 88-2 HRC gG	Zs	Operating at 1 IΔn	Insulation resistance	100701/4664
Num. of ways	6	Rating	100 A	Ipr	Operating at 5 IΔn	Continuity	100701/4664
Supply polarity confirmed	<input checked="" type="checkbox"/>	Voltage	400 V	Time delay (if applicable)		RCD	100701/4664
Phase sequence confirmed	<input checked="" type="checkbox"/>						

### CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	r1	m	r2			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFCD (✓)
														R1 + R2		R2														
					Circuit designation																									
1/L1	3rd Floor Corridor Lights	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.58	N/A	250	LIM	>299	✓	0.68	28.2	22.0	✓	N/A		
1/L2	4th Floor Corridor Lights	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.54	N/A	250	LIM	>299	✓	0.72	28.8	28.5	✓	N/A		
1/L3	5th Floor Corridor Lights	A	E	11	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.62	N/A	250	LIM	>299	✓	0.84	26.4	27.2	✓	N/A		
2/L1	3rd Floor Corridor Lights 2	A	E	6	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.55	N/A	250	LIM	>299	✓	0.74	28.9	22.6	✓	N/A		
2/L2	4th Floor Corridor Lights 2	A	E	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.49	N/A	250	LIM	>299	✓	0.62	28.5	25.4	✓	N/A		
2/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
3/L1	3rd Floor Stair Core Lights	A	E	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.35	N/A	250	LIM	>299	✓	0.50	28.9	22.2	✓	N/A		
3/L2	4th Floor Stair Core Lights	A	E	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.55	28.5	25.4	✓	N/A		
3/L3	5th Floor Stair Core Lights	A	E	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.58	28.9	24.6	✓	N/A		
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 17/08/2022 To 17/08/2022 Date(s) live testing 17/08/2022 To 17/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 17/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - GDS (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location: Dryslwyn [Schneider]	Supply to distribution board is from: Sub Mains(BB Dryslwyn, 7/L1)		Associated RCD(if any): BS (EN) Above 30mA (if applicable) N/A Operating at 1 IΔn N/A ms	
Designation: DB CL13	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC Type: gG Rating: 63 A Voltage: 230 V		Z <sub>s</sub> : 0.12 Ω No. of poles: N/A 30mA or below I <sub>pr</sub> : 1.2 kA IΔn: N/A Operating at 5 IΔn N/A ms	
Num. of ways: 18 Num. of phases: 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable): N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance: 100701/4664		Insulation resistance: 100701/4664		Continuity: 100701/4664
RCD: 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z <sub>s</sub> Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFCD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L1	Lighting Bedrooms 5,6,7	A	E	15	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.64	N/A	250	LIM	>299	✓	0.82	28.4	27.4	✓	N/A
2/L1	Lighting Bedrooms 8,9	A	E	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.72	N/A	250	LIM	>299	✓	0.95	24.2	22.0	✓	N/A
3/L1	Lighting Bedroom 3,2,1	A	E	15	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.68	N/A	250	LIM	>299	✓	0.84	26.0	24.4	✓	N/A
4/L1	Common Room Lighting	A	E	8	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	✓	0.50	28.2	26.0	✓	N/A
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Common Room Ring 1	A	E	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.34	0.34	0.50	✓	0.21	N/A	250	LIM	>299	✓	0.40	25.4	22.8	✓	N/A
7/L1	Common Room Ring 2	A	E	8	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.35	28.4	27.2	✓	N/A
8/L1	Hob 1	A	E	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.25	24.0	20.2	✓	N/A
9/L1	Hob 2	A	E	1	10	4	0.4	61009 RCD/RCBO	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.25	26.2	23.8	✓	N/A
10/L1	Sub Mains(DB CL13/10, DB CL13/10-1)	A	E	2	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.24	0.24	0.40	✓	0.16	N/A	250	LIM	>299	✓	0.42	22.4	20.0	✓	N/A
11/L1	Sub Mains(DB CL13/11, DB CL13/11-1, DB CL13/11-2)	A	E	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.39	0.39	0.52	✓	0.23	N/A	250	LIM	>299	✓	0.49	26.4	20.4	✓	N/A
12/L1	Sub Mains(DB CL13/12, DB CL13/12-1, DB CL13/12-2)	A	E	3	2x2.5	2x1.5	5	61009 RCD/RCBO	B	32	10	30	1.09	0.41	0.41	0.58	✓	0.25	N/A	250	LIM	>299	✓	0.46	28.2	25.2	✓	N/A
13/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 17/08/2022 To 17/08/2022 Date(s) live testing 17/08/2022 To 17/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 17/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

CIRCUIT DETAILS													TEST RESULTS																						
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation								
					L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)							
	r1				m	r2		R1 + R2	R2																										
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 17/08/2022 To 17/08/2022 Date(s) live testing 17/08/2022 To 17/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 17/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan			<b>Postcode</b> SA1 8EN
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 5 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL13, 10/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 Δn 22.4 ms	
Designation DB CL13/10	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.42 Ω No. of poles 2 Operating at 5 Δn 20.0 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA Δn ms	30mA or below 5 Δn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.70	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

**Company Name** PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**

**Client** UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan **Postcode** SA1 8EN

**Distribution board details - Complete in every case**

Location: Room 6 Riser [Schneider]  
 Designation: DB CL13/10-1  
 Num. of ways: 4 Num. of phases: 1  
 Supply polarity confirmed  Phase sequence confirmed

**Complete only if the distribution board is not connected directly to the origin of the installation**

Supply to distribution board is from: Sub Mains (DB CL13, 10/L1)  
 Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V

**Characteristics at this distribution board**

Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1  $\Delta n$  22.4 ms  
 $Z_s$  0.42  $\Omega$  No. of poles 2 30mA or below  
 $I_{pn}$  0.52 kA  $\Delta n$  30 Operating at 5  $\Delta n$  20.0 ms  
 Time delay (if applicable) N/A

**Test instrument serial number(s)**

Loop impedance 100701/4664  
 Insulation resistance 100701/4664  
 Continuity 100701/4664  
 RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL13/10-1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance $\Omega$					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs ( $\Omega$ )	RCD testing		Manual test button operation					
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M( $\Omega$ )	L/E, N/E M( $\Omega$ )	Above 30mA $\Delta n$ ms	30mA or below 5 $\Delta n$ ms			RCD (✓)	AFDD (✓)						
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both				
																												R1 + R2	R2		
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.75	N/A	N/A	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location: Room 7 Riser [Schneider] Designation: DB CL13/11 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>	Supply to distribution board is from: Sub Mains(DB CL13, 11/L1) Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type: B Rating: 32 A Voltage: 230 V	Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 26.4 ms Zs 0.49 Ω No. of poles: 2 30mA or below Ipr 0.48 kA IΔn 30 Operating at 5 IΔn 20.4 ms Time delay (if applicable) N/A	Loop impedance: 100701/4664 Insulation resistance: 100701/4664 Continuity: 100701/4664 RCD: 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2		R2												
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 26/07/2022 To: 26/07/2022 Date(s) live testing: 26/07/2022 To: 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 26/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/EICR 110151231



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>	
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	<b>Postcode</b> SA1 8EN			
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location Room 8 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL13, 11/L1)	Associated RCD(if any): BS (EN) 61008	Above 30mA (if applicable) Operating at 1 IΔn 26.4 ms		Loop impedance 100701/4664
Designation DB CL13/11-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Zs 0.49 Ω	No. of poles 2	30mA or below	Insulation resistance 100701/4664
Num. of ways 4	Type B Rating 32 A Voltage 230 V	Ipf 0.48 kA	IΔn 30	Operating at 5 IΔn 20.4 ms	Continuity 100701/4664
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					Maximum disconnection	BS EN Number	Type No.	Rating (A)	R1	m				r2	Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
																L/N	CPC										R1 + R2	R2	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				r1	m	r2	Fig 8 check (✓)	R1 + R2	R2	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location Room 9 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL13, 11/L1)		<b>Characteristics at this distribution board</b>	
Designation DB CL13/11-2	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable)	
Num. of ways 4 Num. of phases 1			Operating at 1 IΔn 26.4 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Zs 0.49 Ω No. of poles 2 30mA or below	
			Ipf 0.48 kA IΔn 30 Operating at 5 IΔn 20.4 ms	
			Time delay (if applicable) N/A	
			<b>Test instrument serial number(s)</b>	
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2		R2												
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.66	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location Room 3 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL13, 12/L1)		<b>Characteristics at this distribution board</b>	
Designation DB CL13/12	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms	
Num. of ways 4 Num. of phases 1			Zs 0.46 Ω No. of poles 2 30mA or below Ipr 0.52 kA IΔn 30 Operating at 5 IΔn 25.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
			<b>Test instrument serial number(s)</b>	
			Loop impedance 100701/4664	
			Insulation resistance 100701/4664	
			Continuity 100701/4664	
			RCD 100701/4664	

## CIRCUIT DETAILS

## TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB CL13/12 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation						
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)							
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both					
																											R1 + R2	R2				
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.74	N/A	N/A	N/A	N/A	N/A	N/A		
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature *Liam Kimble*

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MI-CB exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231



for Industrial/Commercial Premises

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 2 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL13, 12/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms	
Designation DB CL13/12-1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.46 Ω No. of poles 2 30mA or below	
Num. of ways 4 Num. of phases 1			Ipf 0.52 kA IΔn 30 Operating at 5 IΔn 25.2 ms	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.75	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>
Location Room 1 Riser [Schneider]	Supply to distribution board is from Sub Mains(DB CL13, 12/L1)		Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms	
Designation DB CL13/12-2	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO Type B Rating 32 A Voltage 230 V		Zs 0.46 Ω No. of poles 2 30mA or below Ipr 0.52 kA IΔn 30 Operating at 5 IΔn 25.2 ms	
Num. of ways 4 Num. of phases 1	Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable) N/A	
<b>Test instrument serial number(s)</b>				
Loop impedance 100701/4664				
Insulation resistance 100701/4664				
Continuity 100701/4664				
RCD 100701/4664				

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Sockets	A	B	6	2.5	1.5	0.4	60898 MCB	B	10	6	N/A	3.49	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.69	N/A	N/A	N/A	N/A
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 26/07/2022 To 26/07/2022 Date(s) live testing 26/07/2022 To 26/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 26/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan	Postcode SA1 8EN		

<b>Distribution board details - Complete in every case</b>	<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	<b>Characteristics at this distribution board</b>	<b>Test instrument serial number(s)</b>
Location Flat 4 Nest Riser [Schneider]	Supply to distribution board is from Sub Mains(BB Nest, 1/TP)	Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) ms Operating at 1 IΔn N/A	Loop impedance 100701/4664
Designation DB LL2/P	Overcurrent protective device for the distribution circuit: Type gG Rating 100 A Voltage V	Zs 0.11 Ω No. of poles N/A 30mA or below Ipf 4.4 kA IΔn N/A Operating at 5 IΔn N/A ms	Insulation resistance 100701/4664
Num. of ways 14	BS(EN) 88-2 HRC	Time delay (if applicable)	Continuity 100701/4664
Supply polarity confirmed <input checked="" type="checkbox"/>			RCD 100701/4664

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFCD (✓)			
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/L1	G Floor Cleaners Sockets	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.84	0.84	1.22	✓	0.52	N/A	250	LIM	>299	✓	0.74	28.4	22.0	✓	N/A
1/L2	G Floor IT Hub Commando	A	B	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A
1/L3	1st Floor Cleaner Sockets	A	B	10	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.72	0.72	0.97	✓	0.42	N/A	250	LIM	>299	✓	0.72	29.2	25.6	✓	N/A
2/L1	G Floor Door Access	A	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	✓	0.50	N/A	N/A	N/A	N/A
2/L2	G Floor IT Hub Commando 2	A	B	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A
2/L3	1st Floor Smoke Shaft AOD	O	C	1	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A
3/L1	G Floor Power Assisted Door	A	B	2	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.49	N/A	N/A	N/A	N/A
3/L2	G Floor IT Hub Commando 3	A	B	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A
3/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L1	G Floor Power assisted Doors	A	B	2	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A
4/L2	G Floor IT Ring	A	B	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.47	0.47	0.68	✓	0.29	N/A	250	LIM	>299	✓	0.59	27.6	17.4	✓	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	G Floor Intercom PSU	A	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A
5/L2	G Floor IT Tube Heater	A	B	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.27	N/A	250	LIM	>299	✓	0.39	N/A	N/A	N/A	N/A
5/L3	2nd Floor Comms Commando	A	B	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.48	N/A	N/A	N/A	N/A
6/L1	G Floor Smoke AOD	O	C	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 18/08/2022 To 18/08/2022 Date(s) live testing 18/08/2022 To 18/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 18/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

Circuit No. and Line No.	CIRCUIT DETAILS													TEST RESULTS															
	Distribution board Designation DB LL2/P	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L/N	OPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)		
														r1	m	r2												R1 + R2	R2
6/L2	Second Floor Cleaners Socket	A	B	7	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	1.00	1.00	0.95	✓	0.49	N/A	250	LIM	>299	✓	0.66	28.8	27.2	✓	N/A	
6/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	Second Smoke Shaft AOD	O	C	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.39	N/A	N/A	N/A	N/A	N/A
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L1	Maglocks G Floor	A	B	2	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A	N/A
8/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/L3	2nd Floor Comms Commando 2	A	B	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A	N/A
9/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/L2	1st Floor Maglocks	A	B	2	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.33	N/A	N/A	N/A	N/A	N/A
9/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L2	2nd Floor Maglocks	A	B	2	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A	N/A
10/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 18/08/2022 To 18/08/2022 Date(s) live testing 18/08/2022 To 18/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 18/08/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 110151231

for Industrial/Commercial Premises



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

<b>Company Name</b> PHS Compliance	<b>Company Address</b> Kid Glove Road	<b>Postcode</b> WA3 3GR	<b>Branch No.</b>	<b>Scheme No.</b>
<b>Client</b> UPP Residential Services Ltd	<b>Installation Address</b> Swansea University Bay Campus - Dryslwyn 1B & Nest 2, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea, West Glamorgan		<b>Postcode</b> SA1 8EN	

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>		<b>Test instrument serial number(s)</b>	
Location	Flat 4 Nest Riser [Schneider]	Supply to distribution board is from		Associated RCD(if any): BS (EN)		Loop impedance	
Designation	DB LL2/L	Sub Mains(BB Nest, 1/TP)		Operating at 1 IΔn		100701/4664	
Num. of ways	8	Overcurrent protective device for the distribution circuit: Type gG Rating 100 A Voltage 400 V		Above 30mA (if applicable)		Insulation resistance	
Num. of phases	3			30mA or below		100701/4664	
Supply polarity confirmed	<input checked="" type="checkbox"/>			Ipr 4.4 kA IΔn N/A Operating at 5 IΔn		Continuity	
Phase sequence confirmed	<input checked="" type="checkbox"/>			Time delay (if applicable) N/A		RCD	
						100701/4664	

### CIRCUIT DETAILS

### TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)				
														r1	m	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		
														R1 + R2	R2														
1/L1	G Floor Corridor Lighting	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.53	N/A	250	LIM	>299	✓	0.77	27.4	28.4	✓	N/A	
1/L2	1st Floor Corridor Lighting	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.55	N/A	250	LIM	>299	✓	0.64	28.5	23.8	✓	N/A	
1/L3	2nd Floor Corridor Lighting	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.59	29.9	27.5	✓	N/A	
2/L1	G Floor Corridor Lighting 2	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.69	28.5	22.8	✓	N/A	
2/L2	1st Floor Corridor Lighting 2	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.44	N/A	250	LIM	>299	✓	0.58	26.4	26.0	✓	N/A	
2/L3	2nd Floor Corridor Lighting 2	A	B	10	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.67	28.8	29.0	✓	N/A	
3/L1	G Floor Stair Lights	A	B	9	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.66	N/A	250	LIM	>299	✓	0.74	25.4	20.5	✓	N/A	
3/L2	1st Floor Stair Lights	A	B	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.49	N/A	250	LIM	>299	✓	0.55	22.2	16.4	✓	N/A	
3/L3	2nd Floor Stair Lights	A	B	7	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.49	29.4	28.6	✓	N/A	
4/L1	G Floor IT Lighting	A	B	2	1.5	1	0.4	61009 RCD/RCBO	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.60	N/A	250	LIM	>299	✓	0.82	28.0	27.4	✓	N/A	
4/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	Bus Lighting	A	B	1	2.5	1.5	0.4	61009 RCD/RCBO	C	16	10	30	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.38	29.4	27.9	✓	N/A	
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 18/08/2022 To 18/08/2022 Date(s) live testing 18/08/2022 To 18/08/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 18/08/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other  
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A),  
 G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)





## Generic Continuation

### General Conditions of the Electrical Installation:

#### Origin of Supply

The service head, meter and supply authority fuse are in the Dryslwyn mains room

#### Main Earthing Arrangements

The Main Earthing arrangement for the installation appears to be TN-C-S.

#### Incoming Services

The main incoming water supply appears to enter the property in each of the mains room for both buildings. The main bond is a 50mm copper conductor with warning labels attached.

The main incoming gas supply appears to enter the property riser cupboards located at the front of the buildings.

The main bond is a 50mm copper conductor with warning labels attached.

#### Wiring Systems.

The wiring systems utilized for final circuit wiring in the installation are PVC/PVC T&E cable (A)

Installation methods used are clipped direct or in trunking on the wall.

#### Observation notes

All information and documentation (where available) were used to help compile this report.

Circuit charts should be present for each Distribution Board providing relevant information in accordance with Regulation 514.9.1 of the BS 7671:2018.

On the distribution board schedules of circuit details cable types and sizes have been typed in as what is visible at the distribution board only.

Circuits may have been jointed with a different cable type further along the circuit

Only a percentage of the installation has been dismantled for inspection purposes. The correct connection of every conductor and link throughout the premises cannot be ensured.

#### Additional Comments

No access to sealed supply authority fuses therefore Characteristics of Primary Supply Protective Devices are not filled in on page 2.

A new regulation 421.1.7 has been introduced recommending the installation of Arc Fault detection devices conforming to BS EN 62606 to mitigate the risk of fire in AC final circuits of a fixed installation due to arc fault currents.

This installation has been designed and installed prior to July 2018. There is no evidence of

Over-voltage protection within the electrical installation, we recommend Surge Protective Devices be installed in order to reduce the risk of damage to the installation by external transient

Over-voltage's or switching.

#### Overall Assessment

In general, the installation is in a good condition but is (Un)Satisfactory due to the C2, F/I defects in section K, which require urgent action, with the code 3 observations requiring early attention. Assuming attention is brought to the observations and recommendations listed within section K, it is recommended a maximum 5-year period for the next inspection and test to be carried out.

#### Abbreviations contained in this Report: -

RHS – Right Hand Side

LHS – Left Hand Side

D/B - Distribution board.

RCD - Residual current device.

CPC - Circuit protective conductor.

FCU – Fused Connection Unit.

CSA - Cross Sectional Area.

MET – Main Earthing Terminal.

LIM – Limitation (Agreed or Operational)

MIC – Sheath of MICC cable used as CPC

SWA – Steel Wire Armouring used as CPC

MW – Metalwork used as CPC.

FP – FP200 Fire Resistant Cable.

#### Remarks:

##### DB PL/P Remarks:

1/L2 - Head Of Smoke Shaft AOV: O=FP200

##### DB LL4/P Remarks:

2/L1 - 4th Floor Smoke Shaft AOD: O=FP200

2/L2 - 3rd Floor Smoke Shaft AOD: O=FP200

2/L3 - 5th Floor Smoke Shaft: O=FP200

3/L1 - 4th Floor End Of Corridor AOV: O=FP200

5/L1 - 6th Floor Smoke Shaft AOD: O=FP200

6/L1 - 6th Floor Head of Stair Core AOV: FP200

##### DB LL1/P Remarks:

2/L3 - 1st Floor Smoke Shaft AOD: O=FP200

4/L2 - 2nd Floor Smoke Shaft AOD: o=FP200

6/L1 - G Floor Smoke Shaft AOD: O=FP200

##### DB LL3/P Remarks:

2/L1 - 4th Floor Smoke Shaft AOD: O=FP200

2/L2 - 3rd Floor Smoke Shaft AOD: O=FP200

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR 110151231

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)



2/L3 - 5th Floor Smoke Shaft AOD: O=FP200  
3/L1 - 4th Floor Smoke Shaft AOD: O=FP200  
3/L3 - 5th Floor Stair Core AOD: fp200  
4/L3 - Roof Top AOV: fp200

**DB LL2/P Remarks:**

2/L3 - 1st Floor Smoke Shaft AOD: O=FP200  
6/L1 - G Floor Smoke AOD: O=FP200  
7/L2 - Second Smoke Shaft AOD: O=FP200